


Arrangement for supplying load at 11 kV to Ridge Castle Apartment, Dada Bari Road, Mehrauli.



Analysis of interruption of load as per Consumer's Record, BRPL's SCADA Data and BRPL's MIS Report

Consumer: Ridge Castle Apartment, Dada Bari Road, Mehrauli (11 kV)

S.no	Interruption as deduced from DG details of Consumer				Outage reported in BRPL SCADA (Yes =1, No=0)	Outage reported in BRPL's MIS report		
	Date	From	To	Duration		Timings	Remarks	Faithful reporting (Yes =1, No=0)
		hh:mm	hh:mm	hh:mm		hhmm - hhmm		
	A	B	C	D	M	N		O
1		03:05	04:05	01:00	0	----		0
2	01.06.2009	08:20	08:30	00:10	1	----		0
3	02.06.2009	11:45	11:50	00:05	1	----		0
4	03.06.2009	07:00	07:20	00:20	1	----		0
5	04.06.2009	09:45	09:50	00:05	0	----		0
6	04.06.2009	10:50	11:10	00:20	0	1052-1147	Vasant Kunj (220/66 kV transformer-2 trip)	1
7	04.06.2009	11:20	11:25	00:05	0	1052-1147		1
8	05.06.2009	11:50	11:55	00:05	0	----		0
9	05.06.2009	13:45	14:45	01:00	1	----		0
10	05.06.2009	15:15	15:20	00:05	0	----		0
11	05.06.2009	15:55	16:05	00:10	1	----		0
12	05.06.2009	20:40	20:45	00:05	0	----		0
13	06.06.2009	00:05	00:15	00:10	0	----		0
14	06.06.2009	01:55	02:35	00:40	0	----		0
15	06.06.2009	05:30	05:35	00:05	0	----		0
16	06.06.2009	12:05	12:40	00:35	0	----		0
17		07:00	07:05	00:05	0	----		0
18	08.06.2009	07:08	07:18	00:10	0	----		0
19	09.06.2009	12:25	13:25	01:00	0	----		0
20	10.06.2009	06:40	06:50	00:10	0	----		0
21	10.06.2009	07:30	07:45	00:15	0	----		0
22	11.06.2009	09:25	09:30	00:05	0	----		0
23	11.06.2009	11:00	11:05	00:05	0	----		0
24	11.06.2009	11:30	11:35	00:05	0	----		0
25	11.06.2009	17:55	22:15	04:20	1	----		0
26	14.06.2009	08:00	08:15	00:15	0	----		0
27	14.06.2009	14:30	14:35	00:05	1	----		0
28	14.06.2009	23:15	23:25	00:10	1	----		0
29	15.06.2009	12:25	12:40	00:15	0	----		0
30	17.06.2009	20:00	20:05	00:05	0	----		0
31	17.06.2009	22:05	22:20	00:15	1	----		0
32	18.06.2009	02:20	02:40	00:20	0	----		0
33	18.06.2009	05:55	06:10	00:15	0	----		0
34	18.06.2009	15:25	16:25	01:00	1	----		0
35	18.06.2009	16:40	17:10	00:30	0	1645-1700	Mehrauli (low frequency OD)	1
36	18.06.2009	17:30	18:00	00:30	0	----		0
37	19.06.2009	11:15	12:00	00:45	1	1115-1206	Mehrauli (Under freq relay operation)	1
38	19.06.2009	15:35	16:35	01:00	1	1531-1631	Andheria Bagh (low freq. OD)	1
39	19.06.2009	21:25	22:30	01:05	1	----		0
40	20.06.2009	17:10	18:10	01:00	1	----		0
41	21.06.2009	13:05	13:30	00:25	0	----		0
42	21.06.2009	19:15	20:15	01:00	0	1935-2008	Mehrauli (tripping of 66 kV incomers)	1
43	21.06.2009	22:40	23:30	00:50	1	----		0
44	22.06.2009	13:25	13:40	00:15	0	1320-1340	Mehrauli (low frequency OD)	1
45	22.06.2009	15:35	16:25	00:50	1	1540-1640	Andheria Bagh (low freq. OD)	1
46	22.06.2009	16:55	17:25	00:30	0	1650-1750	Mehrauli (low freq. OD))	1
47	22.06.2009	20:15	21:08	00:53	1	2015-2115	Andheria Bagh (low freq. OD)	1
48	22.06.2009	22:00	22:10	00:10	0	----		0
49	22.06.2009	22:20	22:30	00:10	0	----		0
50	23.06.2009	08:25	09:08	00:43	0	----		0
51	23.06.2009	23:00	00:30	01:30	0	----		0
52	24.06.2009	07:30	08:00	00:30	0	----		0
53	24.06.2009	16:40	17:40	01:00	0	1635-1735	Andheria Bagh (low freq. OD)	1
54	24.06.2009	23:00	23:55	00:55	0	2300-0050	Mehrauli (low freq. OD))	1
55	25.06.2009	00:00	00:50	00:50	0	2300-0050	Mehrauli (low freq. OD))	1
56	25.06.2009	01:10	01:50	00:40	0	0125-0200	Malviya Nagar (low freq. OD)	1
57	25.06.2009	11:50	13:00	01:10	1	----		
58	25.06.2009	17:10	18:10	01:00	1	1710-1810	Andheria Bagh (low freq. OD)	1
59	25.06.2009	23:50	00:35	00:45	0	----		0
60	26.06.2009	00:40	00:55	00:15	0	----		0
61	26.06.2009	17:45	18:45	01:00	1	1740-1840	Malviya Nagar (low freq. OD)	1
62	26.06.2009	21:20	23:00	01:40	1	----		0
63	26.06.2009	23:08	23:20	00:12	0	2310-2400	Malviya Nagar (low freq. OD)	1

Analysis of interruption of load as per Consumer's Record, BRPL's SCADA Data and BRPL's MIS Report

Consumer: Ridge Castle Apartment, Dada Bari Road, Mehrauli (11 kV)

S .no	Interruption as deduced from DG details of Consumer				Outage reported in BRPL SCADA (Yes =1, No=0)	Outage reported in BRPL's MIS report		
	Date	From	To	Duration		Timings	Remarks	Faithful reporting (Yes =1, No=0)
		hh:mm	hh:mm	hh:mm		hhmm - hhmm		
	A	B	C	D	M	N		O
64	26.06.2009	23:25	23:47	00:22	1	2310-2400	Malviya Nagar (low freq. OD)	1
65	26.06.2009	23:50	00:05	00:15	1	2310-2400	Malviya Nagar (low freq. OD)	1
66	27.06.2009	03:25	04:20	00:55	0	----		0
67	27.06.2009	10:15	10:25	00:10	1	----		0
68	27.06.2009	15:05	16:00	00:55	1	1505-1605	Andheria Bagh (low freq. OD)	1
69	27.06.2009	19:55	20:00	00:05	0	----		0
70	27.06.2009	21:50	22:00	00:10	0	----		0
71	28.06.2009	04:35	06:45	02:10	0	----		0
72	28.06.2009	11:20	12:20	01:00	1	1105-1205	Andheria Bagh (low freq. OD)	1
73	28.06.2009	14:25	14:30	00:05	1	----		0
74	29.06.2009	18:05	18:15	00:10	0	----		0
75	30.06.2009	23:15	23:30	00:15	1	----		0

Verification of SCADA data w.r.t. Consumer Report			
Summary of interruptions(for interruption time >= 15 minutes)			
	Consumer	BRPL SCADA	Percentage of interruptions captured by SCADA system
No. of interruptions	47	21	44.68

Verification of MIS data w.r.t. Consumer Report			
Summary of interruptions(for interruption time >= 15 minutes)			
	Consumer	BRPL MIS	Percentage of L.S. reported by MIS
No. of interruptions	47	18	38.30
Interruption duration (Hrs)	39:13	14:00	35.70

Note :

- For the purpose of analysis only those interruptions are considered where the interruption duration is 15 minute or more.
- All such interruptions duration (>=15 Min) are shown in shaded background.
- The following interruptions reported by consumers have not been taken into consideration due to variation in timings reported by consumers vis-a-vis in the energy meters readings supplied by BRPL.

Date	From	To	Duration
04.06.2009	15:05	15:50	00:45
13.06.2009	13:55	14:40	00:45
21.06.2009	13:05	13:30	00:25

Analysis of interruption of load as per BRPL's SCADA Data

Consumer: Ridge Castle Apartment, Dada Bari Road, Mehrauli (11 kV)

S.no	Interruption as deduced from DG details of Consumer				Outage timings as per SCADA Data of BRPL								Outage reported in SCADA (Yes =1, No=0)
	Date	From	To	Duration	66/33 kV/11 kV Malviya Nagar			33/11 kV Andheria Bagh			66/33/11 kV JNU		
		hh:mm	hh:mm	hh:mm	66 kV I/C from Okhla Phase-II	66 kV I/C from Mehrauli	33 kV Andheria Bagh feeder	33 kV Malviya Nagar I/C	33 kV JNU I/C	11 kV Tempo stand feeder	Andheria Bagh 33 kV feeder	66 kV Vasant Kunj C D/C line	
	A	B	C	D	E	F	G	H	I	J	K	L	M
1	01.06.2009	03:05	04:05	01:00	----	----	----	----	----	----	----		0
2		08:20	08:30	00:10	----	----	----	----	----	----	08:21-08:30		1
3	02.06.2009	11:45	11:50	00:05	----	----	----	----	----	----	----	11:45-11:56	1
4	03.06.2009	07:00	07:20	00:20	----	----	----	----	----	----	----	07:05-07:16	1
5	04.06.2009	09:45	09:50	00:05	----	----	----	----	----	----	----		0
6	04.06.2009	10:50	11:10	00:20	----	----	----	----	----	----	----		0
7	04.06.2009	11:20	11:25	00:05	----	----	----	----	----	----	----		0
8	05.06.2009	15:05	15:50	00:45	----	----	----	----	----	----	----		0
9	05.06.2009	11:50	11:55	00:05	----	----	----	----	----	----	----		0
10	05.06.2009	13:45	14:45	01:00	----	----	----	----	----	13:45 - 14:46	----		1
11	05.06.2009	15:15	15:20	00:05	----	----	----	----	----	----	----		0
12		15:55	16:05	00:10	----	----	15.57 - 16.13	----	----	----	----		1
13	06.06.2009	20:40	20:45	00:05	----	----	----	----	----	----	----		0
14	06.06.2009	00:05	00:15	00:10	----	----	----	----	----	----	----		0
15	06.06.2009	01:55	02:35	00:40	----	----	----	----	----	----	----		0
16	06.06.2009	05:30	05:35	00:05	----	----	----	----	----	----	----		0
17	08.06.2009	12:05	12:40	00:35	----	----	----	----	----	----	----		0
18		07:00	07:05	00:05	----	----	----	----	----	----	----		0
19	09.06.2009	07:08	07:18	00:10	----	----	----	----	----	----	----		0
20	10.06.2009	12:25	13:25	01:00	----	----	----	----	----	----	----		0
21	10.06.2009	06:40	06:50	00:10	----	----	----	----	----	----	----		0
22	11.06.2009	07:30	07:45	00:15	----	----	----	----	----	----	----		0
23	11.06.2009	09:25	09:30	00:05	----	----	----	----	----	----	----		0
24	11.06.2009	11:00	11:05	00:05	----	----	----	----	----	----	----		0
25	11.06.2009	11:30	11:35	00:05	----	----	----	----	----	----	----		0
26	14.06.2009	17:55	22:15	04:20	----	----	----	----	----	19:04 - 21:01	----		1
27	14.06.2009	08:00	08:15	00:15	----	----	----	----	----	----	----		0
28	14.06.2009	14:30	14:35	00:05	----	----	14:30 -14:35	----	----	----	----		1
29	15.06.2009	23:15	23:25	00:10	----	----	23:20 - 23:25	----	----	----	----		1
30	17.06.2009	12:25	12:40	00:15	----	----	----	----	----	----	----		0
31	17.06.2009	20:00	20:05	00:05	----	----	----	----	----	----	----		0
32	18.06.2009	22:05	22:20	00:15	----	----	----	----	----	22:11-22:22	----		1
33	18.06.2009	02:20	02:40	00:20	----	----	----	----	----	----	----		0
34	18.06.2009	05:55	06:10	00:15	----	----	----	----	----	----	----		0
35	18.06.2009	15:25	16:25	01:00	----	----	----	----	----	15:26-16:23	----		1
36	18.06.2009	16:40	17:10	00:30	----	----	----	----	----	----	----		0
37	19.06.2009	17:30	18:00	00:30	----	----	----	----	----	----	----		0
38	19.06.2009	11:15	12:00	00:45	----	11:16 - 11:54	11.21 - 11.54	----	----	----	----		1
39	19.06.2009	15:35	16:35	01:00	----	----	----	----	----	15:23-16:21	----		1

Analysis of interruption of load as per BRPL's SCADA Data

Consumer: Ridge Castle Apartment, Dada Bari Road, Mehrauli (11 kV)

S.no	Interruption as deduced from DG details of Consumer				Outage timings as per SCADA Data of BRPL								Outage reported in SCADA (Yes =1, No=0)
	Date	From	To	Duration	66/33 kV/11 kV Malviya Nagar			33/11 kV Andheria Bagh			66/33/11 kV JNU		
		hh:mm	hh:mm	hh:mm	66 kV I/C from Okhla Phase-II	66 kV I/C from Mehrauli	33 kV Andheria Bagh feeder	33 kV Malviya Nagar I/C	33 kV JNU I/C	11 kV Tempo stand feeder	Andheria Bagh 33 kV feeder	66 kV Vasant Kunj C D/C line	
	A	B	C	D	E	F	G	H	I	J	K	L	
40	20.06.2009	21:25	22:30	01:05	----	----	----	----	----	21:18-22:17	----	----	1
41	21.06.2009	17:10	18:10	01:00	----	----	----	----	----	16:56-17:58	----	----	1
42	21.06.2009	19:15	20:15	01:00	----	----	----	----	----	----	----	----	0
43	21.06.2009	22:40	23:30	00:50	----	----	----	----	----	22:55-23:52	----	----	1
44	22.06.2009	13:25	13:40	00:15	----	----	----	----	----	----	----	----	0
45	22.06.2009	15:35	16:25	00:50	----	----	----	----	----	15:25-16:15	----	----	1
46	22.06.2009	16:55	17:25	00:30	----	----	----	----	----	----	----	----	0
47	22.06.2009	20:15	21:08	00:53	----	----	----	----	----	20:06-20:55	----	----	1
48	22.06.2009	22:00	22:10	00:10	----	----	----	----	----	----	----	----	0
49	22.06.2009	22:20	22:30	00:10	----	----	----	----	----	----	----	----	0
50	23.06.2009	08:25	09:08	00:43	----	----	----	----	----	----	----	----	0
51	23.06.2009	23:00	00:30	01:30	----	----	----	----	----	----	----	----	0
52	24.06.2009	07:30	08:00	00:30	----	----	----	----	----	----	----	----	0
53	24.06.2009	16:40	17:40	01:00	----	----	----	----	----	----	----	----	0
54	24.06.2009	23:00	23:55	00:55	----	----	----	----	----	----	----	----	0
55	25.06.2009	00:00	00:50	00:50	----	----	----	----	----	----	----	----	0
56	25.06.2009	01:10	01:50	00:40	----	----	----	----	----	----	----	----	0
57	25.06.2009	11:50	13:00	01:10	----	----	----	----	----	11:46 - 14:35	----	----	1
58	25.06.2009	17:10	18:10	01:00	----	----	----	----	----	17:09-18:12	----	----	1
59	25.06.2009	23:50	00:35	00:45	----	----	----	----	----	----	----	----	0
60	26.06.2009	00:40	00:55	00:15	----	----	----	----	----	----	----	----	0
61	26.06.2009	17:45	18:45	01:00	----	----	----	----	----	17:48 - 18:50	----	----	1
62	26.06.2009	21:20	23:00	01:40	----	22:14 - 00:26/ 27.06.09	----	----	----	----	----	----	1
63	26.06.2009	23:08	23:20	00:12	23:19 - 00:26 on 27.06.09	----	----	----	----	----	----	----	0
64	26.06.2009	23:25	23:47	00:12		----	----	----	----	----	----	----	1
65	26.06.2009	23:50	00:05	00:15		----	----	----	----	----	----	----	1
66	27.06.2009	03:25	04:20	00:55	----	----	----	----	----	----	----	----	0
67	27.06.2009	10:15	10:25	00:10	----	----	10:19 - 10:28	----	----	----	----	----	1
68	27.06.2009	15:05	16:00	00:55	----	----	----	----	----	15:01 - 16:02	----	----	1
69	27.06.2009	19:55	20:00	00:05	----	----	----	----	----	----	----	----	0
70	27.06.2009	21:50	22:00	00:10	----	----	----	----	----	----	----	----	0
71	28.06.2009	04:35	06:45	02:10	----	----	----	----	----	----	----	----	0
72	28.06.2009	11:20	12:20	01:00	----	----	----	----	----	11:18 - 12:20	----	----	1
73	28.06.2009	14:25	14:30	00:05	----	----	14:23 - 14:32	----	----	----	----	----	1
74	29.06.2009	18:05	18:15	00:10	----	----	----	----	----	----	----	----	0
75	30.06.2009	23:15	23:30	00:15	----	----	23:21 - 23:27	----	----	----	----	----	1

ANDHERIA BAGH

TIME	SUNSTN	BREAKER	Status
01/06/2009 08:33:07	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
01/06/2009 08:33:08	ANDHBAG	33 KV JNU BREAKER	CLOSED
04/06/2009 11:30:12	ANDHBAG	33 KV JNU BREAKER	CLOSED
04/06/2009 11:30:12	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
05/06/2009 13:44:58	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
05/06/2009 14:46:31	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
05/06/2009 14:46:31	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED N
05/06/2009 20:49:47	ANDHBAG	33 KV JNU BREAKER	CLOSED
05/06/2009 20:49:47	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
06/06/2009 00:16:08	ANDHBAG	33 KV JNU BREAKER	CLOSED N
06/06/2009 00:16:08	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00 N
06/06/2009 00:16:09	ANDHBAG	33 KV JNU BREAKER	CLOSED
06/06/2009 00:16:09	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
11/06/2009 06:09:30	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
11/06/2009 06:49:41	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
11/06/2009 06:54:18	ANDHBAG	33 KV JNU BREAKER	CLOSED
11/06/2009 07:03:28	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
11/06/2009 19:04:05	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
11/06/2009 21:01:59	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
13/06/2009 11:27:32	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
13/06/2009 11:49:13	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
13/06/2009 13:03:29	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
13/06/2009 13:09:39	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
13/06/2009 17:38:58	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
13/06/2009 17:57:41	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
14/06/2009 02:18:35	ANDHBAG	33 KV JNU BREAKER	CLOSED
14/06/2009 02:18:35	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
17/06/2009 21:46:13	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
17/06/2009 22:11:10	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
17/06/2009 22:17:05	ANDHBAG	33 KV JNU BREAKER	CLOSED
17/06/2009 22:22:51	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
18/06/2009 15:26:30	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
18/06/2009 16:23:10	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
19/06/2009 15:23:54	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
19/06/2009 16:21:58	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
19/06/2009 21:18:58	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
19/06/2009 22:17:59	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
20/06/2009 16:56:18	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
20/06/2009 17:58:47	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
21/06/2009 16:15:48	ANDHBAG	33 KV JNU BREAKER	CLOSED
21/06/2009 16:15:48	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
25/06/2009 08:57:37	ANDHBAG	33 KV MALVIYA NAGAR BREAKER	OPEN
25/06/2009 11:46:20	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
25/06/2009 14:34:58	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
25/06/2009 14:34:59	ANDHBAG	33 KV JNU BREAKER	CLOSED
25/06/2009 14:35:00	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED

ANDHERIA BAGH

TIME	SUNSTN	BREAKER	Status
25/06/2009 17:09:45	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
25/06/2009 18:12:35	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
26/06/2009 00:54:00	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
26/06/2009 00:54:01	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
26/06/2009 17:48:03	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
26/06/2009 18:50:17	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
27/06/2009 13:35:22	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
27/06/2009 13:35:23	ANDHBAG	33 KV JNU BREAKER	CLOSED
27/06/2009 15:01:51	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
27/06/2009 16:02:51	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
27/06/2009 20:01:26	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
27/06/2009 20:01:26	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00 N
27/06/2009 20:01:27	ANDHBAG	33 KV JNU BREAKER	CLOSED N
27/06/2009 20:01:28	ANDHBAG	33 KV JNU BREAKER	CLOSED
27/06/2009 22:02:29	ANDHBAG	33 KV JNU BREAKER	CLOSED
27/06/2009 22:02:29	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00
28/06/2009 11:18:16	ANDHBAG	11 KV TEMPO STAND AND BREAKER	OPEN
28/06/2009 12:20:42	ANDHBAG	11 KV TEMPO STAND AND BREAKER	CLOSED
30/06/2009 23:29:59	ANDHBAG	33 KV JNU BREAKER	CLOSED
30/06/2009 23:29:59	ANDHBAG	33 KV JNU BREAKER	ERR STATUS 00

JNU

TIME	SUNSTN	BREAKER	Status
01/06/2009 08:21:53	JNU	33 KV VASANT VIHAR BREAKER	OPEN
01/06/2009 08:30:17	JNU	33 KV VASANT VIHAR BREAKER	CLOSED
02/06/2009 11:45:10	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
02/06/2009 11:45:11	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
02/06/2009 11:56:31	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
02/06/2009 11:56:31	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
03/06/2009 07:05:57	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
03/06/2009 07:05:57	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
03/06/2009 07:16:48	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
03/06/2009 07:16:48	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
04/06/2009 09:54:03	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
04/06/2009 09:54:03	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
04/06/2009 09:54:03	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
04/06/2009 09:54:03	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
04/06/2009 19:07:10	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
04/06/2009 19:07:11	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
04/06/2009 19:15:52	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
04/06/2009 19:15:52	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
06/06/2009 17:39:38	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
06/06/2009 17:39:38	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
06/06/2009 17:39:38	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
06/06/2009 17:39:38	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
08/06/2009 12:05:55	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
08/06/2009 12:15:14	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
09/06/2009 14:32:36	JNU	33 VASANT VIHAR BREAKER	OPEN N
09/06/2009 14:32:47	JNU	33 VASANT VIHAR BREAKER	OPEN
09/06/2009 14:36:20	JNU	33 VASANT VIHAR BREAKER	CLOSED
11/06/2009 01:03:56	JNU	33 VASANT VIHAR BREAKER	OPEN
11/06/2009 01:05:14	JNU	33 VASANT VIHAR BREAKER	CLOSED
11/06/2009 05:43:17	JNU	33 VASANT VIHAR BREAKER	OPEN
11/06/2009 07:07:12	JNU	33 VASANT VIHAR BREAKER	CLOSED
13/06/2009 07:37:32	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
13/06/2009 07:37:33	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
13/06/2009 07:37:58	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
13/06/2009 07:37:58	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
13/06/2009 18:03:55	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
13/06/2009 18:03:55	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
13/06/2009 18:15:31	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
13/06/2009 18:15:31	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
13/06/2009 18:44:24	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
13/06/2009 18:44:24	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
13/06/2009 18:44:38	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
13/06/2009 18:44:39	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
14/06/2009 07:05:53	JNU	33 Vasant Vihar Breaker	Open
14/06/2009 07:16:04	JNU	33 Vasant Vihar Breaker	Closed
15/06/2009 12:18:40	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
15/06/2009 12:31:03	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
16/06/2009 18:11:13	JNU	33 VASANT VIHAR BREAKER	OPEN N
16/06/2009 18:11:14	JNU	33 VASANT VIHAR BREAKER	OPEN
16/06/2009 18:18:24	JNU	33 VASANT VIHAR BREAKER	CLOSED
17/06/2009 18:48:59	JNU	33 VASANT VIHAR BREAKER	OPEN
17/06/2009 18:54:08	JNU	33 VASANT VIHAR BREAKER	CLOSED
17/06/2009 21:34:03	JNU	33 VASANT VIHAR BREAKER	OPEN
17/06/2009 22:24:31	JNU	33 VASANT VIHAR BREAKER	CLOSED
19/06/2009 11:45:14	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
19/06/2009 11:45:14	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
19/06/2009 11:45:14	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
19/06/2009 11:45:14	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
20/06/2009 18:58:00	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
20/06/2009 18:58:00	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
20/06/2009 19:16:39	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
20/06/2009 19:16:40	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
21/06/2009 00:18:16	JNU	66 KV 1-VASANT KUNJ C BREAKER	CLOSED
21/06/2009 00:18:16	JNU	66 KV 1-VASANT KUNJ C BREAKER	OPEN
21/06/2009 00:18:16	JNU	66 KV 2-VASANT KUNJ C BREAKER	CLOSED
21/06/2009 00:18:16	JNU	66 KV 2-VASANT KUNJ C BREAKER	OPEN
26/06/2009 07:34:47	JNU	33 VASANT VIHAR BREAKER	OPEN
26/06/2009 07:43:55	JNU	33 VASANT VIHAR BREAKER	CLOSED

MALVIYA NAGAR

TIME	SUNSTN	BREAKER	Status
01/06/2009 11:31:07	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
01/06/2009 11:37:31	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
02/06/2009 12:26:21	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
02/06/2009 12:26:24	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
02/06/2009 12:26:30	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
02/06/2009 12:30:37	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
02/06/2009 12:31:31	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
02/06/2009 12:33:53	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
02/06/2009 12:35:11	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
02/06/2009 12:39:42	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
02/06/2009 12:47:24	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
02/06/2009 12:48:13	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
02/06/2009 12:48:41	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
02/06/2009 12:49:52	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
02/06/2009 12:50:02	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
02/06/2009 12:50:02	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
02/06/2009 12:50:02	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
02/06/2009 12:53:01	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
03/06/2009 06:25:46	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
03/06/2009 07:41:33	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
05/06/2009 11:44:46	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN -COMMAND DSAT
05/06/2009 11:44:46	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	SWITCHING WITH BYPASS DSAT
05/06/2009 11:44:48	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
05/06/2009 11:49:11	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED -COMMAND DSAT
05/06/2009 11:49:11	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	SWITCHING WITH BYPASS DSAT
05/06/2009 11:49:12	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
05/06/2009 11:49:12	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED N
05/06/2009 11:54:40	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
05/06/2009 11:54:40	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
05/06/2009 11:54:40	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
05/06/2009 11:54:41	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
05/06/2009 11:54:41	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
05/06/2009 11:56:44	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED -COMMAND DSAT
05/06/2009 11:56:44	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	SWITCHING WITH BYPASS DSAT
05/06/2009 11:56:45	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
05/06/2009 15:57:03	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
05/06/2009 16:13:30	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED N
05/06/2009 16:13:31	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
06/06/2009 10:35:46	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
06/06/2009 10:42:00	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
06/06/2009 19:36:51	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
06/06/2009 19:36:51	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
06/06/2009 19:36:51	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
06/06/2009 19:36:51	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
06/06/2009 19:36:51	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
06/06/2009 19:39:06	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
06/06/2009 19:40:56	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
06/06/2009 19:43:19	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
06/06/2009 19:47:33	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
08/06/2009 07:06:21	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
08/06/2009 07:53:27	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
09/06/2009 00:17:43	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
09/06/2009 00:17:43	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
09/06/2009 00:17:58	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
09/06/2009 00:17:58	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
09/06/2009 00:18:18	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
09/06/2009 00:18:45	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
11/06/2009 12:49:09	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
11/06/2009 15:30:36	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
13/06/2009 02:56:09	MALV NGR	66 KV I/C-1MEHRAULI-2BREAKER	OPEN
13/06/2009 02:56:10	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	OPEN
13/06/2009 04:10:10	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
13/06/2009 08:32:27	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	CLOSED

MALVIYA NAGAR

TIME	SUNSTN	BREAKER	Status
13/06/2009 08:32:28	MALV NGR	66 KV I/C-1MEHRAULI-2BREAKER	CLOSED
13/06/2009 08:32:40	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
14/06/2009 08:05:27	MALV NGR	66 kV I/C-4 Okhla-1 Breaker	Open
14/06/2009 08:27:26	MALV NGR	66 kV I/C-3 Okhla Tow Breaker	Open
14/06/2009 08:27:26	MALV NGR	66 kV I/C-4 Okhla-1 Breaker	Closed
14/06/2009 08:27:26	MALV NGR	33 kV AnderiaBagh Breaker	Closed
14/06/2009 08:27:26	MALV NGR	33 kV AnderiaBagh Breaker	Open
14/06/2009 08:33:29	MALV NGR	66 kV I/C-3 Okhla Tow Breaker	Closed
14/06/2009 14:30:04	MALV NGR	33 kV AnderiaBagh Breaker	Open
14/06/2009 14:30:04	MALV NGR	33 kV AnderiaBagh Breaker	Open N
14/06/2009 14:35:52	MALV NGR	33 kV AnderiaBagh Breaker	Closed
14/06/2009 23:20:04	MALV NGR	33 kV AnderiaBagh Breaker	Open
14/06/2009 23:25:02	MALV NGR	33 kV AnderiaBagh Breaker	Closed
15/06/2009 05:37:23	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
15/06/2009 06:11:44	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
16/06/2009 00:37:45	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
16/06/2009 00:37:45	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
16/06/2009 00:37:46	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
16/06/2009 00:37:46	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
16/06/2009 00:37:46	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
16/06/2009 00:37:48	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
18/06/2009 10:29:22	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	CLOSED
18/06/2009 13:07:16	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
19/06/2009 11:16:33	MALV NGR	66 KV I/C-1MEHRAULI-2BREAKER	OPEN
19/06/2009 11:16:42	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	OPEN
19/06/2009 11:21:41	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
19/06/2009 11:54:26	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	CLOSED
19/06/2009 11:54:37	MALV NGR	66 KV I/C-1MEHRAULI-2BREAKER	CLOSED
19/06/2009 11:54:57	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
25/06/2009 09:01:08	MALV NGR	66 KV I/C-5 OKHLA TOW BREAKER	OPEN
26/06/2009 22:14:40	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	OPEN
26/06/2009 22:14:40	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	OPEN N
26/06/2009 22:14:43	MALV NGR	66 KV I/C-1MEHRAULI-2BREAKER	OPEN
26/06/2009 23:19:39	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN N
26/06/2009 23:19:39	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN N
26/06/2009 23:19:40	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	OPEN
26/06/2009 23:19:40	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
27/06/2009 00:25:58	MALV NGR	66 KV I/C-2 MEHRAULI- BREAKER	CLOSED
27/06/2009 00:25:58	MALV NGR	66 KV I/C-1MEHRAULI-2BREAKER	CLOSED
27/06/2009 00:25:59	MALV NGR	66 KV I/C-3 OKHLA TOW BREAKER	CLOSED
27/06/2009 00:25:59	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
27/06/2009 10:19:57	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
27/06/2009 10:19:57	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN N
27/06/2009 10:28:02	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
27/06/2009 10:28:02	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED N
28/06/2009 14:23:33	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
28/06/2009 14:32:26	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED
30/06/2009 09:54:04	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	OPEN
30/06/2009 09:58:39	MALV NGR	66 KV I/C-4 OKHLA-1 BREAKER	CLOSED
30/06/2009 23:21:00	MALV NGR	33 KV ANDERIABAGH BREAKER	OPEN
30/06/2009 23:27:33	MALV NGR	33 KV ANDERIABAGH BREAKER	CLOSED

STATUS 21-24 ANDHERIA BAGH

TIME	SUBSTN	BREAKER	Status
21/06/2009 16:15:48	ANDHBAG	33 kV JNU Breaker	Closed
21/06/2009 16:15:48	ANDHBAG	33 kV JNU Breaker	Err status 00
21/06/2009 22:55:07	ANDHBAG	11 kV Tempo Stand And Breaker	Open
21/06/2009 23:52:13	ANDHBAG	11 kV Tempo Stand And Breaker	Closed
22/06/2009 15:25:11	ANDHBAG	11 kV Tempo Stand And Breaker	Open
22/06/2009 15:25:11	ANDHBAG	11 kV Tempo Stand And Breaker	Open N
22/06/2009 16:15:46	ANDHBAG	11 kV Tempo Stand And Breaker	Closed
22/06/2009 20:06:38	ANDHBAG	11 kV Tempo Stand And Breaker	Open N
22/06/2009 20:06:39	ANDHBAG	11 kV Tempo Stand And Breaker	Open
22/06/2009 20:55:40	ANDHBAG	11 kV Tempo Stand And Breaker	Closed
22/06/2009 20:55:40	ANDHBAG	11 kV Tempo Stand And Breaker	Closed N
22/06/2009 22:00:27	ANDHBAG	33 kV JNU Breaker	Closed N
22/06/2009 22:00:27	ANDHBAG	33 kV JNU Breaker	Err status 00
22/06/2009 22:00:27	ANDHBAG	33 kV JNU Breaker	Err status 00 N
22/06/2009 22:00:28	ANDHBAG	33 kV JNU Breaker	Closed
22/06/2009 22:20:48	ANDHBAG	33 kV JNU Breaker	Closed N
22/06/2009 22:20:48	ANDHBAG	33 kV JNU Breaker	Err status 00 N
22/06/2009 22:20:49	ANDHBAG	33 kV JNU Breaker	Closed
22/06/2009 22:20:49	ANDHBAG	33 kV JNU Breaker	Err status 00
23/06/2009 20:23:15	ANDHBAG	11 kV Tempo Stand And Breaker	Open
23/06/2009 21:04:08	ANDHBAG	11 kV Tempo Stand And Breaker	Closed

Ridge Castle Welfare Association

Registration no 37327

895-C2, Ward no 8, Dada Bari Road, Mehrauli, New Delhi- 110 030

RCWA/Oct-09/DERC

Dated 18th October 2009

To,
The Joint Director (Engineering),
Delhi Electricity Regulatory Commission,
Viniyamak Bhavan, C-Block,
Shivalik, Malviya Nagar,
New Delhi -110017



**Sub: Your letter dated 15th Oct 2009 requesting for backup Diesel
Generating (DG) set operation data for our Apartment complex during
June 2009.**

Sir,

As requested please find enclosed the above details in respect of our Apartment complex during the month of June 2009. The DG set is operated only during periods of outage of power supply from BRPL. Hence the DG set operation timings for June 2009 may be taken as that of the supply outages from BRPL.

We would seek the Honourable DERC's initiative and intervention in ensuring interruption free power supply to our Apartment complex as well as the residents of Delhi, the National Capital, so that the need for a back up power supply in the form of DG sets is totally eliminated.

Thanking you,

Yours faithfully,

(Avijit Dutt)

President,

Ridge Castle Welfare Association (RCWA),

New Delhi

Tel no: 98110 45138

Encl: as above

Details of Diesel Generator operation at Ridge Castle Apartments, Mehrauli during Jun-2009

Approx. Load of Society in kW/Amp. _____ 70 kW sanctioned

Load met by generator ____ Full 100% power back up CRN No. 2520182961

CA No. 100012325

DATE	Generator ON time	Generator OFF time	Power outage time
01.06.2009	03:05	04:05	01:00
	08:20	08:30	00:10
02.06.2009	11:45	11:50	00:05
03.06.2009	07:00	07:20	00:20
04.06.2009	09:45	09:50	00:05
	10:50	11:10	00:20
	11:20	11:25	00:05
	15:05	15:50	00:45
05.06.2009	11:50	11:55	00:05
	13:45	14:45	01:00
	15:15	15:20	00:05
	15:55	16:05	00:10
	20:40	20:45	00:05
06.06.2009	00:05	00:15	00:10
	01:55	02:35	00:40
	05:30	05:35	00:05
	12:05	12:40	00:35
08.06.2009	07:00	07:05	00:05
08.06.2009	07:08	07:18	00:10
09.06.2009	12:25	13:25	01:00
10.06.2009	06:40	06:50	00:10
	07:30	07:45	00:15
11.06.2009	09:25	09:30	00:05
	11:00	11:05	00:05
	11:30	11:35	00:05
	17:55	22:15	04:20
13.06.2009	13:55	14:40	00:45
14.06.2009	08:00	08:15	00:15
	14:30	14:35	00:05
	23:15	23:25	00:10
15.06.2009	12:25	12:40	00:15
17.06.2009	20:00	20:05	00:05
	22:05	22:20	00:15
18.06.2009	02:20	02:40	00:20
	05:55	06:10	00:15
	15:25	16:25	01:00
	16:40	17:10	00:30
	17:30	18:00	00:30
19.06.2009	11:15	12:00	00:45
	15:35	16:35	01:00
	21:25	22:30	01:05
20.06.2009	17:10	18:10	01:00

Details of Diesel Generator operation at Ridge Castle Apartments, Mehrauli during Jun-2009

Approx. Load of Society in kW/Amp. ____70 kW sanctioned

Load met by generator ____Full 100% power back up CRN No. 2520182961

CA No. 100012325

DATE	Generator ON time	Generator OFF time	Power outage time
21.06.2009	13:05	13:30	00:25
	19:15	20:15	01:00
	22:40	23:30	00:50
22.06.2009	13:25	13:40	00:15
	15:35	16:25	00:50
	16:55	17:25	00:30
	20:15	21:08	00:53
	22:00	22:10	00:10
	22:20	22:30	00:10
23.06.2009	08:25	09:08	00:43
	11:00	13:30	02:30
24.06.2009	07:30	08:00	00:30
	16:40	17:40	01:00
	23:00	23:55	00:55
25.06.2009	00:00	00:50	00:50
	01:10	01:50	00:40
	11:50	13:00	01:10
	17:10	18:10	01:00
26.06.2009	23:50	00:35	00:45
	00:40	00:55	00:15
	17:45	18:45	01:00
	21:20	23:00	01:40
	23:08	23:20	00:12
	23:25	23:47	00:12
27.06.2009	23:50	00:05	00:15
	03:25	04:20	00:55
	10:15	10:25	00:10
	15:05	16:00	00:55
	19:55	20:00	00:05
28.06.2009	21:50	22:00	00:10
	04:35	06:45	02:10
	11:20	12:20	01:00
29.06.2009	14:25	14:30	00:05
30.06.2009	18:05	18:15	00:10
	23:15	23:30	00:15

Total 77 interruptions adding to 44 hours 50 minutes during June 2009


(Signature)

Avijit Dutt, President

Ridge Castle Welfare Association

Dada Bari Road, Ward-8, Mehrauli, New Delhi-110030

Tel no: 98110 45138



दिल्ली विद्युत विनियामक आयोग
Delhi Electricity Regulatory Commission

(A Statutory Body of Govt. of NCT of Delhi)

Viniyamak Bhawan, C-Block, Shivalik,

Malviya Nagar, New Delhi-110017

Phone: 26673610, 26673605 Fax.: 26673608

Website: www.derc.gov.in

F.17(47)/Engg./DERC/2009-10/2147/

15.10.2009

To

Ridge Castle Association
Mehrauli
New Delhi

Subject: Details of load shedding/power backup utilized in the month of June 2009

Sir

It has come to notice of the Commission that unprecedented load shedding was carried out in areas at Delhi in the month of June 2009. In this regard, the Commission is investigating the matter.

In order to ascertain the quantum of the total load shedding, you are requested to furnish the details of the load shedding/operation of DG set in enclosed format in your society/organization.

Yours faithfully,

(K.K. Verma)

Jt. Director (Engg.)

9868243560

Encl: as above

o/c