

Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: APRIL 2017-FEB 18
Year: 2017-18

| Sl. No. | Location of accident and details of victim | Date of occurrence | Type of accident | Cause of accident | Findings of CEI/EI/AEI | Remedies suggested by CEI/EI/AEI in various cases | Whether the remedy suggested is complied | Action taken to avoid recurrence of such accidents | Amount paid as compensation |
|---------|--|--------------------|------------------|---|--|---|--|--|-----------------------------|
| 1 | H.no. 556/31, Gali-15, Vijay Park, Division-YVR Victim: Mr. Ashok(Public) | 4 MAY 17 | FATAL | ELECTROCUTION FROM POLE | No earth connection of street light pole | | | Earth connection provided | |
| 2 | Near C-4/90A, gantry of 66kV Ghonda to Bhagirathi Ckt no 2 Victim: Unknown (Public) | 14 MAY 17 | NON FATAL | INTERFERENCE WITH ELECTRICAL INSTALLATION | Report not received | | | | |
| 3 | H.no. D-21/4, Gali No 3, Shastri Park, Division- YVR Victim: Ms. Nisha (Public) | 15 MAY 17 | NON FATAL | INTERFERENCE WITH ELECTRICAL INSTALLATION | Report not received | | | | |
| 4 | Gate no 1, Pocket A, Dilshad Garden, Division- GTR Victim: Mr. Robin (Public) | 21 MAY 17 | FATAL | SNAPPING OF CONDUCTOR | No earth guarding | | | Guarding provided | |
| 5 | Cycle market, New Lajpat Rai Mkt, Division- Chandni Chowk Victim: Unknown | 21 MAY 17 | FATAL | CURRENT LEAKAGE AT METER OUTGOING | Report not received | | | | |
| 6 | 2A/22, Geeta Colony, Division- KNR Victim: Unknown | 7 AUG 17 | FATAL | ELECTROCUTION | Report not received | | | | |

| | | | | | | | | | |
|----|---|-----------|--------------|---|---|---|--|---|--|
| | (Public) | | | | | | | | |
| 7 | B-Block s/stn, Shriram Colony, Sonia Vihar, Division- KWN Victim: Master Ayaan, S/o Sh. Sattar | 25 AUG 17 | NON FATAL | INTERFERENCE WITH ELECTRICAL INSTALLATION | Report not received | | | | |
| 8 | C/o Sh. Keshav Ram Sharma, H.No. A-392, Gali no 9, Part 5, Sonia Vihar, Division- Karawal Nagar Victim: Master Darshan | 09 DEC 17 | NON FATAL | INTERFERENCE WITH ELECTRICAL INSTALLATION | Unautho rised extensio n in vicinity of high voltage distribut ion system | To take suitable steps to restrain unauthori sed constructi on by pubic | | Regular encroac hment warning letter served. | |
| 9 | A/88 Khasra no 351-352, gali no 2, part 2, pehla pusta, sonia vihar, Karawal Nagar Victim: Unknown | 16 DEC 17 | FATAL | INTERFERENCE WITH ELECTRICAL INSTALLATION AND ENCROACHMENT | Report not received | | | | |
| 10 | H.No. B- 1/115, Gali no 5, New Ashok Nagar Victim: Animal (Goat) | 27 FEB 18 | FATAL | ELECTROCUTION FROM INTERNAL HOUSE WIRING. | | | | | |

(Signature of the Licensee)