

Name Of Distribution Licensee: TATA POWER DDL
Period Of Outage: DEC-2021

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
BADLI												
1	01-Dec-2021	PARTS OF TEJINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADLI	6804	Other Outage	Unplanned Outage	01-Dec-2021	10:37	01-Dec-2021	11:05	28	0.00063	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PARTS OF SANNOOTH VILLAGE BADLI	1380	Other Outage	Unplanned Outage	01-Dec-2021	14:04	01-Dec-2021	14:43	39	0.000163	INTERRUPTION DUE TO FAULT
3	01-Dec-2021	PARTS OF SECTOR - 26, SILJIMS QUARTER SHAHABAD DAIRY, GUPTA COLONY, PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE BADLI	137	Other Outage	Unplanned Outage	01-Dec-2021	15:48	01-Dec-2021	16:22	34	0.000142	INTERRUPTION DUE TO FAULT
4	01-Dec-2021	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	661	Other Outage	Unplanned Outage	01-Dec-2021	16:34	01-Dec-2021	16:50	16	0.000067	INTERRUPTION DUE TO FAULT
5	02-Dec-2021	PART OF BADLI INDUSTRIAL AREA BADLI	3	Other Outage	Unplanned Outage	02-Dec-2021	08:09	02-Dec-2021	08:33	24	0.000007	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	6	Other Outage	Unplanned Outage	02-Dec-2021	12:00	02-Dec-2021	16:35	275	0.000153	FORCE MAJEURE DUE TO SABOTAGE
7	02-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	43	Other Outage	Unplanned Outage	02-Dec-2021	12:31	02-Dec-2021	12:54	23	0.000006	INTERRUPTION DUE TO FAULT
8	02-Dec-2021	PARTS OF SAMAY PUR GALI NO 3 & SAMAY PUR GALI NO 15, GALI NO - 6 SHAKTI BHOG WALI, POST OFFICE WALI GALI, MTNL WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR BADLI	711	Other Outage	Unplanned Outage	02-Dec-2021	13:40	02-Dec-2021	14:25	45	0.00015	INTERRUPTION DUE TO FAULT
9	02-Dec-2021	PARTS OF DIB-1 KHERA KHURD BADLI	762	Other Outage	Unplanned Outage	02-Dec-2021	17:09	02-Dec-2021	17:30	21	0.000085	INTERRUPTION DUE TO FAULT
10	02-Dec-2021	PART OF DIB KHERA KHURD VILLAGE BADLI	9	Other Outage	Unplanned Outage	02-Dec-2021	17:09	02-Dec-2021	18:13	64	0.000053	INTERRUPTION DUE TO FAULT
11	02-Dec-2021	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	24	Other Outage	Unplanned Outage	02-Dec-2021	18:34	02-Dec-2021	19:03	29	0.000049	INTERRUPTION DUE TO FAULT
12	02-Dec-2021	PART OF SURAJ PARK COLONY BADLI	5	Other Outage	Unplanned Outage	02-Dec-2021	18:34	02-Dec-2021	19:30	56	0.000031	INTERRUPTION DUE TO FAULT
13	02-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	1508	Other Outage	Unplanned Outage	02-Dec-2021	20:14	02-Dec-2021	20:52	38	0.000156	INTERRUPTION DUE TO FAULT
14	03-Dec-2021	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	78	Other Outage	Unplanned Outage	03-Dec-2021	13:13	03-Dec-2021	14:10	57	0.000032	INTERRUPTION DUE TO FAULT
15	04-Dec-2021	PARTS OF BARWALA VILLAGE, PAPPU COLONY, SRI ENCLAVE, DEEP VIHAR, DRISHNA COLONY, PRAHLAD VIHAR, BADLI	82	Other Outage	Unplanned Outage	04-Dec-2021	14:09	04-Dec-2021	16:30	141	0.000156	FORCE MAJEURE DUE TO SABOTAGE
16	04-Dec-2021	PARTS OF TEJINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADLI	426	Other Outage	Unplanned Outage	04-Dec-2021	18:34	04-Dec-2021	19:17	43	0.000049	INTERRUPTION DUE TO FAULT
17	05-Dec-2021	PART OF KHADDA BASTI BADLI	3	Other Outage	Unplanned Outage	05-Dec-2021	08:14	05-Dec-2021	10:30	136	0.000038	FORCE MAJEURE DUE TO SABOTAGE
18	05-Dec-2021	PARTS OF GALI NO 9 SAMAYPUR BADLI	80	Other Outage	Unplanned Outage	05-Dec-2021	11:17	05-Dec-2021	19:10	473	0.000263	FORCE MAJEURE DUE TO SABOTAGE
19	05-Dec-2021	PARTS OF GALI NO 9 SAMAYPUR BADLI	155	Other Outage	Unplanned Outage	05-Dec-2021	11:19	05-Dec-2021	19:11	472	0.000524	FORCE MAJEURE DUE TO SABOTAGE
20	05-Dec-2021	PARTS OF MAIN SIRASPUR UBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	1021	Other Outage	Unplanned Outage	05-Dec-2021	14:58	05-Dec-2021	15:28	30	0.000333	INTERRUPTION DUE TO FAULT
21	05-Dec-2021	PART OF SIRAS PUR VILLAGE. BADLI	2	Other Outage	Unplanned Outage	05-Dec-2021	14:58	05-Dec-2021	16:04	66	0.000018	INTERRUPTION DUE TO FAULT
22	05-Dec-2021	PARTS OF ESS NO -1 SAMAYA PUR BADLI	1103	Other Outage	Unplanned Outage	05-Dec-2021	19:45	05-Dec-2021	21:10	85	0.000355	INTERRUPTION DUE TO FAULT
23	05-Dec-2021	PARTS OF H. NO-29, REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	143	Other Outage	Unplanned Outage	05-Dec-2021	21:55	05-Dec-2021	22:45	50	0.000137	INTERRUPTION DUE TO FAULT
24	05-Dec-2021	PARTS OF H. NO-29, REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	437	Other Outage	Unplanned Outage	05-Dec-2021	21:55	05-Dec-2021	23:07	72	0.000099	INTERRUPTION DUE TO FAULT
25	05-Dec-2021	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLY GALI NO - 1,2,3,4,5,6, JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD BADLI	446	Other Outage	Unplanned Outage	05-Dec-2021	21:56	05-Dec-2021	23:15	79	0.000022	INTERRUPTION DUE TO FAULT
26	06-Dec-2021	PARTS OF H. NO-29, REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	428	Other Outage	Unplanned Outage	06-Dec-2021	09:09	06-Dec-2021	09:30	21	0.000047	INTERRUPTION DUE TO FAULT
27	06-Dec-2021	PARTS OF BARWALA VILLAGE, PAPPU COLONY, SRI ENCLAVE, DEEP VIHAR, DRISHNA COLONY, PRAHLAD VIHAR, BADLI	745	Other Outage	Unplanned Outage	06-Dec-2021	11:41	06-Dec-2021	12:24	43	0.000108	INTERRUPTION DUE TO FAULT
28	07-Dec-2021	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	13	Other Outage	Unplanned Outage	07-Dec-2021	12:10	07-Dec-2021	14:03	113	0.000031	INTERRUPTION DUE TO FAULT
29	07-Dec-2021	PART OF SHAHABAD AITY A BLOCK BADLI	8	Other Outage	Unplanned Outage	07-Dec-2021	12:20	07-Dec-2021	12:44	24	0.000007	INTERRUPTION DUE TO FAULT
30	07-Dec-2021	PARTS OF KALI MATA MANDIR, MASTER PROPERTY. BADLI	67	Other Outage	Unplanned Outage	07-Dec-2021	13:30	07-Dec-2021	14:03	33	0.000009	INTERRUPTION DUE TO FAULT
31	07-Dec-2021	PARTS OF AIR NANGLI, NEAR SAMSUNG GODOWN FACTORY, NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LIVING, PYARE LAL, BUDHPUR GT ROAD NEW BADLI	32	Other Outage	Unplanned Outage	07-Dec-2021	15:14	07-Dec-2021	16:56	102	0.000056	SYSTEM SCHEDULE OUTAGE
32	07-Dec-2021	PARTS OF D-342, SEC-8 BHN, JUDICIAL QUARTER, SHAHAB DAIRY 8 BLOCK, BIKASH VIHAR, DAULATPUR, SHIV VIHAR, SHAHAB DAIRY BADLI	314	Other Outage	Unplanned Outage	07-Dec-2021	15:35	07-Dec-2021	16:30	55	0.000122	INTERRUPTION DUE TO FAULT
33	07-Dec-2021	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLY GALI NO - 1,2,3,4,5,6, JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD BADLI	488	Other Outage	Unplanned Outage	07-Dec-2021	21:09	07-Dec-2021	21:57	48	0.000435	INTERRUPTION DUE TO FAULT
34	08-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	3400	Other Outage	Unplanned Outage	08-Dec-2021	00:21	08-Dec-2021	00:50	29	0.000016	INTERRUPTION DUE TO FAULT
35	08-Dec-2021	PARTS OF AMAR YJOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR-28 BADLI	203	Other Outage	Unplanned Outage	08-Dec-2021	09:47	08-Dec-2021	11:15	88	0.000123	INTERRUPTION DUE TO FAULT
36	08-Dec-2021	PARTS OF AMAR YJOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR-28 BADLI	98	Other Outage	Unplanned Outage	08-Dec-2021	09:47	08-Dec-2021	15:00	313	0.000174	FORCE MAJEURE DUE TO SABOTAGE
37	08-Dec-2021	PARTS OF AMAR YJOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR-28 BADLI	203	Other Outage	Unplanned Outage	08-Dec-2021	14:30	08-Dec-2021	15:00	30	0.000033	INTERRUPTION DUE TO FAULT
38	09-Dec-2021	PARTS OF TEJINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADLI	438	Other Outage	Unplanned Outage	09-Dec-2021	02:55	09-Dec-2021	04:00	65	0.000144	INTERRUPTION DUE TO FAULT
39	09-Dec-2021	PARTS OF TEJINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADLI	2245	Other Outage	Unplanned Outage	09-Dec-2021	02:55	09-Dec-2021	06:04	189	0.002363	FORCE MAJEURE DUE TO SABOTAGE
40	09-Dec-2021	PARTS OF GALI NO 14, GALI NO - 3, 12, 15 LIBASPUR, GALI NO - 5, 6 MASTER MOHALLA, SIRAS PUR ROAD, PART OF JJ CLUSTER SAMAY PUR GALI NO-9 BADLI	1195	Other Outage	Unplanned Outage	09-Dec-2021	11:41	09-Dec-2021	12:11	30	0.0001	INTERRUPTION DUE TO FAULT
41	09-Dec-2021	PART OF SAMAY PUR GALI NO-9 BADLI	5	Other Outage	Unplanned Outage	09-Dec-2021	14:48	09-Dec-2021	15:58	70	0.000019	INTERRUPTION DUE TO FAULT
42	09-Dec-2021	PARTS OF TEACHER COLONY, A,B,C,D BLOCK YADAV NAGAR, SHIV PURI, BHUSHHE WALI GALI, BANGALI WALI GALI BADLI	333	Other Outage	Unplanned Outage	09-Dec-2021	16:24	09-Dec-2021	17:12	48	0.000067	INTERRUPTION DUE TO FAULT
43	10-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND, BADLI	832	Other Outage	Unplanned Outage	10-Dec-2021	10:47	10-Dec-2021	11:48	61	0.000085	INTERRUPTION DUE TO FAULT
44	10-Dec-2021	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR, COMPLAINT CENTER PRAHALADPUR BADLI	1708	Other Outage	Unplanned Outage	10-Dec-2021	13:40	10-Dec-2021	14:33	53	0.000251	INTERRUPTION DUE TO FAULT
45	10-Dec-2021	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR, COMPLAINT CENTER PRAHALADPUR BADLI	620	Other Outage	Unplanned Outage	10-Dec-2021	13:40	10-Dec-2021	14:58	78	0.000028	INTERRUPTION DUE TO FAULT
46	10-Dec-2021	PART OF SAMAY PUR GALI NO-9 BADLI	5	Other Outage	Unplanned Outage	10-Dec-2021	15:33	10-Dec-2021	16:41	68	0.000019	INTERRUPTION DUE TO FAULT
47	10-Dec-2021	PARTS OF BADLI AND PARK WALA SAMAYA PUR BADLI	635	Other Outage	Unplanned Outage	10-Dec-2021	22:31	10-Dec-2021	23:22	51	0.000113	SYSTEM SCHEDULE OUTAGE
48	11-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND, BADLI	832	Other Outage	Unplanned Outage	11-Dec-2021	10:39	11-Dec-2021	11:20	41	0.000009	INTERRUPTION DUE TO FAULT
49	11-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND, BADLI	2919	Other Outage	Unplanned Outage	11-Dec-2021	10:39	11-Dec-2021	12:25	106	0.000849	INTERRUPTION DUE TO FAULT
50	11-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND, BADLI	375	Other Outage	Unplanned Outage	11-Dec-2021	11:37	11-Dec-2021	12:25	48	0.000016	INTERRUPTION DUE TO FAULT
51	11-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	539	Other Outage	Unplanned Outage	11-Dec-2021	15:04	11-Dec-2021	16:20	76	0.000106	INTERRUPTION DUE TO FAULT
52	11-Dec-2021	PARTS OF BADLI AND PARK WALA SAMAYA PUR BADLI	635	Other Outage	Unplanned Outage	11-Dec-2021	16:31	11-Dec-2021	16:52	21	0.000029	SYSTEM SCHEDULE OUTAGE
53	11-Dec-2021	PARTS OF SANNOOTH VILLAGE BADLI	884	Other Outage	Unplanned Outage	11-Dec-2021	19:35	11-Dec-2021	19:47	12	0.000033	INTERRUPTION DUE TO FAULT
54	12-Dec-2021	PARTS OF SANNOOTH VILLAGE BADLI	884	Other Outage	Unplanned Outage	12-Dec-2021	11:10	12-Dec-2021	12:28	78	0.000217	INTERRUPTION DUE TO FAULT
55	12-Dec-2021	PART OF AMBEY GARDEN BADLI	8	Other Outage	Unplanned Outage	12-Dec-2021	11:17	12-Dec-2021	12:13	56	0.000015	INTERRUPTION DUE TO FAULT
56	12-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND, BADLI	832	Other Outage	Unplanned Outage	12-Dec-2021	13:21	12-Dec-2021	13:54	33	0.000083	INTERRUPTION DUE TO FAULT
57	13-Dec-2021	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	1141	Other Outage	Unplanned Outage	13-Dec-2021	10:48	13-Dec-2021	11:15	27	0.000006	INTERRUPTION DUE TO FAULT
58	13-Dec-2021	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	51	Other Outage	Unplanned Outage	13-Dec-2021	10:48	13-Dec-2021	11:25	37	0.000002	INTERRUPTION DUE TO FAULT
59	13-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	371	Other Outage	Unplanned Outage	13-Dec-2021	12:22	13-Dec-2021	14:19	117	0.000013	INTERRUPTION DUE TO FAULT
60	13-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	651	Other Outage	Unplanned Outage	13-Dec-2021	13:18	13-Dec-2021	14:22	64	0.000071	INTERRUPTION DUE TO FAULT
61	13-Dec-2021	PARTS OF BARWALA VILLAGE, PAPPU COLONY, SRI ENCLAVE, DEEP VIHAR, DRISHNA COLONY, PRAHLAD VIHAR, BADLI	1055	Other Outage	Unplanned Outage	13-Dec-2021	23:51	14-Dec-2021	00:22	31	0.000086	INTERRUPTION DUE TO FAULT
62	14-Dec-2021	PART OF SIRAS PUR VILLAGE. BADLI	14	Other Outage	Unplanned Outage	14-Dec-2021	13:20	14-Dec-2021	14:28	68	0.000019	INTERRUPTION DUE TO FAULT
63	14-Dec-2021	PARTS OF GALI NO 9 SAMAYA PUR BADLI	80	Other Outage	Unplanned Outage	14-Dec-2021	15:03	14-Dec-2021	16:30	87	0.000121	INTERRUPTION DUE TO FAULT
64	15-Dec-2021	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHALADPUR BADLI	1137	Other Outage	Unplanned Outage	15-Dec-2021	09:17	15-Dec-2021	10:20	63	0.000019	INTERRUPTION DUE TO FAULT
65	15-Dec-2021	PARTS OF AMAR YJOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR-28 BADLI	301	Other Outage	Unplanned Outage	15-Dec-2021	10:16	15-Dec-2021	10:57	41	0.000034	INTERRUPTION DUE TO FAULT
66	15-Dec-2021	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR, COMPLAINT CENTER PRAHALADPUR BADLI	629	Other Outage	Unplanned Outage	15-Dec-2021	10:35	15-Dec-2021	11:12	37	0.000063	INTERRUPTION DUE TO FAULT
67	15-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRAJ SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADLI	917	Other Outage	Unplanned Outage	15-Dec-2021	11:34	15-Dec-2021	12:40	66	0.000165	INTERRUPTION DUE TO FAULT
68	15-Dec-2021	PARTS OF SAMAY PUR GALI NO 9, HEVALS WALI GALI, PIPAL WALI GALI, PART OF JJ CLUSTER SAMAYPUR GN-9 BADLI	205									

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
71	15-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	372	Other Outage	Unplanned Outage	15-Dec-2021	20:33	15-Dec-2021	22:24	111	0.000461	INTERRUPTION DUE TO FAULT
72	16-Dec-2021	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA BADLI	1107	Other Outage	Unplanned Outage	16-Dec-2021	07:13	16-Dec-2021	07:40	27	0.000089	INTERRUPTION DUE TO FAULT
73	16-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJI SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA, BADLI	99	Other Outage	Unplanned Outage	16-Dec-2021	08:19	16-Dec-2021	09:12	53	0.000118	INTERRUPTION DUE TO FAULT
74	16-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJI SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA, BADLI	652	Other Outage	Unplanned Outage	16-Dec-2021	10:33	16-Dec-2021	10:39	6	0.000024	INTERRUPTION DUE TO FAULT
75	16-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	295	Other Outage	Unplanned Outage	16-Dec-2021	14:40	16-Dec-2021	16:05	85	0.000118	SYSTEM SCHEDULE OUTAGE
76	16-Dec-2021	PART OF RAJEEV NAGAR AMBEY GARDEN BADLI	7	Other Outage	Unplanned Outage	16-Dec-2021	16:58	16-Dec-2021	18:57	119	0.000033	INTERRUPTION DUE TO FAULT
77	16-Dec-2021	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHAB DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHAB DAIRY BADLI	535	Other Outage	Unplanned Outage	16-Dec-2021	18:11	16-Dec-2021	18:55	44	0.000037	INTERRUPTION DUE TO FAULT
78	17-Dec-2021	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	437	Other Outage	Unplanned Outage	17-Dec-2021	08:55	17-Dec-2021	09:40	45	0.000062	INTERRUPTION DUE TO FAULT
79	17-Dec-2021	PART OF AMBEY GARDEN BADLI	11	Other Outage	Unplanned Outage	17-Dec-2021	14:42	17-Dec-2021	16:00	78	0.000022	INTERRUPTION DUE TO FAULT
80	17-Dec-2021	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGI SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	1219	Other Outage	Unplanned Outage	17-Dec-2021	16:03	17-Dec-2021	16:45	42	0.00014	INTERRUPTION DUE TO FAULT
81	17-Dec-2021	PART OF SIRAS PUR VILLAGE. BADLI	14	Other Outage	Unplanned Outage	17-Dec-2021	16:38	17-Dec-2021	19:52	194	0.000108	FORCE MAJEURE DUE TO SABOTAGE
82	18-Dec-2021	PART OF GALI NO-05 BADLI	13	Other Outage	Unplanned Outage	18-Dec-2021	13:53	18-Dec-2021	15:36	103	0.000029	INTERRUPTION DUE TO FAULT
83	18-Dec-2021	PARTS OF RAMA ENCLAVE, SAHABAD DULAT PUR, SAHABAD INDS.AREA. BADLI	69	Other Outage	Unplanned Outage	18-Dec-2021	14:06	18-Dec-2021	15:30	84	0.000047	INTERRUPTION DUE TO FAULT
84	18-Dec-2021	PARTS OF MAIN SIRASPUR UBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	753	Other Outage	Unplanned Outage	18-Dec-2021	15:01	18-Dec-2021	15:58	57	0.000189	INTERRUPTION DUE TO FAULT
85	18-Dec-2021	PARTS OF SEC 28 PRAHLADPUR BADLI	889	Other Outage	Unplanned Outage	18-Dec-2021	15:17	18-Dec-2021	15:53	36	0.00012	INTERRUPTION DUE TO FAULT
86	18-Dec-2021	PARTS OF SEC 28 PRAHLADPUR BADLI	843	Other Outage	Unplanned Outage	18-Dec-2021	16:57	18-Dec-2021	17:25	28	0.000087	INTERRUPTION DUE TO FAULT
87	18-Dec-2021	PARTS OF SEC 28 PRAHLADPUR BADLI	46	Other Outage	Unplanned Outage	18-Dec-2021	16:57	18-Dec-2021	18:30	93	0.000052	INTERRUPTION DUE TO FAULT
88	19-Dec-2021	PART OF BADLI INDUSTRIAL AREA PHASE-1 BADLI	3	Other Outage	Unplanned Outage	19-Dec-2021	14:12	19-Dec-2021	14:27	15	0.000004	INTERRUPTION DUE TO FAULT
89	19-Dec-2021	PART OF BADLI INDUSTRIAL AREA PHASE-1 BADLI	5	Other Outage	Unplanned Outage	19-Dec-2021	14:29	19-Dec-2021	15:23	54	0.000015	INTERRUPTION DUE TO FAULT
90	20-Dec-2021	PART OF BADLI INDUSTRIAL AREA PHASE-1 BADLI	2	Other Outage	Unplanned Outage	20-Dec-2021	09:49	20-Dec-2021	10:11	22	0.000006	INTERRUPTION DUE TO FAULT
91	20-Dec-2021	PART OF SAMAY PUR GALI NO.9 BADLI	16	Other Outage	Unplanned Outage	20-Dec-2021	11:33	20-Dec-2021	13:08	95	0.000026	INTERRUPTION DUE TO FAULT
92	20-Dec-2021	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	143	Other Outage	Unplanned Outage	20-Dec-2021	11:46	20-Dec-2021	12:13	27	0.000145	INTERRUPTION DUE TO FAULT
93	20-Dec-2021	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	434	Other Outage	Unplanned Outage	20-Dec-2021	11:46	20-Dec-2021	12:50	64	0.000053	INTERRUPTION DUE TO FAULT
94	20-Dec-2021	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	447	Other Outage	Unplanned Outage	20-Dec-2021	11:46	20-Dec-2021	12:50	64	0.000178	INTERRUPTION DUE TO FAULT
95	20-Dec-2021	PARTS OF ALIUPUR AND HOLAMBI KALA CROSSING BADLI	3406	Other Outage	Unplanned Outage	20-Dec-2021	13:29	20-Dec-2021	13:48	19	0.000132	INTERRUPTION DUE TO FAULT
96	20-Dec-2021	PARTS OF BIA PHASE III, RAJA VIHAR, PART OF BIA PHASE II BADLI	144	Other Outage	Unplanned Outage	20-Dec-2021	19:17	20-Dec-2021	19:44	27	0.000015	INTERRUPTION DUE TO FAULT
97	20-Dec-2021	PARTS OF DIB-1 KHERA KHURD BADLI	764	Other Outage	Unplanned Outage	20-Dec-2021	20:24	20-Dec-2021	20:40	16	0.000036	INTERRUPTION DUE TO FAULT
98	21-Dec-2021	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA BADLI	1109	Other Outage	Unplanned Outage	21-Dec-2021	07:25	21-Dec-2021	07:36	11	0.000037	INTERRUPTION DUE TO FAULT
99	21-Dec-2021	PARTS OF S. P. S. DDA SECTOR - 25 BADLI	1078	Other Outage	Unplanned Outage	21-Dec-2021	08:47	21-Dec-2021	09:32	45	0.000031	INTERRUPTION DUE TO FAULT
100	21-Dec-2021	PART OF S. P. S. DDA SECTOR - 25 BADLI	15	Other Outage	Unplanned Outage	21-Dec-2021	08:47	21-Dec-2021	10:10	83	0.000069	INTERRUPTION DUE TO FAULT
101	21-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADLI	67	Other Outage	Unplanned Outage	21-Dec-2021	09:07	21-Dec-2021	11:05	118	0.000164	INTERRUPTION DUE TO FAULT
102	21-Dec-2021	PART OF S. P. S. DDA SECTOR - 25 BADLI	11	Other Outage	Unplanned Outage	21-Dec-2021	10:25	21-Dec-2021	11:30	65	0.000036	INTERRUPTION DUE TO FAULT
103	21-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADLI	417	Other Outage	Unplanned Outage	21-Dec-2021	10:32	21-Dec-2021	11:05	33	0.000011	INTERRUPTION DUE TO FAULT
104	21-Dec-2021	PART OF CHANDAN PARK BADLI	111	Other Outage	Unplanned Outage	21-Dec-2021	11:10	21-Dec-2021	12:19	69	0.000038	INTERRUPTION DUE TO FAULT
105	21-Dec-2021	PARTS OF SIRAS PUR GALI NO-7 BADLI	435	Other Outage	Unplanned Outage	21-Dec-2021	11:22	21-Dec-2021	12:19	57	0.000019	INTERRUPTION DUE TO FAULT
106	21-Dec-2021	PARTS OF DIB MW CONSUMER, PART OF HOLAMBI KALAN. BADLI	1333	Other Outage	Unplanned Outage	21-Dec-2021	13:05	21-Dec-2021	13:25	20	0.000111	INTERRUPTION DUE TO FAULT
107	21-Dec-2021	PARTS OF PRAHLADPUR CHOWK BADLI	276	Other Outage	Unplanned Outage	21-Dec-2021	13:15	21-Dec-2021	16:00	165	0.000275	FORCE MAJEURE DUE TO SABOTAGE
108	22-Dec-2021	PART OF S. P. S. DDA SECTOR - 25 BADLI	11	Other Outage	Unplanned Outage	22-Dec-2021	11:22	22-Dec-2021	11:51	29	0.000008	INTERRUPTION DUE TO FAULT
109	22-Dec-2021	PARTS OF BAGGAWALA, GALI NO -13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	722	Other Outage	Unplanned Outage	22-Dec-2021	12:01	22-Dec-2021	13:15	74	0.000166	INTERRUPTION DUE TO FAULT
110	22-Dec-2021	PARTS OF BAGGAWALA, GALI NO -13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	340	Other Outage	Unplanned Outage	22-Dec-2021	12:01	22-Dec-2021	13:55	114	0.00019	INTERRUPTION DUE TO FAULT
111	22-Dec-2021	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	29	Other Outage	Unplanned Outage	22-Dec-2021	12:38	22-Dec-2021	13:01	23	0.000038	SYSTEM SCHEDULE OUTAGE
112	22-Dec-2021	PART OF AMBEY GARDEN BADLI	4	Other Outage	Unplanned Outage	22-Dec-2021	18:10	22-Dec-2021	19:15	65	0.000018	INTERRUPTION DUE TO FAULT
113	23-Dec-2021	PARTS OF GALI NO 9 SAMAYPUR BADLI	163	Other Outage	Unplanned Outage	23-Dec-2021	10:33	23-Dec-2021	11:10	37	0.000062	INTERRUPTION DUE TO FAULT
114	23-Dec-2021	PART OF GALI NO 4 SAMAY PUR BADLI	7	Other Outage	Unplanned Outage	23-Dec-2021	13:59	23-Dec-2021	14:48	49	0.000027	INTERRUPTION DUE TO FAULT
115	24-Dec-2021	PARTS OF GALI-4 SAMAYPUR BADLI	80	Other Outage	Unplanned Outage	24-Dec-2021	06:24	24-Dec-2021	06:53	29	0.000097	INTERRUPTION DUE TO FAULT
116	24-Dec-2021	PARTS OF SAMAY PUR GALI NO 3 & SAMAY PUR GALI NO 15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTLI WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR BADLI	615	Other Outage	Unplanned Outage	24-Dec-2021	08:04	24-Dec-2021	08:35	31	0.000042	INTERRUPTION DUE TO FAULT
117	25-Dec-2021	PARTS OF SECTOR - 26, SULIMS QUARTER SHAHAB DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE BADLI	904	Other Outage	Unplanned Outage	25-Dec-2021	05:23	25-Dec-2021	08:04	161	0.000446	FORCE MAJEURE DUE TO SABOTAGE
118	25-Dec-2021	PARTS OF SECTOR - 26, SULIMS QUARTER SHAHAB DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE BADLI	3047	Other Outage	Unplanned Outage	25-Dec-2021	06:34	25-Dec-2021	07:12	38	0.000368	INTERRUPTION DUE TO FAULT
119	25-Dec-2021	PART OF SHAHAB DAIRY A BLOCK BADLI	5	Other Outage	Unplanned Outage	25-Dec-2021	09:00	25-Dec-2021	16:07	427	0.000119	FORCE MAJEURE DUE TO SABOTAGE
120	25-Dec-2021	PARTS OF SAMAY PUR GALI NO 3 & SAMAY PUR GALI NO 15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTLI WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR BADLI	3971	Other Outage	Unplanned Outage	25-Dec-2021	09:46	25-Dec-2021	09:59	13	0.000358	INTERRUPTION DUE TO FAULT
121	25-Dec-2021	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD. BADLI	1728	Other Outage	Unplanned Outage	25-Dec-2021	09:54	25-Dec-2021	10:43	49	0.000136	SYSTEM SCHEDULE OUTAGE
122	25-Dec-2021	PARTS OF SEC 28 PRAHLADPUR BADLI	202	Other Outage	Unplanned Outage	25-Dec-2021	12:25	25-Dec-2021	16:07	222	0.000308	FORCE MAJEURE DUE TO SABOTAGE
123	26-Dec-2021	PART OF SULIMS QUARTER SHAHAB DAIRY BADLI	10	Other Outage	Unplanned Outage	26-Dec-2021	09:24	26-Dec-2021	10:00	36	0.00005	INTERRUPTION DUE TO FAULT
124	26-Dec-2021	PART OF SANJAY COLONY BADLI	8	Other Outage	Unplanned Outage	26-Dec-2021	09:53	26-Dec-2021	11:41	108	0.00006	INTERRUPTION DUE TO FAULT
125	26-Dec-2021	PART OF SURAJ PARK COLONY BADLI	5	Other Outage	Unplanned Outage	26-Dec-2021	10:31	26-Dec-2021	11:13	42	0.000023	INTERRUPTION DUE TO FAULT
126	26-Dec-2021	PARTS OF PRAHAD VILAGE BADLI	222	Other Outage	Unplanned Outage	26-Dec-2021	12:56	26-Dec-2021	14:41	105	0.000035	INTERRUPTION DUE TO FAULT
127	26-Dec-2021	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR-28 BADLI	2699	Other Outage	Unplanned Outage	26-Dec-2021	17:54	26-Dec-2021	18:09	15	0.00001	INTERRUPTION DUE TO FAULT
128	26-Dec-2021	PARTS OF KALI MATA MANDIR, MASTER PROPERTY. BADLI	242	Other Outage	Unplanned Outage	26-Dec-2021	17:55	26-Dec-2021	18:50	55	0.000076	INTERRUPTION DUE TO FAULT
129	26-Dec-2021	PARTS OF KALI MATA MANDIR, MASTER PROPERTY. BADLI	169	Other Outage	Unplanned Outage	26-Dec-2021	17:55	26-Dec-2021	20:27	152	0.000084	FORCE MAJEURE DUE TO RAINSTORM
130	26-Dec-2021	PARTS OF KRISHAN COLONY BADLI	632	Other Outage	Unplanned Outage	26-Dec-2021	17:58	26-Dec-2021	20:05	127	0.000246	FORCE MAJEURE DUE TO RAINSTORM
131	26-Dec-2021	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHAB DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHAB DAIRY BADLI	312	Other Outage	Unplanned Outage	26-Dec-2021	18:01	26-Dec-2021	21:09	188	0.00026	FORCE MAJEURE DUE TO RAINSTORM
132	26-Dec-2021	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHAB DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHAB DAIRY BADLI	636	Other Outage	Unplanned Outage	26-Dec-2021	18:06	26-Dec-2021	21:10	184	0.000357	FORCE MAJEURE DUE TO RAINSTORM
133	26-Dec-2021	PARTS OF BAGGAWALA, GALI NO -13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	1196	Other Outage	Unplanned Outage	26-Dec-2021	18:07	26-Dec-2021	18:56	49	0.000417	INTERRUPTION DUE TO FAULT
134	26-Dec-2021	PARTS OF BAGGAWALA, GALI NO -13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	1123	Other Outage	Unplanned Outage	26-Dec-2021	18:07	26-Dec-2021	19:08	61	0.000487	INTERRUPTION DUE TO FAULT
135	26-Dec-2021	PARTS OF BIA PHASE III, RAJA VIHAR, PART OF BIA PHASE II BADLI	4	Other Outage	Unplanned Outage	26-Dec-2021	18:08	26-Dec-2021	18:30	22	0.000012	INTERRUPTION DUE TO FAULT
136	26-Dec-2021	PART OF BADLI INDUSTRIAL AREA PHASE-3 BADLI	15	Other Outage	Unplanned Outage	26-Dec-2021	18:08	26-Dec-2021	18:32	24	0.000007	INTERRUPTION DUE TO FAULT
137	26-Dec-2021	PARTS OF PRAHLADPUR CHOWK BADLI	1831	Other Outage	Unplanned Outage	26-Dec-2021	18:09	26-Dec-2021	20:27	138	0.000762	FORCE MAJEURE DUE TO RAINSTORM
138	26-Dec-2021	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	1236	Other Outage	Unplanned Outage	26-Dec-2021	18:10	26-Dec-2021	18:25	15	0.000063	INTERRUPTION DUE TO FAULT
139	26-Dec-2021	PARTS OF TEJISINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADLI	427	Other Outage	Unplanned Outage	26-Dec-2021	18:29	26-Dec-2021	21:25	56	0.000077	INTERRUPTION DUE TO FAULT
140	26-Dec-2021	PARTS OF SAMAY PUR GALI NO 9, HEVALS WALI GALI, PIPAL WALI GALI, PART OF JJ CLUSTER SAMAYPUR GN-9 BADLI	205	Other Outage	Unplanned Outage	26-Dec-2021	18:34	26-Dec-2021	19:40	186	0.000517	FORCE MAJEURE DUE TO RAINSTORM
141	26-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	571	Other Outage	Unplanned Outage	26-Dec-2021	18:43	26-Dec-2021	19:20	37	0.000051	INTERRUPTION DUE TO FAULT
142	26-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	980	Other Outage	Unplanned Outage	26-Dec-2021	18:43	26-Dec-2021	20:25	102	0.000281	INTERRUPTION DUE TO FAULT
143	26-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	368	Other Outage	Unplanned Outage	26-Dec-2021	18:43	26-Dec-2021	22:40	237	0.000262	FORCE MAJEURE DUE TO RAINSTORM

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
144	26-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADI	579	Other Outage	Unplanned Outage	26-Dec-2021	18:43	26-Dec-2021	22:40	237	0.000394	FORCE MAJEURE DUE TO RAIN/STORM
145	26-Dec-2021	PARTS OF BADI AND PARK WALA SAMAYA PUR BADI	1831	Other Outage	Unplanned Outage	26-Dec-2021	19:36	26-Dec-2021	22:00	144	0.000756	FORCE MAJEURE DUE TO RAIN/STORM
146	26-Dec-2021	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADI	29	Other Outage	Unplanned Outage	26-Dec-2021	19:36	26-Dec-2021	19:50	14	0.000012	INTERRUPTION DUE TO FAULT
147	26-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADI	3406	Other Outage	Unplanned Outage	26-Dec-2021	19:37	26-Dec-2021	19:53	16	0.000182	INTERRUPTION DUE TO FAULT
148	26-Dec-2021	PARTS OF KAILASH VIHAR, PRAHLADPUR BANGAR, COMPLAINT CENTER PRAHLADPUR BADI	620	Other Outage	Unplanned Outage	26-Dec-2021	20:16	26-Dec-2021	22:02	106	0.000206	INTERRUPTION DUE TO FAULT
149	26-Dec-2021	PARTS OF TEJISINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADI	2252	Other Outage	Unplanned Outage	26-Dec-2021	21:37	26-Dec-2021	22:13	36	0.000199	INTERRUPTION DUE TO FAULT
150	26-Dec-2021	PARTS OF TEJISINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN BADI	438	Other Outage	Unplanned Outage	26-Dec-2021	21:37	26-Dec-2021	22:49	72	0.0001	INTERRUPTION DUE TO FAULT
151	27-Dec-2021	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADI	173	Other Outage	Unplanned Outage	27-Dec-2021	07:11	27-Dec-2021	08:20	69	0.000038	INTERRUPTION DUE TO FAULT
152	27-Dec-2021	PART OF BADI INDUSTRIAL AREA PHASE 3 BADI	6	Other Outage	Unplanned Outage	27-Dec-2021	08:49	27-Dec-2021	12:27	218	0.000061	FORCE MAJEURE DUE TO SABOTAGE
153	27-Dec-2021	PART OF AMBEY GARDEN BADI	16	Other Outage	Unplanned Outage	27-Dec-2021	09:15	27-Dec-2021	15:17	362	0.000503	FORCE MAJEURE DUE TO SABOTAGE
154	27-Dec-2021	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADI	66	Other Outage	Unplanned Outage	27-Dec-2021	09:21	27-Dec-2021	10:14	53	0.000044	INTERRUPTION DUE TO FAULT
155	27-Dec-2021	PART OF BADI INDUSTRIAL AREA BADI	2	Other Outage	Unplanned Outage	27-Dec-2021	09:42	27-Dec-2021	15:39	357	0.000099	FORCE MAJEURE DUE TO SABOTAGE
156	27-Dec-2021	PARTS OF METRO VIHAR PH - 2, J. J. S LUM COLONY (HOLAMBI KALAN) BADI	3489	Other Outage	Unplanned Outage	27-Dec-2021	10:16	27-Dec-2021	11:18	62	0.000603	INTERRUPTION DUE TO FAULT
157	27-Dec-2021	PART OF METRO VIHAR PH - 2 BADI	7	Other Outage	Unplanned Outage	27-Dec-2021	10:16	27-Dec-2021	11:23	67	0.000019	INTERRUPTION DUE TO FAULT
158	27-Dec-2021	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADI	880	Other Outage	Unplanned Outage	27-Dec-2021	10:50	27-Dec-2021	12:18	88	0.000022	INTERRUPTION DUE TO FAULT
159	27-Dec-2021	PART OF LIBASPUR BADI	8	Other Outage	Unplanned Outage	27-Dec-2021	10:50	27-Dec-2021	12:48	118	0.000033	INTERRUPTION DUE TO FAULT
160	27-Dec-2021	PARTS OF BIA PHASE III, RAJA VIHAR, PART OF BIA PHASE II BADI	139	Other Outage	Unplanned Outage	27-Dec-2021	11:48	27-Dec-2021	12:27	39	0.000054	INTERRUPTION DUE TO FAULT
161	27-Dec-2021	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6, JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD BADI	391	Other Outage	Unplanned Outage	27-Dec-2021	12:58	27-Dec-2021	14:09	71	0.000079	INTERRUPTION DUE TO FAULT
162	27-Dec-2021	PART OF AMBEY GARDEN BADI	4	Other Outage	Unplanned Outage	27-Dec-2021	13:13	27-Dec-2021	17:00	227	0.000063	FORCE MAJEURE DUE TO SABOTAGE
163	27-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	2237	Other Outage	Unplanned Outage	27-Dec-2021	14:41	27-Dec-2021	15:10	29	0.000196	INTERRUPTION DUE TO FAULT
164	27-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	1174	Other Outage	Unplanned Outage	27-Dec-2021	14:41	27-Dec-2021	15:40	59	0.000405	INTERRUPTION DUE TO FAULT
165	27-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	50	Other Outage	Unplanned Outage	27-Dec-2021	14:41	27-Dec-2021	17:30	169	0.000374	FORCE MAJEURE DUE TO SABOTAGE
166	27-Dec-2021	PARTS OF SHAHABD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS BADI	661	Other Outage	Unplanned Outage	27-Dec-2021	14:51	27-Dec-2021	16:19	88	0.000391	INTERRUPTION DUE TO FAULT
167	27-Dec-2021	PART OF BHAGWANPURA JJ CLUSTER SAMAY PUR BADI	14	Other Outage	Unplanned Outage	27-Dec-2021	15:25	27-Dec-2021	17:30	125	0.000035	FORCE MAJEURE DUE TO SABOTAGE
168	27-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRAJ SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADI	43	Other Outage	Unplanned Outage	27-Dec-2021	16:05	27-Dec-2021	16:59	54	0.000003	INTERRUPTION DUE TO FAULT
169	27-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	441	Other Outage	Unplanned Outage	27-Dec-2021	16:49	27-Dec-2021	17:17	28	0.000195	INTERRUPTION DUE TO FAULT
170	27-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	2252	Other Outage	Unplanned Outage	27-Dec-2021	16:49	27-Dec-2021	17:35	46	0.000256	INTERRUPTION DUE TO FAULT
171	27-Dec-2021	PARTS OF SHAHABD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS BADI	661	Other Outage	Unplanned Outage	27-Dec-2021	17:34	27-Dec-2021	19:45	131	0.000091	FORCE MAJEURE DUE TO SABOTAGE
172	27-Dec-2021	PART OF AMBEY GARDEN BADI	7	Other Outage	Unplanned Outage	27-Dec-2021	18:43	27-Dec-2021	19:54	71	0.000039	INTERRUPTION DUE TO FAULT
173	28-Dec-2021	PARTS OF SHAHABD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS BADI	661	Other Outage	Unplanned Outage	28-Dec-2021	08:04	28-Dec-2021	08:54	50	0.000137	INTERRUPTION DUE TO FAULT
174	28-Dec-2021	PARTS OF SHAHABD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS BADI	661	Other Outage	Unplanned Outage	28-Dec-2021	10:27	28-Dec-2021	13:16	169	0.000657	FORCE MAJEURE DUE TO SABOTAGE
175	28-Dec-2021	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADI	687	Other Outage	Unplanned Outage	28-Dec-2021	12:20	28-Dec-2021	14:06	106	0.000409	INTERRUPTION DUE TO FAULT
176	28-Dec-2021	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADI	57	Other Outage	Unplanned Outage	28-Dec-2021	12:20	28-Dec-2021	14:06	106	0.000117	INTERRUPTION DUE TO FAULT
177	28-Dec-2021	PART OF SIRAS PUR VILLAGE. BADI	9	Other Outage	Unplanned Outage	28-Dec-2021	12:20	28-Dec-2021	15:20	180	0.000099	FORCE MAJEURE DUE TO SABOTAGE
178	28-Dec-2021	PARTS OF PKT 4 SEC-34 BADI	337	Other Outage	Unplanned Outage	28-Dec-2021	12:27	28-Dec-2021	13:00	33	0.000073	INTERRUPTION DUE TO FAULT
179	28-Dec-2021	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADI	744	Other Outage	Unplanned Outage	28-Dec-2021	14:50	28-Dec-2021	15:20	30	0.00001	INTERRUPTION DUE TO FAULT
180	28-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	205	Other Outage	Unplanned Outage	28-Dec-2021	15:56	28-Dec-2021	16:34	38	0.000042	INTERRUPTION DUE TO FAULT
181	28-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADI	1897	Other Outage	Unplanned Outage	28-Dec-2021	17:07	28-Dec-2021	17:15	8	0.000033	INTERRUPTION DUE TO FAULT
182	28-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADI	495	Other Outage	Unplanned Outage	28-Dec-2021	17:23	28-Dec-2021	17:58	35	0.000244	INTERRUPTION DUE TO FAULT
183	29-Dec-2021	PARTS OF POCKET B-3 ESS-1 SEC-35 PRAHLADPUR BADI	1703	Other Outage	Unplanned Outage	29-Dec-2021	10:54	29-Dec-2021	12:28	94	0.000112	INTERRUPTION DUE TO FAULT
184	29-Dec-2021	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3, DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION BADI	468	Other Outage	Unplanned Outage	29-Dec-2021	12:26	29-Dec-2021	12:59	33	0.000046	INTERRUPTION DUE TO FAULT
185	29-Dec-2021	PART OF GALI NO 9 SAMAY PUR BADI	2	Other Outage	Unplanned Outage	29-Dec-2021	12:49	29-Dec-2021	13:42	53	0.000015	INTERRUPTION DUE TO FAULT
186	29-Dec-2021	PARTS OF ESS NO-1 SAMAYA PUR BADI	197	Other Outage	Unplanned Outage	29-Dec-2021	14:50	29-Dec-2021	15:57	67	0.000056	INTERRUPTION DUE TO FAULT
187	29-Dec-2021	PART OF SULLMS QUARTER SHAHABD DAIRY BADI	10	Other Outage	Unplanned Outage	29-Dec-2021	15:46	29-Dec-2021	16:21	35	0.000002	INTERRUPTION DUE TO FAULT
188	29-Dec-2021	PARTS OF ESS NO-1 SAMAYA PUR BADI	168	Other Outage	Unplanned Outage	29-Dec-2021	16:01	29-Dec-2021	17:55	114	0.000095	INTERRUPTION DUE TO FAULT
189	29-Dec-2021	PARTS OF BADI AND PARK WALA SAMAYA PUR BADI	635	Other Outage	Unplanned Outage	29-Dec-2021	22:08	29-Dec-2021	22:56	48	0.000067	SYSTEM SCHEDULE OUTAGE
190	30-Dec-2021	PARTS OF SHAHABD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHABD DAIRY BADI	162	Other Outage	Unplanned Outage	30-Dec-2021	06:10	30-Dec-2021	07:01	51	0.000028	INTERRUPTION DUE TO FAULT
191	30-Dec-2021	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHAB DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHAB DAIRY BADI	636	Other Outage	Unplanned Outage	30-Dec-2021	07:07	30-Dec-2021	07:32	25	0.000028	INTERRUPTION DUE TO FAULT
192	30-Dec-2021	PARTS OF GIVAN PARK SIRASPUR, PART OF BAGHAT SINGH PARK, PART OF SIRASPUR VILLAGE. BADI	2518	Other Outage	Unplanned Outage	30-Dec-2021	07:34	30-Dec-2021	08:20	46	0.000507	INTERRUPTION DUE TO FAULT
193	30-Dec-2021	PART OF SULLMS QUARTER SHAHABD DAIRY BADI	10	Other Outage	Unplanned Outage	30-Dec-2021	11:32	30-Dec-2021	15:56	264	0.000147	FORCE MAJEURE DUE TO SABOTAGE
194	30-Dec-2021	PART OF SAMAY PUR GALI NO 3 BADI	7	Other Outage	Unplanned Outage	30-Dec-2021	14:11	30-Dec-2021	15:41	90	0.000025	INTERRUPTION DUE TO FAULT
195	30-Dec-2021	PART OF AMBEY GARDEN BADI	8	Other Outage	Unplanned Outage	30-Dec-2021	17:51	30-Dec-2021	18:13	22	0.000006	INTERRUPTION DUE TO FAULT
196	30-Dec-2021	PARTS OF PUMP HOUSE NO-2 SEC -28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADI	75	Other Outage	Unplanned Outage	30-Dec-2021	22:36	31-Dec-2021	00:02	86	0.000048	INTERRUPTION DUE TO FAULT
197	30-Dec-2021	PART OF KANKER KHERA VILLAGE BADI	3	Other Outage	Unplanned Outage	30-Dec-2021	22:36	31-Dec-2021	02:20	224	0.000062	FORCE MAJEURE DUE TO SABOTAGE
198	31-Dec-2021	PARTS OF BADI AND PARK WALA SAMAYA PUR BADI	635	Other Outage	Unplanned Outage	31-Dec-2021	07:11	31-Dec-2021	07:40	29	0.000089	SYSTEM SCHEDULE OUTAGE
199	31-Dec-2021	PARTS OF SEC 28 PRAHLADPUR BADI	891	Other Outage	Unplanned Outage	31-Dec-2021	10:19	31-Dec-2021	11:29	70	0.000273	INTERRUPTION DUE TO FAULT
200	31-Dec-2021	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA BADI	735	Other Outage	Unplanned Outage	31-Dec-2021	10:22	31-Dec-2021	11:49	87	0.000168	INTERRUPTION DUE TO FAULT
201	31-Dec-2021	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA BADI	375	Other Outage	Unplanned Outage	31-Dec-2021	10:22	31-Dec-2021	11:50	88	0.000073	INTERRUPTION DUE TO FAULT
202	31-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADI	51	Other Outage	Unplanned Outage	31-Dec-2021	10:54	31-Dec-2021	12:49	115	0.000128	INTERRUPTION DUE TO FAULT
203	31-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRAJ SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADI	171	Other Outage	Unplanned Outage	31-Dec-2021	13:07	31-Dec-2021	14:44	97	0.000107	INTERRUPTION DUE TO FAULT
204	31-Dec-2021	PART OF AMBEY GARDEN BADI	18	Other Outage	Unplanned Outage	31-Dec-2021	17:24	31-Dec-2021	17:59	35	0.000019	INTERRUPTION DUE TO FAULT
205	31-Dec-2021	PART OF GALI NO-05 BADI	10	Other Outage	Unplanned Outage	31-Dec-2021	19:28	31-Dec-2021	20:01	33	0.000018	SYSTEM SCHEDULE OUTAGE
206	31-Dec-2021	PARTS OF PRAHLADPUR CHOWK BADI	1679	Other Outage	Unplanned Outage	31-Dec-2021	21:00	31-Dec-2021	21:32	32	0.000168	INTERRUPTION DUE TO FAULT
207	01-Dec-2021	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6, JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD BADI	446	Other Outage	Planned Outage	01-Dec-2021	10:12	01-Dec-2021	16:26	374	0.00042	PLANNED OUTAGE
208	01-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRAJ SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADI	274	Other Outage	Planned Outage	01-Dec-2021	10:21	01-Dec-2021	11:35	74	0.00006	PLANNED OUTAGE
209	01-Dec-2021	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADI	437	Other Outage	Planned Outage	01-Dec-2021	10:46	01-Dec-2021	12:20	94	0.000010	PLANNED OUTAGE
210	01-Dec-2021	PARTS OF SHAHABD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS BADI	1605	Other Outage	Planned Outage	01-Dec-2021	11:18	01-Dec-2021	12:06	48	0.000016	PLANNED OUTAGE
211	01-Dec-2021	PARTS OF SHAHABD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS BADI	657	Other Outage	Planned Outage	01-Dec-2021	11:24	01-Dec-2021	12:46	82	0.000021	PLANNED OUTAGE
212	01-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRAJ SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADI	69	Other Outage	Planned Outage	01-Dec-2021	11:37	01-Dec-2021	16:00	263	0.000007	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
222	03-Dec-2021	PART OF KHADDA BASTI BADLI	1	63 KVA	Planned Outage	03-Dec-2021	10:31	03-Dec-2021	16:52	381	0.00011	PLANNED OUTAGE
223	03-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRA SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADLI	1154	Other Outage	Planned Outage	03-Dec-2021	11:12	03-Dec-2021	13:19	127	0.00042	PLANNED OUTAGE
224	03-Dec-2021	PARTS OF GALI NO 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	371	Other Outage	Planned Outage	03-Dec-2021	12:23	03-Dec-2021	13:46	83	0.00021	PLANNED OUTAGE
225	03-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND, BADLI	567	Other Outage	Planned Outage	03-Dec-2021	12:23	03-Dec-2021	14:48	145	0.00024	PLANNED OUTAGE
226	03-Dec-2021	PART OF SANJAY GANDHI PHASE-2 BADLI	10	250 KVA	Unplanned Outage	03-Dec-2021	12:59	03-Dec-2021	14:00	61	0.00002	SYSTEM SCHEDULE OUTAGE
227	03-Dec-2021	PART OF GALI NO 4 SAMAY PUR BADLI	2	63 KVA	Unplanned Outage	03-Dec-2021	15:04	03-Dec-2021	15:12	8	0.00002	SYSTEM SCHEDULE OUTAGE
228	04-Dec-2021	PART OF SAMAY PUR GALI NO.9 BADLI	9	160 KVA	Planned Outage	04-Dec-2021	10:48	04-Dec-2021	14:39	231	0.00006	PLANNED OUTAGE
229	06-Dec-2021	PART OF GALI NO 4 SAMAY PUR BADLI	15	315 KVA	Planned Outage	06-Dec-2021	10:25	06-Dec-2021	12:30	125	0.00003	PLANNED OUTAGE
230	06-Dec-2021	PART OF BHAGWANPURA JI CLUSTER SAMAY PUR BADLI	3	315 KVA	Planned Outage	06-Dec-2021	11:44	06-Dec-2021	14:07	143	0.00004	PLANNED OUTAGE
231	06-Dec-2021	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	6	400 KVA	Unplanned Outage	06-Dec-2021	12:33	06-Dec-2021	13:09	36	0.00001	SYSTEM SCHEDULE OUTAGE
232	06-Dec-2021	PART OF GALI NO 4 SAMAY PUR BADLI	13	400 KVA	Planned Outage	06-Dec-2021	13:27	06-Dec-2021	16:19	172	0.00005	PLANNED OUTAGE
233	07-Dec-2021	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	15	Other Outage	Planned Outage	07-Dec-2021	10:40	07-Dec-2021	14:31	231	0.00045	PLANNED OUTAGE
234	07-Dec-2021	PART OF YADAV NAGAR BADLI	9	160 KVA	Unplanned Outage	07-Dec-2021	12:55	07-Dec-2021	13:48	53	0.00001	SYSTEM SCHEDULE OUTAGE
235	08-Dec-2021	PARTS OF GALI NO 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (ITALAB WALA) BADLI	539	Other Outage	Planned Outage	08-Dec-2021	10:17	08-Dec-2021	16:23	366	0.00061	PLANNED OUTAGE
236	08-Dec-2021	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD, BADLI	1223	Other Outage	Planned Outage	08-Dec-2021	11:02	08-Dec-2021	13:42	160	0.00058	PLANNED OUTAGE
237	09-Dec-2021	PART OF TEACHERS COLONY BADLI	8	315 KVA	Planned Outage	09-Dec-2021	08:12	09-Dec-2021	10:13	121	0.00003	PLANNED OUTAGE
238	09-Dec-2021	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR, COMPLAINT CENTER PRAHALADPUR BADLI	1305	Other Outage	Planned Outage	09-Dec-2021	10:23	09-Dec-2021	17:10	407	0.00113	PLANNED OUTAGE
239	09-Dec-2021	PART OF TEACHERS COLONY BADLI	4	315 KVA	Planned Outage	09-Dec-2021	10:27	09-Dec-2021	12:42	135	0.00004	PLANNED OUTAGE
240	09-Dec-2021	PART OF TEACHERS COLONY BADLI	9	400 KVA	Planned Outage	09-Dec-2021	10:59	09-Dec-2021	13:33	154	0.00004	PLANNED OUTAGE
241	09-Dec-2021	PART OF SANJAY COLONY BADLI	11	315 KVA	Planned Outage	09-Dec-2021	13:09	09-Dec-2021	16:21	192	0.00005	PLANNED OUTAGE
242	10-Dec-2021	PART OF YADAV NAGAR BADLI	15	400 KVA	Planned Outage	10-Dec-2021	08:10	10-Dec-2021	11:07	177	0.00010	PLANNED OUTAGE
243	10-Dec-2021	PARTS OF RAMA ENCLAVE, SAHABAD DULAT PUR, SAHABAD INDS AREA, BADLI	629	Other Outage	Planned Outage	10-Dec-2021	10:19	10-Dec-2021	17:17	418	0.00070	PLANNED OUTAGE
244	10-Dec-2021	PART OF SULMS QUARTER SHAHABAD DAIRY BADLI	1	Other Outage	Planned Outage	10-Dec-2021	10:25	10-Dec-2021	17:17	412	0.00011	PLANNED OUTAGE
245	10-Dec-2021	PART OF YADAV NAGAR BADLI	20	315 KVA	Planned Outage	10-Dec-2021	10:33	10-Dec-2021	13:25	172	0.00010	PLANNED OUTAGE
246	10-Dec-2021	PART OF BIA PAHSE-2 BADLI	3	400 KVA	Unplanned Outage	10-Dec-2021	11:06	10-Dec-2021	12:11	65	0.00002	SYSTEM SCHEDULE OUTAGE
247	10-Dec-2021	PART OF YADAV NAGAR BADLI	12	400 KVA	Planned Outage	10-Dec-2021	11:23	10-Dec-2021	14:16	173	0.00005	PLANNED OUTAGE
248	10-Dec-2021	PART OF SAMAY PUR GALI NO.3 BADLI	5	160 KVA	Unplanned Outage	10-Dec-2021	13:33	10-Dec-2021	14:31	58	0.00002	SYSTEM SCHEDULE OUTAGE
249	10-Dec-2021	PART OF YADAV NAGAR BADLI	13	400 KVA	Planned Outage	10-Dec-2021	13:44	10-Dec-2021	16:35	171	0.00005	PLANNED OUTAGE
250	11-Dec-2021	PART OF AMBEY GARDEN BADLI	5	400 KVA	Planned Outage	11-Dec-2021	08:45	11-Dec-2021	10:55	130	0.00004	PLANNED OUTAGE
251	11-Dec-2021	PARTS OF RAM BABU BHAGAT SINGH PARK, INDIRA SPD, LATT WALA, AMBEY GARDEN, SANTOSH DHARAM KANTA, BADLI	23	315 KVA	Planned Outage	11-Dec-2021	10:16	11-Dec-2021	12:43	147	0.00008	PLANNED OUTAGE
252	11-Dec-2021	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHAB DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHAB DAIRY BADLI	1531	Other Outage	Planned Outage	11-Dec-2021	10:19	11-Dec-2021	16:21	362	0.00151	PLANNED OUTAGE
253	11-Dec-2021	PART OF AMBEY GARDEN BADLI	6	250 KVA	Planned Outage	11-Dec-2021	11:12	11-Dec-2021	14:25	193	0.00005	PLANNED OUTAGE
254	11-Dec-2021	PART OF YADAV NAGAR BADLI	9	160 KVA	Planned Outage	11-Dec-2021	12:10	11-Dec-2021	17:15	305	0.00008	PLANNED OUTAGE
255	11-Dec-2021	PART OF AMBEY GARDEN BADLI	13	400 KVA	Planned Outage	11-Dec-2021	12:58	11-Dec-2021	15:52	174	0.00005	PLANNED OUTAGE
256	13-Dec-2021	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	33	Other Outage	Planned Outage	13-Dec-2021	10:58	13-Dec-2021	15:39	281	0.00008	PLANNED OUTAGE
257	14-Dec-2021	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA BADLI	23	250 KVA	Unplanned Outage	14-Dec-2021	15:45	14-Dec-2021	16:32	47	0.00001	SYSTEM SCHEDULE OUTAGE
258	15-Dec-2021	PARTS OF SAMAY PUR GALI NO.3 & SAMAY PUR GALI NO.15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTNL WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR BADLI	679	Other Outage	Planned Outage	15-Dec-2021	08:42	15-Dec-2021	13:45	303	0.00067	PLANNED OUTAGE
259	15-Dec-2021	PARTS OF POCKET B-4 ESS-1 SECT-35 BADLI	753	Other Outage	Planned Outage	15-Dec-2021	10:51	15-Dec-2021	15:32	281	0.00039	PLANNED OUTAGE
260	16-Dec-2021	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	1219	Other Outage	Planned Outage	16-Dec-2021	10:10	16-Dec-2021	16:38	388	0.00119	PLANNED OUTAGE
261	16-Dec-2021	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHAB DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHAB DAIRY BADLI	314	Other Outage	Planned Outage	16-Dec-2021	10:11	16-Dec-2021	16:15	364	0.00040	PLANNED OUTAGE
262	16-Dec-2021	PART OF SANJAY GANDHI PHASE-2 BADLI	12	400 KVA	Planned Outage	16-Dec-2021	10:26	16-Dec-2021	12:44	138	0.00004	PLANNED OUTAGE
263	16-Dec-2021	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	7	400 KVA	Unplanned Outage	16-Dec-2021	11:08	16-Dec-2021	12:11	63	0.00002	SYSTEM SCHEDULE OUTAGE
264	16-Dec-2021	PART OF SANJAY GANDHI PHASE-2 BADLI	4	400 KVA	Unplanned Outage	16-Dec-2021	11:31	16-Dec-2021	12:16	45	0.00001	SYSTEM SCHEDULE OUTAGE
265	16-Dec-2021	PART OF SANJAY GANDHI PHASE-2 BADLI	8	400 KVA	Planned Outage	16-Dec-2021	13:28	16-Dec-2021	15:37	129	0.00004	PLANNED OUTAGE
266	17-Dec-2021	PART OF YADAV NAGAR BADLI	6	400 KVA	Planned Outage	17-Dec-2021	10:11	17-Dec-2021	13:17	186	0.00005	PLANNED OUTAGE
267	17-Dec-2021	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR, COMPLAINT CENTER PRAHALADPUR BADLI	178	Other Outage	Planned Outage	17-Dec-2021	10:22	17-Dec-2021	15:42	320	0.00018	PLANNED OUTAGE
268	17-Dec-2021	PART OF RAJEEV NAGAR AMBEY GARDEN BADLI	7	315 KVA	Unplanned Outage	17-Dec-2021	13:02	17-Dec-2021	14:15	73	0.00002	SYSTEM SCHEDULE OUTAGE
269	17-Dec-2021	PART OF YADAV NAGAR BADLI	5	400 KVA	Planned Outage	17-Dec-2021	13:31	17-Dec-2021	15:49	138	0.00004	PLANNED OUTAGE
270	18-Dec-2021	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 BADLI	141	Other Outage	Planned Outage	18-Dec-2021	09:47	18-Dec-2021	15:22	335	0.00093	PLANNED OUTAGE
271	18-Dec-2021	PART OF RAM BABU SPD BADLI	5	400 KVA	Planned Outage	18-Dec-2021	10:25	18-Dec-2021	13:22	177	0.00005	PLANNED OUTAGE
272	18-Dec-2021	PART OF RAJEEV NAGAR AMBEY GARDEN BADLI	7	250 KVA	Unplanned Outage	18-Dec-2021	12:06	18-Dec-2021	12:40	34	0.00001	SYSTEM SCHEDULE OUTAGE
273	18-Dec-2021	PARTS OF RAM BABU SPD SAMAYA PUR BADLI	44	400 KVA	Planned Outage	18-Dec-2021	13:36	18-Dec-2021	16:31	175	0.00005	PLANNED OUTAGE
274	18-Dec-2021	PART OF KHADDA BASTI BADLI	8	100 KVA	Unplanned Outage	18-Dec-2021	16:13	18-Dec-2021	16:45	32	0.00001	SYSTEM SCHEDULE OUTAGE
275	20-Dec-2021	PART OF LIBASPUR BADLI	3	315 KVA	Planned Outage	20-Dec-2021	10:19	20-Dec-2021	13:03	164	0.00005	PLANNED OUTAGE
276	20-Dec-2021	PART OF RAM BABU SPD BADLI	9	400 KVA	Planned Outage	20-Dec-2021	13:20	20-Dec-2021	15:35	135	0.00004	PLANNED OUTAGE
277	20-Dec-2021	PART OF GALI NO 4 SAMAY PUR BADLI	13	400 KVA	Unplanned Outage	20-Dec-2021	16:28	20-Dec-2021	16:52	24	0.00001	SYSTEM SCHEDULE OUTAGE
278	21-Dec-2021	PARTS OF GALI NO-23 LIBAS PUR, PART OF E BLK YADAV NGR, PART OF MAIN ROAD SIRASPUR LIBAS PUR BADLI	21	400 KVA	Planned Outage	21-Dec-2021	10:35	21-Dec-2021	13:02	147	0.00012	PLANNED OUTAGE
279	21-Dec-2021	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 BADLI	252	Other Outage	Planned Outage	21-Dec-2021	11:02	21-Dec-2021	16:30	328	0.00036	PLANNED OUTAGE
280	21-Dec-2021	PART OF RAM BABU SPD BADLI	11	250 KVA	Unplanned Outage	21-Dec-2021	12:57	21-Dec-2021	13:30	33	0.00001	SYSTEM SCHEDULE OUTAGE
281	21-Dec-2021	PART OF YADAV NAGAR BADLI	4	315 KVA	Planned Outage	21-Dec-2021	13:19	21-Dec-2021	16:12	173	0.00005	PLANNED OUTAGE
282	22-Dec-2021	PARTS OF GALI NO 9 SAMAYA PUR BADLI	205	Other Outage	Planned Outage	22-Dec-2021	10:03	22-Dec-2021	16:16	373	0.00062	PLANNED OUTAGE
283	22-Dec-2021	PART OF BIA PAHSE-2 BADLI	3	250 KVA	Unplanned Outage	22-Dec-2021	12:15	22-Dec-2021	13:31	76	0.00002	SYSTEM SCHEDULE OUTAGE
284	23-Dec-2021	PART OF RAJEEV NAGAR AMBEY GARDEN BADLI	8	400 KVA	Planned Outage	23-Dec-2021	10:10	23-Dec-2021	12:32	142	0.00004	PLANNED OUTAGE
285	23-Dec-2021	PARTS OF DIB MW CONSUMER, PART OF HOLAMBI KALAN, BADLI	1880	Other Outage	Planned Outage	23-Dec-2021	11:39	23-Dec-2021	14:03	144	0.00072	PLANNED OUTAGE
286	23-Dec-2021	PART OF RAJEEV NAGAR AMBEY GARDEN BADLI	8	400 KVA	Planned Outage	23-Dec-2021	12:59	23-Dec-2021	15:23	144	0.00004	PLANNED OUTAGE
287	24-Dec-2021	PARTS OF KALI MATTA MANDIR, MASTER PROPERTY, BADLI	241	Other Outage	Planned Outage	24-Dec-2021	10:24	24-Dec-2021	16:30	366	0.00051	PLANNED OUTAGE
288	24-Dec-2021	PART OF GALI NO 9 SAMAY PUR BADLI	3	250 KVA	Unplanned Outage	24-Dec-2021	10:34	24-Dec-2021	11:18	44	0.00001	SYSTEM SCHEDULE OUTAGE
289	24-Dec-2021	PART OF BHAGWANPURA JI CLUSTER SAMAY PUR BADLI	6	250 KVA	Unplanned Outage	24-Dec-2021	14:38	24-Dec-2021	14:51	13	0.000004	SYSTEM SCHEDULE OUTAGE
290	27-Dec-2021	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	10	100 KVA	Unplanned Outage	27-Dec-2021	13:10	27-Dec-2021	14:05	55	0.00002	SYSTEM SCHEDULE OUTAGE
291	28-Dec-2021	PART OF BIA PAHSE-2 BADLI	3	250 KVA	Planned Outage	28-Dec-2021	10:12	28-Dec-2021	17:25	433	0.00012	PLANNED OUTAGE
292	28-Dec-2021	PARTS OF S. P. S. DDA SECTOR - 25 BADLI	26	Other Outage	Planned Outage	28-Dec-2021	10:42	28-Dec-2021	12:20	98	0.00003	PLANNED OUTAGE
293	28-Dec-2021	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	7	400 KVA	Unplanned Outage	28-Dec-2021	11:02	28-Dec-2021	12:41	99	0.00003	SYSTEM SCHEDULE OUTAGE
294	28-Dec-2021	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	528	Other Outage	Planned Outage							

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unsed (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
2	01-Dec-2021	PART OF G BLOCK BAWANA	5	Other Outage	Unplanned Outage	01-Dec-2021	11:25	01-Dec-2021	12:07	42	0.00023	INTERRUPTION DUE TO FAULT
3	01-Dec-2021	PART OF E BLK SEC-5 BAWANA	7	Other Outage	Unplanned Outage	01-Dec-2021	11:26	01-Dec-2021	16:08	282	0.000157	FORCE MAJEURE DUE TO SABOTAGE
4	01-Dec-2021	PARTS OF G-BLOCK SEC-3 POOTH KHURD BAWANA	236	Other Outage	Unplanned Outage	01-Dec-2021	11:30	01-Dec-2021	12:08	38	0.000106	INTERRUPTION DUE TO FAULT
5	01-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	Other Outage	Unplanned Outage	01-Dec-2021	12:45	01-Dec-2021	13:21	36	0.00021	INTERRUPTION DUE TO FAULT
6	01-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	01-Dec-2021	13:19	01-Dec-2021	16:39	200	0.000111	FORCE MAJEURE DUE TO SABOTAGE
7	01-Dec-2021	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DIB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	4126	Other Outage	Unplanned Outage	01-Dec-2021	15:16	01-Dec-2021	15:45	29	0.000403	INTERRUPTION DUE TO FAULT
8	01-Dec-2021	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DIB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	4126	Other Outage	Unplanned Outage	01-Dec-2021	17:08	01-Dec-2021	17:58	50	0.000694	INTERRUPTION DUE TO FAULT
9	01-Dec-2021	PART OF LM BLOCK SEC-1 DSIDC BAWANA	4	Other Outage	Unplanned Outage	01-Dec-2021	18:48	01-Dec-2021	19:25	37	0.00001	INTERRUPTION DUE TO FAULT
10	01-Dec-2021	PARTS OF G BLK SEC-1 BAWANA	135	Other Outage	Unplanned Outage	01-Dec-2021	19:26	01-Dec-2021	20:05	39	0.000054	INTERRUPTION DUE TO FAULT
11	01-Dec-2021	PART OF G BLK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	01-Dec-2021	19:36	01-Dec-2021	21:03	87	0.000024	INTERRUPTION DUE TO FAULT
12	01-Dec-2021	PART OF C BLK SEC-02 BAWANA	9	Other Outage	Unplanned Outage	01-Dec-2021	19:52	01-Dec-2021	20:49	57	0.000016	INTERRUPTION DUE TO FAULT
13	01-Dec-2021	PART OF I BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	01-Dec-2021	19:58	01-Dec-2021	20:53	55	0.000015	INTERRUPTION DUE TO FAULT
14	02-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	Other Outage	Unplanned Outage	02-Dec-2021	06:55	02-Dec-2021	08:11	76	0.000021	INTERRUPTION DUE TO FAULT
15	02-Dec-2021	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	119	Other Outage	Unplanned Outage	02-Dec-2021	07:30	02-Dec-2021	10:11	161	0.000894	FORCE MAJEURE DUE TO SABOTAGE
16	02-Dec-2021	PART OF DD MALL SEC-5 BAWANA	2	Other Outage	Unplanned Outage	02-Dec-2021	11:03	02-Dec-2021	20:19	556	0.000154	FORCE MAJEURE DUE TO RAINSTORM
17	02-Dec-2021	PART OF FG BLOCK SEC-3 DSIDC BAWANA	5	Other Outage	Unplanned Outage	02-Dec-2021	11:10	02-Dec-2021	16:39	329	0.000091	FORCE MAJEURE DUE TO RAINSTORM
18	02-Dec-2021	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	02-Dec-2021	11:14	02-Dec-2021	12:18	64	0.000018	INTERRUPTION DUE TO FAULT
19	02-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	5	Other Outage	Unplanned Outage	02-Dec-2021	13:09	02-Dec-2021	13:45	36	0.00001	INTERRUPTION DUE TO FAULT
20	02-Dec-2021	PARTS OF FG BLOCK SEC-3 DSIDC BAWANA	299	Other Outage	Unplanned Outage	02-Dec-2021	14:27	02-Dec-2021	15:05	38	0.000198	INTERRUPTION DUE TO FAULT
21	02-Dec-2021	PARTS OF VILLAGE KANJHAWALA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	27	Other Outage	Unplanned Outage	02-Dec-2021	14:27	02-Dec-2021	19:55	328	0.000091	FORCE MAJEURE DUE TO RAINSTORM
22	02-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	Other Outage	Unplanned Outage	02-Dec-2021	14:43	02-Dec-2021	16:51	128	0.000036	FORCE MAJEURE DUE TO SABOTAGE
23	02-Dec-2021	PART OF E BLK SEC-5 BAWANA	6	Other Outage	Unplanned Outage	02-Dec-2021	15:31	02-Dec-2021	17:04	93	0.000026	INTERRUPTION DUE TO FAULT
24	02-Dec-2021	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADIWA DT-2 BAWANA	595	Other Outage	Unplanned Outage	02-Dec-2021	16:09	02-Dec-2021	17:58	109	0.000106	INTERRUPTION DUE TO FAULT
25	02-Dec-2021	PARTS OF SUZET MANDI KANJHAWALA ROAD, INDIRAJI COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD BAWANA	1227	Other Outage	Unplanned Outage	02-Dec-2021	19:55	02-Dec-2021	20:15	20	0.000072	INTERRUPTION DUE TO FAULT
26	02-Dec-2021	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL KRISHNA MARKET NO-1 BAWANA	1326	Other Outage	Unplanned Outage	02-Dec-2021	22:30	02-Dec-2021	22:38	8	0.000047	INTERRUPTION DUE TO FAULT
27	03-Dec-2021	PARTS OF POOTH KHURD VILLAGE BAWANA	3555	Other Outage	Unplanned Outage	03-Dec-2021	01:21	03-Dec-2021	02:05	44	0.000421	INTERRUPTION DUE TO FAULT
28	03-Dec-2021	PARTS OF POOTH KHURD VILLAGE BAWANA	1173	Other Outage	Unplanned Outage	03-Dec-2021	01:34	03-Dec-2021	04:22	168	0.000467	FORCE MAJEURE DUE TO FIRE
29	03-Dec-2021	PARTS OF POOTH KHURD VILLAGE BAWANA	854	Other Outage	Unplanned Outage	03-Dec-2021	01:34	03-Dec-2021	07:09	335	0.000837	FORCE MAJEURE DUE TO FIRE
30	03-Dec-2021	PARTS OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	334	Other Outage	Unplanned Outage	03-Dec-2021	05:13	03-Dec-2021	05:38	25	0.000049	INTERRUPTION DUE TO FAULT
31	03-Dec-2021	PART OF VILLAGE KANJHAWALA BAWANA	11	Other Outage	Unplanned Outage	03-Dec-2021	06:36	03-Dec-2021	09:20	164	0.000045	FORCE MAJEURE DUE TO SABOTAGE
32	03-Dec-2021	PART OF HI BLOCK SEC 5 DSIDC BAWANA	3	Other Outage	Unplanned Outage	03-Dec-2021	09:07	03-Dec-2021	11:48	161	0.000045	FORCE MAJEURE DUE TO SABOTAGE
33	03-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	5	Other Outage	Unplanned Outage	03-Dec-2021	09:24	03-Dec-2021	11:44	140	0.000039	FORCE MAJEURE DUE TO SABOTAGE
34	03-Dec-2021	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DIB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	92	Other Outage	Unplanned Outage	03-Dec-2021	10:25	03-Dec-2021	11:11	46	0.000026	INTERRUPTION DUE TO FAULT
35	03-Dec-2021	PART OF F BLOCK SEC-4 DSIDC BAWANA	4	Other Outage	Unplanned Outage	03-Dec-2021	10:56	03-Dec-2021	12:48	112	0.000062	INTERRUPTION DUE TO FAULT
36	03-Dec-2021	PARTS OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	334	Other Outage	Unplanned Outage	03-Dec-2021	11:30	03-Dec-2021	12:45	75	0.000063	INTERRUPTION DUE TO FAULT
37	03-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	03-Dec-2021	11:58	03-Dec-2021	13:05	67	0.000037	INTERRUPTION DUE TO FAULT
38	03-Dec-2021	PARTS OF LADPUR VILLAGE BAWANA	154	Other Outage	Unplanned Outage	03-Dec-2021	12:49	03-Dec-2021	13:10	21	0.000006	INTERRUPTION DUE TO FAULT
39	03-Dec-2021	PART OF LADPUR VILLAGE BAWANA	8	Other Outage	Unplanned Outage	03-Dec-2021	12:49	03-Dec-2021	16:39	230	0.000128	FORCE MAJEURE DUE TO SABOTAGE
40	03-Dec-2021	PARTS OF O BLOCK SEC-1 POOTH KHURD BAWANA	109	Other Outage	Unplanned Outage	03-Dec-2021	13:46	03-Dec-2021	14:22	36	0.00002	INTERRUPTION DUE TO FAULT
41	03-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	Other Outage	Unplanned Outage	03-Dec-2021	15:51	03-Dec-2021	20:25	274	0.000152	FORCE MAJEURE DUE TO SABOTAGE
42	03-Dec-2021	PARTS OF LADPUR VILLAGE BAWANA	154	Other Outage	Unplanned Outage	03-Dec-2021	16:09	03-Dec-2021	16:39	30	0.000025	INTERRUPTION DUE TO FAULT
43	03-Dec-2021	PART OF G BLK SEC-5 BAWANA	3	Other Outage	Unplanned Outage	03-Dec-2021	18:49	03-Dec-2021	21:56	187	0.000104	INTERRUPTION DUE TO SABOTAGE
44	03-Dec-2021	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	614	Other Outage	Unplanned Outage	03-Dec-2021	19:02	03-Dec-2021	20:44	102	0.00017	INTERRUPTION DUE TO FAULT
45	03-Dec-2021	PARTS OF NMO BLOCK SEC-5 POOTH KHURD BAWANA	83	Other Outage	Unplanned Outage	03-Dec-2021	19:47	03-Dec-2021	22:30	163	0.000181	FORCE MAJEURE DUE TO SABOTAGE
46	03-Dec-2021	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	666	Other Outage	Unplanned Outage	03-Dec-2021	19:58	03-Dec-2021	20:44	46	0.000089	INTERRUPTION DUE TO FAULT
47	03-Dec-2021	PART OF SEC-4 C,D,J BLOCK BAWANA	5	Other Outage	Unplanned Outage	03-Dec-2021	23:04	03-Dec-2021	23:41	37	0.000021	INTERRUPTION DUE TO FAULT
48	04-Dec-2021	PART OF LM BLOCK SEC-3 DSIDC BAWANA	2	Other Outage	Unplanned Outage	04-Dec-2021	09:14	04-Dec-2021	11:52	158	0.000044	FORCE MAJEURE DUE TO SABOTAGE
49	04-Dec-2021	PARTS OF ASTHAL CLNY, KOTAKKHAR RD, RAMESH NAGAR BAWANA	2145	Other Outage	Unplanned Outage	04-Dec-2021	10:19	04-Dec-2021	10:50	31	0.000186	INTERRUPTION DUE TO FAULT
50	04-Dec-2021	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	196	Other Outage	Unplanned Outage	04-Dec-2021	12:05	04-Dec-2021	12:45	40	0.000049	INTERRUPTION DUE TO FAULT
51	04-Dec-2021	PART OF C BLK SEC-02 BAWANA	6	Other Outage	Unplanned Outage	04-Dec-2021	14:04	04-Dec-2021	15:11	67	0.000019	INTERRUPTION DUE TO FAULT
52	04-Dec-2021	PART OF I BLK SEC-5 BAWANA	3	Other Outage	Unplanned Outage	04-Dec-2021	14:51	04-Dec-2021	16:09	78	0.000023	INTERRUPTION DUE TO FAULT
53	04-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	3	Other Outage	Unplanned Outage	04-Dec-2021	18:55	04-Dec-2021	20:16	81	0.000023	INTERRUPTION DUE TO FAULT
54	04-Dec-2021	PARTS OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	334	Other Outage	Unplanned Outage	04-Dec-2021	21:13	04-Dec-2021	21:39	28	0.000107	INTERRUPTION DUE TO FAULT
55	04-Dec-2021	PART OF O BLOCK SEC-3 BAWANA	6	Other Outage	Unplanned Outage	04-Dec-2021	21:21	04-Dec-2021	22:03	42	0.000012	INTERRUPTION DUE TO FAULT
56	05-Dec-2021	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1280	Other Outage	Unplanned Outage	05-Dec-2021	08:27	05-Dec-2021	09:15	48	0.000107	INTERRUPTION DUE TO FAULT
57	05-Dec-2021	PART OF SEC-5 B BLOCK BAWANA	6	Other Outage	Unplanned Outage	05-Dec-2021	09:26	05-Dec-2021	11:01	95	0.000027	INTERRUPTION DUE TO FAULT
58	05-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	05-Dec-2021	10:20	05-Dec-2021	11:20	60	0.000017	INTERRUPTION DUE TO FAULT
59	05-Dec-2021	PART OF C BLK SEC-1 BAWANA	9	Other Outage	Unplanned Outage	05-Dec-2021	11:29	05-Dec-2021	11:54	25	0.000007	INTERRUPTION DUE TO FAULT
60	05-Dec-2021	PART OF LM BLOCK SEC-1 BAWANA	7	Other Outage	Unplanned Outage	05-Dec-2021	11:49	05-Dec-2021	12:14	25	0.000007	INTERRUPTION DUE TO FAULT
61	05-Dec-2021	PART OF JHONTI VILLAGE BAWANA	19	Other Outage	Unplanned Outage	05-Dec-2021	12:01	05-Dec-2021	12:44	43	0.000024	INTERRUPTION DUE TO FAULT
62	05-Dec-2021	PART OF H-BLOCK SEC-1 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	05-Dec-2021	12:23	05-Dec-2021	13:44	81	0.000023	INTERRUPTION DUE TO FAULT
63	05-Dec-2021	PART OF DD MALL SEC-5 BAWANA	4	Other Outage	Unplanned Outage	05-Dec-2021	21:44	05-Dec-2021	22:05	21	0.000006	INTERRUPTION DUE TO FAULT
64	06-Dec-2021	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	111	Other Outage	Unplanned Outage	06-Dec-2021	00:31	06-Dec-2021	00:50	19	0.000058	INTERRUPTION DUE TO FAULT
65	06-Dec-2021	PARTS OF ARIHANT SQUARE SHOPING COMPLEX,SEC- 4, D & I BLK SEC-4 BAWANA	247	Other Outage	Unplanned Outage	06-Dec-2021	08:31	06-Dec-2021	10:24	113	0.000471	SYSTEM SCHEDULE OUTAGE
66	06-Dec-2021	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	10	Other Outage	Unplanned Outage	06-Dec-2021	10:17	06-Dec-2021	17:12	415	0.000115	FORCE MAJEURE DUE TO FIRE
67	06-Dec-2021	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	24	Other Outage	Unplanned Outage	06-Dec-2021	10:18	06-Dec-2021	17:13	415	0.000115	FORCE MAJEURE DUE TO FIRE
68	06-Dec-2021	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	9	Other Outage	Unplanned Outage	06-Dec-2021	10:32	06-Dec-2021	15:57	325	0.00009	FORCE MAJEURE DUE TO SABOTAGE
69	06-Dec-2021	PART OF KANJHAWALA VILLAGE BAWANA	20	Other Outage	Unplanned Outage	06-Dec-2021	10:38	06-Dec-2021	21:16	638	0.000532	FORCE MAJEURE DUE TO SABOTAGE
70	06-Dec-2021	PART OF FG-27 SEC-3 BAWANA	2	Other Outage	Unplanned Outage	06-Dec-2021	10:50	06-Dec-2021	11:40	50	0.000014	INTERRUPTION DUE TO FAULT
71	06-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	7	Other Outage	Unplanned Outage	06-Dec-2021	11:15	06-Dec-2021	12:20	65	0.000018	INTERRUPTION DUE TO FAULT
72	06-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	2	Other Outage	Unplanned Outage	06-Dec-2021	11:21	06-Dec-2021	12:20	59	0.000016	INTERRUPTION DUE TO FAULT
73	06-Dec-2021	PART OF POOTH VILLAGE BAWANA	2	Other Outage	Unplanned Outage	06-Dec-2021	11:38	06-Dec-2021	14:11	153	0.000043	FORCE MAJEURE DUE TO SABOTAGE
74	06-Dec-2021	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADIWA DT-2 BAWANA	595	Other Outage	Unplanned Outage	06-Dec-2021	11:59	06-Dec-2021	12:30	31	0.000103	INTERRUPTION DUE TO FAULT
75	06-Dec-2021	PART OF I BLK SEC-5 BAWANA	2	Other Outage	Unplanned Outage	06-Dec-2021	13:11	06-Dec-2021	14:25	74	0.000021	INTERRUPTION DUE TO FAULT
76	06-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	Other Outage	Unplanned Outage	06-Dec-2021	13:39	06-Dec-2021	15:00	81	0.000022	INTERRUPTION DUE TO FAULT
77	06-Dec-2021	PART OF C BLK SEC-1 BAWANA	3	Other Outage	Unplanned Outage	06-Dec-2021	13:47	06-Dec-2021	15:25	98	0.000027	INTERRUPTION DUE TO FAULT
78	06-Dec-2021	PARTS OF KANJHAWALA VILLAGE & INDUSTRIAL AREA BAWANA	106	Other Outage	Unplanned Outage	06-Dec-2021	13:55	06-Dec-2021	18:33	278	0.000309	FORCE MAJEURE DUE TO SABOTAGE
79	06-Dec-2021	PART OF POOTH VILLAGE BAWANA	2	Other Outage	Unplanned Outage	06-Dec-2021	14:54	06-Dec-2021	16:06	72	0.00002	INTERRUPTION DUE TO FAULT
80	06-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	06-Dec-2021	17:59	06-Dec-2021	20:00	121	0.000067	FORCE MAJEURE DUE TO SABOTAGE
81	06-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	06-Dec-2021	18:21	06-Dec-2021	19:32	71	0.000019	INTERRUPTION DUE TO FAULT
82	06-Dec-2021	PART OF G BLK SEC-02 BAWANA	4	Other Outage								

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unscheduled (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
86	07-Dec-2021	PART OF I-19 SEC-2 NEAR GUL CHAKKAR. BAWANA	3	Other Outage	Unplanned Outage	07-Dec-2021	07:36	07-Dec-2021	09:05	89	0.00025	INTERRUPTION DUE TO FAULT
87	07-Dec-2021	PART OF C BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	07:51	07-Dec-2021	09:20	89	0.00025	INTERRUPTION DUE TO FAULT
88	07-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	Other Outage	Unplanned Outage	07-Dec-2021	10:00	07-Dec-2021	17:10	430	0.00119	FORCE MAJEURE DUE TO SABOTAGE
89	07-Dec-2021	PARTS OF POLICE STATION KHANJAWALA, JAI BHAGWAN AT DEPOT ROAD, HARIJAN BASTI - KHANJAWALA, HARISH CHAUHAN, KHANJAWALA LADPUR ROAD MAIRA VILLAGE, HIMAR PURA VILLAGE, MITAL CHANDPUR, CHANDPUR HARIJAN BASTI BAL KISHAN BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KHANJAWALA SDM COURT KHANJAWALA BAWANA	525	Other Outage	Unplanned Outage	07-Dec-2021	10:06	07-Dec-2021	11:00	54	0.00074	INTERRUPTION DUE TO FAULT
90	07-Dec-2021	PART OF N BLK SEC-2 AND PART OF BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	10:30	07-Dec-2021	12:03	93	0.00026	INTERRUPTION DUE TO FAULT
91	07-Dec-2021	PARTS OF N-9 BLOCK SEC-2 BAWANA	50	Other Outage	Unplanned Outage	07-Dec-2021	10:50	07-Dec-2021	12:03	73	0.00101	INTERRUPTION DUE TO FAULT
92	07-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	7	Other Outage	Unplanned Outage	07-Dec-2021	11:05	07-Dec-2021	15:00	235	0.00065	FORCE MAJEURE DUE TO SABOTAGE
93	07-Dec-2021	PART OF C-BLK SEC-4 BAWANA	2	Other Outage	Unplanned Outage	07-Dec-2021	11:11	07-Dec-2021	12:08	57	0.00016	INTERRUPTION DUE TO FAULT
94	07-Dec-2021	PART OF O BLOCK SEC-3 BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	11:26	07-Dec-2021	14:56	210	0.00058	FORCE MAJEURE DUE TO SABOTAGE
95	07-Dec-2021	PART OF F BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	11:58	07-Dec-2021	13:05	67	0.00018	INTERRUPTION DUE TO FAULT
96	07-Dec-2021	PART OF F BLK SEC-1 BAWANA	3	Other Outage	Unplanned Outage	07-Dec-2021	13:23	07-Dec-2021	14:20	57	0.00016	INTERRUPTION DUE TO FAULT
97	07-Dec-2021	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL, KRISHNA MARKET NO-1 BAWANA	421	Other Outage	Unplanned Outage	07-Dec-2021	13:55	07-Dec-2021	14:05	10	0.00014	INTERRUPTION DUE TO FAULT
98	07-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	14:02	07-Dec-2021	17:10	188	0.00052	FORCE MAJEURE DUE TO SABOTAGE
99	07-Dec-2021	PART OF FG-27 SEC-3 BAWANA	6	Other Outage	Unplanned Outage	07-Dec-2021	14:15	07-Dec-2021	15:40	85	0.00047	INTERRUPTION DUE TO FAULT
100	07-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	2	Other Outage	Unplanned Outage	07-Dec-2021	14:58	07-Dec-2021	15:39	41	0.00012	INTERRUPTION DUE TO FAULT
101	07-Dec-2021	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	15:12	07-Dec-2021	17:24	132	0.00037	FORCE MAJEURE DUE TO SABOTAGE
102	07-Dec-2021	PART OF J-BLOCK SEC-3 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	07-Dec-2021	15:13	07-Dec-2021	22:00	407	0.00226	FORCE MAJEURE DUE TO SABOTAGE
103	07-Dec-2021	PART OF G BLOCK BAWANA	4	Other Outage	Unplanned Outage	07-Dec-2021	16:11	07-Dec-2021	16:50	39	0.00021	INTERRUPTION DUE TO FAULT
104	07-Dec-2021	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILIA FLOUR MILL BAWANA	285	Other Outage	Unplanned Outage	07-Dec-2021	17:56	07-Dec-2021	19:08	72	0.00047	INTERRUPTION DUE TO FAULT
105	07-Dec-2021	PART OF I BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	07-Dec-2021	18:33	07-Dec-2021	19:26	53	0.00015	INTERRUPTION DUE TO FAULT
106	07-Dec-2021	PARTS OF JJ CLUSTER NO.3 KHANJAWALA BAWANA	700	Other Outage	Unplanned Outage	07-Dec-2021	19:12	07-Dec-2021	20:20	68	0.00029	INTERRUPTION DUE TO FAULT
107	07-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	2	Other Outage	Unplanned Outage	07-Dec-2021	20:05	07-Dec-2021	22:21	136	0.00038	FORCE MAJEURE DUE TO SABOTAGE
108	07-Dec-2021	PARTS OF JJ CLUSTER NO.3 KHANJAWALA BAWANA	144	Other Outage	Unplanned Outage	07-Dec-2021	20:36	07-Dec-2021	21:50	74	0.00082	INTERRUPTION DUE TO FAULT
109	07-Dec-2021	PARTS OF F-86 SEC 5, E-1 SEC-5, F-51 SEC-5 BAWANA	286	Other Outage	Unplanned Outage	07-Dec-2021	21:34	07-Dec-2021	22:10	36	0.00005	INTERRUPTION DUE TO FAULT
110	07-Dec-2021	PARTS OF I-BLOCK SEC-5 POOTH KHURD BAWANA	206	Other Outage	Unplanned Outage	07-Dec-2021	22:17	07-Dec-2021	22:54	37	0.00031	INTERRUPTION DUE TO FAULT
111	08-Dec-2021	PART OF I-BLOCK SEC-2 DSIDC BAWANA	6	Other Outage	Unplanned Outage	08-Dec-2021	07:21	08-Dec-2021	09:08	107	0.00006	INTERRUPTION DUE TO FAULT
112	08-Dec-2021	PART OF G BLK SEC-5 BAWANA	4	Other Outage	Unplanned Outage	08-Dec-2021	07:23	08-Dec-2021	08:37	74	0.00002	INTERRUPTION DUE TO FAULT
113	08-Dec-2021	PART OF I-BLOCK SEC-5 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	08-Dec-2021	08:00	08-Dec-2021	08:10	10	0.00006	INTERRUPTION DUE TO FAULT
114	08-Dec-2021	PART OF F BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	08-Dec-2021	09:34	08-Dec-2021	11:00	86	0.00024	INTERRUPTION DUE TO FAULT
115	08-Dec-2021	PARTS OF JYONTI VILLAGE BAWANA	83	Other Outage	Unplanned Outage	08-Dec-2021	10:50	08-Dec-2021	13:30	160	0.00267	FORCE MAJEURE DUE TO SABOTAGE
116	08-Dec-2021	PART OF I-BLOCK SEC-2 DSIDC BAWANA	3	Other Outage	Unplanned Outage	08-Dec-2021	11:02	08-Dec-2021	13:53	171	0.00095	FORCE MAJEURE DUE TO SABOTAGE
117	08-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	7	Other Outage	Unplanned Outage	08-Dec-2021	11:45	08-Dec-2021	17:49	364	0.00101	FORCE MAJEURE DUE TO SABOTAGE
118	08-Dec-2021	PART OF F BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	08-Dec-2021	14:28	08-Dec-2021	17:15	167	0.00046	FORCE MAJEURE DUE TO SABOTAGE
119	08-Dec-2021	PART OF JYONTI VILLAGE BAWANA	3	Other Outage	Unplanned Outage	08-Dec-2021	15:11	08-Dec-2021	16:40	89	0.00025	INTERRUPTION DUE TO FAULT
120	08-Dec-2021	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILIA FLOUR MILL BAWANA	215	Other Outage	Unplanned Outage	08-Dec-2021	15:44	08-Dec-2021	17:47	123	0.000137	FORCE MAJEURE DUE TO SABOTAGE
121	08-Dec-2021	PART OF LM BLOCK SEC-1 BAWANA	8	Other Outage	Unplanned Outage	08-Dec-2021	15:59	08-Dec-2021	16:50	51	0.00014	SYSTEM SCHEDULE OUTAGE
122	08-Dec-2021	PARTS OF JJ CLUSTER NO.3 KHANJAWALA BAWANA	144	Other Outage	Unplanned Outage	08-Dec-2021	16:15	08-Dec-2021	17:30	75	0.00021	INTERRUPTION DUE TO FAULT
123	08-Dec-2021	PART OF GARTH RINDHALA BAWANA	8	Other Outage	Unplanned Outage	08-Dec-2021	18:30	08-Dec-2021	19:45	75	0.00021	INTERRUPTION DUE TO FAULT
124	08-Dec-2021	PART OF E BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	08-Dec-2021	18:42	08-Dec-2021	21:10	148	0.00041	FORCE MAJEURE DUE TO SABOTAGE
125	08-Dec-2021	PART OF G BLK SEC-5 BAWANA	4	Other Outage	Unplanned Outage	08-Dec-2021	19:44	08-Dec-2021	20:43	59	0.00016	INTERRUPTION DUE TO FAULT
126	08-Dec-2021	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	196	Other Outage	Unplanned Outage	08-Dec-2021	20:07	08-Dec-2021	20:42	35	0.00003	INTERRUPTION DUE TO FAULT
127	09-Dec-2021	PART OF POOTH VILLAGE BAWANA	4	Other Outage	Unplanned Outage	09-Dec-2021	07:03	09-Dec-2021	10:30	207	0.00114	FORCE MAJEURE DUE TO SABOTAGE
128	09-Dec-2021	PART OF I-BLOCK SEC-2 DSIDC BAWANA	9	Other Outage	Unplanned Outage	09-Dec-2021	08:06	09-Dec-2021	08:30	24	0.00007	INTERRUPTION DUE TO FAULT
129	09-Dec-2021	PART OF I-1-BLOCK SEC-5 BAWANA	8	Other Outage	Unplanned Outage	09-Dec-2021	08:20	09-Dec-2021	11:18	178	0.00198	FORCE MAJEURE DUE TO SABOTAGE
130	09-Dec-2021	PART OF LM BLOCK SEC-1 DSIDC BAWANA	6	Other Outage	Unplanned Outage	09-Dec-2021	11:27	09-Dec-2021	13:57	150	0.00042	FORCE MAJEURE DUE TO SABOTAGE
131	09-Dec-2021	PART OF H-BLOCK SEC-1 POOTH KHURD BAWANA	2	Other Outage	Unplanned Outage	09-Dec-2021	11:56	09-Dec-2021	14:40	164	0.00091	FORCE MAJEURE DUE TO SABOTAGE
132	09-Dec-2021	PARTS OF VIJAY NAGAR, SKY DARYA PUR, MAIN BUS STAND BAWANA	90	Other Outage	Unplanned Outage	09-Dec-2021	12:04	09-Dec-2021	16:03	239	0.00032	FORCE MAJEURE DUE TO SABOTAGE
133	09-Dec-2021	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	9	Other Outage	Unplanned Outage	09-Dec-2021	12:15	09-Dec-2021	16:44	269	0.00075	FORCE MAJEURE DUE TO SABOTAGE
134	09-Dec-2021	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	4	Other Outage	Unplanned Outage	09-Dec-2021	12:17	09-Dec-2021	16:44	267	0.00074	FORCE MAJEURE DUE TO SABOTAGE
135	09-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	8	Other Outage	Unplanned Outage	09-Dec-2021	12:44	09-Dec-2021	15:00	136	0.00075	FORCE MAJEURE DUE TO SABOTAGE
136	09-Dec-2021	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	343	Other Outage	Unplanned Outage	09-Dec-2021	13:13	09-Dec-2021	13:50	37	0.00013	INTERRUPTION DUE TO FAULT
137	09-Dec-2021	PART OF I-BLOCK SEC-3 POOTH KHURD BAWANA	9	Other Outage	Unplanned Outage	09-Dec-2021	13:35	09-Dec-2021	15:04	89	0.00074	INTERRUPTION DUE TO FAULT
138	09-Dec-2021	PART OF F BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	09-Dec-2021	14:47	09-Dec-2021	15:15	28	0.00008	INTERRUPTION DUE TO FAULT
139	09-Dec-2021	PART OF D BLOCK SEC-2 BAWANA	4	Other Outage	Unplanned Outage	09-Dec-2021	15:07	09-Dec-2021	16:58	111	0.00031	INTERRUPTION DUE TO FAULT
140	09-Dec-2021	PART OF C BLK SEC-02 BAWANA	9	Other Outage	Unplanned Outage	09-Dec-2021	15:20	09-Dec-2021	15:41	21	0.00006	INTERRUPTION DUE TO FAULT
141	09-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	8	Other Outage	Unplanned Outage	09-Dec-2021	15:25	09-Dec-2021	15:45	20	0.00006	INTERRUPTION DUE TO FAULT
142	09-Dec-2021	PART OF G BLK SEC-5 BAWANA	5	Other Outage	Unplanned Outage	09-Dec-2021	15:29	09-Dec-2021	16:37	68	0.00019	INTERRUPTION DUE TO FAULT
143	09-Dec-2021	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	249	Other Outage	Unplanned Outage	09-Dec-2021	15:30	09-Dec-2021	16:23	53	0.00177	INTERRUPTION DUE TO FAULT
144	09-Dec-2021	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	23	Other Outage	Unplanned Outage	09-Dec-2021	15:54	09-Dec-2021	16:23	29	0.00161	INTERRUPTION DUE TO FAULT
145	09-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	6	Other Outage	Unplanned Outage	09-Dec-2021	16:34	09-Dec-2021	18:00	86	0.00024	INTERRUPTION DUE TO FAULT
146	09-Dec-2021	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DIB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	1681	Other Outage	Unplanned Outage	09-Dec-2021	17:04	09-Dec-2021	18:05	61	0.001356	INTERRUPTION DUE TO FAULT
147	09-Dec-2021	PARTS OF PUNJAB KHOD BAWANA	2332	Other Outage	Unplanned Outage	09-Dec-2021	17:48	09-Dec-2021	18:33	45	0.000372	INTERRUPTION DUE TO FAULT
148	09-Dec-2021	PARTS OF PUNJAB KHOD BAWANA	861	Other Outage	Unplanned Outage	09-Dec-2021	17:48	09-Dec-2021	21:07	199	0.000552	FORCE MAJEURE DUE TO SABOTAGE
149	09-Dec-2021	PART OF I-1-BLOCK SEC-5 BAWANA	7	Other Outage	Unplanned Outage	09-Dec-2021	18:45	09-Dec-2021	19:00	15	0.00004	INTERRUPTION DUE TO FAULT
150	09-Dec-2021	PART OF I-1-BLOCK SEC-5 BAWANA	7	Other Outage	Unplanned Outage	09-Dec-2021	19:37	09-Dec-2021	21:56	139	0.00077	FORCE MAJEURE DUE TO SABOTAGE
151	09-Dec-2021	PARTS OF ARIHANT SQUARE SHOPING COMPLEX, SEC-4, D & I BLK SEC-4 BAWANA	241	Other Outage	Unplanned Outage	09-Dec-2021	23:29	10-Dec-2021	00:51	82	0.00046	INTERRUPTION DUE TO FAULT
152	10-Dec-2021	PARTS OF G BLOCK SEC-4 POOTH KHURD BAWANA	253	Other Outage	Unplanned Outage	10-Dec-2021	04:28	10-Dec-2021	06:07	99	0.00055	INTERRUPTION DUE TO FAULT
153	10-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	2	Other Outage	Unplanned Outage	10-Dec-2021	09:01	10-Dec-2021	11:09	128	0.00071	FORCE MAJEURE DUE TO SABOTAGE
154	10-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	10-Dec-2021	09:48	10-Dec-2021	11:37	109	0.00006	INTERRUPTION DUE TO FAULT
155	10-Dec-2021	PART OF JYONTI VILLAGE BAWANA	19	Other Outage	Unplanned Outage	10-Dec-2021	11:11	10-Dec-2021	12:09	58	0.00032	INTERRUPTION DUE TO FAULT
156	10-Dec-2021	PART OF LM BLOCK SEC-3 DSIDC BAWANA	2	Other Outage	Unplanned Outage	10-Dec-2021	12:19	10-Dec-2021	15:00	161	0.00045	FORCE MAJEURE DUE TO SABOTAGE
157	10-Dec-2021	PART OF DD MALL SEC-5 BAWANA	7	Other Outage	Unplanned Outage	10-Dec-2021	12:30	10-Dec-2021	12:46	16	0.00009	INTERRUPTION DUE TO FAULT
158	10-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	Other Outage	Unplanned Outage	10-Dec-2021	13:05	10-Dec-2021	13:55	50	0.00014	INTERRUPTION DUE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
167	12-Dec-2021	PART OF POOTH VILLAGE BAWANA	3	Other Outage	Unplanned Outage	12-Dec-2021	07:50	12-Dec-2021	10:03	133	0.00037	FORCE MAJEURE DUE TO SABOTAGE
168	12-Dec-2021	PARTS OF KANJAWLA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEVRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	2272	Other Outage	Unplanned Outage	12-Dec-2021	08:08	12-Dec-2021	08:51	43	0.000303	INTERRUPTION DUE TO FAULT
169	12-Dec-2021	PART OF O BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	12-Dec-2021	09:20	12-Dec-2021	13:03	223	0.00062	FORCE MAJEURE DUE TO SABOTAGE
170	12-Dec-2021	PART OF I-19 SEC-2 NEAR GOL CHAKKAR, BAWANA	7	Other Outage	Unplanned Outage	12-Dec-2021	09:44	12-Dec-2021	11:25	101	0.000228	INTERRUPTION DUE TO FAULT
171	12-Dec-2021	PART OF J-32 SECTOR-5 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	12-Dec-2021	10:17	12-Dec-2021	12:23	126	0.000335	FORCE MAJEURE DUE TO SABOTAGE
172	12-Dec-2021	PART OF G BLOCK BAWANA	3	Other Outage	Unplanned Outage	12-Dec-2021	11:23	12-Dec-2021	12:43	80	0.000222	INTERRUPTION DUE TO FAULT
173	12-Dec-2021	PART OF A- BLOCK SEC-1 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	12-Dec-2021	11:45	12-Dec-2021	13:12	87	0.000224	INTERRUPTION DUE TO FAULT
174	12-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	6	Other Outage	Unplanned Outage	12-Dec-2021	11:56	12-Dec-2021	14:24	148	0.00041	FORCE MAJEURE DUE TO SABOTAGE
175	12-Dec-2021	PART OF I BLOCK SEC - 2 BAWANA	3	Other Outage	Unplanned Outage	12-Dec-2021	13:41	12-Dec-2021	15:01	80	0.000222	INTERRUPTION DUE TO FAULT
176	12-Dec-2021	PARTS OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	21	Other Outage	Unplanned Outage	12-Dec-2021	13:54	12-Dec-2021	14:31	37	0.000221	INTERRUPTION DUE TO FAULT
177	12-Dec-2021	PART OF E BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	12-Dec-2021	14:59	12-Dec-2021	16:40	101	0.000228	INTERRUPTION DUE TO FAULT
178	12-Dec-2021	PARTS OF B BLK SEC-2 POOTH KHURD BAWANA	172	Other Outage	Unplanned Outage	12-Dec-2021	19:27	12-Dec-2021	20:17	50	0.000114	INTERRUPTION DUE TO FAULT
179	12-Dec-2021	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILIA FLOUR MILL BAWANA	285	Other Outage	Unplanned Outage	12-Dec-2021	23:05	12-Dec-2021	23:40	35	0.000449	INTERRUPTION DUE TO FAULT
180	13-Dec-2021	PART OF F BLK SEC-1 BAWANA	9	Other Outage	Unplanned Outage	13-Dec-2021	09:05	13-Dec-2021	11:27	142	0.000339	FORCE MAJEURE DUE TO SABOTAGE
181	13-Dec-2021	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	13-Dec-2021	09:31	13-Dec-2021	11:42	131	0.000336	FORCE MAJEURE DUE TO SABOTAGE
182	13-Dec-2021	PART OF G BLK SEC-1 BAWANA	8	Other Outage	Unplanned Outage	13-Dec-2021	10:57	13-Dec-2021	15:26	269	0.00075	FORCE MAJEURE DUE TO SABOTAGE
183	13-Dec-2021	PARTS OF D BLOCK SEC-2 POOTH KHURD BAWANA	261	Other Outage	Unplanned Outage	13-Dec-2021	11:13	13-Dec-2021	11:41	28	0.000078	INTERRUPTION DUE TO FAULT
184	13-Dec-2021	PART OF J BLOCK SEC - 2 BAWANA	5	Other Outage	Unplanned Outage	13-Dec-2021	11:17	13-Dec-2021	13:34	137	0.000338	FORCE MAJEURE DUE TO SABOTAGE
185	13-Dec-2021	PART OF E BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	13-Dec-2021	12:00	13-Dec-2021	12:30	30	0.000008	INTERRUPTION DUE TO FAULT
186	13-Dec-2021	PART OF D BLOCK SEC-2 BAWANA	4	Other Outage	Unplanned Outage	13-Dec-2021	12:02	13-Dec-2021	12:50	48	0.000227	INTERRUPTION DUE TO FAULT
187	13-Dec-2021	PARTS OF C, G, E BLOCK SEC - 5 DSIDC BAWANA	275	Other Outage	Unplanned Outage	13-Dec-2021	12:07	13-Dec-2021	12:55	48	0.0012	INTERRUPTION DUE TO FAULT
188	13-Dec-2021	PARTS OF DD MALL SEC-5 BAWANA	148	Other Outage	Unplanned Outage	13-Dec-2021	13:25	13-Dec-2021	13:51	26	0.000108	INTERRUPTION DUE TO FAULT
189	13-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	Other Outage	Unplanned Outage	13-Dec-2021	13:54	13-Dec-2021	15:06	72	0.000202	INTERRUPTION DUE TO FAULT
190	13-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	13-Dec-2021	14:18	13-Dec-2021	16:43	145	0.00004	FORCE MAJEURE DUE TO SABOTAGE
191	13-Dec-2021	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	18	Other Outage	Unplanned Outage	13-Dec-2021	14:46	13-Dec-2021	17:01	135	0.000337	FORCE MAJEURE DUE TO SABOTAGE
192	13-Dec-2021	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	249	Other Outage	Unplanned Outage	13-Dec-2021	17:03	13-Dec-2021	17:53	50	0.002088	SYSTEM SCHEDULE OUTAGE
193	13-Dec-2021	PART OF SEC-2 O.N.J BLOCK BAWANA	4	Other Outage	Unplanned Outage	13-Dec-2021	18:35	13-Dec-2021	19:16	41	0.000011	INTERRUPTION DUE TO FAULT
194	13-Dec-2021	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	272	Other Outage	Unplanned Outage	13-Dec-2021	21:26	13-Dec-2021	23:25	119	0.001653	INTERRUPTION DUE TO FAULT
195	14-Dec-2021	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	272	Other Outage	Unplanned Outage	14-Dec-2021	00:44	14-Dec-2021	03:33	169	0.001268	FORCE MAJEURE DUE TO SABOTAGE
196	14-Dec-2021	PART OF G BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	14-Dec-2021	09:57	14-Dec-2021	11:37	100	0.000228	INTERRUPTION DUE TO FAULT
197	14-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	14-Dec-2021	10:51	14-Dec-2021	14:17	206	0.000057	FORCE MAJEURE DUE TO FIRE
198	14-Dec-2021	PART OF FG-27 SEC-3 BAWANA	4	Other Outage	Unplanned Outage	14-Dec-2021	11:17	14-Dec-2021	13:20	123	0.000034	FORCE MAJEURE DUE TO SABOTAGE
199	14-Dec-2021	PART OF D-BLK SEC-4 BAWANA	4	Other Outage	Unplanned Outage	14-Dec-2021	16:05	14-Dec-2021	17:03	58	0.000016	INTERRUPTION DUE TO FAULT
200	14-Dec-2021	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	142	Other Outage	Unplanned Outage	14-Dec-2021	23:05	14-Dec-2021	23:30	25	0.000209	INTERRUPTION DUE TO FAULT
201	15-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	15-Dec-2021	11:35	15-Dec-2021	13:12	97	0.000227	INTERRUPTION DUE TO FAULT
202	15-Dec-2021	PARTS OF I-BLOCK SEC-4 POOTH KHURD BAWANA	192	Other Outage	Unplanned Outage	15-Dec-2021	12:46	15-Dec-2021	13:49	63	0.000053	INTERRUPTION DUE TO FAULT
203	15-Dec-2021	PART OF JJ CLUSTER BAWANA	20	Other Outage	Unplanned Outage	15-Dec-2021	13:20	15-Dec-2021	17:23	243	0.000135	FORCE MAJEURE DUE TO SABOTAGE
204	15-Dec-2021	PART OF JJ CLUSTER BAWANA	15	Other Outage	Unplanned Outage	15-Dec-2021	13:37	15-Dec-2021	17:24	227	0.000126	FORCE MAJEURE DUE TO SABOTAGE
205	15-Dec-2021	PARTS OF E BLK SEC-1 POOTH KHURD BAEANA BAWANA	312	Other Outage	Unplanned Outage	15-Dec-2021	15:00	15-Dec-2021	15:15	15	0.000733	INTERRUPTION DUE TO FAULT
206	15-Dec-2021	PART OF E BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	15-Dec-2021	16:27	15-Dec-2021	17:41	74	0.000021	INTERRUPTION DUE TO FAULT
207	16-Dec-2021	PARTS OF I-19 SEC-2 NEAR GOL CHAKKAR, BAWANA	28	Other Outage	Unplanned Outage	16-Dec-2021	00:47	16-Dec-2021	02:56	129	0.000036	FORCE MAJEURE DUE TO SABOTAGE
208	16-Dec-2021	PARTS OF I-19 SEC-2 NEAR GOL CHAKKAR, BAWANA	297	Other Outage	Unplanned Outage	16-Dec-2021	01:32	16-Dec-2021	02:56	84	0.000047	SYSTEM SCHEDULE OUTAGE
209	16-Dec-2021	PART OF E BLK SEC-5 BAWANA	3	Other Outage	Unplanned Outage	16-Dec-2021	11:01	16-Dec-2021	14:50	229	0.000064	FORCE MAJEURE DUE TO SABOTAGE
210	16-Dec-2021	PARTS OF E BLK SEC-1 POOTH KHURD BAEANA BAWANA	313	Other Outage	Unplanned Outage	16-Dec-2021	11:37	16-Dec-2021	12:45	68	0.000075	INTERRUPTION DUE TO FAULT
211	16-Dec-2021	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	134	Other Outage	Unplanned Outage	16-Dec-2021	12:49	16-Dec-2021	14:40	111	0.000061	INTERRUPTION DUE TO FAULT
212	16-Dec-2021	PART OF JJ CLUSTER BAWANA	17	Other Outage	Unplanned Outage	16-Dec-2021	12:59	16-Dec-2021	15:33	154	0.000214	FORCE MAJEURE DUE TO SABOTAGE
213	16-Dec-2021	PART OF JJ CLUSTER BAWANA	13	Other Outage	Unplanned Outage	16-Dec-2021	13:21	16-Dec-2021	16:10	169	0.000094	FORCE MAJEURE DUE TO SABOTAGE
214	16-Dec-2021	PART OF D-BLK SEC-4 BAWANA	6	Other Outage	Unplanned Outage	16-Dec-2021	13:27	16-Dec-2021	15:12	105	0.000029	INTERRUPTION DUE TO FAULT
215	16-Dec-2021	PART OF D-BLK SEC-4 BAWANA	5	Other Outage	Unplanned Outage	16-Dec-2021	14:45	16-Dec-2021	15:13	28	0.000008	INTERRUPTION DUE TO FAULT
216	16-Dec-2021	PART OF I BLK SEC5 BAWANA	3	Other Outage	Unplanned Outage	16-Dec-2021	14:47	16-Dec-2021	15:55	68	0.000019	INTERRUPTION DUE TO FAULT
217	16-Dec-2021	PART OF O BLOCK SEC-3 BAWANA	5	Other Outage	Unplanned Outage	16-Dec-2021	17:22	16-Dec-2021	18:30	68	0.000019	INTERRUPTION DUE TO FAULT
218	16-Dec-2021	PART OF LM BLOCK SEC-1 DSIDC BAWANA	4	Other Outage	Unplanned Outage	16-Dec-2021	21:40	16-Dec-2021	23:25	105	0.000029	INTERRUPTION DUE TO FAULT
219	16-Dec-2021	PARTS OF J & K BLOCK POOTHKHURD BAWANA	192	Other Outage	Unplanned Outage	16-Dec-2021	23:03	16-Dec-2021	23:33	30	0.000008	INTERRUPTION DUE TO FAULT
220	17-Dec-2021	PARTS OF DIVYA JYOTI APARTMENT BAWANA	308	Other Outage	Unplanned Outage	17-Dec-2021	07:53	17-Dec-2021	08:30	37	0.000031	INTERRUPTION DUE TO FAULT
221	17-Dec-2021	PART OF POOTH VILLAGE BAWANA	5	Other Outage	Unplanned Outage	17-Dec-2021	10:51	17-Dec-2021	13:15	144	0.00004	FORCE MAJEURE DUE TO SABOTAGE
222	17-Dec-2021	PART OF G BLOCK BAWANA	4	Other Outage	Unplanned Outage	17-Dec-2021	11:39	17-Dec-2021	12:45	66	0.000018	INTERRUPTION DUE TO FAULT
223	17-Dec-2021	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	12	Other Outage	Unplanned Outage	17-Dec-2021	11:45	17-Dec-2021	19:20	455	0.000126	FORCE MAJEURE DUE TO SABOTAGE
224	17-Dec-2021	PART OF E BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	17-Dec-2021	12:07	17-Dec-2021	12:48	41	0.000023	INTERRUPTION DUE TO FAULT
225	17-Dec-2021	PARTS OF C BLOCK SEC-3 POOTH KHURD BAWANA	234	Other Outage	Unplanned Outage	17-Dec-2021	13:50	17-Dec-2021	14:40	50	0.000027	INTERRUPTION DUE TO FAULT
226	17-Dec-2021	PART OF POOTH VILLAGE BAWANA	2	Other Outage	Unplanned Outage	17-Dec-2021	14:19	17-Dec-2021	15:44	85	0.000024	INTERRUPTION DUE TO FAULT
227	17-Dec-2021	PART OF LM BLOCK SEC-1 BAWANA	7	Other Outage	Unplanned Outage	17-Dec-2021	14:55	17-Dec-2021	20:11	316	0.000088	FORCE MAJEURE DUE TO SABOTAGE
228	17-Dec-2021	PART OF B BLK SEC-1 POOTH KHURD BAWANA	8	Other Outage	Unplanned Outage	17-Dec-2021	16:18	17-Dec-2021	20:12	234	0.000065	FORCE MAJEURE DUE TO SABOTAGE
229	17-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	17-Dec-2021	17:08	17-Dec-2021	18:40	92	0.000026	INTERRUPTION DUE TO FAULT
230	18-Dec-2021	PART OF MBS BAWANA	10	Other Outage	Unplanned Outage	18-Dec-2021	03:00	18-Dec-2021	16:30	810	0.00045	FORCE MAJEURE DUE TO SABOTAGE
231	18-Dec-2021	PARTS OF WATER SUPPLY DARIYA PUR, DTC DEPOT AUCHANDI RD BAWANA	3949	Other Outage	Unplanned Outage	18-Dec-2021	08:24	18-Dec-2021	09:53	89	0.002473	INTERRUPTION DUE TO FAULT
232	18-Dec-2021	PARTS OF JYONTI VILLAGE BAWANA	1554	Other Outage	Unplanned Outage	18-Dec-2021	10:13	18-Dec-2021	10:27	14	0.000186	INTERRUPTION DUE TO FAULT
233	18-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	5	Other Outage	Unplanned Outage	18-Dec-2021	10:35	18-Dec-2021	12:22	107	0.000003	INTERRUPTION DUE TO FAULT
234	18-Dec-2021	PARTS OF A F BLK SEC-2 DSIDC, DIB-TW NO-17 BAWANA	300	Other Outage	Unplanned Outage	18-Dec-2021	11:20	18-Dec-2021	11:50	30	0.000783	INTERRUPTION DUE TO FAULT
235	18-Dec-2021	PARTS OF CHANDPUR MAJRA BAWANA	2126	Other Outage	Unplanned Outage	18-Dec-2021	11:55	18-Dec-2021	12:08	13	0.000213	INTERRUPTION DUE TO FAULT
236	18-Dec-2021	PART OF O BLOCK SEC-3 BAWANA	3	Other Outage	Unplanned Outage	18-Dec-2021	12:21	18-Dec-2021	14:00	99	0.000027	INTERRUPTION DUE TO FAULT
237	18-Dec-2021	PART OF K BLOCK BAWANA	3	Other Outage	Unplanned Outage	18-Dec-2021	15:22	18-Dec-2021	16:38	76	0.000021	INTERRUPTION DUE TO FAULT
238	18-Dec-2021	PARTS OF D BLOCK SEC-2 POOTH KHURD BAWANA	33	Other Outage	Unplanned Outage	18-Dec-2021	19:12	18-Dec-2021	20:11	59	0.000016	INTERRUPTION DUE TO FAULT
239	18-Dec-2021	PART OF DD MALL SEC-5 BAWANA	11	Other Outage	Unplanned Outage	18-Dec-2021	19:14	18-Dec-2021	21:01	107	0.000003	INTERRUPTION DUE TO FAULT
240	19-Dec-2021	PART OF F BLOCK BAWANA	2	Other Outage	Unplanned Outage	19-Dec-2021	09:35	19				

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
253	20-Dec-2021	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	20-Dec-2021	13:50	20-Dec-2021	16:19	149	0.000041	FORCE MAJEURE DUE TO SABOTAGE
254	20-Dec-2021	PART OF K BLOCK SEC-2 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	20-Dec-2021	14:06	20-Dec-2021	15:00	54	0.00003	INTERRUPTION DUE TO FAULT
255	20-Dec-2021	PARTS OF KANJAWILA VILLAGE & INDUSTRIAL AREA BAWANA	196	Other Outage	Unplanned Outage	20-Dec-2021	15:45	20-Dec-2021	16:14	29	0.000024	INTERRUPTION DUE TO FAULT
256	20-Dec-2021	PARTS OF DD MALL SEC-5 BAWANA	264	Other Outage	Unplanned Outage	20-Dec-2021	16:05	20-Dec-2021	17:00	55	0.000122	INTERRUPTION DUE TO FAULT
257	20-Dec-2021	PART OF C-BLK SEC-4 BAWANA	6	Other Outage	Unplanned Outage	20-Dec-2021	16:32	20-Dec-2021	17:02	30	0.000008	INTERRUPTION DUE TO FAULT
258	21-Dec-2021	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	250	Other Outage	Unplanned Outage	21-Dec-2021	01:18	21-Dec-2021	01:50	32	0.000489	INTERRUPTION DUE TO FAULT
259	21-Dec-2021	PARTS OF G BLOCK SEC-4 POOTH KHURD BAWANA	228	Other Outage	Unplanned Outage	21-Dec-2021	02:07	21-Dec-2021	02:20	13	0.000141	INTERRUPTION DUE TO FAULT
260	21-Dec-2021	PARTS OF G BLOCK SEC-4 POOTH KHURD BAWANA	44	Other Outage	Unplanned Outage	21-Dec-2021	02:07	21-Dec-2021	02:20	13	0.00007	INTERRUPTION DUE TO FAULT
261	21-Dec-2021	PART OF L BLOCK SEC-2 DSIDC BAWANA	13	Other Outage	Unplanned Outage	21-Dec-2021	07:45	21-Dec-2021	09:06	81	0.000023	INTERRUPTION DUE TO FAULT
262	21-Dec-2021	PART OF I-BLOCK SEC-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	21-Dec-2021	08:20	21-Dec-2021	11:00	160	0.000044	FORCE MAJEURE DUE TO SABOTAGE
263	21-Dec-2021	PART OF SEC-5 B BLOCK BAWANA	5	Other Outage	Unplanned Outage	21-Dec-2021	09:08	21-Dec-2021	11:40	152	0.000085	FORCE MAJEURE DUE TO SABOTAGE
264	21-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	21-Dec-2021	09:16	21-Dec-2021	11:40	144	0.00004	FORCE MAJEURE DUE TO SABOTAGE
265	21-Dec-2021	PART OF LM BLOCK SEC-3 DSIDC BAWANA	2	Other Outage	Unplanned Outage	21-Dec-2021	10:21	21-Dec-2021	11:45	84	0.000023	INTERRUPTION DUE TO FAULT
266	21-Dec-2021	PART OF LM BLOCK SEC-3 DSIDC BAWANA	9	Other Outage	Unplanned Outage	21-Dec-2021	11:07	21-Dec-2021	14:00	173	0.000144	FORCE MAJEURE DUE TO SABOTAGE
267	21-Dec-2021	PART OF SEC-2 O,N,J BLOCK BAWANA	2	Other Outage	Unplanned Outage	21-Dec-2021	14:23	21-Dec-2021	16:01	98	0.000027	INTERRUPTION DUE TO FAULT
268	21-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	2	Other Outage	Unplanned Outage	21-Dec-2021	14:24	21-Dec-2021	15:46	82	0.000045	INTERRUPTION DUE TO FAULT
269	21-Dec-2021	PART OF LM BLOCK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	21-Dec-2021	14:25	21-Dec-2021	16:05	100	0.000056	INTERRUPTION DUE TO FAULT
270	21-Dec-2021	PART OF C BLK SEC-1 BAWANA	9	Other Outage	Unplanned Outage	21-Dec-2021	15:14	21-Dec-2021	17:05	111	0.000061	INTERRUPTION DUE TO FAULT
271	21-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	21-Dec-2021	15:43	21-Dec-2021	16:42	59	0.000033	INTERRUPTION DUE TO FAULT
272	21-Dec-2021	PARTS OF C BLK SEC-1 BAWANA	154	Other Outage	Unplanned Outage	21-Dec-2021	16:30	21-Dec-2021	17:05	35	0.000049	INTERRUPTION DUE TO FAULT
273	21-Dec-2021	PART OF LM BLOCK SEC-1 DSIDC BAWANA	2	Other Outage	Unplanned Outage	21-Dec-2021	18:20	21-Dec-2021	20:45	145	0.00004	FORCE MAJEURE DUE TO SABOTAGE
274	21-Dec-2021	PART OF LM BLOCK SEC-1 BAWANA	8	Other Outage	Unplanned Outage	21-Dec-2021	18:58	21-Dec-2021	19:30	32	0.000018	INTERRUPTION DUE TO FAULT
275	21-Dec-2021	PART OF K BLOCK BAWANA	7	Other Outage	Unplanned Outage	21-Dec-2021	22:31	21-Dec-2021	23:25	54	0.000015	INTERRUPTION DUE TO FAULT
276	21-Dec-2021	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, P55-400-MB HOSPITAL,KRISHNA MARKET NO-1 BAWANA	600	Other Outage	Unplanned Outage	21-Dec-2021	23:50	22-Dec-2021	00:10	20	0.00011	INTERRUPTION DUE TO FAULT
277	22-Dec-2021	PARTS OF E BLK SEC-5 POOTH KHURD BAWANA	166	Other Outage	Unplanned Outage	22-Dec-2021	10:49	22-Dec-2021	11:30	41	0.000056	INTERRUPTION DUE TO FAULT
278	22-Dec-2021	PART OF POOTH VILLAGE BAWANA	5	Other Outage	Unplanned Outage	22-Dec-2021	10:59	22-Dec-2021	12:30	91	0.000025	FORCE MAJEURE DUE TO SABOTAGE
279	22-Dec-2021	PART OF I BLOCK SEC-2 DSIDC BAWANA	5	Other Outage	Unplanned Outage	22-Dec-2021	11:19	22-Dec-2021	16:16	297	0.000083	FORCE MAJEURE DUE TO SABOTAGE
280	22-Dec-2021	PARTS OF DD MALL SEC-5 BAWANA	143	Other Outage	Unplanned Outage	22-Dec-2021	12:02	22-Dec-2021	12:46	44	0.000061	INTERRUPTION DUE TO FAULT
281	22-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	22-Dec-2021	13:41	22-Dec-2021	16:20	159	0.000044	FORCE MAJEURE DUE TO SABOTAGE
282	22-Dec-2021	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2 BAWANA	35	Other Outage	Unplanned Outage	22-Dec-2021	13:55	22-Dec-2021	14:43	48	0.000027	INTERRUPTION DUE TO FAULT
283	22-Dec-2021	PART OF KRISHNA MARKET BAWANA	15	Other Outage	Unplanned Outage	22-Dec-2021	16:35	22-Dec-2021	17:52	77	0.000021	INTERRUPTION DUE TO FAULT
284	23-Dec-2021	PART OF BLK-A BHOARGAR BAWANA	5	Other Outage	Unplanned Outage	23-Dec-2021	07:50	23-Dec-2021	09:10	80	0.000044	INTERRUPTION DUE TO FAULT
285	23-Dec-2021	PART OF FG BLOCK SEC-3 DSIDC BAWANA	4	Other Outage	Unplanned Outage	23-Dec-2021	09:10	23-Dec-2021	11:00	110	0.000061	INTERRUPTION DUE TO FAULT
286	23-Dec-2021	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	144	Other Outage	Unplanned Outage	23-Dec-2021	11:14	23-Dec-2021	11:48	34	0.000189	INTERRUPTION DUE TO FAULT
287	23-Dec-2021	PART OF B BLK SEC-1 POOTH KHURD BAWANA	2	Other Outage	Unplanned Outage	23-Dec-2021	11:16	23-Dec-2021	11:52	36	0.00001	INTERRUPTION DUE TO FAULT
288	23-Dec-2021	PART OF B BLK SEC-1 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	23-Dec-2021	12:17	23-Dec-2021	16:02	225	0.000188	FORCE MAJEURE DUE TO SABOTAGE
289	23-Dec-2021	PARTS OF SEC-2 O,N,J BLOCK BAWANA	534	Other Outage	Unplanned Outage	23-Dec-2021	12:42	23-Dec-2021	13:25	43	0.000598	INTERRUPTION DUE TO FAULT
290	23-Dec-2021	PARTS OF VILLAGE KANJAWILA, BULLIA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	2818	Other Outage	Unplanned Outage	23-Dec-2021	12:45	23-Dec-2021	13:32	47	0.000662	INTERRUPTION DUE TO FAULT
291	23-Dec-2021	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	135	Other Outage	Unplanned Outage	23-Dec-2021	13:16	23-Dec-2021	13:40	24	0.000067	INTERRUPTION DUE TO FAULT
292	23-Dec-2021	PART OF FG BLOCK SEC-3 DSIDC BAWANA	4	Other Outage	Unplanned Outage	23-Dec-2021	13:39	23-Dec-2021	15:25	106	0.000029	INTERRUPTION DUE TO FAULT
293	23-Dec-2021	PART OF E BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	23-Dec-2021	14:02	23-Dec-2021	16:05	123	0.000068	FORCE MAJEURE DUE TO SABOTAGE
294	23-Dec-2021	PARTS OF CISF DMRC FAMILY DSIDC FLATS CNG ROAD SEC 4 BAWANA	1985	Other Outage	Unplanned Outage	23-Dec-2021	16:51	23-Dec-2021	17:25	34	0.000167	INTERRUPTION DUE TO FAULT
295	24-Dec-2021	PARTS OF ESS-1 & 2 BAWANA	1061	Other Outage	Unplanned Outage	24-Dec-2021	07:20	24-Dec-2021	08:25	65	0.000181	INTERRUPTION DUE TO FAULT
296	24-Dec-2021	PART OF K BLOCK BAWANA	4	Other Outage	Unplanned Outage	24-Dec-2021	07:27	24-Dec-2021	09:55	148	0.000082	FORCE MAJEURE DUE TO SABOTAGE
297	24-Dec-2021	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	24-Dec-2021	10:26	24-Dec-2021	16:26	360	0.0002	FORCE MAJEURE DUE TO FIRE
298	24-Dec-2021	PARTS OF A,F,BLK SEC-2 DSIDC, DIB-TW NO-17 BAWANA	300	Other Outage	Unplanned Outage	24-Dec-2021	10:43	24-Dec-2021	11:12	29	0.000201	INTERRUPTION DUE TO FAULT
299	24-Dec-2021	PART OF FG-27 SEC-3 BAWANA	3	Other Outage	Unplanned Outage	24-Dec-2021	11:02	24-Dec-2021	13:59	177	0.000098	FORCE MAJEURE DUE TO SABOTAGE
300	24-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	467	Other Outage	Unplanned Outage	24-Dec-2021	11:04	24-Dec-2021	11:14	10	0.000014	INTERRUPTION DUE TO FAULT
301	24-Dec-2021	PART OF JJ CLUSTER BAWANA	9	Other Outage	Unplanned Outage	24-Dec-2021	11:05	24-Dec-2021	14:14	189	0.000263	FORCE MAJEURE DUE TO SABOTAGE
302	24-Dec-2021	PART OF O BLK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	24-Dec-2021	11:20	24-Dec-2021	13:14	114	0.000031	INTERRUPTION DUE TO FAULT
303	24-Dec-2021	PART OF JJ CLUSTER BAWANA	3	Other Outage	Unplanned Outage	24-Dec-2021	11:21	24-Dec-2021	14:14	173	0.000096	FORCE MAJEURE DUE TO SABOTAGE
304	24-Dec-2021	PART OF O BLK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	24-Dec-2021	12:17	24-Dec-2021	13:00	43	0.000012	INTERRUPTION DUE TO FAULT
305	24-Dec-2021	PARTS OF LADPUR VILLAGE BAWANA	164	Other Outage	Unplanned Outage	24-Dec-2021	12:40	24-Dec-2021	16:08	208	0.000116	FORCE MAJEURE DUE TO SABOTAGE
306	24-Dec-2021	PART OF ARIHANT SQUARE SHOPING COMPLEX BAWANA	5	Other Outage	Unplanned Outage	24-Dec-2021	13:14	24-Dec-2021	14:25	71	0.00002	INTERRUPTION DUE TO FAULT
307	24-Dec-2021	PART OF O BLOCK SEC-2 BAWANA	7	Other Outage	Unplanned Outage	24-Dec-2021	13:30	24-Dec-2021	14:35	65	0.000018	INTERRUPTION DUE TO FAULT
308	24-Dec-2021	PARTS OF VIJAY NAGAR, SKY DARYA PUR, MAIN BUS STAND BAWANA	3802	Other Outage	Unplanned Outage	24-Dec-2021	14:23	24-Dec-2021	14:45	22	0.000238	INTERRUPTION DUE TO FAULT
309	24-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	8	Other Outage	Unplanned Outage	24-Dec-2021	14:24	24-Dec-2021	17:07	163	0.000045	FORCE MAJEURE DUE TO SABOTAGE
310	24-Dec-2021	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	394	Other Outage	Unplanned Outage	24-Dec-2021	17:53	24-Dec-2021	18:38	45	0.000025	INTERRUPTION DUE TO FAULT
311	25-Dec-2021	PART OF DD MALL SEC-5 BAWANA	4	Other Outage	Unplanned Outage	25-Dec-2021	11:35	25-Dec-2021	13:41	126	0.00007	FORCE MAJEURE DUE TO SABOTAGE
312	25-Dec-2021	PART OF A- BLOCK SEC-1 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	25-Dec-2021	11:46	25-Dec-2021	12:39	53	0.000029	INTERRUPTION DUE TO FAULT
313	25-Dec-2021	PART OF LM BLOCK SEC-3 DSIDC BAWANA	3	Other Outage	Unplanned Outage	25-Dec-2021	12:38	25-Dec-2021	13:24	46	0.000013	INTERRUPTION DUE TO FAULT
314	25-Dec-2021	PART OF ARIHANT SQUARE SHOPING COMPLEX BAWANA	3	Other Outage	Unplanned Outage	25-Dec-2021	13:39	25-Dec-2021	16:39	180	0.0001	FORCE MAJEURE DUE TO SABOTAGE
315	25-Dec-2021	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	142	Other Outage	Unplanned Outage	25-Dec-2021	14:13	25-Dec-2021	14:50	37	0.00001	INTERRUPTION DUE TO FAULT
316	25-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	2	Other Outage	Unplanned Outage	25-Dec-2021	14:19	25-Dec-2021	15:00	41	0.000022	INTERRUPTION DUE TO FAULT
317	25-Dec-2021	PART OF E BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	25-Dec-2021	15:00	25-Dec-2021	15:30	30	0.000017	INTERRUPTION DUE TO FAULT
318	25-Dec-2021	PART OF DD MALL SEC-5 BAWANA	3	Other Outage	Unplanned Outage	25-Dec-2021	15:19	25-Dec-2021	16:20	61	0.000034	INTERRUPTION DUE TO FAULT
319	26-Dec-2021	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	144	Other Outage	Unplanned Outage	26-Dec-2021	10:59	26-Dec-2021	11:30	31	0.000862	INTERRUPTION DUE TO FAULT
320	26-Dec-2021	PART OF DD MALL SEC-5 BAWANA	4	Other Outage	Unplanned Outage	26-Dec-2021	13:01	26-Dec-2021	16:00	179	0.00005	FORCE MAJEURE DUE TO SABOTAGE
321	26-Dec-2021	PART OF JHONTI VILLAGE BAWANA	10	Other Outage	Unplanned Outage	26-Dec-2021	16:59	26-Dec-2021	17:54	55	0.000031	INTERRUPTION DUE TO FAULT
322	26-Dec-2021	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	48	Other Outage	Unplanned Outage	26-Dec-2021	17:54	26-Dec-2021	18:44	50	0.00007	INTERRUPTION DUE TO FAULT
323	26-Dec-2021	PARTS OF KANJAWILA VILLAGE & INDUSTRIAL AREA BAWANA	199	Other Outage	Unplanned Outage	26-Dec-2021	17:59	26-Dec-2021	18:50	51	0.000286	INTERRUPTION DUE TO FAULT
324	26-Dec-2021	PARTS OF VIJAY NAGAR, SKY DARYA PUR, MAIN BUS STAND BAWANA	3813	Other Outage	Unplanned Outage	26-Dec-2021	19:17	26-Dec-2021	20:25	68	0.000944	INTERRUPTION DUE TO FAULT
325	26-Dec-2021	PARTS OF SEC-4 C,D,J BLOCK BAWANA	44	Other Outage	Unplanned Outage	26-Dec-2021	19:21	26-Dec-2021	22:10	169	0.00	

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
339	27-Dec-2021	PARTS OF ARIHANT SQUARE SHOPING COMPLEX,SEC-4, D & I BLK SEC-4 BAWANA	247	Other Outage	Unplanned Outage	27-Dec-2021	12:20	27-Dec-2021	13:22	62	0.000052	INTERRUPTION DUE TO FAULT
340	27-Dec-2021	PARTS OF L-BLOCK SEC-3 POOTH KHURD BAWANA	74	Other Outage	Unplanned Outage	27-Dec-2021	12:30	27-Dec-2021	13:37	67	0.000037	INTERRUPTION DUE TO FAULT
341	27-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	27-Dec-2021	12:37	27-Dec-2021	14:12	95	0.000026	INTERRUPTION DUE TO FAULT
342	27-Dec-2021	PART OF C BLK SEC-02 BAWANA	5	Other Outage	Unplanned Outage	27-Dec-2021	13:05	27-Dec-2021	16:45	220	0.000061	FORCE MAJEURE DUE TO SABOTAGE
343	27-Dec-2021	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL BAWANA	116	Other Outage	Unplanned Outage	27-Dec-2021	14:35	27-Dec-2021	16:08	93	0.000284	INTERRUPTION DUE TO FAULT
344	27-Dec-2021	PARTS OF JYANTI VILLAGE BAWANA	1557	Other Outage	Unplanned Outage	27-Dec-2021	14:37	27-Dec-2021	15:15	38	0.000222	INTERRUPTION DUE TO FAULT
345	27-Dec-2021	PARTS OF B-BLOCK SEC-3 POOTH KHURD BAWANA	222	Other Outage	Unplanned Outage	27-Dec-2021	14:57	27-Dec-2021	16:09	72	0.000024	INTERRUPTION DUE TO FAULT
346	27-Dec-2021	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL BAWANA	69	Other Outage	Unplanned Outage	27-Dec-2021	15:17	27-Dec-2021	16:09	52	0.000087	INTERRUPTION DUE TO FAULT
347	27-Dec-2021	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	2430	Other Outage	Unplanned Outage	27-Dec-2021	16:17	27-Dec-2021	16:45	28	0.000319	INTERRUPTION DUE TO FAULT
348	27-Dec-2021	PARTS OF LM BLOCK SEC-3 DSIDC BAWANA	30	Other Outage	Unplanned Outage	27-Dec-2021	16:34	27-Dec-2021	17:23	49	0.000027	INTERRUPTION DUE TO FAULT
349	27-Dec-2021	PART OF F BLK SEC-1 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	27-Dec-2021	16:37	27-Dec-2021	18:39	122	0.000034	FORCE MAJEURE DUE TO SABOTAGE
350	28-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	Other Outage	Unplanned Outage	28-Dec-2021	02:11	28-Dec-2021	02:45	34	0.000019	INTERRUPTION DUE TO FAULT
351	28-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	1843	Other Outage	Unplanned Outage	28-Dec-2021	02:40	28-Dec-2021	03:15	35	0.000146	INTERRUPTION DUE TO FAULT
352	28-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	471	Other Outage	Unplanned Outage	28-Dec-2021	03:35	28-Dec-2021	05:59	144	0.00002	FORCE MAJEURE DUE TO SABOTAGE
353	28-Dec-2021	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	27	Other Outage	Unplanned Outage	28-Dec-2021	06:04	28-Dec-2021	07:34	90	0.000125	INTERRUPTION DUE TO FAULT
354	28-Dec-2021	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	22	Other Outage	Unplanned Outage	28-Dec-2021	06:04	28-Dec-2021	15:23	559	0.000311	FORCE MAJEURE DUE TO SABOTAGE
355	28-Dec-2021	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	26	Other Outage	Unplanned Outage	28-Dec-2021	10:22	28-Dec-2021	15:23	301	0.000251	FORCE MAJEURE DUE TO SABOTAGE
356	28-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	28-Dec-2021	10:49	28-Dec-2021	12:29	100	0.000028	INTERRUPTION DUE TO FAULT
357	28-Dec-2021	PART OF GARTH RINDHALA BAWANA	2	Other Outage	Unplanned Outage	28-Dec-2021	13:01	28-Dec-2021	17:10	249	0.000069	FORCE MAJEURE DUE TO SABOTAGE
358	28-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	469	Other Outage	Unplanned Outage	28-Dec-2021	13:02	28-Dec-2021	13:24	22	0.000037	INTERRUPTION DUE TO FAULT
359	28-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	Other Outage	Unplanned Outage	28-Dec-2021	14:08	28-Dec-2021	16:39	151	0.000042	FORCE MAJEURE DUE TO SABOTAGE
360	28-Dec-2021	PART OF G BLK SEC-5 BAWANA	3	Other Outage	Unplanned Outage	28-Dec-2021	15:36	28-Dec-2021	15:50	14	0.000004	INTERRUPTION DUE TO FAULT
361	28-Dec-2021	PARTS OF VIJAY NAGAR, SKY DARYA PUR, MAIN BUS STAND BAWANA	3808	Other Outage	Unplanned Outage	28-Dec-2021	15:46	28-Dec-2021	16:40	54	0.000075	INTERRUPTION DUE TO FAULT
362	28-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	469	Other Outage	Unplanned Outage	28-Dec-2021	16:33	28-Dec-2021	17:10	37	0.000082	INTERRUPTION DUE TO FAULT
363	28-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	1039	Other Outage	Unplanned Outage	28-Dec-2021	16:57	28-Dec-2021	18:54	117	0.00039	INTERRUPTION DUE TO FAULT
364	28-Dec-2021	PART OF N-1 BLOCK SEC-3 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	28-Dec-2021	20:35	28-Dec-2021	21:20	45	0.000025	INTERRUPTION DUE TO FAULT
365	28-Dec-2021	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL KRISHNA MARKET NO-1 BAWANA	421	Other Outage	Unplanned Outage	28-Dec-2021	21:35	28-Dec-2021	21:45	10	0.000014	INTERRUPTION DUE TO FAULT
366	28-Dec-2021	PARTS OF HI BLOCK SEC-5 DSIDC BAWANA	189	Other Outage	Unplanned Outage	28-Dec-2021	22:29	28-Dec-2021	22:59	30	0.000042	INTERRUPTION DUE TO FAULT
367	29-Dec-2021	PARTS OF DJB RAW WATER PUMP HOUSE BAWANA	125	Other Outage	Unplanned Outage	29-Dec-2021	02:10	29-Dec-2021	02:28	18	0.000191	INTERRUPTION DUE TO FAULT
368	29-Dec-2021	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL BAWANA	286	Other Outage	Unplanned Outage	29-Dec-2021	05:33	29-Dec-2021	06:25	52	0.000289	INTERRUPTION DUE TO FAULT
369	29-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	8	Other Outage	Unplanned Outage	29-Dec-2021	11:09	29-Dec-2021	11:35	26	0.000014	INTERRUPTION DUE TO FAULT
370	29-Dec-2021	PART OF E BLK SEC-5 BAWANA	2	Other Outage	Unplanned Outage	29-Dec-2021	14:11	29-Dec-2021	16:30	139	0.000039	FORCE MAJEURE DUE TO SABOTAGE
371	29-Dec-2021	PART OF RAW WATER WITH T-OFFS BAWANA	3	Other Outage	Unplanned Outage	29-Dec-2021	15:35	29-Dec-2021	17:16	101	0.000028	INTERRUPTION DUE TO FAULT
372	29-Dec-2021	PART OF C-BLK SEC-4 BAWANA	6	Other Outage	Unplanned Outage	29-Dec-2021	22:09	29-Dec-2021	22:39	30	0.000017	INTERRUPTION DUE TO FAULT
373	30-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	30-Dec-2021	09:14	30-Dec-2021	10:55	101	0.000028	INTERRUPTION DUE TO FAULT
374	30-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	7	Other Outage	Unplanned Outage	30-Dec-2021	10:28	30-Dec-2021	11:12	44	0.000012	INTERRUPTION DUE TO FAULT
375	30-Dec-2021	PART OF F BLOCK SEC-2 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	30-Dec-2021	10:51	30-Dec-2021	12:15	84	0.000023	INTERRUPTION DUE TO FAULT
376	30-Dec-2021	PART OF I BLK SEC-5 BAWANA	2	Other Outage	Unplanned Outage	30-Dec-2021	10:53	30-Dec-2021	11:38	45	0.000012	INTERRUPTION DUE TO FAULT
377	30-Dec-2021	PART OF A- BLOCK SEC-1 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	30-Dec-2021	12:18	30-Dec-2021	16:36	258	0.000072	FORCE MAJEURE DUE TO SABOTAGE
378	30-Dec-2021	PART OF A- BLOCK SEC-1 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	30-Dec-2021	12:21	30-Dec-2021	16:37	256	0.000071	FORCE MAJEURE DUE TO SABOTAGE
379	30-Dec-2021	PART OF D BLOCK SEC-2 BAWANA	4	Other Outage	Unplanned Outage	30-Dec-2021	12:21	30-Dec-2021	12:55	34	0.000009	INTERRUPTION DUE TO FAULT
380	30-Dec-2021	PART OF A- BLOCK SEC-1 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	30-Dec-2021	12:23	30-Dec-2021	16:37	254	0.000071	FORCE MAJEURE DUE TO SABOTAGE
381	30-Dec-2021	PARTS OF JJ CLUSTER NO-3 KANJAHAWALA BAWANA	213	Other Outage	Unplanned Outage	30-Dec-2021	13:49	30-Dec-2021	14:18	29	0.000016	INTERRUPTION DUE TO FAULT
382	30-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	3	Other Outage	Unplanned Outage	30-Dec-2021	13:53	30-Dec-2021	14:15	22	0.000006	INTERRUPTION DUE TO FAULT
383	30-Dec-2021	PARTS OF E BLK SEC-1 POOTH KHURD BAWANA	313	Other Outage	Unplanned Outage	30-Dec-2021	16:16	30-Dec-2021	16:35	19	0.000024	INTERRUPTION DUE TO FAULT
384	30-Dec-2021	PART OF BAWANA STADIUM AND INDS. AREA BAWANA	11	Other Outage	Unplanned Outage	30-Dec-2021	18:29	30-Dec-2021	19:55	86	0.000024	INTERRUPTION DUE TO FAULT
385	30-Dec-2021	PARTS OF BAWANA STADIUM AND INDS. AREA BAWANA	42	Other Outage	Unplanned Outage	30-Dec-2021	19:30	30-Dec-2021	19:55	25	0.000021	INTERRUPTION DUE TO FAULT
386	30-Dec-2021	PARTS OF KANJAHAWALA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEWRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	2245	Other Outage	Unplanned Outage	30-Dec-2021	22:56	30-Dec-2021	23:25	29	0.000279	INTERRUPTION DUE TO FAULT
387	30-Dec-2021	PARTS OF KANJAHAWALA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEWRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	30	Other Outage	Unplanned Outage	30-Dec-2021	22:56	31-Dec-2021	00:35	99	0.00011	INTERRUPTION DUE TO FAULT
388	31-Dec-2021	PART OF DD MALL SECT-5 BAWANA	5	Other Outage	Unplanned Outage	31-Dec-2021	07:08	31-Dec-2021	11:34	266	0.000148	FORCE MAJEURE DUE TO SABOTAGE
389	31-Dec-2021	PART OF HI BLOCK SEC-5 DSIDC BAWANA	4	Other Outage	Unplanned Outage	31-Dec-2021	08:11	31-Dec-2021	11:56	225	0.000125	FORCE MAJEURE DUE TO SABOTAGE
390	31-Dec-2021	PARTS OF JJ CLUSTER NO-3 KANJAHAWALA BAWANA	124	Other Outage	Unplanned Outage	31-Dec-2021	09:33	31-Dec-2021	11:29	116	0.000161	INTERRUPTION DUE TO FAULT
391	31-Dec-2021	PART OF B BLOCK SEC-5 DSIDC BAWANA	3	Other Outage	Unplanned Outage	31-Dec-2021	10:32	31-Dec-2021	12:30	118	0.000033	INTERRUPTION DUE TO FAULT
392	31-Dec-2021	PARTS OF JJ CLUSTER NO-3 KANJAHAWALA BAWANA	362	Other Outage	Unplanned Outage	31-Dec-2021	10:58	31-Dec-2021	11:29	31	0.000069	INTERRUPTION DUE TO FAULT
393	31-Dec-2021	PART OF LM BLOCK SEC-2 DSIDC BAWANA	7	Other Outage	Unplanned Outage	31-Dec-2021	11:49	31-Dec-2021	12:15	26	0.000007	INTERRUPTION DUE TO FAULT
394	31-Dec-2021	PART OF GARTH RINDHALA BAWANA	2	Other Outage	Unplanned Outage	31-Dec-2021	12:41	31-Dec-2021	15:27	166	0.000046	FORCE MAJEURE DUE TO SABOTAGE
395	31-Dec-2021	PART OF FG-27 SEC-3 BAWANA	2	Other Outage	Unplanned Outage	31-Dec-2021	14:35	31-Dec-2021	16:48	133	0.000074	FORCE MAJEURE DUE TO SABOTAGE
396	31-Dec-2021	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	31-Dec-2021	14:35	31-Dec-2021	15:37	62	0.000017	INTERRUPTION DUE TO FAULT
397	31-Dec-2021	PART OF RAW WATER WITH T-OFFS BAWANA	7	Other Outage	Unplanned Outage	31-Dec-2021	15:23	31-Dec-2021	16:24	61	0.000085	INTERRUPTION DUE TO FAULT
398	31-Dec-2021	PARTS OF F BLOCK SEC-4 DSIDC BAWANA	37	Other Outage	Unplanned Outage	31-Dec-2021	15:43	31-Dec-2021	16:43	60	0.000083	INTERRUPTION DUE TO FAULT
399	31-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	31-Dec-2021	15:49	31-Dec-2021	16:55	66	0.000037	SYSTEM SCHEDULE OUTAGE
400	31-Dec-2021	PARTS OF KANJAHAWALA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEWRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	25	Other Outage	Unplanned Outage	31-Dec-2021	17:51	31-Dec-2021	18:42	51	0.000071	INTERRUPTION DUE TO FAULT
401	01-Dec-2021	PARTS OF L.C.H.-3184 BLOCK-8 DSIDC BAWANA	883	Other Outage	Planned Outage	01-Dec-2021	10:22	01-Dec-2021	16:14	352	0.000078	PLANNED OUTAGE
402	01-Dec-2021	PARTS OF SUJZI MANDI KANJAHAWALA ROAD, INDIRA COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJAHAWALA ROAD BAWANA	344	630 kVA	Planned Outage	01-Dec-2021	10:50	01-Dec-2021	12:20	90	0.00008	PLANNED OUTAGE
403	01-Dec-2021	PART OF G BLK SEC-02 BAWANA	1	160 kVA	Unplanned Outage	01-Dec-2021	10:51	01-Dec-2021	12:03	72	0.000002	SYSTEM SCHEDULE OUTAGE
404	01-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	8	160 kVA	Unplanned Outage	01-Dec-2021	11:01	01-Dec-2021	12:16	75	0.000002	SYSTEM SCHEDULE OUTAGE
405	01-Dec-2021	PART OF UPKAR COLONY NO-2 BAWANA	19	160 kVA	Planned Outage	01-Dec-2021	11:03	01-Dec-2021	15:02	239	0.000007	PLANNED OUTAGE
406	01-Dec-2021	PART OF G BLOCK BAWANA	6	315 kVA	Unplanned Outage	01-Dec-2021	11:40	01-Dec-2021	12:56	76	0.000002	SYSTEM SCHEDULE OUTAGE
407	01-Dec-2021	PART OF I BLK SEC-1 BAWANA	3	100 kVA	Unplanned Outage	01-Dec-2021	11:54	01-Dec-2021	12:33	39	0.000001	SYSTEM SCHEDULE OUTAGE
408	01-Dec-2021	PART OF G BLK SEC-5 BAWANA	3	160 kVA	Unplanned Outage	01-Dec-2021	11:59	01-Dec-2021	12:47	48	0.000001	SYSTEM SCHEDULE OUTAGE
409	01-Dec-2021	PART OF POLICE STATION KHANJAHAWALA BAWANA	1	63 kVA	Unplanned Outage	01-Dec-2021	12:29	01-Dec-2021	12:52	23	0.000001	SYSTEM SCHEDULE OUTAGE
410	01-Dec-2021	PART OF G BLOCK BAWANA	6	250 kVA</								

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (In 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
423	02-Dec-2021	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADIWA DT-2 BAWANA	206	Other Outage	Planned Outage	02-Dec-2021	11:24	02-Dec-2021	15:22	238	0.00013	PLANNED OUTAGE
424	02-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	7	250 KVA	Unplanned Outage	02-Dec-2021	11:24	02-Dec-2021	11:58	34	0.00001	SYSTEM SCHEDULE OUTAGE
425	02-Dec-2021	PART OF I BLK SEC-5 BAWANA	2	63 KVA	Unplanned Outage	02-Dec-2021	11:41	02-Dec-2021	12:31	50	0.00001	SYSTEM SCHEDULE OUTAGE
426	02-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	6	160 KVA	Unplanned Outage	02-Dec-2021	11:47	02-Dec-2021	12:12	25	0.00001	SYSTEM SCHEDULE OUTAGE
427	02-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	6	315 KVA	Unplanned Outage	02-Dec-2021	11:55	02-Dec-2021	13:31	96	0.00003	SYSTEM SCHEDULE OUTAGE
428	02-Dec-2021	PART OF J BLOCK SEC - 2 BAWANA	3	315 KVA	Unplanned Outage	02-Dec-2021	13:21	02-Dec-2021	14:23	62	0.00002	SYSTEM SCHEDULE OUTAGE
429	02-Dec-2021	PART OF I1- BLOCK SEC-5 BAWANA	5	400 KVA	Unplanned Outage	02-Dec-2021	13:27	02-Dec-2021	14:37	70	0.00002	SYSTEM SCHEDULE OUTAGE
430	02-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	10	160 KVA	Unplanned Outage	02-Dec-2021	14:33	02-Dec-2021	16:18	105	0.00003	SYSTEM SCHEDULE OUTAGE
431	02-Dec-2021	PART OF FG-27 SEC-3 BAWANA	1	100 KVA	Unplanned Outage	02-Dec-2021	14:39	02-Dec-2021	15:01	22	0.00001	SYSTEM SCHEDULE OUTAGE
432	02-Dec-2021	PART OF G BLK SEC-5 BAWANA	3	315 KVA	Unplanned Outage	02-Dec-2021	15:41	02-Dec-2021	17:13	92	0.00003	SYSTEM SCHEDULE OUTAGE
433	02-Dec-2021	PART OF SEC-2 O,N,J BLOCK BAWANA	6	315 KVA	Unplanned Outage	02-Dec-2021	15:44	02-Dec-2021	16:30	46	0.00001	SYSTEM SCHEDULE OUTAGE
434	02-Dec-2021	PART OF F BLK SEC-1 POOTH KHURD BAWANA	3	315 KVA	Unplanned Outage	02-Dec-2021	15:49	02-Dec-2021	16:16	27	0.00001	SYSTEM SCHEDULE OUTAGE
435	03-Dec-2021	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPLCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD BAWANA	1230	Other Outage	Planned Outage	03-Dec-2021	10:25	03-Dec-2021	17:20	415	0.00138	PLANNED OUTAGE
436	03-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	160 KVA	Planned Outage	03-Dec-2021	11:14	03-Dec-2021	14:06	172	0.00005	PLANNED OUTAGE
437	03-Dec-2021	PART OF G BLK SEC-5 BAWANA	3	315 KVA	Unplanned Outage	03-Dec-2021	11:19	03-Dec-2021	11:45	26	0.00001	SYSTEM SCHEDULE OUTAGE
438	03-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	63 KVA	Planned Outage	03-Dec-2021	11:31	03-Dec-2021	13:23	112	0.00003	PLANNED OUTAGE
439	03-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	6	315 KVA	Unplanned Outage	03-Dec-2021	11:40	03-Dec-2021	13:16	96	0.00003	SYSTEM SCHEDULE OUTAGE
440	03-Dec-2021	PART OF E BLK SEC-1 BAWANA	5	315 KVA	Unplanned Outage	03-Dec-2021	12:02	03-Dec-2021	12:34	32	0.00001	SYSTEM SCHEDULE OUTAGE
441	03-Dec-2021	PART OF SEC-5 B BLOCK BAWANA	2	250 KVA	Unplanned Outage	03-Dec-2021	12:09	03-Dec-2021	13:22	73	0.00002	SYSTEM SCHEDULE OUTAGE
442	03-Dec-2021	PART OF SEC-5 B BLOCK BAWANA	5	315 KVA	Unplanned Outage	03-Dec-2021	12:12	03-Dec-2021	13:21	69	0.00002	SYSTEM SCHEDULE OUTAGE
443	03-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	8	315 KVA	Unplanned Outage	03-Dec-2021	13:33	03-Dec-2021	14:14	41	0.00001	SYSTEM SCHEDULE OUTAGE
444	03-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	5	400 KVA	Planned Outage	03-Dec-2021	14:01	03-Dec-2021	14:24	23	0.00001	PLANNED OUTAGE
445	03-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	3	315 KVA	Planned Outage	03-Dec-2021	14:03	03-Dec-2021	16:30	147	0.00004	PLANNED OUTAGE
446	03-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	5	315 KVA	Unplanned Outage	03-Dec-2021	14:18	03-Dec-2021	15:20	62	0.00002	SYSTEM SCHEDULE OUTAGE
447	03-Dec-2021	PART OF O BLOCK SEC-5 BAWANA	3	315 KVA	Unplanned Outage	03-Dec-2021	14:23	03-Dec-2021	15:49	86	0.00002	SYSTEM SCHEDULE OUTAGE
448	03-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	1	100 KVA	Planned Outage	03-Dec-2021	14:26	03-Dec-2021	15:33	67	0.00002	PLANNED OUTAGE
449	03-Dec-2021	PART OF D-BLK SEC-4 BAWANA	5	315 KVA	Unplanned Outage	03-Dec-2021	14:27	03-Dec-2021	15:39	72	0.00002	SYSTEM SCHEDULE OUTAGE
450	03-Dec-2021	PART OF O BLOCK SEC-5 BAWANA	6	160 KVA	Unplanned Outage	03-Dec-2021	14:46	03-Dec-2021	15:13	27	0.00001	SYSTEM SCHEDULE OUTAGE
451	03-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	5	160 KVA	Unplanned Outage	03-Dec-2021	15:24	03-Dec-2021	16:12	48	0.00001	SYSTEM SCHEDULE OUTAGE
452	03-Dec-2021	PART OF I BLK SEC-1 BAWANA	7	315 KVA	Unplanned Outage	03-Dec-2021	16:01	03-Dec-2021	17:00	59	0.00002	SYSTEM SCHEDULE OUTAGE
453	03-Dec-2021	PART OF G BLK SEC-5 BAWANA	4	250 KVA	Unplanned Outage	03-Dec-2021	16:04	03-Dec-2021	17:21	77	0.00002	SYSTEM SCHEDULE OUTAGE
454	03-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	8	160 KVA	Unplanned Outage	03-Dec-2021	16:20	03-Dec-2021	16:57	37	0.00001	SYSTEM SCHEDULE OUTAGE
455	03-Dec-2021	PART OF D BLK SEC-5 BAWANA	2	100 KVA	Unplanned Outage	03-Dec-2021	16:24	03-Dec-2021	17:04	40	0.00001	SYSTEM SCHEDULE OUTAGE
456	03-Dec-2021	PART OF B BLOCK SEC-1 BAWANA	7	315 KVA	Unplanned Outage	03-Dec-2021	16:31	03-Dec-2021	16:49	18	0.00001	SYSTEM SCHEDULE OUTAGE
457	04-Dec-2021	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	145	Other Outage	Planned Outage	04-Dec-2021	08:03	04-Dec-2021	17:26	563	0.00031	PLANNED OUTAGE
458	04-Dec-2021	PARTS OF J-BLOCK SEC-3 POOTH KHURD BAWANA	92	Other Outage	Planned Outage	04-Dec-2021	10:04	04-Dec-2021	17:22	437	0.00024	PLANNED OUTAGE
459	04-Dec-2021	PARTS OF G-BLOCK SEC-3 POOTH KHURD BAWANA	295	Other Outage	Planned Outage	04-Dec-2021	10:05	04-Dec-2021	17:20	435	0.00060	PLANNED OUTAGE
460	04-Dec-2021	PARTS OF O,N,L BLOCK SEC-3 POOTH KHURD BAWANA	23	Other Outage	Planned Outage	04-Dec-2021	10:19	04-Dec-2021	16:50	391	0.00022	PLANNED OUTAGE
461	04-Dec-2021	PART OF LN BLOCK SEC-1 BAWANA	7	160 KVA	Unplanned Outage	04-Dec-2021	10:50	04-Dec-2021	12:25	95	0.00003	SYSTEM SCHEDULE OUTAGE
462	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	04-Dec-2021	10:57	04-Dec-2021	11:33	36	0.00001	SYSTEM SCHEDULE OUTAGE
463	04-Dec-2021	PARTS OF NMO BLOCK SEC-5 POOTH KHURD BAWANA	108	Other Outage	Planned Outage	04-Dec-2021	10:58	04-Dec-2021	14:18	200	0.00006	PLANNED OUTAGE
464	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	6	160 KVA	Unplanned Outage	04-Dec-2021	11:01	04-Dec-2021	12:21	80	0.00002	SYSTEM SCHEDULE OUTAGE
465	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	9	250 KVA	Unplanned Outage	04-Dec-2021	11:06	04-Dec-2021	12:35	89	0.00002	SYSTEM SCHEDULE OUTAGE
466	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	04-Dec-2021	11:10	04-Dec-2021	12:57	107	0.00003	SYSTEM SCHEDULE OUTAGE
467	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	400 KVA	Unplanned Outage	04-Dec-2021	11:17	04-Dec-2021	13:33	136	0.00004	FORCE MAJEURE DUE TO SABOTAGE
468	04-Dec-2021	PART OF C BLK SEC-02 BAWANA	5	160 KVA	Unplanned Outage	04-Dec-2021	11:24	04-Dec-2021	11:45	21	0.00001	SYSTEM SCHEDULE OUTAGE
469	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	4	100 KVA	Unplanned Outage	04-Dec-2021	11:36	04-Dec-2021	12:29	53	0.00001	SYSTEM SCHEDULE OUTAGE
470	04-Dec-2021	PART OF I-BLOCK SEC-5 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	04-Dec-2021	11:50	04-Dec-2021	16:54	304	0.00008	FORCE MAJEURE DUE TO SABOTAGE
471	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	250 KVA	Unplanned Outage	04-Dec-2021	12:32	04-Dec-2021	13:21	49	0.00001	SYSTEM SCHEDULE OUTAGE
472	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	04-Dec-2021	12:39	04-Dec-2021	13:29	50	0.00001	SYSTEM SCHEDULE OUTAGE
473	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	100 KVA	Unplanned Outage	04-Dec-2021	12:50	04-Dec-2021	13:27	37	0.00001	SYSTEM SCHEDULE OUTAGE
474	04-Dec-2021	PARTS OF D BLOCK SEC-5 BAWANA	50	Other Outage	Planned Outage	04-Dec-2021	13:03	04-Dec-2021	14:39	96	0.00003	PLANNED OUTAGE
475	04-Dec-2021	PART OF F BLK SEC-1 POOTH KHURD BAWANA	1	63 KVA	Unplanned Outage	04-Dec-2021	13:17	04-Dec-2021	14:16	59	0.00002	SYSTEM SCHEDULE OUTAGE
476	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	04-Dec-2021	13:23	04-Dec-2021	14:34	71	0.00002	SYSTEM SCHEDULE OUTAGE
477	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	7	160 KVA	Unplanned Outage	04-Dec-2021	14:12	04-Dec-2021	14:40	28	0.00001	SYSTEM SCHEDULE OUTAGE
478	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	04-Dec-2021	14:17	04-Dec-2021	17:17	180	0.00005	FORCE MAJEURE DUE TO SABOTAGE
479	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	04-Dec-2021	14:30	04-Dec-2021	15:02	32	0.00001	SYSTEM SCHEDULE OUTAGE
480	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	250 KVA	Unplanned Outage	04-Dec-2021	15:20	04-Dec-2021	16:14	54	0.00002	SYSTEM SCHEDULE OUTAGE
481	04-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	160 KVA	Unplanned Outage	04-Dec-2021	15:25	04-Dec-2021	16:05	40	0.00001	SYSTEM SCHEDULE OUTAGE
482	04-Dec-2021	PART OF SEC-4 C,DJ BLOCK BAWANA	4	160 KVA	Unplanned Outage	04-Dec-2021	15:49	04-Dec-2021	16:46	57	0.00002	SYSTEM SCHEDULE OUTAGE
483	04-Dec-2021	PART OF D BLK SEC-5 BAWANA	5	250 KVA	Unplanned Outage	04-Dec-2021	16:16	04-Dec-2021	16:24	8	0.00002	SYSTEM SCHEDULE OUTAGE
484	06-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	7	160 KVA	Unplanned Outage	06-Dec-2021	11:34	06-Dec-2021	13:42	128	0.00004	FORCE MAJEURE DUE TO SABOTAGE
485	06-Dec-2021	PART OF C-BLK SEC-4 BAWANA	6	400 KVA	Unplanned Outage	06-Dec-2021	11:50	06-Dec-2021	12:26	36	0.00001	SYSTEM SCHEDULE OUTAGE
486	06-Dec-2021	PART OF G BLK SEC-5 BAWANA	5	315 KVA	Unplanned Outage	06-Dec-2021	11:59	06-Dec-2021	13:40	101	0.00003	SYSTEM SCHEDULE OUTAGE
487	06-Dec-2021	PART OF F-BLK SEC-2 DISDC BAWANA	6	315 KVA	Unplanned Outage	06-Dec-2021	12:04	06-Dec-2021	12:47	43	0.00001	SYSTEM SCHEDULE OUTAGE
488	06-Dec-2021	PART OF F-BLK SEC-2 DISDC BAWANA	4	400 KVA	Unplanned Outage	06-Dec-2021	13:02	06-Dec-2021	15:26	144	0.00004	FORCE MAJEURE DUE TO SABOTAGE
489	06-Dec-2021	PART OF F-BLK SEC-2 DISDC BAWANA	3	63 KVA	Unplanned Outage	06-Dec-2021	14:06	06-Dec-2021	14:31	25	0.00001	SYSTEM SCHEDULE OUTAGE
490	06-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	1	160 KVA	Unplanned Outage	06-Dec-2021	14:09	06-Dec-2021	17:02	173	0.00005	FORCE MAJEURE DUE TO SABOTAGE
491	06-Dec-2021	PART OF O BLOCK SEC-5 BAWANA	5	315 KVA	Unplanned Outage	06-Dec-2021	14:36	06-Dec-2021	16:27	111	0.00003	SYSTEM SCHEDULE OUTAGE
492	06-Dec-2021	PART OF F BLK SEC-1 POOTH KHURD BAWANA	7	315 KVA	Unplanned Outage	06-Dec-2021	15:10	06-Dec-2021	15:40	30	0.00001	SYSTEM SCHEDULE OUTAGE
493	06-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	7	160 KVA	Unplanned Outage	06-Dec-2021	15:14	06-Dec-2021	15:50	36	0.00001	SYSTEM SCHEDULE OUTAGE
494	06-Dec-2021	PART OF POOTH VILLAGE BAWANA	6	250 KVA	Unplanned Outage	06-Dec-2021	15:29	06-Dec-2021	16:30	61	0.00002	SYSTEM SCHEDULE OUTAGE
495	06-Dec-2021	PART OF F-BLK SEC-2 DISDC BAWANA	4	315 KVA	Unplanned Outage	06-Dec-2021	16:16	06-Dec-2021	16:45	29	0.00001	SYSTEM SCHEDULE OUTAGE
496	06-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	3	160 KVA	Unplanned Outage	06-Dec-2021	16:19	06-Dec-2021	16:55	36	0.00001	SYSTEM SCHEDULE OUTAGE
497	06-Dec-2021	PART OF O BLOCK SEC-3 POOTH KHURD BAWANA	3	160 KVA	Unplanned Outage	06-Dec-2021	16:25	06-Dec-2021	16:42	17	0.000005	

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
526	08-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	3	250 kVA	Unplanned Outage	08-Dec-2021	14:19	08-Dec-2021	15:34	75	0.00002	SYSTEM SCHEDULE OUTAGE
527	08-Dec-2021	PART OF E BLOCK SEC-2 BAWANA	5	160 kVA	Unplanned Outage	08-Dec-2021	14:33	08-Dec-2021	15:17	44	0.00001	SYSTEM SCHEDULE OUTAGE
528	08-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	08-Dec-2021	14:40	08-Dec-2021	16:00	80	0.00002	SYSTEM SCHEDULE OUTAGE
529	08-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	7	315 kVA	Unplanned Outage	08-Dec-2021	14:43	08-Dec-2021	15:02	19	0.00001	SYSTEM SCHEDULE OUTAGE
530	08-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	7	160 kVA	Unplanned Outage	08-Dec-2021	14:48	08-Dec-2021	15:27	39	0.00001	SYSTEM SCHEDULE OUTAGE
531	08-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	7	100 kVA	Unplanned Outage	08-Dec-2021	15:22	08-Dec-2021	15:50	28	0.00001	SYSTEM SCHEDULE OUTAGE
532	08-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	08-Dec-2021	15:53	08-Dec-2021	17:02	69	0.00002	SYSTEM SCHEDULE OUTAGE
533	08-Dec-2021	PART OF D BLK SEC-5 BAWANA	6	315 kVA	Unplanned Outage	08-Dec-2021	16:18	08-Dec-2021	16:57	39	0.00001	SYSTEM SCHEDULE OUTAGE
534	09-Dec-2021	PART OF INTERCONNECTOR-1 BAWANA	1	160 kVA	Planned Outage	09-Dec-2021	07:38	09-Dec-2021	08:02	84	0.00002	PLANNED OUTAGE
535	09-Dec-2021	PARTS OF VILLAGE KANHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	189	Other Outage	Planned Outage	09-Dec-2021	08:19	09-Dec-2021	11:57	218	0.00012	PLANNED OUTAGE
536	09-Dec-2021	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	48	Other Outage	Planned Outage	09-Dec-2021	10:07	09-Dec-2021	14:53	286	0.00008	PLANNED OUTAGE
537	09-Dec-2021	PARTS OF FIONTI VILLAGE BAWANA	52	Other Outage	Planned Outage	09-Dec-2021	10:19	09-Dec-2021	14:49	270	0.00008	PLANNED OUTAGE
538	09-Dec-2021	PART OF G BLK SEC-1 BAWANA	7	315 kVA	Unplanned Outage	09-Dec-2021	11:20	09-Dec-2021	11:36	16	0.00005	SYSTEM SCHEDULE OUTAGE
539	09-Dec-2021	PART OF E BLOCK SEC-5 DSIDC BAWANA	4	315 kVA	Unplanned Outage	09-Dec-2021	12:15	09-Dec-2021	14:00	105	0.00003	SYSTEM SCHEDULE OUTAGE
540	09-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	25 kVA	Unplanned Outage	09-Dec-2021	12:21	09-Dec-2021	13:00	39	0.00001	SYSTEM SCHEDULE OUTAGE
541	09-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	9	250 kVA	Unplanned Outage	09-Dec-2021	12:25	09-Dec-2021	13:21	56	0.00002	SYSTEM SCHEDULE OUTAGE
542	09-Dec-2021	PART OF I BLK SEC-1 BAWANA	7	315 kVA	Unplanned Outage	09-Dec-2021	12:27	09-Dec-2021	12:47	20	0.00001	SYSTEM SCHEDULE OUTAGE
543	09-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	4	160 kVA	Unplanned Outage	09-Dec-2021	12:31	09-Dec-2021	13:32	61	0.00002	SYSTEM SCHEDULE OUTAGE
544	09-Dec-2021	PART OF J BLOCK SEC - 2 BAWANA	5	160 kVA	Unplanned Outage	09-Dec-2021	12:35	09-Dec-2021	14:24	109	0.00003	SYSTEM SCHEDULE OUTAGE
545	09-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	6	315 kVA	Unplanned Outage	09-Dec-2021	14:09	09-Dec-2021	14:49	40	0.00001	SYSTEM SCHEDULE OUTAGE
546	09-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	6	160 kVA	Unplanned Outage	09-Dec-2021	14:15	09-Dec-2021	14:55	40	0.00001	SYSTEM SCHEDULE OUTAGE
547	09-Dec-2021	PART OF DE BLOCK SEC-5 DSIDC BAWANA	3	315 kVA	Unplanned Outage	09-Dec-2021	14:20	09-Dec-2021	14:47	27	0.00001	SYSTEM SCHEDULE OUTAGE
548	09-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	8	315 kVA	Unplanned Outage	09-Dec-2021	14:28	09-Dec-2021	15:25	57	0.00002	SYSTEM SCHEDULE OUTAGE
549	09-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	1	160 kVA	Unplanned Outage	09-Dec-2021	14:32	09-Dec-2021	15:19	37	0.00001	SYSTEM SCHEDULE OUTAGE
550	09-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	4	100 kVA	Unplanned Outage	09-Dec-2021	14:52	09-Dec-2021	15:37	45	0.00001	SYSTEM SCHEDULE OUTAGE
551	09-Dec-2021	PART OF E BLK SEC-5 BAWANA	4	63 kVA	Unplanned Outage	09-Dec-2021	15:00	09-Dec-2021	15:18	18	0.00001	SYSTEM SCHEDULE OUTAGE
552	09-Dec-2021	PART OF F BLK SEC-1 BAWANA	10	315 kVA	Unplanned Outage	09-Dec-2021	15:51	09-Dec-2021	16:29	38	0.00001	SYSTEM SCHEDULE OUTAGE
553	09-Dec-2021	PART OF E BLK SEC-5 BAWANA	5	315 kVA	Unplanned Outage	09-Dec-2021	15:54	09-Dec-2021	16:34	40	0.00001	SYSTEM SCHEDULE OUTAGE
554	09-Dec-2021	PART OF C BLK SEC-02 BAWANA	4	250 kVA	Unplanned Outage	09-Dec-2021	15:58	09-Dec-2021	16:47	49	0.00001	SYSTEM SCHEDULE OUTAGE
555	09-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	9	400 kVA	Unplanned Outage	09-Dec-2021	16:02	09-Dec-2021	16:45	43	0.00001	SYSTEM SCHEDULE OUTAGE
556	10-Dec-2021	PARTS OF D-BLK SEC-4 POOTH KHURD BAWANA	179	Other Outage	Planned Outage	10-Dec-2021	07:20	10-Dec-2021	08:50	90	0.00015	PLANNED OUTAGE
557	10-Dec-2021	PARTS OF JJ CLUSTER NO.3 KANHAWLA BAWANA	617	Other Outage	Planned Outage	10-Dec-2021	10:29	10-Dec-2021	16:41	372	0.00062	PLANNED OUTAGE
558	10-Dec-2021	PARTS OF JJ CLUSTER NO.3 KANHAWLA BAWANA	634	Other Outage	Planned Outage	10-Dec-2021	10:32	10-Dec-2021	16:41	369	0.00062	PLANNED OUTAGE
559	10-Dec-2021	PARTS OF VIJAY NAGAR, SKY DARYA PUR, MAIN BUS STAND BAWANA	1267	Other Outage	Planned Outage	10-Dec-2021	10:46	10-Dec-2021	16:53	367	0.00123	PLANNED OUTAGE
560	10-Dec-2021	PARTS OF E-BLOCK J POLYUR BAWANA	996	Other Outage	Planned Outage	10-Dec-2021	11:01	10-Dec-2021	16:53	352	0.00088	PLANNED OUTAGE
561	10-Dec-2021	PART OF F BLOCK SEC-2 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	10-Dec-2021	11:09	10-Dec-2021	11:59	50	0.00001	SYSTEM SCHEDULE OUTAGE
562	10-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	4	100 kVA	Unplanned Outage	10-Dec-2021	11:16	10-Dec-2021	12:08	52	0.00001	SYSTEM SCHEDULE OUTAGE
563	10-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	7	100 kVA	Unplanned Outage	10-Dec-2021	11:24	10-Dec-2021	12:13	49	0.00001	SYSTEM SCHEDULE OUTAGE
564	10-Dec-2021	PARTS OF LADPUR VILLAGE BAWANA	977	Other Outage	Planned Outage	10-Dec-2021	11:42	10-Dec-2021	14:02	140	0.00035	PLANNED OUTAGE
565	10-Dec-2021	PART OF E BLK SEC-5 BAWANA	2	160 kVA	Unplanned Outage	10-Dec-2021	11:42	10-Dec-2021	12:45	63	0.00002	SYSTEM SCHEDULE OUTAGE
566	10-Dec-2021	PARTS OF LADPUR VILLAGE BAWANA	573	Other Outage	Planned Outage	10-Dec-2021	11:44	10-Dec-2021	14:02	138	0.00019	PLANNED OUTAGE
567	10-Dec-2021	PART OF J-BLOCK SEC-3 POOTH KHURD BAWANA	6	315 kVA	Unplanned Outage	10-Dec-2021	12:41	10-Dec-2021	13:04	23	0.00001	SYSTEM SCHEDULE OUTAGE
568	10-Dec-2021	PART OF F BLK SEC-1 BAWANA	8	250 kVA	Unplanned Outage	10-Dec-2021	12:49	10-Dec-2021	13:15	26	0.00001	SYSTEM SCHEDULE OUTAGE
569	10-Dec-2021	PART OF SEC-2 O,N,J BLOCK BAWANA	6	315 kVA	Unplanned Outage	10-Dec-2021	13:02	10-Dec-2021	13:46	44	0.00001	SYSTEM SCHEDULE OUTAGE
570	10-Dec-2021	PART OF F BLOCK SEC-2 POOTH KHURD BAWANA	6	315 kVA	Unplanned Outage	10-Dec-2021	14:40	10-Dec-2021	16:04	84	0.00002	SYSTEM SCHEDULE OUTAGE
571	10-Dec-2021	PART OF E BLOCK SEC-5 DSIDC BAWANA	3	63 kVA	Unplanned Outage	10-Dec-2021	14:43	10-Dec-2021	15:16	33	0.00001	SYSTEM SCHEDULE OUTAGE
572	10-Dec-2021	PART OF F BLK SEC-1 BAWANA	3	100 kVA	Unplanned Outage	10-Dec-2021	14:48	10-Dec-2021	16:02	74	0.00002	SYSTEM SCHEDULE OUTAGE
573	10-Dec-2021	PART OF J BLOCK SEC - 2 BAWANA	5	160 kVA	Unplanned Outage	10-Dec-2021	15:03	10-Dec-2021	15:43	40	0.00001	SYSTEM SCHEDULE OUTAGE
574	10-Dec-2021	PART OF G BLOCK BAWANA	2	250 kVA	Unplanned Outage	10-Dec-2021	15:41	10-Dec-2021	16:28	47	0.00001	SYSTEM SCHEDULE OUTAGE
575	10-Dec-2021	PART OF J BLOCK SEC - 2 BAWANA	3	100 kVA	Unplanned Outage	10-Dec-2021	15:45	10-Dec-2021	16:12	27	0.00001	SYSTEM SCHEDULE OUTAGE
576	10-Dec-2021	PART OF K BLOCK BAWANA	7	100 kVA	Unplanned Outage	10-Dec-2021	16:35	10-Dec-2021	17:53	78	0.00002	SYSTEM SCHEDULE OUTAGE
577	11-Dec-2021	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	72	Other Outage	Planned Outage	11-Dec-2021	09:51	11-Dec-2021	17:10	439	0.00012	PLANNED OUTAGE
578	11-Dec-2021	PARTS OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	330	Other Outage	Planned Outage	11-Dec-2021	10:01	11-Dec-2021	17:17	436	0.00036	PLANNED OUTAGE
579	11-Dec-2021	PARTS OF INTERCONNECTOR-4 BAWANA	269	Other Outage	Planned Outage	11-Dec-2021	10:16	11-Dec-2021	17:42	446	0.00025	PLANNED OUTAGE
580	11-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	8	160 kVA	Unplanned Outage	11-Dec-2021	11:38	11-Dec-2021	13:28	110	0.00003	SYSTEM SCHEDULE OUTAGE
581	11-Dec-2021	PART OF N O BLK SEC-5 BAWANA	6	160 kVA	Unplanned Outage	11-Dec-2021	11:43	11-Dec-2021	12:26	43	0.00001	SYSTEM SCHEDULE OUTAGE
582	11-Dec-2021	PARTS OF N O BLK SEC-3 BAWANA	310	Other Outage	Planned Outage	11-Dec-2021	11:44	11-Dec-2021	16:53	308	0.00051	PLANNED OUTAGE
583	11-Dec-2021	PART OF E BLOCK SEC-5 DSIDC BAWANA	6	250 kVA	Unplanned Outage	11-Dec-2021	13:19	11-Dec-2021	14:04	45	0.00001	SYSTEM SCHEDULE OUTAGE
584	11-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	5	160 kVA	Unplanned Outage	11-Dec-2021	14:27	11-Dec-2021	15:07	40	0.00001	SYSTEM SCHEDULE OUTAGE
585	12-Dec-2021	PARTS OF BLK-A, B, C, K, L, M BHORSARI BAWANA	182	Other Outage	Planned Outage	12-Dec-2021	08:03	12-Dec-2021	09:41	98	0.00014	PLANNED OUTAGE
586	13-Dec-2021	PARTS OF KANHAWLA VILLAGE & INDUSTRIAL AREA BAWANA PARTS OF POLICE STATION KANHAWLA, JAI BHAGWAN AT DEPOT ROAD, HARIJAN BASTI- KANHAWLA, HARISH CHAUHAN, KANHAWLA LADPUR ROAD MAJRA VILLAGE, HIMAR PURA VILLAGE, MTNL CHANDPUR, CHANDPUR HARIJAN BASTI BAL KISHAN, BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANHAWLA SDM COURT KANHAWLA BAWANA	106	Other Outage	Planned Outage	13-Dec-2021	10:11	13-Dec-2021	16:58	407	0.00023	PLANNED OUTAGE
587	13-Dec-2021	PARTS OF SUBZI MANDI KANHAWLA ROAD, INDIRAJI COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANHAWLA ROAD BAWANA	523	Other Outage	Planned Outage	13-Dec-2021	10:27	13-Dec-2021	16:50	383	0.00064	PLANNED OUTAGE
588	13-Dec-2021	PARTS OF SUBZI MANDI KANHAWLA ROAD, INDIRAJI COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANHAWLA ROAD BAWANA	335	630 kVA	Planned Outage	13-Dec-2021	10:41	13-Dec-2021	17:20	399	0.00044	PLANNED OUTAGE
589	13-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	13-Dec-2021	11:10	13-Dec-2021	14:00	170	0.00005	FORCE MAJEURE DUE TO SABOTAGE
590	13-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	3	315 kVA	Unplanned Outage	13-Dec-2021	11:41	13-Dec-2021	12:41	60	0.00002	SYSTEM SCHEDULE OUTAGE
591	13-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	5	100 kVA	Unplanned Outage	13-Dec-2021	11:48	13-Dec-2021	12:29	41	0.00001	SYSTEM SCHEDULE OUTAGE
592	13-Dec-2021	PART OF B BLK SEC-2 BAWANA	2	160 kVA	Unplanned Outage	13-Dec-2021	11:57	13-Dec-2021	12:35	38	0.00001	SYSTEM SCHEDULE OUTAGE
593	13-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	5	160 kVA	Unplanned Outage	13-Dec-2021	12:15	13-Dec-2021	12:56	41	0.00001	SYSTEM SCHEDULE OUTAGE
594	13-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	2	315 kVA	Unplanned Outage	13-Dec-2021	12:47	13-Dec-2021	13:55	68	0.00002	SYSTEM SCHEDULE OUTAGE
595	13-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	9	400 kVA	Unplanned Outage	13-Dec-2021	12:58	13-Dec-2021	14:00	62	0.00002	SYSTEM SCHEDULE OUTAGE
596	13-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	6	250 kVA	Unplanned Outage	13-Dec-2021	13:02	13-Dec-2021	13:23	21	0.00001	SYSTEM SCHEDULE OUTAGE
597	13-Dec-2021	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	13-Dec-2021	13:25	13-Dec-2021	14:36	71	0.00002	SYSTEM SCHEDULE OUTAGE
598	13-Dec-2021	PART OF O BLK SEC-1 BAWANA	1	100 kVA	Unplanned Outage	13-Dec-2021	13:28	13-Dec-2021	14:32	64	0.00002	SYSTEM SCHEDULE OUTAGE
599	13-Dec-2021	PART OF N SEC-5 BAWANA	1	160 kVA	Unplanned Outage	13-Dec-2021	13:31	13-Dec-2021	14:30	59	0.00002	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
627	15-Dec-2021	PARTS OF L.CH.-3164 BLOCK-8 DSIDC BAWANA	352	Other Outage	Planned Outage	15-Dec-2021	10:35	15-Dec-2021	16:04	329	0.00037	PLANNED OUTAGE
628	15-Dec-2021	PART OF FG-27 SEC-3 BAWANA	10	315 KVA	Unplanned Outage	15-Dec-2021	15:08	15-Dec-2021	16:25	77	0.00002	SYSTEM SCHEDULE OUTAGE
629	15-Dec-2021	PART OF FG-27 SEC-3 BAWANA	4	63 KVA	Unplanned Outage	15-Dec-2021	15:11	15-Dec-2021	15:53	42	0.00001	SYSTEM SCHEDULE OUTAGE
630	15-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	6	250 KVA	Unplanned Outage	15-Dec-2021	15:15	15-Dec-2021	15:45	30	0.00001	SYSTEM SCHEDULE OUTAGE
631	15-Dec-2021	PART OF C BLK SEC-02 BAWANA	5	315 KVA	Unplanned Outage	15-Dec-2021	15:21	15-Dec-2021	17:31	130	0.00004	FORCE MAJEURE DUE TO SABOTAGE
632	15-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	8	315 KVA	Unplanned Outage	15-Dec-2021	15:35	15-Dec-2021	16:14	39	0.00001	SYSTEM SCHEDULE OUTAGE
633	15-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	2	400 KVA	Unplanned Outage	15-Dec-2021	15:42	15-Dec-2021	16:59	77	0.00002	SYSTEM SCHEDULE OUTAGE
634	15-Dec-2021	PART OF F BLOCK SEC-2 BAWANA	7	315 KVA	Unplanned Outage	15-Dec-2021	15:49	15-Dec-2021	16:42	53	0.00001	SYSTEM SCHEDULE OUTAGE
635	15-Dec-2021	PART OF POLICE STATION KHANJHAWLA BAWANA	7	160 KVA	Unplanned Outage	15-Dec-2021	15:56	15-Dec-2021	16:30	34	0.00001	SYSTEM SCHEDULE OUTAGE
636	15-Dec-2021	PART OF ARIHANT SQUARE SHOPING COMPLEX BAWANA	2	315 KVA	Unplanned Outage	15-Dec-2021	16:33	15-Dec-2021	17:01	28	0.00001	SYSTEM SCHEDULE OUTAGE
637	16-Dec-2021	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	189	Other Outage	Planned Outage	16-Dec-2021	10:41	16-Dec-2021	16:54	373	0.00021	PLANNED OUTAGE
638	16-Dec-2021	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	2033	Other Outage	Planned Outage	16-Dec-2021	10:50	16-Dec-2021	17:46	416	0.00243	PLANNED OUTAGE
639	16-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	16-Dec-2021	11:36	16-Dec-2021	12:05	29	0.00001	SYSTEM SCHEDULE OUTAGE
640	16-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	9	315 KVA	Unplanned Outage	16-Dec-2021	11:40	16-Dec-2021	13:03	83	0.00002	SYSTEM SCHEDULE OUTAGE
641	16-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	6	400 KVA	Unplanned Outage	16-Dec-2021	11:47	16-Dec-2021	13:13	86	0.00002	SYSTEM SCHEDULE OUTAGE
642	16-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	5	400 KVA	Unplanned Outage	16-Dec-2021	12:08	16-Dec-2021	14:13	125	0.00003	FORCE MAJEURE DUE TO SABOTAGE
643	16-Dec-2021	PART OF FG-27 SEC-3 BAWANA	2	315 KVA	Unplanned Outage	16-Dec-2021	12:20	16-Dec-2021	14:11	111	0.00003	SYSTEM SCHEDULE OUTAGE
644	16-Dec-2021	PART OF SEC-2 O,N J BLOCK BAWANA	9	160 KVA	Unplanned Outage	16-Dec-2021	12:37	16-Dec-2021	14:00	83	0.00002	SYSTEM SCHEDULE OUTAGE
645	16-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	9	315 KVA	Unplanned Outage	16-Dec-2021	13:14	16-Dec-2021	14:33	79	0.00002	SYSTEM SCHEDULE OUTAGE
646	16-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	3	250 KVA	Unplanned Outage	16-Dec-2021	14:07	16-Dec-2021	14:37	30	0.00001	SYSTEM SCHEDULE OUTAGE
647	16-Dec-2021	PART OF IM BLOCK SEC-5 DSIDC BAWANA	2	160 KVA	Unplanned Outage	16-Dec-2021	15:07	16-Dec-2021	15:38	31	0.00001	SYSTEM SCHEDULE OUTAGE
648	16-Dec-2021	PART OF E BLOCK SEC-5 DSIDC BAWANA	3	315 KVA	Unplanned Outage	16-Dec-2021	15:21	16-Dec-2021	16:40	79	0.00002	SYSTEM SCHEDULE OUTAGE
649	16-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	2	315 KVA	Unplanned Outage	16-Dec-2021	15:36	16-Dec-2021	16:38	62	0.00002	SYSTEM SCHEDULE OUTAGE
650	16-Dec-2021	PART OF IM BLOCK SEC-3 DSIDC BAWANA	2	160 KVA	Unplanned Outage	16-Dec-2021	16:01	16-Dec-2021	16:32	31	0.00001	SYSTEM SCHEDULE OUTAGE
651	16-Dec-2021	PART OF IM BLOCK SEC-3 DSIDC BAWANA	2	250 KVA	Unplanned Outage	16-Dec-2021	16:33	16-Dec-2021	17:05	32	0.00001	SYSTEM SCHEDULE OUTAGE
652	16-Dec-2021	PART OF IM BLOCK SEC-3 DSIDC BAWANA	2	160 KVA	Unplanned Outage	16-Dec-2021	16:36	16-Dec-2021	17:23	47	0.00001	SYSTEM SCHEDULE OUTAGE
653	17-Dec-2021	PARTS OF PUNJAB KHOD BAWANA	26	Other Outage	Planned Outage	17-Dec-2021	10:53	17-Dec-2021	17:31	398	0.00011	PLANNED OUTAGE
654	17-Dec-2021	PART OF G BLK SEC-02 BAWANA	5	160 KVA	Unplanned Outage	17-Dec-2021	11:15	17-Dec-2021	11:36	21	0.00001	SYSTEM SCHEDULE OUTAGE
655	17-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	1	250 KVA	Unplanned Outage	17-Dec-2021	11:27	17-Dec-2021	12:56	89	0.00002	SYSTEM SCHEDULE OUTAGE
656	17-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	8	100 KVA	Unplanned Outage	17-Dec-2021	11:40	17-Dec-2021	12:29	49	0.00001	SYSTEM SCHEDULE OUTAGE
657	17-Dec-2021	PART OF F-19 SEC-2 NEAR GOL CHAKKAR, BAWANA	5	315 KVA	Unplanned Outage	17-Dec-2021	12:11	17-Dec-2021	13:50	99	0.00003	SYSTEM SCHEDULE OUTAGE
658	17-Dec-2021	PART OF DD MALL SEC-5 BAWANA	5	160 KVA	Unplanned Outage	17-Dec-2021	12:15	17-Dec-2021	12:51	36	0.00001	SYSTEM SCHEDULE OUTAGE
659	17-Dec-2021	PART OF DD MALL SEC-5 BAWANA	4	315 KVA	Unplanned Outage	17-Dec-2021	12:18	17-Dec-2021	14:16	118	0.00003	SYSTEM SCHEDULE OUTAGE
660	17-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	17-Dec-2021	12:58	17-Dec-2021	16:12	194	0.00005	FORCE MAJEURE DUE TO SABOTAGE
661	17-Dec-2021	PART OF O BLK SEC-1 BAWANA	10	400 KVA	Unplanned Outage	17-Dec-2021	13:19	17-Dec-2021	14:20	61	0.00002	SYSTEM SCHEDULE OUTAGE
662	17-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	4	250 KVA	Unplanned Outage	17-Dec-2021	14:31	17-Dec-2021	15:45	74	0.00002	SYSTEM SCHEDULE OUTAGE
663	17-Dec-2021	PART OF POOTH VILLAGE BAWANA	6	250 KVA	Unplanned Outage	17-Dec-2021	14:47	17-Dec-2021	17:01	134	0.00004	FORCE MAJEURE DUE TO SABOTAGE
664	17-Dec-2021	PART OF I-BLOCK SEC-3 POOTH KHURD BAWANA	9	315 KVA	Unplanned Outage	17-Dec-2021	14:50	17-Dec-2021	15:26	36	0.00001	SYSTEM SCHEDULE OUTAGE
665	17-Dec-2021	PART OF SEC-4 C,D J BLOCK BAWANA	6	250 KVA	Unplanned Outage	17-Dec-2021	15:39	17-Dec-2021	16:00	21	0.00001	SYSTEM SCHEDULE OUTAGE
666	17-Dec-2021	PART OF H-BLOCK SEC-1 POOTH KHURD BAWANA	10	315 KVA	Unplanned Outage	17-Dec-2021	16:08	17-Dec-2021	16:53	45	0.00001	SYSTEM SCHEDULE OUTAGE
667	17-Dec-2021	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	3	250 KVA	Unplanned Outage	17-Dec-2021	16:43	17-Dec-2021	17:10	27	0.00001	SYSTEM SCHEDULE OUTAGE
668	17-Dec-2021	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	17-Dec-2021	16:47	17-Dec-2021	17:21	34	0.00001	SYSTEM SCHEDULE OUTAGE
669	18-Dec-2021	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	252	Other Outage	Planned Outage	18-Dec-2021	08:04	18-Dec-2021	15:56	472	0.00262	PLANNED OUTAGE
670	18-Dec-2021	PARTS OF INTERCONNECTOR -3 AND POOTH KHURD VILLAGE BAWANA	288	Other Outage	Planned Outage	18-Dec-2021	09:41	18-Dec-2021	17:04	443	0.00246	PLANNED OUTAGE
671	18-Dec-2021	PARTS OF DD MALL SEC-5 BAWANA	264	Other Outage	Planned Outage	18-Dec-2021	10:07	18-Dec-2021	17:00	413	0.00287	PLANNED OUTAGE
672	18-Dec-2021	PART OF JJ CLUSTER BAWANA	4	25 KVA	Planned Outage	18-Dec-2021	10:42	18-Dec-2021	14:56	254	0.00007	PLANNED OUTAGE
673	18-Dec-2021	PART OF JJ CLUSTER BAWANA	9	25 KVA	Planned Outage	18-Dec-2021	10:46	18-Dec-2021	14:56	250	0.00007	PLANNED OUTAGE
674	18-Dec-2021	PART OF JJ CLUSTER BAWANA	12	25 KVA	Planned Outage	18-Dec-2021	10:50	18-Dec-2021	14:56	246	0.00007	PLANNED OUTAGE
675	18-Dec-2021	PART OF BLK-A BHORGARH BAWANA	2	250 KVA	Unplanned Outage	18-Dec-2021	11:08	18-Dec-2021	12:28	86	0.00002	SYSTEM SCHEDULE OUTAGE
676	18-Dec-2021	PARTS OF FG BLOCK SEC-3 DSIDC BAWANA	304	Other Outage	Planned Outage	18-Dec-2021	11:08	18-Dec-2021	15:45	277	0.00023	PLANNED OUTAGE
677	18-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	1	250 KVA	Unplanned Outage	18-Dec-2021	12:13	18-Dec-2021	13:21	68	0.00002	SYSTEM SCHEDULE OUTAGE
678	18-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	4	100 KVA	Unplanned Outage	18-Dec-2021	12:48	18-Dec-2021	14:24	96	0.00003	SYSTEM SCHEDULE OUTAGE
679	18-Dec-2021	PARTS OF D.BLK SEC-5 POOTH KHURD BAWANA	170	Other Outage	Planned Outage	18-Dec-2021	14:51	18-Dec-2021	16:38	107	0.00006	PLANNED OUTAGE
680	18-Dec-2021	PART OF I-BLOCK SEC-5 POOTH KHURD BAWANA	9	315 KVA	Unplanned Outage	18-Dec-2021	16:16	18-Dec-2021	16:26	10	0.000003	SYSTEM SCHEDULE OUTAGE
681	20-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	160 KVA	Planned Outage	20-Dec-2021	10:47	20-Dec-2021	11:57	70	0.00002	PLANNED OUTAGE
682	20-Dec-2021	PARTS OF BAWANA STADIUM AND INDS. AREA BAWANA	1380	Other Outage	Planned Outage	20-Dec-2021	10:55	20-Dec-2021	17:35	400	0.00133	PLANNED OUTAGE
683	20-Dec-2021	PART OF DD MALL SEC-5 BAWANA	2	100 KVA	Unplanned Outage	20-Dec-2021	11:18	20-Dec-2021	11:38	31	0.00001	SYSTEM SCHEDULE OUTAGE
684	20-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	250 KVA	Unplanned Outage	20-Dec-2021	11:18	20-Dec-2021	12:01	43	0.00001	SYSTEM SCHEDULE OUTAGE
685	20-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	20-Dec-2021	11:22	20-Dec-2021	12:10	48	0.00001	SYSTEM SCHEDULE OUTAGE
686	20-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	4	400 KVA	Unplanned Outage	20-Dec-2021	11:34	20-Dec-2021	12:20	46	0.00001	SYSTEM SCHEDULE OUTAGE
687	20-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	8	315 KVA	Unplanned Outage	20-Dec-2021	12:22	20-Dec-2021	12:51	29	0.00001	SYSTEM SCHEDULE OUTAGE
688	20-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	1	315 KVA	Unplanned Outage	20-Dec-2021	12:31	20-Dec-2021	12:53	22	0.00001	SYSTEM SCHEDULE OUTAGE
689	20-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	25 KVA	Planned Outage	20-Dec-2021	12:36	20-Dec-2021	13:26	50	0.00001	PLANNED OUTAGE
690	20-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	20-Dec-2021	13:02	20-Dec-2021	13:36	34	0.00001	SYSTEM SCHEDULE OUTAGE
691	20-Dec-2021	PART OF I-BLOCK SECTOR-3 POOTH KHURD BAWANA	7	160 KVA	Unplanned Outage	20-Dec-2021	13:07	20-Dec-2021	14:06	59	0.00002	SYSTEM SCHEDULE OUTAGE
692	20-Dec-2021	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	20-Dec-2021	13:11	20-Dec-2021	14:10	59	0.00002	SYSTEM SCHEDULE OUTAGE
693	20-Dec-2021	PART OF SEC-5 B BLOCK BAWANA	8	400 KVA	Unplanned Outage	20-Dec-2021	13:40	20-Dec-2021	14:51	71	0.00002	SYSTEM SCHEDULE OUTAGE
694	20-Dec-2021	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	20-Dec-2021	14:42	20-Dec-2021	16:42	120	0.00003	SYSTEM SCHEDULE OUTAGE
695	20-Dec-2021	PART OF I BLK SEC-1 BAWANA	4	315 KVA	Unplanned Outage	20-Dec-2021	14:56	20-Dec-2021	15:30	34	0.00001	SYSTEM SCHEDULE OUTAGE
696	20-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	315 KVA	Unplanned Outage	20-Dec-2021	15:06	20-Dec-2021	17:36	150	0.00004	FORCE MAJEURE DUE TO SABOTAGE
697	20-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	1	63 KVA	Planned Outage	20-Dec-2021	15:08	20-Dec-2021	15:55	47	0.00001	PLANNED OUTAGE
698	20-Dec-2021	PART OF G BLOCK BAWANA	8	315 KVA	Unplanned Outage	20-Dec-2021	15:10	20-Dec-2021	16:31	81	0.00002	SYSTEM SCHEDULE OUTAGE
699	20-Dec-2021	PARTS OF F-BLOCK SEC-3 POOTH KHURD BAWANA	189	Other Outage	Planned Outage	20-Dec-2021	16:03	20-Dec-2021	17:17	74	0.00002	SYSTEM SCHEDULE OUTAGE
700	21-Dec-2021	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	56	Other Outage	Planned Outage	21-Dec-2021	07:49	21-Dec-2021	11:09	200	0.00262	PLANNED OUTAGE
701	21-Dec-2021	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	56	Other Outage	Planned Outage	21-Dec-2021	10:41	21-Dec-2021	15:46	305	0.00017	PLANNED OUTAGE
702	21-Dec-2021	PARTS OF WATER SUPPLY DARIYA PUR, DTC DEPOT AUCHANDI RD BAWANA	558	Other Outage	Planned Outage	21-Dec-2021	10:44	21-Dec-2021	17:15	391	0.00085	PLANNED OUTAGE
703	21-Dec-2021	PART OF DD MALL SEC-5 BAWANA	5	250 KVA	Unplanned Outage	21-Dec-2021	11:31	21-Dec-2021	12:39	68	0.00002	SYSTEM SCHEDULE OUTAGE
704	21-Dec-2021	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	8	315 KVA	Unplanned Outage	21-Dec-2021	11:48	21-Dec-2021	12:07	19	0.00001	SYSTEM SCHEDULE OUTAGE
705	21-Dec-2021	PART OF BLK-A BHORGARH BAWANA	5	400 KVA	Unplanned Outage	21-Dec-2021	11:51	21-Dec-2021	12:45	54	0.00002	SYSTEM SCHEDULE OUTAGE
706	21-Dec-2021	PART OF DD MALL SEC-5 BAWANA	6	315 KVA	Unplanned Outage	21-Dec-2021	13:05	21-Dec-2021	14:10	65	0.00002	SYSTEM SCHEDULE OUTAGE
707	21-Dec-2021	PART OF DD MALL SEC-5 BAWANA	2	160 KVA	Unplanned Outage	21-Dec-2021	13:08	21-Dec-2021	14:11	63	0.00002	SYSTEM SCHEDULE OUTAGE
708	21-Dec-2021	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	3	250 KVA	Unplanned Outage	21-Dec-2021	13:20	21-Dec-2021	14:53	93	0.00003	SYSTEM SCHEDULE OUTAGE
709	21-Dec-2021	PART OF I BLOCK SEC-2 DSIDC BAWANA	5									

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserviced (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
734	22-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	250 KVA	Unplanned Outage	22-Dec-2021	15:27	22-Dec-2021	16:34	67	0.00002	SYSTEM SCHEDULE OUTAGE
735	22-Dec-2021	PART OF SEC-5 B BLOCK BAWANA	2	250 KVA	Unplanned Outage	22-Dec-2021	16:16	22-Dec-2021	16:27	11	0.00003	SYSTEM SCHEDULE OUTAGE
736	23-Dec-2021	PARTS OF JI SAWDA ALL BLOCKS KANJAHAWALA BAWANA	666	Other Outage	Planned Outage	23-Dec-2021	10:25	23-Dec-2021	14:20	235	0.00046	PLANNED OUTAGE
737	23-Dec-2021	PART OF JI CLUSTER BAWANA	14	25 KVA	Planned Outage	23-Dec-2021	11:04	23-Dec-2021	14:35	211	0.00006	PLANNED OUTAGE
738	23-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	5	400 KVA	Unplanned Outage	23-Dec-2021	11:04	23-Dec-2021	12:09	65	0.00002	SYSTEM SCHEDULE OUTAGE
739	23-Dec-2021	PART OF JI CLUSTER BAWANA	18	25 KVA	Planned Outage	23-Dec-2021	11:07	23-Dec-2021	14:36	209	0.00006	PLANNED OUTAGE
740	23-Dec-2021	PARTS OF POOTH KHURD VILLAGE BAWANA	119	Other Outage	Planned Outage	23-Dec-2021	11:10	23-Dec-2021	16:20	310	0.00017	PLANNED OUTAGE
741	23-Dec-2021	PARTS OF BAWANA STADIUM AND INDS. AREA BAWANA	80	Other Outage	Planned Outage	23-Dec-2021	11:20	23-Dec-2021	17:09	349	0.00097	PLANNED OUTAGE
742	23-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	5	315 KVA	Unplanned Outage	23-Dec-2021	12:04	23-Dec-2021	14:12	128	0.00004	FORCE MAJEURE DUE TO SABOTAGE
743	23-Dec-2021	PART OF DD MALL SEC-5 BAWANA	7	315 KVA	Unplanned Outage	23-Dec-2021	12:10	23-Dec-2021	14:08	118	0.00003	SYSTEM SCHEDULE OUTAGE
744	23-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	315 KVA	Unplanned Outage	23-Dec-2021	12:20	23-Dec-2021	13:50	90	0.00003	SYSTEM SCHEDULE OUTAGE
745	23-Dec-2021	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	4	400 KVA	Unplanned Outage	23-Dec-2021	12:25	23-Dec-2021	12:46	21	0.00001	SYSTEM SCHEDULE OUTAGE
746	23-Dec-2021	PART OF DD MALL SEC-5 BAWANA	5	315 KVA	Unplanned Outage	23-Dec-2021	12:27	23-Dec-2021	13:24	57	0.00002	SYSTEM SCHEDULE OUTAGE
747	23-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	23-Dec-2021	14:02	23-Dec-2021	15:03	61	0.00002	SYSTEM SCHEDULE OUTAGE
748	23-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	2	315 KVA	Unplanned Outage	23-Dec-2021	14:32	23-Dec-2021	15:38	66	0.00002	SYSTEM SCHEDULE OUTAGE
749	23-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	315 KVA	Unplanned Outage	23-Dec-2021	14:36	23-Dec-2021	15:33	57	0.00002	SYSTEM SCHEDULE OUTAGE
750	23-Dec-2021	PART OF DD MALL SEC-5 BAWANA	2	160 KVA	Unplanned Outage	23-Dec-2021	14:59	23-Dec-2021	15:49	50	0.00001	SYSTEM SCHEDULE OUTAGE
751	23-Dec-2021	PART OF ESS-1 & 2 BAWANA	13	25 KVA	Planned Outage	23-Dec-2021	15:01	23-Dec-2021	17:04	123	0.00003	PLANNED OUTAGE
752	23-Dec-2021	PART OF DD MALL SEC-5 BAWANA	1	100 KVA	Unplanned Outage	23-Dec-2021	15:25	23-Dec-2021	16:15	50	0.00001	SYSTEM SCHEDULE OUTAGE
753	23-Dec-2021	PART OF DD MALL SEC-5 BAWANA	4	315 KVA	Unplanned Outage	23-Dec-2021	15:52	23-Dec-2021	16:27	35	0.00001	SYSTEM SCHEDULE OUTAGE
754	23-Dec-2021	PART OF F-BLK SEC-2 DSIDC BAWANA	6	250 KVA	Unplanned Outage	23-Dec-2021	15:57	23-Dec-2021	16:19	22	0.00001	SYSTEM SCHEDULE OUTAGE
755	24-Dec-2021	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	1612	Other Outage	Planned Outage	24-Dec-2021	10:23	24-Dec-2021	17:00	397	0.00176	PLANNED OUTAGE
756	24-Dec-2021	PARTS OF KANJAHAWLA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEVRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	293	630 KVA	Planned Outage	24-Dec-2021	10:30	24-Dec-2021	14:21	231	0.00013	PLANNED OUTAGE
757	24-Dec-2021	PART OF JI CLUSTER BAWANA	8	25 KVA	Planned Outage	24-Dec-2021	10:43	24-Dec-2021	13:28	165	0.00005	PLANNED OUTAGE
758	24-Dec-2021	PART OF JI CLUSTER BAWANA	15	25 KVA	Planned Outage	24-Dec-2021	11:03	24-Dec-2021	13:58	175	0.00005	PLANNED OUTAGE
759	24-Dec-2021	PART OF SEC-2 O,N JI BLOCK BAWANA	9	160 KVA	Unplanned Outage	24-Dec-2021	11:21	24-Dec-2021	12:16	55	0.00002	SYSTEM SCHEDULE OUTAGE
760	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	2	315 KVA	Unplanned Outage	24-Dec-2021	11:25	24-Dec-2021	12:31	66	0.00002	SYSTEM SCHEDULE OUTAGE
761	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	315 KVA	Unplanned Outage	24-Dec-2021	11:44	24-Dec-2021	12:29	45	0.00001	SYSTEM SCHEDULE OUTAGE
762	24-Dec-2021	PART OF B BLK SEC-2 BAWANA	7	315 KVA	Unplanned Outage	24-Dec-2021	12:12	24-Dec-2021	13:16	64	0.00002	SYSTEM SCHEDULE OUTAGE
763	24-Dec-2021	PART OF OLD ZONAL OFFICE POOTH KHURD VILLAGE BAWANA	5	100 KVA	Unplanned Outage	24-Dec-2021	12:37	24-Dec-2021	12:57	20	0.00001	SYSTEM SCHEDULE OUTAGE
764	24-Dec-2021	PART OF SEC-4 C,D JI BLOCK BAWANA	1	Other Outage	Planned Outage	24-Dec-2021	12:40	24-Dec-2021	17:07	266	0.00007	PLANNED OUTAGE
765	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	5	160 KVA	Unplanned Outage	24-Dec-2021	12:40	24-Dec-2021	13:12	32	0.00001	SYSTEM SCHEDULE OUTAGE
766	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	6	315 KVA	Unplanned Outage	24-Dec-2021	13:13	24-Dec-2021	14:46	33	0.00001	SYSTEM SCHEDULE OUTAGE
767	24-Dec-2021	PART OF B BLK SEC-2 BAWANA	7	315 KVA	Unplanned Outage	24-Dec-2021	13:18	24-Dec-2021	14:57	99	0.00003	SYSTEM SCHEDULE OUTAGE
768	24-Dec-2021	PART OF B BLK SEC-2 BAWANA	3	250 KVA	Unplanned Outage	24-Dec-2021	13:20	24-Dec-2021	14:58	98	0.00003	SYSTEM SCHEDULE OUTAGE
769	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	1	63 KVA	Unplanned Outage	24-Dec-2021	13:25	24-Dec-2021	14:34	69	0.00002	SYSTEM SCHEDULE OUTAGE
770	24-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	100 KVA	Unplanned Outage	24-Dec-2021	13:29	24-Dec-2021	14:36	67	0.00002	SYSTEM SCHEDULE OUTAGE
771	24-Dec-2021	PART OF JI CLUSTER BAWANA	20	16 KVA	Planned Outage	24-Dec-2021	13:37	24-Dec-2021	16:09	152	0.00008	PLANNED OUTAGE
772	24-Dec-2021	PART OF DE B BLOCK SEC-3 DSIDC BAWANA	3	315 KVA	Unplanned Outage	24-Dec-2021	14:31	24-Dec-2021	15:06	35	0.00001	SYSTEM SCHEDULE OUTAGE
773	24-Dec-2021	PARTS OF KANJAHAWLA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEVRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	656	630 KVA	Planned Outage	24-Dec-2021	14:34	24-Dec-2021	16:14	100	0.00017	PLANNED OUTAGE
774	24-Dec-2021	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	4	160 KVA	Unplanned Outage	24-Dec-2021	14:43	24-Dec-2021	15:11	28	0.00001	SYSTEM SCHEDULE OUTAGE
775	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	8	400 KVA	Unplanned Outage	24-Dec-2021	14:47	24-Dec-2021	16:05	78	0.00002	SYSTEM SCHEDULE OUTAGE
776	24-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	315 KVA	Unplanned Outage	24-Dec-2021	15:02	24-Dec-2021	15:42	40	0.00001	SYSTEM SCHEDULE OUTAGE
777	24-Dec-2021	PART OF ARIHANT SQUARE SHOPPING COMPLEX BAWANA	5	250 KVA	Unplanned Outage	24-Dec-2021	15:31	24-Dec-2021	17:03	92	0.00003	SYSTEM SCHEDULE OUTAGE
778	27-Dec-2021	PARTS OF KANJAHAWLA VILLAGE & INDUSTRIAL AREA BAWANA	199	Other Outage	Planned Outage	27-Dec-2021	10:14	27-Dec-2021	16:33	379	0.00021	PLANNED OUTAGE
779	27-Dec-2021	PARTS OF POLICE STATION KHANJAHAWLA, JI BHAGWAN AT DEPOT ROAD, HARIJAN BASTI- KHANJAHAWLA, HARISH CHAUHAN, KANJAHAWLA LADPUR ROAD MAIRA VILLAGE, HIMAR PURA VILLAGE, MTNL CHANDPUR, CHANDPUR HARIJAN BASTI BAL KISHAN, BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJAHAWLA SDM COURT KANJAHAWLA BAWANA	433	Other Outage	Planned Outage	27-Dec-2021	10:37	27-Dec-2021	17:00	383	0.00043	PLANNED OUTAGE
780	27-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	9	315 KVA	Unplanned Outage	27-Dec-2021	11:45	27-Dec-2021	12:23	38	0.00001	SYSTEM SCHEDULE OUTAGE
781	27-Dec-2021	PART OF IM BLOCK SEC-3 DSIDC BAWANA	6	400 KVA	Unplanned Outage	27-Dec-2021	11:50	27-Dec-2021	13:26	96	0.00003	SYSTEM SCHEDULE OUTAGE
782	27-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	315 KVA	Unplanned Outage	27-Dec-2021	12:05	27-Dec-2021	12:56	51	0.00001	SYSTEM SCHEDULE OUTAGE
783	27-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	315 KVA	Unplanned Outage	27-Dec-2021	13:15	27-Dec-2021	15:09	114	0.00003	SYSTEM SCHEDULE OUTAGE
784	27-Dec-2021	PART OF E BLOCK SEC-5 DSIDC BAWANA	2	100 KVA	Unplanned Outage	27-Dec-2021	13:27	27-Dec-2021	14:28	61	0.00002	SYSTEM SCHEDULE OUTAGE
785	27-Dec-2021	PART OF I-BLOCK SEC-5 POOTH KHURD BAWANA	2	160 KVA	Unplanned Outage	27-Dec-2021	13:32	27-Dec-2021	13:58	26	0.00001	SYSTEM SCHEDULE OUTAGE
786	27-Dec-2021	PART OF LM BLOCK SEC-1 BAWANA	5	315 KVA	Unplanned Outage	27-Dec-2021	14:35	27-Dec-2021	15:51	76	0.00002	SYSTEM SCHEDULE OUTAGE
787	27-Dec-2021	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	2	160 KVA	Unplanned Outage	27-Dec-2021	14:59	27-Dec-2021	16:14	75	0.00002	SYSTEM SCHEDULE OUTAGE
788	27-Dec-2021	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	4	315 KVA	Unplanned Outage	27-Dec-2021	15:05	27-Dec-2021	16:16	71	0.00002	SYSTEM SCHEDULE OUTAGE
789	27-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	4	63 KVA	Unplanned Outage	27-Dec-2021	16:21	27-Dec-2021	17:15	54	0.00002	SYSTEM SCHEDULE OUTAGE
790	28-Dec-2021	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	335	Other Outage	Planned Outage	28-Dec-2021	07:10	28-Dec-2021	08:56	106	0.00074	PLANNED OUTAGE
791	28-Dec-2021	PART OF I-BLOCK SEC-5 POOTH KHURD BAWANA	5	315 KVA	Unplanned Outage	28-Dec-2021	10:53	28-Dec-2021	12:53	120	0.00003	SYSTEM SCHEDULE OUTAGE
792	28-Dec-2021	PARTS OF VILLAGE NIZAM PUR, VILLAGE GAD RANDHALA, DTS OF LADPUR- NIZAM PUR ROAD BAWANA	38	100 KVA	Planned Outage	28-Dec-2021	11:11	28-Dec-2021	11:48	37	0.00001	PLANNED OUTAGE
793	28-Dec-2021	PARTS OF DIVYA JYOTI APARTMENT BAWANA	879	Other Outage	Planned Outage	28-Dec-2021	11:19	28-Dec-2021	14:31	192	0.00043	PLANNED OUTAGE
794	28-Dec-2021	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-3 BAWANA	216	400 KVA	Planned Outage	28-Dec-2021	11:24	28-Dec-2021	12:33	69	0.00006	PLANNED OUTAGE
795	28-Dec-2021	PART OF B BLOCK SEC-3 POOTH KHURD BAWANA	3	160 KVA	Unplanned Outage	28-Dec-2021	11:25	28-Dec-2021	12:36	71	0.00002	SYSTEM SCHEDULE OUTAGE
796	28-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	5	400 KVA	Unplanned Outage	28-Dec-2021	12:28	28-Dec-2021	14:41	133	0.00004	FORCE MAJEURE DUE TO SABOTAGE
797	28-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	1	315 KVA	Unplanned Outage	28-Dec-2021	12:30	28-Dec-2021	14:43	133	0.00004	FORCE MAJEURE DUE TO SABOTAGE
798	28-Dec-2021	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	1	160 KVA	Unplanned Outage	28-Dec-2021	12:38	28-Dec-2021	13:43	65	0.00002	SYSTEM SCHEDULE OUTAGE
799	28-Dec-2021	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	201	400 KVA	Planned Outage	28-Dec-2021	12:43	28-Dec-2021	13:48	65	0.00027	PLANNED OUTAGE
800	28-Dec-2021	PART OF G BLK SEC-5 BAWANA	5	315 KVA	Unplanned Outage	28-Dec-2021	12:45	28-Dec-2021	13:12	27	0.00001	SYSTEM SCHEDULE OUTAGE
801	28-Dec-2021	PART OF G BLK SEC-5 BAWANA	4	315 KVA	Unplanned Outage	28-Dec-2021	13:15	28-Dec-2021	14:04	49	0.00001	SYSTEM SCHEDULE OUTAGE
802	28-Dec-2021	PART OF K BLOCK BAWANA	8	400 KVA	Unplanned Outage	28-Dec-2021	13:26	28-Dec-2021	14:14	48	0.00001	SYSTEM SCHEDULE OUTAGE
803	28-Dec-2021	PARTS OF JI CLUSTER NO.3 KANJAHAWLA BAWANA	616	Other Outage	Planned Outage	28-Dec-2021	14:11	28-Dec-2021	16:26	135	0.00023	PLANNED OUTAGE
804	28-Dec-2021	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	344	630 KVA	Planned Outage	28-Dec-2021	14:34	28-Dec-2021	15:38	64	0.00009	PLANNED OUTAGE
805	28-Dec-2021	PARTS OF POLICE STATION KHANJAHAWLA BAWANA	1	25 KVA	Unplanned Outage	28-Dec-2021	14:37	28-Dec-2021	15:06	29	0.00001	SYSTEM SCHEDULE OUTAGE
806	28-Dec-2021	PARTS OF SUBZI MANDI KANJAHAWLA ROAD, INDIRA COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJAHAWLA ROAD BAWANA	467	Other Outage	Planned Outage	28-Dec-2021	14:49	28-Dec-2021	16:30	101	0.00011	PLANNED OUTAGE
807	28-Dec-2021	PART OF JI SAWDA ALL BLOCKS BAWANA	1	Other Outage	Planned Outage	28-Dec-2021	14:53	28-Dec-2021	16:28	95	0.00003	PLANNED OUTAGE
808	28-Dec-2021	PART OF D BLK SEC-5 BAWANA	3	400 KVA	Unplanned Outage	28-Dec-2021	14:54	28-Dec-2021	15:15	21	0.00001	SYSTEM SCHEDULE OUTAGE
809	28-Dec-2021	PART OF G BLK SEC-5 BAWANA	5	400 KVA	Unplanned Outage	28-Dec-2021	15:02	28-Dec-2021	16:46	104	0.00003	SYSTEM SCHEDULE OUTAGE
810	28-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	4	160 KVA	Unplanned Outage	28-Dec-2021	15:09	28-Dec-2021	15:24	15	0.00004	SYSTEM SCHEDULE OUTAGE
811	28-Dec-2021	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	6	315 KVA	Unplanned Outage	28-Dec-2021	15:26	28-Dec-2021	16:28	62	0.00002	SYSTEM SCHEDULE OUTAGE
812	28-Dec-2021	PART OF N BLOCK SEC-2 BAWANA	7	250 KVA	Unplanned Outage	28-Dec-2021	15:29	28-Dec-2021	16:24	55	0.00002	SYSTEM SCHEDULE OUTAGE
813	28-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	8	315 KVA	Unplanned Outage	28-Dec-2021	15:40	28-Dec-2021	16:44	64	0.00002	SYSTEM SCHEDULE OUTAGE
814	28-Dec-2021	PART OF POLICE STATION KHANJAHAWLA BAWANA	4	160 KVA	Unplanned Outage	28-Dec-2021	15:48	28-Dec-2021	16:58	70	0	

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
831	29-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	3	100 kVA	Unplanned Outage	29-Dec-2021	16:24	29-Dec-2021	16:57	33	0.00001	SYSTEM SCHEDULE OUTAGE
832	30-Dec-2021	PART OF KANJAWLA VILLAGE BAWANA	18	100 kVA	Planned Outage	30-Dec-2021	10:45	30-Dec-2021	12:21	96	0.00003	PLANNED OUTAGE
833	30-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	6	250 kVA	Unplanned Outage	30-Dec-2021	11:26	30-Dec-2021	11:51	25	0.00001	SYSTEM SCHEDULE OUTAGE
834	30-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	10	315 kVA	Unplanned Outage	30-Dec-2021	11:32	30-Dec-2021	11:49	17	0.00005	SYSTEM SCHEDULE OUTAGE
835	30-Dec-2021	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	9	315 kVA	Unplanned Outage	30-Dec-2021	11:43	30-Dec-2021	12:19	36	0.00001	SYSTEM SCHEDULE OUTAGE
836	30-Dec-2021	PART OF F-1 BLOCK SEC-5 BAWANA	4	315 kVA	Unplanned Outage	30-Dec-2021	12:00	30-Dec-2021	12:32	32	0.00001	SYSTEM SCHEDULE OUTAGE
837	30-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	315 kVA	Unplanned Outage	30-Dec-2021	12:07	30-Dec-2021	13:10	63	0.00002	SYSTEM SCHEDULE OUTAGE
838	30-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	8	315 kVA	Unplanned Outage	30-Dec-2021	12:15	30-Dec-2021	12:35	20	0.00001	SYSTEM SCHEDULE OUTAGE
839	30-Dec-2021	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	3	100 kVA	Unplanned Outage	30-Dec-2021	12:42	30-Dec-2021	14:13	91	0.00003	SYSTEM SCHEDULE OUTAGE
840	30-Dec-2021	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	13	315 kVA	Unplanned Outage	30-Dec-2021	13:06	30-Dec-2021	13:32	26	0.00001	SYSTEM SCHEDULE OUTAGE
841	30-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	315 kVA	Unplanned Outage	30-Dec-2021	14:04	30-Dec-2021	15:30	86	0.00002	SYSTEM SCHEDULE OUTAGE
842	30-Dec-2021	PART OF F-1 BK SEC-1. BAWANA	7	400 kVA	Unplanned Outage	30-Dec-2021	14:16	30-Dec-2021	16:27	131	0.00004	FORCE MAJEURE DUE TO SABOTAGE
843	30-Dec-2021	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	30-Dec-2021	14:43	30-Dec-2021	15:13	30	0.00001	SYSTEM SCHEDULE OUTAGE
844	30-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	4	400 kVA	Unplanned Outage	30-Dec-2021	14:51	30-Dec-2021	15:22	31	0.00001	SYSTEM SCHEDULE OUTAGE
845	30-Dec-2021	PART OF D BLK SEC-5 BAWANA	4	160 kVA	Unplanned Outage	30-Dec-2021	15:00	30-Dec-2021	15:44	44	0.00001	SYSTEM SCHEDULE OUTAGE
846	30-Dec-2021	PART OF B BLOCK SEC-2 BAWANA	3	250 kVA	Unplanned Outage	30-Dec-2021	15:05	30-Dec-2021	15:27	22	0.00001	SYSTEM SCHEDULE OUTAGE
847	30-Dec-2021	PART OF G BLK SEC-5 BAWANA	4	315 kVA	Unplanned Outage	30-Dec-2021	15:18	30-Dec-2021	15:50	32	0.00001	SYSTEM SCHEDULE OUTAGE
848	30-Dec-2021	PART OF I BLK SEC-1 BAWANA	4	315 kVA	Unplanned Outage	30-Dec-2021	15:46	30-Dec-2021	16:10	24	0.00001	SYSTEM SCHEDULE OUTAGE
849	30-Dec-2021	PART OF SEC-2 O.N.J BLOCK BAWANA	3	160 kVA	Unplanned Outage	30-Dec-2021	16:24	30-Dec-2021	17:05	41	0.00001	SYSTEM SCHEDULE OUTAGE
850	30-Dec-2021	PART OF F BLK SEC-1 POOTH KHURD BAWANA	3	315 kVA	Unplanned Outage	30-Dec-2021	16:31	30-Dec-2021	17:10	39	0.00001	SYSTEM SCHEDULE OUTAGE
851	30-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	400 kVA	Unplanned Outage	30-Dec-2021	16:47	30-Dec-2021	17:38	51	0.00001	SYSTEM SCHEDULE OUTAGE
852	31-Dec-2021	PARTS OF VILLAGE KANJAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING BAWANA	191	Other Outage	Planned Outage	31-Dec-2021	10:18	31-Dec-2021	14:41	263	0.00015	PLANNED OUTAGE
853	31-Dec-2021	PARTS OF PUNJAB KHOD BAWANA	1536	Other Outage	Planned Outage	31-Dec-2021	11:17	31-Dec-2021	17:54	397	0.00176	PLANNED OUTAGE
854	31-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	6	315 kVA	Unplanned Outage	31-Dec-2021	11:20	31-Dec-2021	11:50	30	0.00001	SYSTEM SCHEDULE OUTAGE
855	31-Dec-2021	PART OF POOTH KHURD VILLAGE BAWANA	1	160 kVA	Unplanned Outage	31-Dec-2021	11:24	31-Dec-2021	11:58	34	0.00001	SYSTEM SCHEDULE OUTAGE
856	31-Dec-2021	PART OF F BLOCK SEC-2 DSICD BAWANA	5	100 kVA	Unplanned Outage	31-Dec-2021	11:27	31-Dec-2021	12:49	82	0.00002	SYSTEM SCHEDULE OUTAGE
857	31-Dec-2021	PARTS OF LADPUR VILLAGE BAWANA	978	Other Outage	Planned Outage	31-Dec-2021	11:29	31-Dec-2021	14:21	172	0.00043	PLANNED OUTAGE
858	31-Dec-2021	PART OF LM BLOCK SEC-1 DSICD BAWANA	3	315 kVA	Unplanned Outage	31-Dec-2021	11:41	31-Dec-2021	12:29	48	0.00001	SYSTEM SCHEDULE OUTAGE
859	31-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	2	315 kVA	Unplanned Outage	31-Dec-2021	11:55	31-Dec-2021	13:42	107	0.00003	SYSTEM SCHEDULE OUTAGE
860	31-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	5	160 kVA	Unplanned Outage	31-Dec-2021	12:22	31-Dec-2021	13:02	40	0.00001	SYSTEM SCHEDULE OUTAGE
861	31-Dec-2021	PART OF F BLOCK SEC-2 POOTH KHURD BAWANA	6	250 kVA	Unplanned Outage	31-Dec-2021	12:57	31-Dec-2021	13:06	9	0.00003	SYSTEM SCHEDULE OUTAGE
862	31-Dec-2021	PART OF L-BLOCK SEC-4 POOTH KHURD BAWANA	7	400 kVA	Unplanned Outage	31-Dec-2021	13:11	31-Dec-2021	14:24	73	0.00002	SYSTEM SCHEDULE OUTAGE
863	31-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	160 kVA	Unplanned Outage	31-Dec-2021	14:21	31-Dec-2021	15:16	55	0.00002	SYSTEM SCHEDULE OUTAGE
864	31-Dec-2021	PART OF L-BLOCK SEC-4 POOTH KHURD BAWANA	7	315 kVA	Unplanned Outage	31-Dec-2021	14:25	31-Dec-2021	15:22	57	0.00002	SYSTEM SCHEDULE OUTAGE
865	31-Dec-2021	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	250 kVA	Unplanned Outage	31-Dec-2021	14:28	31-Dec-2021	15:11	43	0.00001	SYSTEM SCHEDULE OUTAGE
866	31-Dec-2021	PART OF D-BLOCK SEC-1 POOTH KHURD BAWANA	4	160 kVA	Unplanned Outage	31-Dec-2021	14:37	31-Dec-2021	15:14	37	0.00001	SYSTEM SCHEDULE OUTAGE
867	31-Dec-2021	PART OF L-BLOCK SEC-4 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	31-Dec-2021	15:25	31-Dec-2021	16:02	37	0.00001	SYSTEM SCHEDULE OUTAGE
868	31-Dec-2021	PART OF POLICE STATION KHANJAWLA BAWANA	2	100 kVA	Unplanned Outage	31-Dec-2021	15:43	31-Dec-2021	16:39	56	0.00002	SYSTEM SCHEDULE OUTAGE
869	31-Dec-2021	PART OF L-BLOCK SEC-4 POOTH KHURD BAWANA	11	100 kVA	Unplanned Outage	31-Dec-2021	16:13	31-Dec-2021	16:48	35	0.00001	SYSTEM SCHEDULE OUTAGE
CIVIL LINES												
1	02-Dec-2021	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINES	110	Other Outage	Unplanned Outage	02-Dec-2021	18:03	02-Dec-2021	19:25	82	0.000091	INTERRUPTION DUE TO FAULT
2	04-Dec-2021	PARTS OF BARA HINDU RAO CIVIL LINES	1036	Other Outage	Unplanned Outage	04-Dec-2021	18:04	04-Dec-2021	20:17	133	0.000688	FORCE MAJEURE DUE TO SABOTAGE
3	05-Dec-2021	PARTS OF ROHTAK ROAD, PART OF 65, 66 & 67 BLOCKS MOTI NAGAR, RATTAN NAGAR, KATRA GANGA BISHAN, BAGH RAO JJ DHOBIH WALI GALLI, GAU SALIA ROAD CIVIL LINES	2310	Other Outage	Unplanned Outage	05-Dec-2021	07:13	05-Dec-2021	08:05	52	0.000434	INTERRUPTION DUE TO FAULT
4	05-Dec-2021	PARTS OF OLD ST.STEPHAN COLLEGE, DELHI SCHOOL OF ECONOMICS, NEW ST.STEPHAN COLLEGE, SRI RAM INSTITUTE, HINDU COLLEGE, I.E.G. CIVIL LINES	236	Other Outage	Unplanned Outage	05-Dec-2021	18:43	05-Dec-2021	18:55	12	0.000017	INTERRUPTION DUE TO FAULT
5	07-Dec-2021	PARTS OF VARDHMAN PLAZA PACKAGE 1 & 2, A & C- BLK. NEHRU VIHAR, OLD & NEW TIMARPUR CIVIL LINES	1090	Other Outage	Unplanned Outage	07-Dec-2021	12:22	07-Dec-2021	13:15	53	0.000221	INTERRUPTION DUE TO FAULT
6	09-Dec-2021	PARTS OF ANDHA MUGHAL BAGICHI PEER, PART OF PRTPAT NAGAR, PARSHV NATH METRO MALL CIVIL LINES	1036	Other Outage	Unplanned Outage	09-Dec-2021	12:54	09-Dec-2021	13:45	51	0.000708	INTERRUPTION DUE TO FAULT
7	13-Dec-2021	PARTS OF SARAI ROHILLA , AHATA THAKUR DASS, 1C, 2C, 3C, 4C BLOCKS SARAI ROHILLA RAILWAY STATION CIVIL LINES	324	Other Outage	Unplanned Outage	13-Dec-2021	12:54	13-Dec-2021	13:25	31	0.000052	INTERRUPTION DUE TO FAULT
8	13-Dec-2021	PARTS OF SARAI ROHILLA , AHATA THAKUR DASS, 1C, 2C, 3C, 4C BLOCKS SARAI ROHILLA RAILWAY STATION CIVIL LINES	855	Other Outage	Unplanned Outage	13-Dec-2021	12:54	13-Dec-2021	13:50	56	0.000233	INTERRUPTION DUE TO FAULT
9	13-Dec-2021	PARTS OF SARAI ROHILLA , AHATA THAKUR DASS, 1C, 2C, 3C, 4C BLOCKS SARAI ROHILLA RAILWAY STATION CIVIL LINES	400	Other Outage	Unplanned Outage	13-Dec-2021	12:54	13-Dec-2021	13:55	61	0.000136	INTERRUPTION DUE TO FAULT
10	16-Dec-2021	PART OF NEW COURT CIVIL LINES	2	Other Outage	Unplanned Outage	16-Dec-2021	12:38	16-Dec-2021	12:55	17	0.000005	INTERRUPTION DUE TO FAULT
11	17-Dec-2021	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINES	1440	Other Outage	Unplanned Outage	17-Dec-2021	07:24	17-Dec-2021	07:42	18	0.000115	INTERRUPTION DUE TO FAULT
12	18-Dec-2021	PARTS OF FLAGSTAFF ROAD, 16 RAIPUR ROAD, 21 RAIPUR ROAD, 24 RAIPUR ROAD, 4 BATTERY LANE, TIRATH RAM HOSPITAL, CIVIL LINES	394	Other Outage	Unplanned Outage	18-Dec-2021	10:15	18-Dec-2021	11:00	45	0.000062	INTERRUPTION DUE TO FAULT
13	19-Dec-2021	PARTS OF SINGH SABHA ROAD, 10 - A BLOCK, E.S.I. DISPENSARY CIVIL LINES	3035	Other Outage	Unplanned Outage	19-Dec-2021	14:07	19-Dec-2021	15:15	68	0.000844	INTERRUPTION DUE TO FAULT
14	19-Dec-2021	PARTS OF G. B. ADMINISTRATION FLATS, G. B. GARRIAGE AND ANDHA MUGHAL AREA CIVIL LINES	2616	Other Outage	Unplanned Outage	19-Dec-2021	20:13	19-Dec-2021	21:48	95	0.000549	INTERRUPTION DUE TO FAULT
15	19-Dec-2021	PARTS OF G. B. ADMINISTRATION FLATS, G. B. GARRIAGE AND ANDHA MUGHAL AREA CIVIL LINES	111	Other Outage	Unplanned Outage	19-Dec-2021	20:13	19-Dec-2021	21:49	96	0.000185	INTERRUPTION DUE TO FAULT
16	19-Dec-2021	PARTS OF PETROL PUMP AND SINDHORAK KALAN SHASTRI NAGAR CIVIL LINES	1456	Other Outage	Unplanned Outage	19-Dec-2021	20:56	19-Dec-2021	21:25	29	0.000175	INTERRUPTION DUE TO FAULT
17	20-Dec-2021	PART OF WAZIRABAD WATER WORKS CIVIL LINES	8	Other Outage	Unplanned Outage	20-Dec-2021	03:38	20-Dec-2021	04:50	72	0.00002	INTERRUPTION DUE TO FAULT
18	26-Dec-2021	PARTS OF 13, 14, 15, 18, 21, 26, 38, 39 & 40 BLOCK CIVIL LINES	173	Other Outage	Unplanned Outage	26-Dec-2021	18:51	26-Dec-2021	19:05	14	0.000016	INTERRUPTION DUE TO FAULT
19	26-Dec-2021	PARTS OF C C COLONY, PART OF GURMANDIKHATIK BASTI AND JAIN COLONY CIVIL LINES	1362	Other Outage	Unplanned Outage	26-Dec-2021	18:58	26-Dec-2021	19:50	52	0.000361	INTERRUPTION DUE TO FAULT
20	26-Dec-2021	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAIPUR ROAD, UNDER HILL LANE CIVIL LINES	449	Other Outage	Unplanned Outage	26-Dec-2021	20:14	26-Dec-2021	21:13	59	0.000328	INTERRUPTION DUE TO FAULT
21	27-Dec-2021	PARTS OF NEW COURT CIVIL LINES	439	Other Outage	Unplanned Outage	27-Dec-2021	10:25	27-Dec-2021	11:27	62	0.000086	INTERRUPTION DUE TO FAULT
22	27-Dec-2021	PARTS OF NEW COURT CIVIL LINES	456	Other Outage	Unplanned Outage	27-Dec-2021	10:28	27-Dec-2021	11:27	59	0.000098	INTERRUPTION DUE TO FAULT
23	27-Dec-2021	PARTS OF ROAD NO- 45, POLIC CHONKI, GUDWARA, CNG PUMP CIVIL LINES	795	Other Outage	Unplanned Outage	27-Dec-2021	13:19	27-Dec-2021	13:30	11	0.000031	INTERRUPTION DUE TO FAULT
24	27-Dec-2021	PARTS OF DOULAT RAM COLLEGE & TIMAR PUR CIVIL LINES	326	Other Outage	Unplanned Outage	27-Dec-2021	15:09	27-Dec-2021	15:23	14	0.000047	INTERRUPTION DUE TO FAULT
25	28-Dec-2021	PARTS OF MULTI LEVEL PARKING KAMALA NAGAR CIVIL LINES	837	Other Outage	Unplanned Outage	28-Dec-2021	00:53	28-Dec-2021	01:17	24	0.000097	INTERRUPTION DUE TO FAULT
26	28-Dec-2021	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	536	Other Outage	Unplanned Outage	28-Dec-2021	16:00	28-Dec-2021	16:40	40	0.00001	INTERRUPTION DUE TO FAULT
27	28-Dec-2021	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	113	Other Outage	Unplanned Outage	28-Dec-2021	16:00	28-Dec-2021	16:50	50	0.000028	INTERRUPTION DUE TO FAULT
28	28-Dec-2021	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	315	Other Outage	Unplanned Outage	28-Dec-2021	16:00	28-Dec-2021	18:19	139	0.000269	FORCE MAJEURE DUE TO RAIN/STORM
29	28-Dec-2021	PARTS OF BARA HINDU RAO CIVIL LINES	2579	Other Outage	Unplanned Outage	28-Dec-2021	23:32	29-Dec-2021	00:20	48	0.000329	INTERRUPTION DUE TO FAULT
30	01-Dec-2021	PARTS OF G. B. ADMINISTRATION FLATS, G. B. GARRIAGE AND ANDHA MUGHAL AREA CIVIL LINES	112	Other Outage	Planned Outage	01-Dec-2021	10:52	01-Dec-2021	13:45	173	0.00010	PLANNED OUTAGE
31	01-Dec-2021	PARTS OF JINDAL HOSPITAL, VISHWA APPARTMENTS, SANT PARMANAND HOSPITAL, 1 RAM KISHORE ROAD CIVIL LINES	179	990 kVA	Planned Outage	01-Dec-2021	11:34	01-Dec-2021	14:18	164	0.00009	PLANNED OUTAGE
32	03-Dec-2021	PARTS OF KAMLA NAGAR, JAWAHAR NAGAR, BANGLOW ROAD CIVIL LINES	158	990 kVA	Planned Outage	03-Dec-2021	10:34	03-Dec-2021	11:47	73	0.00012	PLANNED OUTAGE
33	03-Dec-2021	PARTS OF 9 RAI NARAYAN ROAD, BELA ROAD, SWISS APPT, GUJRATI SAMAI, CLUB ROAD (CIVIL LINES), 16 JAMUNA ROAD, QUEDASIA GARDEN, C. C. OFFICE CIVIL LINES	180	Other Outage	Planned Outage	03-Dec-2021	11:10	03-Dec-2021	16:07	297	0.00017	PLANNED OUTAGE
34	03-Dec-2021	PART OF GOKHLE MARKET CIVIL LINES	15	Other Outage	Planned Outage	03-Dec-2021	11:27	03-Dec-2021	16:37	310	0.00009	PLANNED OUTAGE
35	03-Dec-2021	PARTS OF KAMLA NAGAR, JAWAHAR NAGAR, BANGLOW ROAD CIVIL LINES	129	990 kVA	Planned Outage	03-Dec-2021	12:33	03-Dec-2021	14:02	89	0.00005	PLANNED OUTAGE
36	03-Dec-2021	PARTS OF KAMLA NAGAR, JAWAHAR NAGAR, BANGLOW ROAD CIVIL LINES	191	990 kVA	Planned Outage	03-Dec-2021	14:43	03-Dec-2021	15:47	64	0.00004	PLANNED OUTAGE
37	06-Dec-2021	PARTS OF M.C.D. FLATS & A - BLOCK SHASTRI NAGAR, PETROL PUMP SHASTRI NAGAR, HEALTH CENTER CIVIL LINES	390	630 kVA	Planned Outage	06-Dec-2021	10:52	06-Dec-2021	13:35	163	0.00036	PLANNED OUTAGE
38	06-Dec-2021	PARTS OF M.C.D. FLATS & A - BLOCK SHASTRI NAGAR, PETROL PUMP SHASTRI NAGAR, HEALTH CENTER CIVIL LINES	544	Other Outage	Planned Outage	06-Dec-2021	10:55	06-Dec-2021	13:36	161	0.00040	PLANNED OUTAGE
39	07-Dec-2021	PARTS OF M.C.D. FLATS & A - BLOCK SHASTRI NAGAR, PETROL PUMP SHASTRI NAGAR, HEALTH CENTER CIVIL LINES										

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
44	10-Dec-2021	PARTS OF 9 RAJ NARAYAN ROAD, BELA ROAD, SWISS APPT, GUJRATI SAMAJ, CLUB ROAD (CIVIL LINES), 16 JAMUNA ROAD, QUEDASIA GARDEN, C. C. OFFICE CIVIL LINES	53	Other Outage	Planned Outage	10-Dec-2021	11:18	10-Dec-2021	14:53	215	0.00006	PLANNED OUTAGE
45	11-Dec-2021	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, SST, QUEDASIA GARDEN CIVIL LINES	348	Other Outage	Planned Outage	11-Dec-2021	10:52	11-Dec-2021	15:35	283	0.00063	PLANNED OUTAGE
46	11-Dec-2021	PARTS OF CSAKISHAN GANG MKT., KISHAN GANG RAILWAYS QTR., PART OF PADAM NAGAR,PART OF ROHTAK ROAD CIVIL LINES	614	990 kVA	Planned Outage	11-Dec-2021	10:53	11-Dec-2021	14:40	227	0.00044	PLANNED OUTAGE
47	16-Dec-2021	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	196	Other Outage	Planned Outage	16-Dec-2021	11:08	16-Dec-2021	15:30	262	0.00022	PLANNED OUTAGE
48	16-Dec-2021	PART OF ROAD NO- 45 CIVIL LINES	1	Other Outage	Planned Outage	16-Dec-2021	14:40	16-Dec-2021	16:39	119	0.00003	PLANNED OUTAGE
49	17-Dec-2021	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	109	Other Outage	Planned Outage	17-Dec-2021	11:08	17-Dec-2021	14:30	202	0.00056	PLANNED OUTAGE
50	17-Dec-2021	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	142	Other Outage	Planned Outage	17-Dec-2021	11:20	17-Dec-2021	14:34	194	0.00081	PLANNED OUTAGE
51	18-Dec-2021	PARTS OF C.S.A.COLONY, CIVIL LINES	220	400 kVA	Planned Outage	18-Dec-2021	10:22	18-Dec-2021	13:46	204	0.00113	PLANNED OUTAGE
52	19-Dec-2021	PART OF 19 RAJ PUR ROAD CIVIL LINES	2	Other Outage	Planned Outage	19-Dec-2021	14:14	19-Dec-2021	16:40	146	0.00004	PLANNED OUTAGE
53	21-Dec-2021	PARTS OF BARA HINDU RAO CIVIL LINES	477	990 kVA	Planned Outage	21-Dec-2021	13:00	21-Dec-2021	18:45	345	0.00038	FORCE MAJEURE DUE TO SABOTAGE
54	23-Dec-2021	PARTS OF DU STAFF QTRS, KHALSA COLLEGE, SFS FLATS, RIVERA APARTMENTS, ISM, PATEL CHEST, MIRANDA HOUSE, ART FACULTY CIVIL LINES	52	Other Outage	Planned Outage	23-Dec-2021	10:51	23-Dec-2021	17:47	416	0.00173	PLANNED OUTAGE
55	24-Dec-2021	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	42	Other Outage	Planned Outage	24-Dec-2021	10:41	24-Dec-2021	14:46	245	0.00007	PLANNED OUTAGE
56	25-Dec-2021	PART OF TYRE MKT AREA CIVIL LINES	1	Other Outage	Planned Outage	25-Dec-2021	11:35	25-Dec-2021	13:10	95	0.00003	PLANNED OUTAGE
57	29-Dec-2021	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	135	Other Outage	Planned Outage	29-Dec-2021	11:11	29-Dec-2021	13:57	166	0.00014	PLANNED OUTAGE
58	30-Dec-2021	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAIPUR ROAD, UNDER HILL LANE CIVIL LINES	46	Other Outage	Planned Outage	30-Dec-2021	11:32	30-Dec-2021	14:35	183	0.00010	PLANNED OUTAGE
59	31-Dec-2021	PART OF ROAD NO- 45 CIVIL LINES	1	Other Outage	Planned Outage	31-Dec-2021	11:00	31-Dec-2021	16:55	355	0.00010	PLANNED OUTAGE
60	31-Dec-2021	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAIPUR ROAD, UNDER HILL LANE CIVIL LINES	73	630 kVA	Planned Outage	31-Dec-2021	11:04	31-Dec-2021	12:38	94	0.00003	PLANNED OUTAGE
KESHAV PURAM												
1	01-Dec-2021	PART OF DSICD CKT.1 KESHAV PURAM	6	Other Outage	Unplanned Outage	01-Dec-2021	08:47	01-Dec-2021	10:34	107	0.00059	INTERRUPTION DUE TO FAULT
2	02-Dec-2021	PART OF C-34 INDUSTRIAL AREA KESHAV PURAM	18	Other Outage	Unplanned Outage	02-Dec-2021	03:37	02-Dec-2021	03:50	13	0.00007	INTERRUPTION DUE TO FAULT
3	02-Dec-2021	PARTS OF C - 1, A - 2 MIG A - 2 LIS, A - 1 KESHAV PURAM	30	Other Outage	Unplanned Outage	02-Dec-2021	10:50	02-Dec-2021	11:04	14	0.00004	INTERRUPTION DUE TO FAULT
4	02-Dec-2021	PARTS OF COMMUNITY CENTRE, PART OF STRIPLEX RAMPURA KESHAV PURAM	59	Other Outage	Unplanned Outage	02-Dec-2021	13:32	02-Dec-2021	16:04	152	0.00084	FORCE MAJEURE DUE TO RAIN/STORM
5	02-Dec-2021	PARTS OF C & A- BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	95	Other Outage	Unplanned Outage	02-Dec-2021	16:11	02-Dec-2021	17:14	63	0.00035	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK) KESHAV PURAM	250	Other Outage	Unplanned Outage	02-Dec-2021	17:12	02-Dec-2021	19:22	130	0.00059	FORCE MAJEURE DUE TO SABOTAGE
7	03-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	90	Other Outage	Unplanned Outage	03-Dec-2021	10:10	03-Dec-2021	11:23	73	0.00004	INTERRUPTION DUE TO FAULT
8	03-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	28	Other Outage	Unplanned Outage	03-Dec-2021	10:56	03-Dec-2021	11:23	27	0.00008	INTERRUPTION DUE TO FAULT
9	03-Dec-2021	PART OF G-40 LAWARNCE ROAD INDUSTRIAL AREA KESHAV PURAM	3	Other Outage	Unplanned Outage	03-Dec-2021	13:56	03-Dec-2021	14:48	52	0.00014	INTERRUPTION DUE TO FAULT
10	03-Dec-2021	PART OF G-40 LAWARNCE ROAD INDUSTRIAL AREA KESHAV PURAM	10	Other Outage	Unplanned Outage	03-Dec-2021	13:56	03-Dec-2021	14:48	52	0.00014	INTERRUPTION DUE TO FAULT
11	03-Dec-2021	PART OF DDA PHASE-2 SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	4	Other Outage	Unplanned Outage	03-Dec-2021	22:50	03-Dec-2021	23:55	65	0.00018	INTERRUPTION DUE TO FAULT
12	04-Dec-2021	PART OF DDA PHASE-2 SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	7	Other Outage	Unplanned Outage	04-Dec-2021	08:45	04-Dec-2021	09:19	34	0.00019	INTERRUPTION DUE TO FAULT
13	04-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	79	Other Outage	Unplanned Outage	04-Dec-2021	11:20	04-Dec-2021	12:35	75	0.00028	INTERRUPTION DUE TO FAULT
14	04-Dec-2021	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	8	Other Outage	Unplanned Outage	04-Dec-2021	19:13	04-Dec-2021	20:04	51	0.00014	INTERRUPTION DUE TO FAULT
15	06-Dec-2021	PART OF B/66 WAZIR PUR KESHAV PURAM	5	Other Outage	Unplanned Outage	06-Dec-2021	10:57	06-Dec-2021	11:22	25	0.00014	INTERRUPTION DUE TO FAULT
16	06-Dec-2021	PARTS OF IP TOWER, COMMUNITY CENTRE, MOHAN TOWER KESHAV PURAM	167	Other Outage	Unplanned Outage	06-Dec-2021	14:18	06-Dec-2021	17:42	204	0.000283	FORCE MAJEURE DUE TO SABOTAGE
17	07-Dec-2021	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	83	Other Outage	Unplanned Outage	07-Dec-2021	13:04	07-Dec-2021	13:49	45	0.00038	INTERRUPTION DUE TO FAULT
18	07-Dec-2021	PARTS OF DSICD CKT.1 CKT.2, B - 71, B - 40 KESHAV PURAM	72	Other Outage	Unplanned Outage	07-Dec-2021	21:02	07-Dec-2021	21:30	28	0.00039	INTERRUPTION DUE TO FAULT
19	08-Dec-2021	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK) KESHAV PURAM	24	Other Outage	Unplanned Outage	08-Dec-2021	11:36	08-Dec-2021	14:10	154	0.000214	FORCE MAJEURE DUE TO SABOTAGE
20	08-Dec-2021	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	53	Other Outage	Unplanned Outage	08-Dec-2021	13:27	08-Dec-2021	14:05	38	0.00053	INTERRUPTION DUE TO FAULT
21	08-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	3	Other Outage	Unplanned Outage	08-Dec-2021	18:50	08-Dec-2021	19:10	20	0.00006	INTERRUPTION DUE TO FAULT
22	09-Dec-2021	PART OF RAM PURACOMMUNITY CENTRE KESHAV PURAM	3	Other Outage	Unplanned Outage	09-Dec-2021	10:47	09-Dec-2021	11:06	19	0.00005	INTERRUPTION DUE TO FAULT
23	10-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	126	Other Outage	Unplanned Outage	10-Dec-2021	11:27	10-Dec-2021	11:41	14	0.00008	INTERRUPTION DUE TO FAULT
24	10-Dec-2021	PART OF A-93 WPIA KESHAV PURAM	5	Other Outage	Unplanned Outage	10-Dec-2021	12:22	10-Dec-2021	12:48	26	0.00014	INTERRUPTION DUE TO FAULT
25	10-Dec-2021	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	90	Other Outage	Unplanned Outage	10-Dec-2021	13:36	10-Dec-2021	14:47	71	0.000158	INTERRUPTION DUE TO FAULT
26	10-Dec-2021	PARTS OF GANESH PURA, PART OF SHANTI NAGAR & ANAJ MANDI KESHAV PURAM	1905	Other Outage	Unplanned Outage	10-Dec-2021	22:20	10-Dec-2021	22:42	22	0.00012	INTERRUPTION DUE TO FAULT
27	11-Dec-2021	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	33	Other Outage	Unplanned Outage	11-Dec-2021	09:27	11-Dec-2021	09:57	30	0.000041	INTERRUPTION DUE TO FAULT
28	11-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	2	Other Outage	Unplanned Outage	11-Dec-2021	10:12	11-Dec-2021	11:00	48	0.00013	INTERRUPTION DUE TO FAULT
29	11-Dec-2021	PART OF L-BLOCK JI COLONY KESHAV PURAM	9	Other Outage	Unplanned Outage	11-Dec-2021	14:21	11-Dec-2021	16:36	135	0.00038	FORCE MAJEURE DUE TO SABOTAGE
30	11-Dec-2021	PARTS OF M/S SUBHASH ENTER PRIZES, AJAY PLASTICS UNIT - 2, SHAHZADA BAGH NO.3, DDA SLUM TENAMANT KESHAV PURAM	49	Other Outage	Unplanned Outage	11-Dec-2021	20:23	11-Dec-2021	20:40	17	0.00023	INTERRUPTION DUE TO FAULT
31	11-Dec-2021	PARTS OF M/S SUBHASH ENTER PRIZES, AJAY PLASTICS UNIT - 2, SHAHZADA BAGH NO.3, DDA SLUM TENAMANT KESHAV PURAM	1183	Other Outage	Unplanned Outage	11-Dec-2021	20:23	11-Dec-2021	21:00	37	0.000202	INTERRUPTION DUE TO FAULT
32	12-Dec-2021	PARTS OF KANHAYA NAGAR, SHANTI NAGAR & DEVA RAM PARK KESHAV PURAM	2428	Other Outage	Unplanned Outage	12-Dec-2021	07:19	12-Dec-2021	07:29	10	0.000132	INTERRUPTION DUE TO FAULT
33	12-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	3	Other Outage	Unplanned Outage	12-Dec-2021	16:40	12-Dec-2021	16:56	16	0.00004	SYSTEM SCHEDULE OUTAGE
34	13-Dec-2021	PARTS OF RAM PURA VILLAGE, ONKAR NAGAR 'B' & CHANDER QUARTER KESHAV PURAM	1825	Other Outage	Unplanned Outage	13-Dec-2021	09:55	13-Dec-2021	10:22	27	0.000368	INTERRUPTION DUE TO FAULT
35	13-Dec-2021	PARTS OF RAM PURA VILLAGE, ONKAR NAGAR 'B' & CHANDER QUARTER KESHAV PURAM	608	Other Outage	Unplanned Outage	13-Dec-2021	09:55	13-Dec-2021	10:38	43	0.00012	INTERRUPTION DUE TO FAULT
36	13-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	2	Other Outage	Unplanned Outage	13-Dec-2021	10:04	13-Dec-2021	10:23	19	0.000011	INTERRUPTION DUE TO FAULT
37	13-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	8	Other Outage	Unplanned Outage	13-Dec-2021	11:55	13-Dec-2021	12:12	17	0.00009	INTERRUPTION DUE TO FAULT
38	13-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	3	Other Outage	Unplanned Outage	13-Dec-2021	13:00	13-Dec-2021	13:52	52	0.000014	INTERRUPTION DUE TO FAULT
39	14-Dec-2021	PART OF DSICD CKT.1 KESHAV PURAM	9	Other Outage	Unplanned Outage	14-Dec-2021	11:01	14-Dec-2021	12:48	107	0.00003	INTERRUPTION DUE TO FAULT
40	14-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	62	Other Outage	Unplanned Outage	14-Dec-2021	13:24	14-Dec-2021	14:02	38	0.000021	INTERRUPTION DUE TO FAULT
41	14-Dec-2021	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	287	Other Outage	Unplanned Outage	14-Dec-2021	18:44	14-Dec-2021	19:06	22	0.000041	INTERRUPTION DUE TO FAULT
42	14-Dec-2021	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	75	Other Outage	Unplanned Outage	14-Dec-2021	18:44	14-Dec-2021	20:40	116	0.000128	INTERRUPTION DUE TO FAULT
43	15-Dec-2021	PART OF DSICD CKT.1 KESHAV PURAM	9	Other Outage	Unplanned Outage	15-Dec-2021	12:40	15-Dec-2021	13:45	65	0.000036	INTERRUPTION DUE TO FAULT
44	17-Dec-2021	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	6	Other Outage	Unplanned Outage	17-Dec-2021	11:50	17-Dec-2021	12:45	55	0.000031	INTERRUPTION DUE TO FAULT
45	17-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	38	Other Outage	Unplanned Outage	17-Dec-2021	12:09	17-Dec-2021	12:20	11	0.000046	INTERRUPTION DUE TO FAULT
46	17-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	105	Other Outage	Unplanned Outage	17-Dec-2021	12:09	17-Dec-2021	13:05	56	0.000156	INTERRUPTION DUE TO FAULT
47	17-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	32	Other Outage	Unplanned Outage	17-Dec-2021	12:40	17-Dec-2021	13:10	30	0.000008	INTERRUPTION DUE TO FAULT
48	17-Dec-2021	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2 KESHAV PURAM	371	Other Outage	Unplanned Outage	17-Dec-2021	18:01	17-Dec-2021	18:56	55	0.000031	INTERRUPTION DUE TO FAULT
49	17-Dec-2021	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2 KESHAV PURAM	23	Other Outage	Unplanned Outage	17-Dec-2021	18:01	17-Dec-2021	18:56	55	0.000031	INTERRUPTION DUE TO FAULT
50	19-Dec-2021	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4 KESHAV PURAM	1269	Other Outage	Unplanned Outage	19-Dec-2021	07:05	19-Dec-2021	07:45	40	0.000124	INTERRUPTION DUE TO FAULT
51	19-Dec-2021	PARTS OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	259	Other Outage	Unplanned Outage	19-Dec-2021	09:31	19-Dec-2021	09:45	14	0.000114	INTERRUPTION DUE TO FAULT
52	20-Dec-2021	PARTS OF IA-BLOCK, PART OF H & J BLOCK ASHOK VIHAR PH- 1, POLICE COLONY & SPORTS COMPLEX, TRANSFORMER WORK SHOP J BLOCK KESHAV PURAM	10	Other Outage	Unplanned Outage	20-Dec-2021	13:01	20-Dec-2021	13:09	8	0.000067	INTERRUPTION DUE TO FAULT
53	20-Dec-2021	PART OF DISTRICT OFFICE BUILDING KESHAV PURAM	13	Other Outage	Unplanned Outage	20-Dec-2021	14:11	20-Dec-2021	14:24	13	0.000014	INTERRUPTION DUE TO FAULT
54	20-Dec-2021	PARTS OF COMMUNITY CENTRE, PART OF STRIPLEX RAMPURA KESHAV PURAM	50	Other Outage	Unplanned Outage	20-Dec-2021	15:39	20-Dec-2021	15:56	17	0.000009	INTERRUPTION DUE TO FAULT
55	21-Dec-2021	PART OF L-2 BLOCK SHATRI NAGAR KESHAV PURAM	10	Other Outage	Unplanned Outage	21-Dec-2021	09:22	21-Dec-2021	10:20	58	0.000032	INTERRUPTION DUE TO FAULT
56	25-Dec-2021	PARTS OF RAM PURA VILLAGE, JAI MATA MARKET & HANSA PURI ROAD KESHAV PURAM	438	Other Outage	Unplanned Outage	25-Dec-2021	12:03	25-Dec-2021	12:51	48	0.000267	INTERRUPTION DUE TO FAULT
57	25-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	3	Other Outage	Unplanned Outage	25-Dec-2021	12:30	25-Dec-2021	13:00	30	0.000017	INTERRUPTION DUE TO FAULT
58	25-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	4	Other Outage	Unplanned Outage	25-Dec-2021	13:06	25-Dec-2021	13:35	29	0.000016	INTERRUPTION DUE TO FAULT

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
59	26-Dec-2021	PARTS OF DDA PH-1 & II, DAYA BASTI KESHAV PURAM	616	Other Outage	Unplanned Outage	26-Dec-2021	09:21	26-Dec-2021	09:35	14	0.00019	INTERRUPTION DUE TO FAULT
60	26-Dec-2021	PARTS OF DDA PH-1 & II, DAYA BASTI KESHAV PURAM	146	Other Outage	Unplanned Outage	26-Dec-2021	09:21	26-Dec-2021	09:57	36	0.00002	INTERRUPTION DUE TO FAULT
61	26-Dec-2021	PARTS OF DDA PH-1 & II, DAYA BASTI KESHAV PURAM	186	Other Outage	Unplanned Outage	26-Dec-2021	09:50	26-Dec-2021	09:57	7	0.000016	INTERRUPTION DUE TO FAULT
62	26-Dec-2021	PARTS OF BUS STAND ROAD, TOTA RAM BAZAR & ZOODR BAGH KESHAV PURAM	782	Other Outage	Unplanned Outage	26-Dec-2021	18:28	26-Dec-2021	20:15	107	0.000357	INTERRUPTION DUE TO FAULT
63	26-Dec-2021	PARTS OF BUS STAND ROAD, TOTA RAM BAZAR & ZOODR BAGH KESHAV PURAM	773	Other Outage	Unplanned Outage	26-Dec-2021	18:35	26-Dec-2021	20:15	100	0.000278	INTERRUPTION DUE TO FAULT
64	26-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA, KESHAV PURAM	414	Other Outage	Unplanned Outage	26-Dec-2021	18:37	26-Dec-2021	20:35	118	0.000392	INTERRUPTION DUE TO FAULT
65	26-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	228	Other Outage	Unplanned Outage	26-Dec-2021	19:50	26-Dec-2021	20:05	15	0.00005	INTERRUPTION DUE TO FAULT
66	26-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	35	Other Outage	Unplanned Outage	26-Dec-2021	19:51	27-Dec-2021	00:28	277	0.000077	FORCE MAJEURE DUE TO RAIN/STORM
67	26-Dec-2021	PART OF DDA PHASE-2 SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	2	Other Outage	Unplanned Outage	26-Dec-2021	19:51	27-Dec-2021	01:29	338	0.000094	FORCE MAJEURE DUE TO RAIN/STORM
68	27-Dec-2021	PARTS OF DSIDC CKT.1 CKT.2, B-71, B-40 KESHAV PURAM	66	Other Outage	Unplanned Outage	27-Dec-2021	05:21	27-Dec-2021	13:14	473	0.000394	FORCE MAJEURE DUE TO FIRE
69	27-Dec-2021	PART OF DSIDC CKT.1 KESHAV PURAM	4	Other Outage	Unplanned Outage	27-Dec-2021	05:21	29-Dec-2021	17:19	3598	0.000999	FORCE MAJEURE DUE TO FIRE
70	27-Dec-2021	PART OF DSIDC CKT.1 KESHAV PURAM	3	Other Outage	Unplanned Outage	27-Dec-2021	05:21	29-Dec-2021	17:20	3599	0.001	FORCE MAJEURE DUE TO FIRE
71	27-Dec-2021	PARTS OF B - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	48	Other Outage	Unplanned Outage	27-Dec-2021	15:48	27-Dec-2021	16:25	37	0.000031	SYSTEM SCHEDULE OUTAGE
72	28-Dec-2021	PARTS OF RAM PURA VILLAGE, ONKAR NAGAR 'B' & CHANDER QUARTER KESHAV PURAM	871	Other Outage	Unplanned Outage	28-Dec-2021	02:56	28-Dec-2021	03:29	33	0.000092	INTERRUPTION DUE TO FAULT
73	28-Dec-2021	PARTS OF RAM PURA VILLAGE, ONKAR NAGAR 'B' & CHANDER QUARTER KESHAV PURAM	346	Other Outage	Unplanned Outage	28-Dec-2021	02:56	28-Dec-2021	03:29	33	0.000046	INTERRUPTION DUE TO FAULT
74	28-Dec-2021	PARTS OF RAM PURA VILLAGE, ONKAR NAGAR 'B' & CHANDER QUARTER KESHAV PURAM	610	Other Outage	Unplanned Outage	28-Dec-2021	02:56	28-Dec-2021	03:42	46	0.000064	INTERRUPTION DUE TO FAULT
75	28-Dec-2021	PARTS OF SFS FLATS, DA FLATS, KC-KD PH-1, WAZIRPUR VILLAGE KESHAV PURAM	1757	Other Outage	Unplanned Outage	28-Dec-2021	03:09	28-Dec-2021	03:15	6	0.000015	INTERRUPTION DUE TO FAULT
76	28-Dec-2021	PARTS OF SFS FLATS, DA FLATS, KC-KD PH-1, WAZIRPUR VILLAGE KESHAV PURAM	659	Other Outage	Unplanned Outage	28-Dec-2021	03:09	28-Dec-2021	03:38	29	0.000039	INTERRUPTION DUE TO FAULT
77	28-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	97	Other Outage	Unplanned Outage	28-Dec-2021	17:09	28-Dec-2021	18:08	59	0.000164	INTERRUPTION DUE TO FAULT
78	30-Dec-2021	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	54	Other Outage	Unplanned Outage	30-Dec-2021	12:27	30-Dec-2021	13:15	48	0.000066	INTERRUPTION DUE TO FAULT
79	31-Dec-2021	PART OF DDA PHASE-2 SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	5	Other Outage	Unplanned Outage	31-Dec-2021	13:00	31-Dec-2021	13:21	21	0.000006	SYSTEM SCHEDULE OUTAGE
80	31-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	143	Other Outage	Unplanned Outage	31-Dec-2021	14:12	31-Dec-2021	14:50	38	0.000158	INTERRUPTION DUE TO FAULT
81	31-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	5	Other Outage	Unplanned Outage	31-Dec-2021	14:28	31-Dec-2021	16:58	150	0.000083	FORCE MAJEURE DUE TO SABOTAGE
82	01-Dec-2021	PART OF B/66 WAZIR PUR KESHAV PURAM	1	Other Outage	Planned Outage	01-Dec-2021	09:51	01-Dec-2021	11:51	120	0.00003	PLANNED OUTAGE
83	01-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	539	Other Outage	Planned Outage	01-Dec-2021	10:05	01-Dec-2021	17:36	451	0.00063	PLANNED OUTAGE
84	01-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	242	Other Outage	Planned Outage	01-Dec-2021	10:06	01-Dec-2021	17:36	450	0.00025	PLANNED OUTAGE
85	01-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	6	400 KVA	Unplanned Outage	01-Dec-2021	10:08	01-Dec-2021	10:39	31	0.00001	SYSTEM SCHEDULE OUTAGE
86	01-Dec-2021	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	69	Other Outage	Planned Outage	01-Dec-2021	10:31	01-Dec-2021	15:07	276	0.00008	PLANNED OUTAGE
87	01-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 KVA	Unplanned Outage	01-Dec-2021	11:32	01-Dec-2021	12:36	64	0.00002	SYSTEM SCHEDULE OUTAGE
88	01-Dec-2021	PART OF A-93 WPIA KESHAV PURAM	4	400 KVA	Unplanned Outage	01-Dec-2021	13:35	01-Dec-2021	14:38	63	0.00002	SYSTEM SCHEDULE OUTAGE
89	01-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	16	400 KVA	Unplanned Outage	01-Dec-2021	16:10	01-Dec-2021	17:07	57	0.00002	SYSTEM SCHEDULE OUTAGE
90	02-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA & SHASTRI NAGAR KESHAV PURAM	491	630 KVA	Planned Outage	02-Dec-2021	10:31	02-Dec-2021	12:00	89	0.00020	PLANNED OUTAGE
91	02-Dec-2021	PARTS OF NIMRI VILLAGE, PART OF A, B, & L BLOCK SHASTRI NAGAR KESHAV PURAM	825	990 KVA	Planned Outage	02-Dec-2021	10:31	02-Dec-2021	12:00	89	0.00025	PLANNED OUTAGE
92	02-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 KVA	Planned Outage	02-Dec-2021	10:39	02-Dec-2021	12:37	118	0.00003	PLANNED OUTAGE
93	02-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 KVA	Planned Outage	02-Dec-2021	10:46	02-Dec-2021	12:46	120	0.00003	PLANNED OUTAGE
94	02-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	250 KVA	Unplanned Outage	02-Dec-2021	11:13	02-Dec-2021	12:37	84	0.00002	SYSTEM SCHEDULE OUTAGE
95	02-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	5	400 KVA	Unplanned Outage	02-Dec-2021	12:01	02-Dec-2021	13:44	103	0.00003	SYSTEM SCHEDULE OUTAGE
96	02-Dec-2021	PART OF SALONA A-9/3 KESHAV PURAM	6	400 KVA	Planned Outage	02-Dec-2021	14:50	02-Dec-2021	16:28	98	0.00003	PLANNED OUTAGE
97	02-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	8	400 KVA	Planned Outage	02-Dec-2021	14:56	02-Dec-2021	16:26	90	0.00003	PLANNED OUTAGE
98	02-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA AND PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	44	400 KVA	Unplanned Outage	02-Dec-2021	15:06	02-Dec-2021	16:29	83	0.00002	SYSTEM SCHEDULE OUTAGE
99	03-Dec-2021	PART OF SALONA A-9/3 KESHAV PURAM	4	400 KVA	Planned Outage	03-Dec-2021	10:31	03-Dec-2021	13:03	152	0.00004	PLANNED OUTAGE
100	03-Dec-2021	PART OF SALONA A-9/3 KESHAV PURAM	8	400 KVA	Planned Outage	03-Dec-2021	10:37	03-Dec-2021	12:58	141	0.00004	PLANNED OUTAGE
101	03-Dec-2021	PART OF SALONA A-9/3 KESHAV PURAM	4	400 KVA	Planned Outage	03-Dec-2021	10:40	03-Dec-2021	11:11	31	0.00001	PLANNED OUTAGE
102	03-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	4	400 KVA	Unplanned Outage	03-Dec-2021	10:52	03-Dec-2021	11:59	67	0.00002	SYSTEM SCHEDULE OUTAGE
103	03-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	3	400 KVA	Unplanned Outage	03-Dec-2021	12:16	03-Dec-2021	13:07	51	0.00001	SYSTEM SCHEDULE OUTAGE
104	03-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	5	400 KVA	Unplanned Outage	03-Dec-2021	13:27	03-Dec-2021	14:40	73	0.00002	SYSTEM SCHEDULE OUTAGE
105	03-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	3	400 KVA	Planned Outage	03-Dec-2021	14:23	03-Dec-2021	16:24	121	0.00003	PLANNED OUTAGE
106	03-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	2	315 KVA	Planned Outage	03-Dec-2021	14:33	03-Dec-2021	16:22	109	0.00003	PLANNED OUTAGE
107	03-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	4	100 KVA	Unplanned Outage	03-Dec-2021	15:15	03-Dec-2021	16:14	59	0.00002	SYSTEM SCHEDULE OUTAGE
108	04-Dec-2021	PARTS OF MASZID PARK, 13/380,NAGAR NIGAM SCHOOL KESHAV PURAM	227	Other Outage	Planned Outage	04-Dec-2021	10:43	04-Dec-2021	15:05	262	0.00015	PLANNED OUTAGE
109	04-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA, KESHAV PURAM	86	Other Outage	Planned Outage	04-Dec-2021	11:01	04-Dec-2021	16:22	321	0.00009	PLANNED OUTAGE
110	06-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	8	400 KVA	Unplanned Outage	06-Dec-2021	11:05	06-Dec-2021	12:27	82	0.00002	SYSTEM SCHEDULE OUTAGE
111	06-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 KVA	Unplanned Outage	06-Dec-2021	14:13	06-Dec-2021	15:18	65	0.00002	SYSTEM SCHEDULE OUTAGE
112	06-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	5	400 KVA	Unplanned Outage	06-Dec-2021	15:58	06-Dec-2021	16:47	49	0.00001	SYSTEM SCHEDULE OUTAGE
113	07-Dec-2021	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	7	400 KVA	Unplanned Outage	07-Dec-2021	12:05	07-Dec-2021	13:49	104	0.00003	SYSTEM SCHEDULE OUTAGE
114	07-Dec-2021	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	3	250 KVA	Unplanned Outage	07-Dec-2021	14:20	07-Dec-2021	15:01	41	0.00001	SYSTEM SCHEDULE OUTAGE
115	08-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA, KESHAV PURAM	118	Other Outage	Planned Outage	08-Dec-2021	10:59	08-Dec-2021	16:30	331	0.00009	PLANNED OUTAGE
116	09-Dec-2021	PART OF B-69 LAW RD IND AREA, KESHAV PURAM	17	400 KVA	Unplanned Outage	09-Dec-2021	10:53	09-Dec-2021	11:26	33	0.00001	SYSTEM SCHEDULE OUTAGE
117	10-Dec-2021	PART OF C - 6/12 INDUSTRIAL AREA LAWRENCE ROAD KESHAV PURAM	6	250 KVA	Unplanned Outage	10-Dec-2021	11:21	10-Dec-2021	12:29	68	0.00002	SYSTEM SCHEDULE OUTAGE
118	10-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	4	250 KVA	Unplanned Outage	10-Dec-2021	16:20	10-Dec-2021	17:30	70	0.00002	SYSTEM SCHEDULE OUTAGE
119	11-Dec-2021	PARTS OF MASZID PARK, 13/380,NAGAR NIGAM SCHOOL KESHAV PURAM	791	Other Outage	Planned Outage	11-Dec-2021	10:32	11-Dec-2021	15:14	282	0.00063	PLANNED OUTAGE
120	11-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA, KESHAV PURAM	118	Other Outage	Planned Outage	11-Dec-2021	11:31	11-Dec-2021	16:28	297	0.00025	PLANNED OUTAGE
121	11-Dec-2021	PART OF G-40 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	3	250 KVA	Unplanned Outage	11-Dec-2021	12:41	11-Dec-2021	14:04	83	0.00002	SYSTEM SCHEDULE OUTAGE
122	11-Dec-2021	PART OF G-40 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	8	500 KVA	Unplanned Outage	11-Dec-2021	15:01	11-Dec-2021	15:37	36	0.00001	SYSTEM SCHEDULE OUTAGE
123	13-Dec-2021	PARTS OF B - BLOCK (OUTER), GANDA NALA SHASTRI NAGAR 5/5 NO-1, STATUE PARK KESHAV PURAM	724	990 KVA	Planned Outage	13-Dec-2021	10:22	13-Dec-2021	12:38	136	0.00030	PLANNED OUTAGE
124	13-Dec-2021	PARTS OF B - BLOCK (OUTER), GANDA NALA SHASTRI NAGAR 5/5 NO-1, STATUE PARK KESHAV PURAM	832	990 KVA	Planned Outage	13-Dec-2021	10:23	13-Dec-2021	12:38	135	0.00034	PLANNED OUTAGE
125	13-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	4	400 KVA	Unplanned Outage	13-Dec-2021	12:18	13-Dec-2021	13:14	56	0.00002	SYSTEM SCHEDULE OUTAGE
126	14-Dec-2021	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	5	400 KVA	Unplanned Outage	14-Dec-2021	11:13	14-Dec-2021	13:26	133	0.00004	FORCE MAJEURE DUE TO SABOTAGE
127	15-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	105	Other Outage	Planned Outage	15-Dec-2021	10:10	15-Dec-2021	14:04	234	0.00013	PLANNED OUTAGE
128	15-Dec-2021	PART OF B/66 WAZIR PUR KESHAV PURAM	2	400 KVA	Unplanned Outage	15-Dec-2021	11:05	15-Dec-2021	11:41	36	0.00001	SYSTEM SCHEDULE OUTAGE
129	15-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	3	250 KVA	Unplanned Outage	15-Dec-2021	13:00	15-Dec-2021	13:25	25	0.00001	SYSTEM SCHEDULE OUTAGE
130	16-Dec-2021	PART OF WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	3	315 KVA	Unplanned Outage	16-Dec-2021	15:55	16-Dec-2021	17:04	69	0.00002	SYSTEM SCHEDULE OUTAGE
131	17-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	4	400 KVA	Planned Outage	17-Dec-2021	10:50	17-Dec-2021	12:35	105	0.00003	PLANNED OUTAGE
132	17-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	1	315 KVA	Planned Outage	17-Dec-2021	10:53	17-Dec-2021	12:37	104	0.00003	PLANNED OUTAGE
133	17-Dec-2021	PART OF RAMPURA VILLAGE KESHAV PURAM	11	500 KVA	Planned Outage	17-Dec-2021	11:25	17-Dec-2021	12:52	87	0.00002	PLANNED OUTAGE
134	17-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	3	400 KVA	Planned Outage	17-Dec-2021	13:47	17-Dec-2021	15:49	122	0.00003	PLANNED OUTAGE
135	17-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	8	315 KVA	Planned Outage	17-Dec-2021	13:51	17-Dec-2021	16:14	143	0.00004	PLANNED OUTAGE
136	17-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 KVA	Planned Outage	17-Dec-2021	13:54	17-Dec-2021	15:51	117	0.00003	PLANNED OUTAGE
137	17-Dec-2021	PART OF DSIDC CKT.1 KESHAV PURAM	1	250 KVA	Planned Outage	17-Dec-2021	14:44	17-Dec-2021	15:30	46	0.00001	PLANNED OUTAGE
138	18-Dec-2021	PART OF STRIPLEX RAMPURA KESHAV PURAM	8	160 KVA	Unplanned Outage	18-Dec-2021	11					

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
153	23-Dec-2021	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	4	400 kVA	Unplanned Outage	23-Dec-2021	16:01	23-Dec-2021	16:49	48	0.00001	SYSTEM SCHEDULE OUTAGE
154	24-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	79	Other Outage	Planned Outage	24-Dec-2021	10:04	24-Dec-2021	16:36	392	0.00022	PLANNED OUTAGE
155	24-Dec-2021	PART OF B BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	6	315 kVA	Planned Outage	24-Dec-2021	12:53	24-Dec-2021	14:35	102	0.00003	PLANNED OUTAGE
156	24-Dec-2021	PART OF B BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	6	400 kVA	Planned Outage	24-Dec-2021	12:55	24-Dec-2021	14:46	111	0.00003	PLANNED OUTAGE
157	27-Dec-2021	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK) KESHAV PURAM	782	Other Outage	Planned Outage	27-Dec-2021	09:54	27-Dec-2021	11:03	69	0.00015	PLANNED OUTAGE
158	27-Dec-2021	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK) KESHAV PURAM	32	Other Outage	Planned Outage	27-Dec-2021	09:56	27-Dec-2021	10:53	57	0.00002	PLANNED OUTAGE
159	27-Dec-2021	PART OF VICTORIA B - 32 KESHAV PURAM	3	Other Outage	Planned Outage	27-Dec-2021	11:34	27-Dec-2021	12:34	60	0.00002	PLANNED OUTAGE
160	27-Dec-2021	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	5	400 kVA	Unplanned Outage	27-Dec-2021	13:38	27-Dec-2021	14:30	52	0.00001	SYSTEM SCHEDULE OUTAGE
161	28-Dec-2021	PART OF B BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	4	315 kVA	Unplanned Outage	28-Dec-2021	13:34	28-Dec-2021	14:17	43	0.00001	SYSTEM SCHEDULE OUTAGE
162	29-Dec-2021	PART OF B BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	4	250 kVA	Unplanned Outage	29-Dec-2021	10:31	29-Dec-2021	11:22	51	0.00001	SYSTEM SCHEDULE OUTAGE
163	29-Dec-2021	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	1	400 kVA	Planned Outage	29-Dec-2021	11:30	29-Dec-2021	15:50	260	0.00007	PLANNED OUTAGE
164	29-Dec-2021	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	117	Other Outage	Planned Outage	29-Dec-2021	11:36	29-Dec-2021	16:39	303	0.00084	PLANNED OUTAGE
165	29-Dec-2021	PART OF A-93 WPIA KESHAV PURAM	5	400 kVA	Unplanned Outage	29-Dec-2021	11:55	29-Dec-2021	12:32	37	0.00001	SYSTEM SCHEDULE OUTAGE
166	29-Dec-2021	PARTS OF E-BLOCK SHASTRI NAGAR KESHAV PURAM	796	Other Outage	Planned Outage	29-Dec-2021	12:00	29-Dec-2021	12:45	44	0.00037	PLANNED OUTAGE
167	29-Dec-2021	PART OF DSIDC CKT.1 KESHAV PURAM	6	315 kVA	Unplanned Outage	29-Dec-2021	13:21	29-Dec-2021	14:10	49	0.00001	SYSTEM SCHEDULE OUTAGE
168	30-Dec-2021	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	35	Other Outage	Planned Outage	30-Dec-2021	10:30	30-Dec-2021	15:36	306	0.00009	PLANNED OUTAGE
169	31-Dec-2021	PARTS OF G - 5, G - 29 TO G - 40 LAWRENCE ROAD INDUSTRIAL AREA, G - 41 TO G - 59, B - 38, 39, B - 34, B - 35, B - 36 KESHAV PURAM	68	Other Outage	Planned Outage	31-Dec-2021	08:47	31-Dec-2021	12:54	247	0.00007	PLANNED OUTAGE
170	31-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	33	Other Outage	Planned Outage	31-Dec-2021	11:32	31-Dec-2021	14:58	206	0.00006	PLANNED OUTAGE
171	31-Dec-2021	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	136	Other Outage	Planned Outage	31-Dec-2021	11:37	31-Dec-2021	15:01	204	0.00011	PLANNED OUTAGE
172	31-Dec-2021	PART OF G-40 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	13	250 kVA	Planned Outage	31-Dec-2021	11:58	31-Dec-2021	15:33	215	0.00006	PLANNED OUTAGE
173	31-Dec-2021	PART OF B BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	3	250 kVA	Unplanned Outage	31-Dec-2021	15:49	31-Dec-2021	16:21	32	0.00001	SYSTEM SCHEDULE OUTAGE
KIRARI												
1	02-Dec-2021	PARTS OF MASTER FACTORY B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR 2 KIRARI	5434	Other Outage	Unplanned Outage	02-Dec-2021	14:17	02-Dec-2021	14:46	29	0.000398	INTERRUPTION DUE TO FAULT
2	02-Dec-2021	PARTS OF MASTER FACTORY B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR 2 KIRARI	1105	Other Outage	Unplanned Outage	02-Dec-2021	14:17	02-Dec-2021	14:57	40	0.00011	INTERRUPTION DUE TO FAULT
3	02-Dec-2021	PART OF B-BLK. PREM NAGAR KIRARI	20	Other Outage	Unplanned Outage	02-Dec-2021	14:17	02-Dec-2021	17:14	177	0.000147	FORCE MAJEURE DUE TO SABOTAGE
4	02-Dec-2021	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	648	Other Outage	Unplanned Outage	02-Dec-2021	20:48	02-Dec-2021	21:20	32	0.000053	INTERRUPTION DUE TO FAULT
5	02-Dec-2021	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	43	Other Outage	Unplanned Outage	02-Dec-2021	22:55	02-Dec-2021	23:41	46	0.000013	INTERRUPTION DUE TO FAULT
6	03-Dec-2021	PARTS OF B BLK INDER ENCLAVE NO-1 KIRARI	647	Other Outage	Unplanned Outage	03-Dec-2021	12:52	03-Dec-2021	16:00	188	0.000366	FORCE MAJEURE DUE TO SABOTAGE
7	03-Dec-2021	PARTS OF SOM BAIAR AND SECTOR-20 KIRARI	559	Other Outage	Unplanned Outage	03-Dec-2021	20:24	03-Dec-2021	20:48	24	0.00004	INTERRUPTION DUE TO FAULT
8	03-Dec-2021	PARTS OF SOM BAIAR AND SECTOR-20 KIRARI	1132	Other Outage	Unplanned Outage	03-Dec-2021	20:24	03-Dec-2021	21:20	56	0.000187	INTERRUPTION DUE TO FAULT
9	04-Dec-2021	PARTS OF MASTER FACTORY B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR 2 KIRARI	255	Other Outage	Unplanned Outage	04-Dec-2021	14:42	04-Dec-2021	18:23	221	0.000368	FORCE MAJEURE DUE TO SABOTAGE
10	05-Dec-2021	PART OF SUKHBIR NAGAR KIRARI	6	Other Outage	Unplanned Outage	05-Dec-2021	22:08	05-Dec-2021	23:38	90	0.000075	INTERRUPTION DUE TO FAULT
11	05-Dec-2021	PART OF SUKHBIR NAGAR KIRARI	2	Other Outage	Unplanned Outage	05-Dec-2021	22:08	06-Dec-2021	00:04	116	0.000032	INTERRUPTION DUE TO FAULT
12	05-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	1216	Other Outage	Unplanned Outage	05-Dec-2021	23:24	05-Dec-2021	23:38	14	0.000093	INTERRUPTION DUE TO FAULT
13	06-Dec-2021	PART OF SUKHBIR NAGAR KIRARI	5	Other Outage	Unplanned Outage	06-Dec-2021	12:44	06-Dec-2021	15:05	141	0.000039	FORCE MAJEURE DUE TO SABOTAGE
14	06-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO 2 KIRARI	1237	Other Outage	Unplanned Outage	06-Dec-2021	16:25	06-Dec-2021	16:40	15	0.000063	INTERRUPTION DUE TO FAULT
15	08-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	549	Other Outage	Unplanned Outage	08-Dec-2021	08:32	08-Dec-2021	08:48	16	0.000111	INTERRUPTION DUE TO FAULT
16	09-Dec-2021	PARTS OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	1194	Other Outage	Unplanned Outage	09-Dec-2021	14:36	09-Dec-2021	14:58	22	0.000122	SYSTEM SCHEDULE OUTAGE
17	11-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	132	Other Outage	Unplanned Outage	11-Dec-2021	00:53	11-Dec-2021	01:28	35	0.00003	INTERRUPTION DUE TO FAULT
18	11-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	1856	Other Outage	Unplanned Outage	11-Dec-2021	00:53	11-Dec-2021	01:45	52	0.00026	INTERRUPTION DUE TO FAULT
19	11-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	953	Other Outage	Unplanned Outage	11-Dec-2021	00:53	11-Dec-2021	03:00	127	0.000353	FORCE MAJEURE DUE TO SABOTAGE
20	11-Dec-2021	PART OF MAIN ROAD KARALA KIRARI	10	Other Outage	Unplanned Outage	11-Dec-2021	00:53	11-Dec-2021	13:30	757	0.000421	FORCE MAJEURE DUE TO SABOTAGE
21	11-Dec-2021	PARTS OF SOM BAIAR AND SECTOR-20 KIRARI	3152	Other Outage	Unplanned Outage	11-Dec-2021	07:56	11-Dec-2021	08:40	44	0.000384	INTERRUPTION DUE TO FAULT
22	11-Dec-2021	PARTS OF SOM BAIAR AND SECTOR-20 KIRARI	1123	Other Outage	Unplanned Outage	11-Dec-2021	07:56	11-Dec-2021	09:12	76	0.00021	INTERRUPTION DUE TO FAULT
23	12-Dec-2021	PARTS OF BHAGYA VIHAR AND SADBHAV ENGG(DMRC) KIRARI	538	Other Outage	Unplanned Outage	12-Dec-2021	09:55	12-Dec-2021	10:59	64	0.00016	INTERRUPTION DUE TO FAULT
24	13-Dec-2021	PART OF SHIV CHOWK KIRARI	9	Other Outage	Unplanned Outage	13-Dec-2021	01:15	13-Dec-2021	02:15	60	0.000033	INTERRUPTION DUE TO FAULT
25	13-Dec-2021	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	88	Other Outage	Unplanned Outage	13-Dec-2021	01:40	13-Dec-2021	02:10	30	0.000042	INTERRUPTION DUE TO FAULT
26	13-Dec-2021	PART OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	4	Other Outage	Unplanned Outage	13-Dec-2021	16:04	13-Dec-2021	17:42	98	0.000027	INTERRUPTION DUE TO FAULT
27	13-Dec-2021	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	2239	Other Outage	Unplanned Outage	13-Dec-2021	23:14	13-Dec-2021	23:45	31	0.00019	INTERRUPTION DUE TO FAULT
28	13-Dec-2021	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	487	Other Outage	Unplanned Outage	13-Dec-2021	23:14	14-Dec-2021	01:07	113	0.000157	INTERRUPTION DUE TO FAULT
29	14-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO 2 KIRARI	1238	Other Outage	Unplanned Outage	14-Dec-2021	17:55	14-Dec-2021	18:28	33	0.000101	INTERRUPTION DUE TO FAULT
30	14-Dec-2021	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	487	Other Outage	Unplanned Outage	14-Dec-2021	20:32	14-Dec-2021	22:01	89	0.000371	INTERRUPTION DUE TO FAULT
31	15-Dec-2021	PARTS OF MASTER FACTORY B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR 2 KIRARI	29	Other Outage	Unplanned Outage	15-Dec-2021	08:59	15-Dec-2021	10:08	69	0.000019	INTERRUPTION DUE TO FAULT
32	15-Dec-2021	PARTS OF MASTER FACTORY B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR 2 KIRARI	21	Other Outage	Unplanned Outage	15-Dec-2021	18:16	15-Dec-2021	18:56	40	0.000011	SYSTEM SCHEDULE OUTAGE
33	16-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	33	Other Outage	Unplanned Outage	16-Dec-2021	14:04	16-Dec-2021	15:30	86	0.000048	INTERRUPTION DUE TO FAULT
34	16-Dec-2021	PART OF B-BLK. PREM NAGAR KIRARI	7	Other Outage	Unplanned Outage	16-Dec-2021	20:33	16-Dec-2021	20:54	21	0.000006	INTERRUPTION DUE TO FAULT
35	19-Dec-2021	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DIB KIRARI, HARI ENCLAVE-2 KIRARI	1209	Other Outage	Unplanned Outage	19-Dec-2021	15:01	19-Dec-2021	15:21	20	0.000044	INTERRUPTION DUE TO FAULT
36	19-Dec-2021	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	2492	Other Outage	Unplanned Outage	19-Dec-2021	18:00	19-Dec-2021	19:14	74	0.000495	INTERRUPTION DUE TO FAULT
37	19-Dec-2021	PART OF SHIV CHOWK KIRARI	20	Other Outage	Unplanned Outage	19-Dec-2021	18:00	19-Dec-2021	19:30	90	0.00005	INTERRUPTION DUE TO FAULT
38	19-Dec-2021	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	187	Other Outage	Unplanned Outage	19-Dec-2021	19:45	19-Dec-2021	20:51	66	0.000055	INTERRUPTION DUE TO FAULT
39	20-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	1647	Other Outage	Unplanned Outage	20-Dec-2021	16:23	20-Dec-2021	17:01	38	0.000211	INTERRUPTION DUE TO FAULT
40	21-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	2453	Other Outage	Unplanned Outage	21-Dec-2021	07:18	21-Dec-2021	07:36	18	0.000475	INTERRUPTION DUE TO FAULT
41	21-Dec-2021	PARTS OF ROOPALI ENCLAVE KIRARI	2644	Other Outage	Unplanned Outage	21-Dec-2021	14:19	21-Dec-2021	14:55	36	0.000358	INTERRUPTION DUE TO FAULT
42	23-Dec-2021	PART OF BHAGYA VIHAR KIRARI	3	Other Outage	Unplanned Outage	23-Dec-2021	15:12	23-Dec-2021	16:03	51	0.000014	INTERRUPTION DUE TO FAULT
43	23-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	281	Other Outage	Unplanned Outage	23-Dec-2021	16:45	23-Dec-2021	17:52	67	0.000056	INTERRUPTION DUE TO FAULT
44	23-Dec-2021	PART OF BHAGYA VIHAR KIRARI	3	Other Outage	Unplanned Outage	23-Dec-2021	20:54	23-Dec-2021	21:25	31	0.000017	INTERRUPTION DUE TO FAULT
45	24-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	598	Other Outage	Unplanned Outage	24-Dec-2021	03:37	24-Dec-2021	04:53	76	0.000106	INTERRUPTION DUE TO FAULT
46	24-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	340	Other Outage	Unplanned Outage	24-Dec-2021	03:37	24-Dec-2021	04:53	76	0.000042	INTERRUPTION DUE TO FAULT
47	24-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	1321	Other Outage	Unplanned Outage	24-Dec-2021	03:37	24-Dec-2021	05:34	117	0.000325	INTERRUPTION DUE TO FAULT
48	24-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	196	Other Outage	Unplanned Outage	24-Dec-2021	03:37	24-Dec-2021	06:03	146	0.000081	FORCE MAJEURE DUE TO SABOTAGE
49	24-Dec-2021	PARTS OF MUBARAK PUR VILLAGE, MEER VIHAR & PART OF BHAGYA VIHAR KIRARI	341	Other Outage	Unplanned Outage	24-Dec-2021	16:53	24-Dec-2021	17:30	37	0.000052	INTERRUPTION DUE TO FAULT
50	25-Dec-2021	PARTS OF MAJRI VILLAGE KARALA KIRARI	1321	Other Outage	Unplanned Outage	25-Dec-2021	08:36	25-Dec-2021	09:35	59	0.000328	INTERRUPTION DUE TO FAULT
51	25-Dec-2021	PARTS OF MASTER FACTORY B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR 2 KIRARI	39	Other Outage	Unplanned Outage	25-Dec-2021	13:26	25-Dec-2021	14:20	54	0.00006	INTERRUPTION DUE TO FAULT
52	25-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	327	Other Outage	Unplanned Outage	25-Dec-2021	15:52	25-Dec-2021	18:05	133	0.000222	FORCE MAJEURE DUE TO SABOTAGE
53	26-Dec-2021	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DIB BOOSTER PUMP SUKHI NAHAR TALAS KIRARI	1794	Other Outage	Unplanned Outage	26-Dec-2021	17:56	26-Dec-2021	18:01	5	0.000024	INTERRUPTION DUE TO FAULT
54	26-Dec-2021	PARTS OF PASHU AUSHADHALAYA KIRARI	3951	Other Outage	Unplanned Outage	26-Dec-2021	17:58	26-Dec-2021	18:42	44	0.000603	INTERRUPTION DUE TO FAULT
55	26-Dec-2021	PARTS OF BHAGYA VIHAR AND SADBHAV ENGG(DMRC) KIRARI	773	Other Outage	Unplanned Outage	26-Dec-2021	17:59	26-Dec-2021	19:12	73	0.000142	INTERRUPTION DUE TO FAULT
56	26-Dec-2021	PARTS OF BHAGYA VIHAR AND SADBHAV ENGG(DMRC) KIRARI	928	Other Outage	Unplanned Outage	26-Dec-2021	17:59	26-Dec-2021	20:17	138	0.000345	FORCE MAJEURE DUE TO RAIN/STORM
57	26-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO 2 KIRARI	1242	Other Outage	Unplanned Outage	26-Dec-2021	20:15	26-Dec-2021	20:39	24	0.000098	INTERRUPTION DUE TO FA

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unscheduled (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
65	27-Dec-2021	PART OF NITHARI KIRARI	2	Other Outage	Unplanned Outage	27-Dec-2021	18:17	27-Dec-2021	18:28	11	0.00003	INTERRUPTION DUE TO FAULT
66	27-Dec-2021	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	2246	Other Outage	Unplanned Outage	27-Dec-2021	18:43	27-Dec-2021	19:21	38	0.000317	INTERRUPTION DUE TO FAULT
67	28-Dec-2021	PARTS OF AGAR NAGAR AND PREM NAGAR III KIRARI	6700	Other Outage	Unplanned Outage	28-Dec-2021	13:02	28-Dec-2021	13:27	25	0.000663	INTERRUPTION DUE TO FAULT
68	28-Dec-2021	PARTS OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	1206	Other Outage	Unplanned Outage	28-Dec-2021	15:54	28-Dec-2021	16:12	18	0.000353	INTERRUPTION DUE TO FAULT
69	28-Dec-2021	PART OF B-BLK. PREM NAGAR KIRARI	19	Other Outage	Unplanned Outage	28-Dec-2021	18:49	28-Dec-2021	19:25	36	0.00002	INTERRUPTION DUE TO FAULT
70	29-Dec-2021	PARTS OF MASTER FACTORY, B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2 KIRARI	2647	Other Outage	Unplanned Outage	29-Dec-2021	08:06	29-Dec-2021	08:55	49	0.000516	INTERRUPTION DUE TO FAULT
71	29-Dec-2021	PARTS OF VIDYA PATTI NAGAR AREA KIRARI	3056	Other Outage	Unplanned Outage	29-Dec-2021	11:31	29-Dec-2021	12:02	31	0.000586	INTERRUPTION DUE TO FAULT
72	29-Dec-2021	PARTS OF VIDYAPATI NAGAR NO. 2 KARALA KIRARI	1333	Other Outage	Unplanned Outage	29-Dec-2021	12:11	29-Dec-2021	12:42	31	0.000156	INTERRUPTION DUE TO FAULT
73	29-Dec-2021	PART OF B-BLK. PREM NAGAR KIRARI	7	Other Outage	Unplanned Outage	29-Dec-2021	13:30	29-Dec-2021	14:00	30	0.000017	INTERRUPTION DUE TO FAULT
74	29-Dec-2021	PARTS OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	173	Other Outage	Unplanned Outage	29-Dec-2021	14:52	29-Dec-2021	16:10	78	0.00013	INTERRUPTION DUE TO FAULT
75	29-Dec-2021	PART OF NITHARI KIRARI	17	Other Outage	Unplanned Outage	29-Dec-2021	16:46	29-Dec-2021	17:20	34	0.000028	INTERRUPTION DUE TO FAULT
76	30-Dec-2021	PARTS OF MASTER FACTORY, B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2 KIRARI	41	Other Outage	Unplanned Outage	30-Dec-2021	12:48	30-Dec-2021	13:12	24	0.000007	INTERRUPTION DUE TO FAULT
77	31-Dec-2021	PART OF SOM BALJAR KIRARI	4	Other Outage	Unplanned Outage	31-Dec-2021	09:24	31-Dec-2021	09:35	11	0.000006	INTERRUPTION DUE TO FAULT
78	31-Dec-2021	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P-V-3 (NALE WALA), PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	246	Other Outage	Unplanned Outage	31-Dec-2021	11:34	31-Dec-2021	12:46	72	0.0001	INTERRUPTION DUE TO FAULT
79	31-Dec-2021	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DIB, NAG MANDIR, U-BLOCK, DIB KIRARI, DHURVA ENCL. KIRARI	5091	Other Outage	Unplanned Outage	31-Dec-2021	23:57	01-Jan-2022	00:30	33	0.000312	INTERRUPTION DUE TO FAULT
80	31-Dec-2021	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DIB, NAG MANDIR, U-BLOCK, DIB KIRARI, DHURVA ENCL. KIRARI	1577	Other Outage	Unplanned Outage	31-Dec-2021	23:57	01-Jan-2022	00:40	43	0.00006	INTERRUPTION DUE TO FAULT
81	31-Dec-2021	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DIB, NAG MANDIR, U-BLOCK, DIB KIRARI, DHURVA ENCL. KIRARI	78	Other Outage	Unplanned Outage	31-Dec-2021	23:57	01-Jan-2022	01:45	108	0.00012	INTERRUPTION DUE TO FAULT
82	04-Dec-2021	PART OF VILL-RANI KHERA KIRARI	20	Other Outage	Planned Outage	04-Dec-2021	11:10	04-Dec-2021	15:35	264	0.00007	PLANNED OUTAGE
83	06-Dec-2021	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	282	Other Outage	Planned Outage	06-Dec-2021	10:57	06-Dec-2021	15:45	288	0.00096	PLANNED OUTAGE
84	07-Dec-2021	PARTS OF HINDU MUSLIM AMAN VIHAR, RAMESH ENCLAVE, TATA TOWER, BITTOO WALA, KAILASH VIHAR NO-1, RAJ BIR AMAN VIHAR KIRARI	502	Other Outage	Planned Outage	07-Dec-2021	11:42	07-Dec-2021	13:45	123	0.00017	PLANNED OUTAGE
85	08-Dec-2021	PARTS OF RAMESH ENCLAVE AND SHIV CHOWK KIRARI	49	250 kVA	Planned Outage	08-Dec-2021	11:18	08-Dec-2021	13:57	159	0.00022	PLANNED OUTAGE
86	08-Dec-2021	PART OF BHAGYA VIHAR KIRARI	3	Other Outage	Planned Outage	08-Dec-2021	11:31	08-Dec-2021	15:07	216	0.00006	PLANNED OUTAGE
87	08-Dec-2021	PARTS OF RAMESH ENCLAVE AND SHIV CHOWK KIRARI	627	400 kVA	Planned Outage	08-Dec-2021	13:44	08-Dec-2021	15:32	108	0.00021	PLANNED OUTAGE
88	08-Dec-2021	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	514	Other Outage	Planned Outage	08-Dec-2021	15:52	08-Dec-2021	16:43	51	0.00007	PLANNED OUTAGE
89	10-Dec-2021	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DIB BOOSTER PUMP SUKHI NAHAR TALAB KIRARI	1050	Other Outage	Planned Outage	10-Dec-2021	13:48	10-Dec-2021	14:49	61	0.00019	PLANNED OUTAGE
90	13-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	40	Other Outage	Planned Outage	13-Dec-2021	10:33	13-Dec-2021	12:58	145	0.00008	PLANNED OUTAGE
91	13-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	33	Other Outage	Planned Outage	13-Dec-2021	11:40	13-Dec-2021	15:45	245	0.00007	PLANNED OUTAGE
92	14-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	549	Other Outage	Planned Outage	14-Dec-2021	10:48	14-Dec-2021	12:15	87	0.00019	PLANNED OUTAGE
93	14-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	50	Other Outage	Planned Outage	14-Dec-2021	11:50	14-Dec-2021	16:35	285	0.00008	PLANNED OUTAGE
94	14-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	89	Other Outage	Planned Outage	14-Dec-2021	12:16	14-Dec-2021	17:54	338	0.00009	PLANNED OUTAGE
95	15-Dec-2021	PARTS OF BHAGYA VIHAR AND SADBHAV ENGG(DMRC) KIRARI	538	Other Outage	Planned Outage	15-Dec-2021	10:59	15-Dec-2021	15:42	283	0.00039	PLANNED OUTAGE
96	16-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	269	Other Outage	Planned Outage	16-Dec-2021	11:01	16-Dec-2021	12:12	71	0.00008	PLANNED OUTAGE
97	16-Dec-2021	PARTS OF GAURI SHANKER ENCLAVE, TRIPATHI ENCLAVE SHUKHI NAHAR, SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR KIRARI	706	630 kVA	Planned Outage	16-Dec-2021	11:29	16-Dec-2021	13:40	131	0.00022	PLANNED OUTAGE
98	16-Dec-2021	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	21	Other Outage	Planned Outage	16-Dec-2021	12:16	16-Dec-2021	16:12	236	0.00007	PLANNED OUTAGE
99	16-Dec-2021	PARTS OF GAURI SHANKER ENCLAVE, TRIPATHI ENCLAVE SHUKHI NAHAR, SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR KIRARI	392	630 kVA	Planned Outage	16-Dec-2021	14:09	16-Dec-2021	16:49	160	0.00022	PLANNED OUTAGE
100	18-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	505	Other Outage	Planned Outage	18-Dec-2021	11:03	18-Dec-2021	12:00	57	0.00008	PLANNED OUTAGE
101	18-Dec-2021	PART OF SUKHBIR NAGAR KIRARI	15	Other Outage	Planned Outage	18-Dec-2021	12:03	18-Dec-2021	16:58	295	0.00008	PLANNED OUTAGE
102	18-Dec-2021	PART OF SUKHBIR NAGAR KIRARI	5	315 kVA	Unplanned Outage	18-Dec-2021	14:15	18-Dec-2021	15:07	52	0.00001	SYSTEM SCHEDULE OUTAGE
103	20-Dec-2021	PARTS OF KARALA WATER SUPPLY KIRARI	882	Other Outage	Planned Outage	20-Dec-2021	11:13	20-Dec-2021	15:05	232	0.00161	PLANNED OUTAGE
104	21-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	55	500 kVA	Planned Outage	21-Dec-2021	12:31	21-Dec-2021	15:54	203	0.00011	PLANNED OUTAGE
105	21-Dec-2021	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P-V-3 (NALE WALA), PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	288	630 kVA	Planned Outage	21-Dec-2021	12:46	21-Dec-2021	17:53	307	0.00034	PLANNED OUTAGE
106	23-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	307	Other Outage	Planned Outage	23-Dec-2021	11:19	23-Dec-2021	16:07	288	0.00024	PLANNED OUTAGE
107	23-Dec-2021	PARTS OF PRATAP VIHAR AND SHIV CHOWK KIRARI MANGOLPURI KIRARI	994	Other Outage	Planned Outage	23-Dec-2021	11:31	23-Dec-2021	14:52	201	0.00112	PLANNED OUTAGE
108	24-Dec-2021	PARTS OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	1194	Other Outage	Planned Outage	24-Dec-2021	11:37	24-Dec-2021	15:15	218	0.00067	PLANNED OUTAGE
109	27-Dec-2021	PARTS OF KARALA VILLAGE KIRARI	514	Other Outage	Planned Outage	27-Dec-2021	11:02	27-Dec-2021	13:51	169	0.00033	PLANNED OUTAGE
110	28-Dec-2021	PARTS OF RAMA VIHAR AND SUKHBIR NAGAR MAIN ROAD, KIRARI	941	Other Outage	Planned Outage	28-Dec-2021	11:29	28-Dec-2021	14:00	151	0.00126	PLANNED OUTAGE
111	28-Dec-2021	PARTS OF RAMA VIHAR AND SUKHBIR NAGAR MAIN ROAD, KIRARI	1166	Other Outage	Planned Outage	28-Dec-2021	14:25	28-Dec-2021	15:50	85	0.00026	PLANNED OUTAGE
112	29-Dec-2021	PARTS OF TRIPATHI ENCLAVE SHUKHI NAHAR KIRARI	410	315 kVA	Planned Outage	29-Dec-2021	10:47	29-Dec-2021	15:54	307	0.00026	PLANNED OUTAGE
113	29-Dec-2021	PARTS OF TRIPATHI ENCLAVE SHUKHI NAHAR KIRARI	1080	Other Outage	Planned Outage	29-Dec-2021	12:26	29-Dec-2021	15:34	188	0.00057	PLANNED OUTAGE
114	30-Dec-2021	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	33	Other Outage	Planned Outage	30-Dec-2021	11:20	30-Dec-2021	16:54	334	0.00009	PLANNED OUTAGE
115	30-Dec-2021	PART OF MAIN ROAD KARALA KIRARI	1	Other Outage	Planned Outage	30-Dec-2021	12:37	30-Dec-2021	17:39	302	0.00008	PLANNED OUTAGE
116	30-Dec-2021	PART OF SUKHBIR NAGAR KIRARI	5	Other Outage	Planned Outage	30-Dec-2021	13:15	30-Dec-2021	17:33	258	0.00007	PLANNED OUTAGE
117	30-Dec-2021	PART OF BHAGYA VIHAR KIRARI	2	Other Outage	Planned Outage	30-Dec-2021	14:51	30-Dec-2021	16:51	120	0.00003	PLANNED OUTAGE
MANGOLPURI												
1	01-Dec-2021	PART OF 55-7 BUDHVIHAR PH-1 MANGOLPURI	8	Other Outage	Unplanned Outage	01-Dec-2021	14:44	01-Dec-2021	15:07	23	0.00013	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	5199	Other Outage	Unplanned Outage	01-Dec-2021	23:40	02-Dec-2021	00:19	39	0.000736	INTERRUPTION DUE TO FAULT
3	02-Dec-2021	PARTS OF T-BLK - M. PURI PARTIALY-B.1,2,3,4,5,A-1,2,3,4,5 BLKS S. PURI MANGOLPURI	1149	Other Outage	Unplanned Outage	02-Dec-2021	05:59	02-Dec-2021	06:25	26	0.000043	INTERRUPTION DUE TO FAULT
4	02-Dec-2021	PART OF HARSHDEV PARK MANGOLPURI	16	Other Outage	Unplanned Outage	02-Dec-2021	10:06	02-Dec-2021	10:30	24	0.000007	INTERRUPTION DUE TO FAULT
5	02-Dec-2021	PARTS OF E-1,2,3,4,5 BLKS S. PURI, JHSDE SHAIJI BAZAR ROAD, RAJ PARK, BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY LOHA MKT. EAST FRIENDS ENCLAVE, MANGOLPURI	254	Other Outage	Unplanned Outage	02-Dec-2021	11:46	02-Dec-2021	13:35	109	0.000091	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PARTS OF MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY), 8 LOCK MIA MANGOLPURI	60	Other Outage	Unplanned Outage	02-Dec-2021	14:06	02-Dec-2021	14:31	25	0.000083	INTERRUPTION DUE TO FAULT
7	02-Dec-2021	PARTS OF MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY), 8 LOCK MIA MANGOLPURI	39	Other Outage	Unplanned Outage	02-Dec-2021	14:06	02-Dec-2021	15:20	74	0.000103	INTERRUPTION DUE TO FAULT
8	02-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1155	Other Outage	Unplanned Outage	02-Dec-2021	14:16	02-Dec-2021	14:57	41	0.000126	INTERRUPTION DUE TO FAULT
9	02-Dec-2021	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY, BRAHM SHAKTI HOSPITAL, MTNL MANGOLPURI	2949	Other Outage	Unplanned Outage	02-Dec-2021	14:19	02-Dec-2021	15:33	74	0.00074	INTERRUPTION DUE TO FAULT
10	02-Dec-2021	PARTS OF KRISHNA VIHAR NO. 1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	3123	Other Outage	Unplanned Outage	02-Dec-2021	14:24	02-Dec-2021	15:24	60	0.000919	INTERRUPTION DUE TO FAULT
11	02-Dec-2021	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARJIAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK, HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR, MANGOLPURI	202	Other Outage	Unplanned Outage	02-Dec-2021	14:38	02-Dec-2021	15:40	62	0.000207	INTERRUPTION DUE TO FAULT
12	02-Dec-2021	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO-7, BEGAMPUR NO-4, NAVIN VIHAR MANGOLPURI	4767	Other Outage	Unplanned Outage	02-Dec-2021	15:56	02-Dec-2021	16:12	16	0.000237	INTERRUPTION DUE TO FAULT
13	02-Dec-2021	PARTS OF T-1, T-2 & T-5 MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	87	Other Outage	Unplanned Outage	02-Dec-2021	16:30	02-Dec-2021	16:40	10	0.000014	INTERRUPTION DUE TO FAULT
14	02-Dec-2021	PART OF T-5 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	16	Other Outage	Unplanned Outage	02-Dec-2021	16:30	02-Dec-2021	17:30	60	0.00005	INTERRUPTION DUE TO FAULT
15	02-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	63	Other Outage	Unplanned Outage	02-Dec-2021	18:50	02-Dec-2021	19:01	11	0.000003	INTERRUPTION DUE TO FAULT
16	02-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	1726	Other Outage	Unplanned Outage	02-Dec-2021	19:48	02-Dec-2021	21:33	105	0.000495	INTERRUPTION DUE TO FAULT
17	02-Dec-2021	PARTS OF P-1,2,3, BLKS S. PURI & P-1 J/C. (JHANEWALA PARK, BALMIKI PARK,										

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
28	04-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	3471	Other Outage	Unplanned Outage	04-Dec-2021	10:01	04-Dec-2021	10:27	26	0.00014	INTERRUPTION DUE TO FAULT
29	04-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	696	Other Outage	Unplanned Outage	04-Dec-2021	10:01	04-Dec-2021	10:30	29	0.00004	INTERRUPTION DUE TO FAULT
30	05-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	241	Other Outage	Unplanned Outage	05-Dec-2021	09:24	05-Dec-2021	10:15	51	0.00007	INTERRUPTION DUE TO FAULT
31	05-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	976	Other Outage	Unplanned Outage	05-Dec-2021	10:34	05-Dec-2021	11:05	31	0.000129	INTERRUPTION DUE TO FAULT
32	05-Dec-2021	PARTS OF MUSKAN HOSPITAL MANGOLPURI	1005	Other Outage	Unplanned Outage	05-Dec-2021	19:49	05-Dec-2021	20:22	33	0.000138	INTERRUPTION DUE TO FAULT
33	06-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	58	Other Outage	Unplanned Outage	06-Dec-2021	09:26	06-Dec-2021	12:40	194	0.000108	FORCE MAJEURE DUE TO SABOTAGE
34	07-Dec-2021	PARTS OF MANGOL PURI MARKET MANGOLPURI	388	Other Outage	Unplanned Outage	07-Dec-2021	11:17	07-Dec-2021	12:02	45	0.000038	INTERRUPTION DUE TO FAULT
35	08-Dec-2021	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	525	Other Outage	Unplanned Outage	08-Dec-2021	08:00	08-Dec-2021	08:18	18	0.000015	INTERRUPTION DUE TO FAULT
36	08-Dec-2021	PART OF PKT-16 SEC-20 N-1 MANGOLPURI	15	Other Outage	Unplanned Outage	08-Dec-2021	14:54	08-Dec-2021	15:10	16	0.000009	INTERRUPTION DUE TO FAULT
37	09-Dec-2021	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BKLS. S. PURI ,HGI LABOUR CLY, W-48,49 JI CLUSTER, MANGOLPURI	1809	Other Outage	Unplanned Outage	09-Dec-2021	17:07	09-Dec-2021	18:45	98	0.000487	INTERRUPTION DUE TO FAULT
38	10-Dec-2021	PARTS OF E-1,2,3,4,5 BKLS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, B.LK S. PURI PARTIALLY LOHA MKT. EAST FRIENDS ENCLAVE, MANGOLPURI	1699	Other Outage	Unplanned Outage	10-Dec-2021	03:07	10-Dec-2021	03:14	7	0.000066	INTERRUPTION DUE TO FAULT
39	10-Dec-2021	PARTS OF E-1,2,3,4,5 BKLS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, B.LK S. PURI PARTIALLY LOHA MKT. EAST FRIENDS ENCLAVE, MANGOLPURI	802	Other Outage	Unplanned Outage	10-Dec-2021	03:07	10-Dec-2021	03:39	32	0.000142	INTERRUPTION DUE TO FAULT
40	10-Dec-2021	PARTS OF L BLOCK WATER TANK, Q BLOCK, P&QBLOCK, R BLOCK, S BLOCK MANGOLPURI	1462	Other Outage	Unplanned Outage	10-Dec-2021	07:38	10-Dec-2021	07:51	13	0.000109	INTERRUPTION DUE TO FAULT
41	10-Dec-2021	PARTS OF F-1,2,3,4,5 BKLS. S. PURI ,GH BKLS S. PURI,RATAN VIHAR , KIRARI FURNITURE MKT. BALBER NAGAR, H-2,3 BKLS. S. PURI MANGOLPURI	1198	Other Outage	Unplanned Outage	10-Dec-2021	20:16	10-Dec-2021	21:42	86	0.000239	INTERRUPTION DUE TO FAULT
42	12-Dec-2021	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO.2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	2592	Other Outage	Unplanned Outage	12-Dec-2021	07:38	12-Dec-2021	07:58	20	0.000165	INTERRUPTION DUE TO FAULT
43	12-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	73	Other Outage	Unplanned Outage	12-Dec-2021	08:18	12-Dec-2021	10:07	109	0.000091	INTERRUPTION DUE TO FAULT
44	12-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	4178	Other Outage	Unplanned Outage	12-Dec-2021	11:30	12-Dec-2021	11:56	26	0.00003	INTERRUPTION DUE TO FAULT
45	12-Dec-2021	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	977	Other Outage	Unplanned Outage	12-Dec-2021	12:29	12-Dec-2021	13:27	58	0.000161	INTERRUPTION DUE TO FAULT
46	12-Dec-2021	PARTS OF MANGOL PURI MARKET MANGOLPURI	4672	Other Outage	Unplanned Outage	12-Dec-2021	22:06	12-Dec-2021	23:03	57	0.000733	INTERRUPTION DUE TO FAULT
47	12-Dec-2021	PARTS OF MANGOL PURI MARKET MANGOLPURI	388	Other Outage	Unplanned Outage	12-Dec-2021	22:35	12-Dec-2021	23:02	27	0.00009	INTERRUPTION DUE TO FAULT
48	13-Dec-2021	PARTS OF SULTANPURI P3 BLOCK MANGOLPURI	1959	Other Outage	Unplanned Outage	13-Dec-2021	09:06	13-Dec-2021	09:30	24	0.00001	INTERRUPTION DUE TO FAULT
49	13-Dec-2021	PART OF A-4 SEC-20 MANGOLPURI	14	Other Outage	Unplanned Outage	13-Dec-2021	13:32	13-Dec-2021	13:52	20	0.000006	INTERRUPTION DUE TO FAULT
50	14-Dec-2021	PARTS OF L BLOCK WATER TANK, Q BLOCK, P&QBLOCK, R BLOCK, S BLOCK MANGOLPURI	1045	Other Outage	Unplanned Outage	14-Dec-2021	10:13	14-Dec-2021	14:24	251	0.000697	FORCE MAJEURE DUE TO SABOTAGE
51	14-Dec-2021	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	1532	Other Outage	Unplanned Outage	14-Dec-2021	15:43	14-Dec-2021	16:04	21	0.000086	INTERRUPTION DUE TO FAULT
52	15-Dec-2021	PART OF HARIZEN BASTI MANGOLPURI	16	Other Outage	Unplanned Outage	15-Dec-2021	13:50	15-Dec-2021	14:50	60	0.000017	INTERRUPTION DUE TO FAULT
53	15-Dec-2021	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BKLS. S. PURI ,HGI LABOUR CLY, W-48,49 JI CLUSTER, MANGOLPURI	140	Other Outage	Unplanned Outage	15-Dec-2021	14:08	15-Dec-2021	14:50	42	0.000023	INTERRUPTION DUE TO FAULT
54	15-Dec-2021	PART OF T- BLK SULTAN PURI MANGOLPURI	4	Other Outage	Unplanned Outage	15-Dec-2021	16:25	15-Dec-2021	16:54	29	0.000008	INTERRUPTION DUE TO FAULT
55	15-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	3005	Other Outage	Unplanned Outage	15-Dec-2021	16:37	15-Dec-2021	17:10	33	0.00028	INTERRUPTION DUE TO FAULT
56	15-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	916	Other Outage	Unplanned Outage	15-Dec-2021	17:15	15-Dec-2021	18:31	76	0.00021	INTERRUPTION DUE TO FAULT
57	15-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	686	Other Outage	Unplanned Outage	15-Dec-2021	17:24	15-Dec-2021	17:43	19	0.000037	INTERRUPTION DUE TO FAULT
58	16-Dec-2021	PARTS OF KRISHAN VIHAR NO-1, BUDH VIHAR PH-1, SATSANG BHAWAN MANGOLPURI	677	Other Outage	Unplanned Outage	16-Dec-2021	08:11	16-Dec-2021	09:56	105	0.000321	INTERRUPTION DUE TO FAULT
59	16-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	44	Other Outage	Unplanned Outage	16-Dec-2021	14:35	16-Dec-2021	15:20	45	0.000025	INTERRUPTION DUE TO FAULT
60	16-Dec-2021	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN 2-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR, MANGOLPURI	63	Other Outage	Unplanned Outage	16-Dec-2021	16:01	16-Dec-2021	16:42	41	0.000023	INTERRUPTION DUE TO FAULT
61	17-Dec-2021	PART OF T-4 MANGOL PURI INDUSTRIAL AREA PH.-1 MANGOLPURI	5	Other Outage	Unplanned Outage	17-Dec-2021	10:17	17-Dec-2021	11:39	82	0.000023	INTERRUPTION DUE TO FAULT
62	18-Dec-2021	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	2971	Other Outage	Unplanned Outage	18-Dec-2021	01:04	18-Dec-2021	01:40	36	0.000377	INTERRUPTION DUE TO FAULT
63	19-Dec-2021	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN 2-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR, MANGOLPURI	22	Other Outage	Unplanned Outage	19-Dec-2021	12:54	19-Dec-2021	13:15	21	0.000012	INTERRUPTION DUE TO FAULT
64	19-Dec-2021	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	1535	Other Outage	Unplanned Outage	19-Dec-2021	15:29	19-Dec-2021	15:46	17	0.000074	INTERRUPTION DUE TO FAULT
65	20-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1593	Other Outage	Unplanned Outage	20-Dec-2021	08:44	20-Dec-2021	09:44	60	0.00025	INTERRUPTION DUE TO FAULT
66	20-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	949	Other Outage	Unplanned Outage	20-Dec-2021	08:45	20-Dec-2021	09:20	35	0.000049	INTERRUPTION DUE TO FAULT
67	20-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	758	Other Outage	Unplanned Outage	20-Dec-2021	08:45	20-Dec-2021	11:54	189	0.000263	FORCE MAJEURE DUE TO SABOTAGE
68	20-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	42	Other Outage	Unplanned Outage	20-Dec-2021	09:46	20-Dec-2021	10:26	40	0.000011	INTERRUPTION DUE TO FAULT
69	20-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	56	Other Outage	Unplanned Outage	20-Dec-2021	09:46	20-Dec-2021	11:53	127	0.000035	FORCE MAJEURE DUE TO SABOTAGE
70	20-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	231	Other Outage	Unplanned Outage	20-Dec-2021	10:19	20-Dec-2021	11:53	94	0.000052	INTERRUPTION DUE TO FAULT
71	21-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	421	Other Outage	Unplanned Outage	21-Dec-2021	13:37	21-Dec-2021	14:20	43	0.000024	INTERRUPTION DUE TO FAULT
72	22-Dec-2021	PART OF SULTANPURI P3 BLOCK MANGOLPURI	9	Other Outage	Unplanned Outage	22-Dec-2021	12:23	22-Dec-2021	13:16	53	0.000015	INTERRUPTION DUE TO FAULT
73	23-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	3408	Other Outage	Unplanned Outage	23-Dec-2021	08:23	23-Dec-2021	08:40	17	0.000335	INTERRUPTION DUE TO FAULT
74	23-Dec-2021	PART OF HARSHDEV PARK MANGOLPURI	12	Other Outage	Unplanned Outage	23-Dec-2021	11:50	23-Dec-2021	13:43	113	0.000063	INTERRUPTION DUE TO FAULT
75	23-Dec-2021	PARTS OF N-1 BLOCK MANGOLPURI	6555	Other Outage	Unplanned Outage	23-Dec-2021	12:13	23-Dec-2021	12:32	19	0.000354	INTERRUPTION DUE TO FAULT
76	23-Dec-2021	PARTS OF N-1 BLOCK MANGOLPURI	1950	Other Outage	Unplanned Outage	23-Dec-2021	12:13	23-Dec-2021	12:33	20	0.000154	INTERRUPTION DUE TO FAULT
77	23-Dec-2021	PART OF SULTANPURI P2 BLOCK MANGOLPURI	15	Other Outage	Unplanned Outage	23-Dec-2021	13:47	23-Dec-2021	16:31	164	0.000046	FORCE MAJEURE DUE TO SABOTAGE
78	23-Dec-2021	PARTS OF PKT-11 SEC-22 MANGOLPURI	799	Other Outage	Unplanned Outage	23-Dec-2021	15:03	23-Dec-2021	15:40	37	0.000205	INTERRUPTION DUE TO FAULT
79	23-Dec-2021	PARTS OF E-1,2,3,4,5 BKLS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, B.LK S. PURI PARTIALLY LOHA MKT. EAST FRIENDS ENCLAVE, MANGOLPURI	22	Other Outage	Unplanned Outage	23-Dec-2021	15:36	23-Dec-2021	16:53	77	0.000043	INTERRUPTION DUE TO FAULT
80	26-Dec-2021	PARTS OF PKT-11 SEC-22 MANGOLPURI	965	Other Outage	Unplanned Outage	26-Dec-2021	12:01	26-Dec-2021	12:18	17	0.000139	INTERRUPTION DUE TO FAULT
81	26-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	68	Other Outage	Unplanned Outage	26-Dec-2021	17:24	27-Dec-2021	00:59	455	0.000253	FORCE MAJEURE DUE TO RAINSTORM
82	26-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	1046	Other Outage	Unplanned Outage	26-Dec-2021	17:34	26-Dec-2021	21:09	215	0.000596	FORCE MAJEURE DUE TO RAINSTORM
83	26-Dec-2021	PARTS OF K BLOCK, K-2 BLOCK, K-2 BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI MANGOLPURI	4853	Other Outage	Unplanned Outage	26-Dec-2021	17:53	26-Dec-2021	18:52	59	0.000917	INTERRUPTION DUE TO FAULT
84	26-Dec-2021	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	1538	Other Outage	Unplanned Outage	26-Dec-2021	17:54	26-Dec-2021	18:43	49	0.000285	INTERRUPTION DUE TO FAULT
85	26-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1161	Other Outage	Unplanned Outage	26-Dec-2021	17:54	26-Dec-2021	19:55	121	0.000334	FORCE MAJEURE DUE TO RAINSTORM
86	26-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	1339	Other Outage	Unplanned Outage	26-Dec-2021	17:54	26-Dec-2021	18:40	46	0.000189	INTERRUPTION DUE TO FAULT
87	26-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	2362	Other Outage	Unplanned Outage	26-Dec-2021	17:54	26-Dec-2021	19:16	82	0.000571	INTERRUPTION DUE TO FAULT
88	26-Dec-2021	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL, PKT-8 MANGOLPURI	3257	Other Outage	Unplanned Outage	26-Dec-2021	17:56	26-Dec-2021	20:08	132	0.001274	FORCE MAJEURE DUE TO RAINSTORM
89	26-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1864	Other Outage	Unplanned Outage	26-Dec-2021	18:01	26-Dec-2021	19:53	112	0.000559	INTERRUPTION DUE TO FAULT
90	26-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1706	Other Outage	Unplanned Outage	26-Dec-2021	18:01	26-Dec-2021	20:46	165	0.000824	FORCE MAJEURE DUE TO RAINSTORM
91	26-Dec-2021	PARTS OF BUDH VIHAR BLOCK A,B,E,J MANGOLPURI	2025	Other Outage	Unplanned Outage	26-Dec-2021	18:02	26-Dec-2021	21:03	181	0.001257	FORCE MAJEURE DUE TO RAINSTORM
92	26-Dec-2021	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1, MANGOLPURI	923	Other Outage	Unplanned Outage	26-Dec-2021	18:04	26-Dec-2021	22:16	252	0.000699	FORCE MAJEURE DUE TO RAINSTORM
93	26-Dec-2021	PARTS OF MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY), B LOCK MIA MANGOLPURI	101	Other Outage	Unplanned Outage	26-Dec-2021	18:29	26-Dec-2021	19:48	79	0.000241	INTERRUPTION DUE TO FAULT
94	26-Dec-2021	PARTS OF E-1,2,3,4,5 BKLS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA,										

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unreserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
98	26-Dec-2021	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL MANGOLPURI	376	Other Outage	Unplanned Outage	26-Dec-2021	19:24	26-Dec-2021	21:08	104	0.000116	INTERRUPTION DUE TO FAULT
99	26-Dec-2021	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL MANGOLPURI	2965	Other Outage	Unplanned Outage	26-Dec-2021	19:25	26-Dec-2021	20:34	69	0.000575	INTERRUPTION DUE TO FAULT
100	26-Dec-2021	PARTS OF SULTAN PUR MAZRA VILL. , U- BLK & T- BLK M. PURI MANGOLPURI	515	Other Outage	Unplanned Outage	26-Dec-2021	19:47	26-Dec-2021	20:30	43	0.000177	INTERRUPTION DUE TO FAULT
101	26-Dec-2021	PARTS OF SULTAN PUR MAZRA VILL. , U- BLK & T- BLK M. PURI MANGOLPURI	138	Other Outage	Unplanned Outage	26-Dec-2021	19:47	26-Dec-2021	21:13	86	0.000047	INTERRUPTION DUE TO FAULT
102	26-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	2362	Other Outage	Unplanned Outage	26-Dec-2021	19:49	26-Dec-2021	20:56	67	0.000463	INTERRUPTION DUE TO FAULT
103	26-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	761	Other Outage	Unplanned Outage	26-Dec-2021	19:59	26-Dec-2021	22:26	147	0.000327	FORCE MAJEURE DUE TO RAIN/STORM
104	26-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	4185	Other Outage	Unplanned Outage	26-Dec-2021	20:07	26-Dec-2021	20:25	18	0.000229	INTERRUPTION DUE TO FAULT
105	26-Dec-2021	PARTS OF SULTAN PUR MAZRA MANGOLPURI	2022	Other Outage	Unplanned Outage	26-Dec-2021	20:38	26-Dec-2021	20:47	9	0.000053	INTERRUPTION DUE TO FAULT
106	26-Dec-2021	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	31	Other Outage	Unplanned Outage	26-Dec-2021	20:50	26-Dec-2021	21:35	45	0.000025	INTERRUPTION DUE TO FAULT
107	26-Dec-2021	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	1507	Other Outage	Unplanned Outage	26-Dec-2021	20:50	26-Dec-2021	21:35	45	0.000189	INTERRUPTION DUE TO FAULT
108	26-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	109	Other Outage	Unplanned Outage	26-Dec-2021	21:38	26-Dec-2021	23:43	125	0.000069	FORCE MAJEURE DUE TO RAIN/STORM
109	27-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	43	Other Outage	Unplanned Outage	27-Dec-2021	07:24	27-Dec-2021	08:14	50	0.000014	INTERRUPTION DUE TO FAULT
110	27-Dec-2021	PART OF T-5 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	17	Other Outage	Unplanned Outage	27-Dec-2021	09:03	27-Dec-2021	14:50	347	0.000675	FORCE MAJEURE DUE TO SABOTAGE
111	27-Dec-2021	PARTS OF T-1, T-2 & T-5 MANGOL PURI INDUSTRIAL AREA PH- 1 MANGOLPURI	49	Other Outage	Unplanned Outage	27-Dec-2021	09:12	27-Dec-2021	14:47	335	0.000465	FORCE MAJEURE DUE TO SABOTAGE
112	27-Dec-2021	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-538 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR, MANGOLPURI	38	Other Outage	Unplanned Outage	27-Dec-2021	11:52	27-Dec-2021	13:10	78	0.000108	INTERRUPTION DUE TO FAULT
113	27-Dec-2021	PART OF T-5 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	3	Other Outage	Unplanned Outage	27-Dec-2021	15:07	27-Dec-2021	16:00	53	0.000015	INTERRUPTION DUE TO FAULT
114	27-Dec-2021	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	1971	Other Outage	Unplanned Outage	27-Dec-2021	15:30	27-Dec-2021	16:14	44	0.000245	INTERRUPTION DUE TO FAULT
115	27-Dec-2021	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	261	Other Outage	Unplanned Outage	27-Dec-2021	15:30	27-Dec-2021	16:40	70	0.000097	INTERRUPTION DUE TO FAULT
116	27-Dec-2021	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	399	Other Outage	Unplanned Outage	27-Dec-2021	16:18	27-Dec-2021	16:40	22	0.000031	INTERRUPTION DUE TO FAULT
117	27-Dec-2021	PARTS OF PKT-09 SEC-21, MANGOLPURI	536	Other Outage	Unplanned Outage	27-Dec-2021	18:39	27-Dec-2021	19:04	25	0.000181	INTERRUPTION DUE TO FAULT
118	27-Dec-2021	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL, PKT-8 MANGOLPURI	941	Other Outage	Unplanned Outage	27-Dec-2021	19:35	27-Dec-2021	20:18	43	0.000012	INTERRUPTION DUE TO FAULT
119	27-Dec-2021	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	91	Other Outage	Unplanned Outage	27-Dec-2021	21:11	27-Dec-2021	22:13	62	0.000086	INTERRUPTION DUE TO FAULT
120	28-Dec-2021	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL, PKT-8 MANGOLPURI	2641	Other Outage	Unplanned Outage	28-Dec-2021	00:06	28-Dec-2021	00:34	28	0.000389	INTERRUPTION DUE TO FAULT
121	28-Dec-2021	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL, PKT-8 MANGOLPURI	220	Other Outage	Unplanned Outage	28-Dec-2021	00:06	28-Dec-2021	00:34	28	0.000078	INTERRUPTION DUE TO FAULT
122	28-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	23	Other Outage	Unplanned Outage	28-Dec-2021	16:26	28-Dec-2021	17:04	38	0.000052	INTERRUPTION DUE TO FAULT
123	28-Dec-2021	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER, MANGOLPURI	1358	Other Outage	Unplanned Outage	28-Dec-2021	17:02	28-Dec-2021	17:20	18	0.000059	INTERRUPTION DUE TO FAULT
124	28-Dec-2021	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER, MANGOLPURI	329	Other Outage	Unplanned Outage	28-Dec-2021	17:02	28-Dec-2021	17:24	22	0.00003	INTERRUPTION DUE TO FAULT
125	28-Dec-2021	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER, MANGOLPURI	2712	Other Outage	Unplanned Outage	28-Dec-2021	17:02	28-Dec-2021	17:54	52	0.000359	INTERRUPTION DUE TO FAULT
126	28-Dec-2021	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER, MANGOLPURI	1796	Other Outage	Unplanned Outage	28-Dec-2021	17:02	28-Dec-2021	18:33	91	0.000378	INTERRUPTION DUE TO FAULT
127	29-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	1054	Other Outage	Unplanned Outage	29-Dec-2021	07:56	29-Dec-2021	08:28	32	0.000089	INTERRUPTION DUE TO FAULT
128	29-Dec-2021	PART OF A-4 SEC-20 MANGOLPURI	9	Other Outage	Unplanned Outage	29-Dec-2021	08:02	29-Dec-2021	11:57	235	0.000131	FORCE MAJEURE DUE TO SABOTAGE
129	29-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1708	Other Outage	Unplanned Outage	29-Dec-2021	09:35	29-Dec-2021	10:21	46	0.000256	INTERRUPTION DUE TO FAULT
130	29-Dec-2021	PART OF HARSHDEV PARK MANGOLPURI	12	Other Outage	Unplanned Outage	29-Dec-2021	09:35	29-Dec-2021	11:16	101	0.00014	INTERRUPTION DUE TO FAULT
131	29-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	466	Other Outage	Unplanned Outage	29-Dec-2021	10:27	29-Dec-2021	11:09	42	0.000058	INTERRUPTION DUE TO FAULT
132	29-Dec-2021	PARTS OF MANGOL PURI MARKET MANGOLPURI	5281	Other Outage	Unplanned Outage	29-Dec-2021	11:28	29-Dec-2021	12:03	35	0.000763	INTERRUPTION DUE TO FAULT
133	29-Dec-2021	PARTS OF MANGOL PURI MARKET MANGOLPURI	1113	Other Outage	Unplanned Outage	29-Dec-2021	11:28	29-Dec-2021	12:05	37	0.000222	INTERRUPTION DUE TO FAULT
134	29-Dec-2021	PARTS OF BEGAMPUR BUS STAND MANGOLPURI	373	Other Outage	Unplanned Outage	29-Dec-2021	12:54	29-Dec-2021	15:33	159	0.000177	FORCE MAJEURE DUE TO SABOTAGE
135	30-Dec-2021	PART OF T-5 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	3	Other Outage	Unplanned Outage	30-Dec-2021	16:50	30-Dec-2021	17:46	56	0.000016	SYSTEM SCHEDULED OUTAGE
136	31-Dec-2021	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL, PKT-8 MANGOLPURI	398	Other Outage	Unplanned Outage	31-Dec-2021	01:09	31-Dec-2021	01:37	28	0.000038	INTERRUPTION DUE TO FAULT
137	31-Dec-2021	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL, PKT-8 MANGOLPURI	2862	Other Outage	Unplanned Outage	31-Dec-2021	01:09	31-Dec-2021	02:32	83	0.000527	INTERRUPTION DUE TO FAULT
138	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	4729	Other Outage	Unplanned Outage	31-Dec-2021	09:02	31-Dec-2021	09:40	38	0.000828	INTERRUPTION DUE TO FAULT
139	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	2318	Other Outage	Unplanned Outage	31-Dec-2021	09:50	31-Dec-2021	10:03	13	0.000083	INTERRUPTION DUE TO FAULT
140	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	1594	Other Outage	Unplanned Outage	31-Dec-2021	09:50	31-Dec-2021	10:25	35	0.000146	INTERRUPTION DUE TO FAULT
141	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	453	Other Outage	Unplanned Outage	31-Dec-2021	09:50	31-Dec-2021	11:59	129	0.000215	FORCE MAJEURE DUE TO SABOTAGE
142	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	2318	Other Outage	Unplanned Outage	31-Dec-2021	11:59	31-Dec-2021	12:39	40	0.000251	INTERRUPTION DUE TO FAULT
143	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	453	Other Outage	Unplanned Outage	31-Dec-2021	11:59	31-Dec-2021	13:14	75	0.000083	INTERRUPTION DUE TO FAULT
144	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	949	Other Outage	Unplanned Outage	31-Dec-2021	13:06	31-Dec-2021	13:33	27	0.000075	INTERRUPTION DUE TO FAULT
145	31-Dec-2021	PARTS OF KRISHNA VIHAR NO.1 & 2, O & P BLOCK, HARSHDEV PARK MANGOLPURI	391	Other Outage	Unplanned Outage	31-Dec-2021	13:06	31-Dec-2021	14:09	63	0.000053	INTERRUPTION DUE TO FAULT
146	01-Dec-2021	PART OF T-4 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	4	400 kVA	Unplanned Outage	01-Dec-2021	12:08	01-Dec-2021	12:44	36	0.00001	SYSTEM SCHEDULED OUTAGE
147	02-Dec-2021	PARTS OF A-4 SEC-20 MANGOLPURI	173	Other Outage	Planned Outage	02-Dec-2021	11:44	02-Dec-2021	12:40	56	0.00003	PLANNED OUTAGE
148	03-Dec-2021	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 MANGOLPURI	253	Other Outage	Planned Outage	03-Dec-2021	10:55	03-Dec-2021	13:55	180	0.00010	PLANNED OUTAGE
149	03-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	114	Other Outage	Planned Outage	03-Dec-2021	10:57	03-Dec-2021	13:00	123	0.00007	PLANNED OUTAGE
150	04-Dec-2021	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, U-BLOCK, DJB KIRARI, DHURVA ENCL MANGOLPURI	167	Other Outage	Planned Outage	04-Dec-2021	10:37	04-Dec-2021	15:22	285	0.00016	PLANNED OUTAGE
151	04-Dec-2021	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	245	Other Outage	Planned Outage	04-Dec-2021	11:11	04-Dec-2021	13:04	113	0.00009	PLANNED OUTAGE
152	04-Dec-2021	PARTS OF BUDH VIHAR PH.1 NO.15, BUDH VIHAR PH.2 NO.4, 5, 6, 3 MANGOLPURI	474	630 kVA	Planned Outage	04-Dec-2021	14:02	04-Dec-2021	15:50	108	0.00033	PLANNED OUTAGE
153	07-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	24	160 kVA	Planned Outage	07-Dec-2021	10:58	07-Dec-2021	13:05	127	0.00007	PLANNED OUTAGE
154	07-Dec-2021	PART OF POOTHKALAN NO.1 MANGOLPURI	3	100 kVA	Unplanned Outage	07-Dec-2021	11:58	07-Dec-2021	12:16	18	0.00001	SYSTEM SCHEDULED OUTAGE
155	07-Dec-2021	PARTS OF PKT-16 SEC-20 MANGOLPURI	354	Other Outage	Planned Outage	07-Dec-2021	14:17	07-Dec-2021	15:02	45	0.00004	PLANNED OUTAGE
156	08-Dec-2021	PART OF A-4 SEC-20 MANGOLPURI	3	160 kVA	Unplanned Outage	08-Dec-2021	11:25	08-Dec-2021	11:53	28	0.00001	SYSTEM SCHEDULED OUTAGE
157	10-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	1041	Other Outage	Planned Outage	10-Dec-2021	10:55	10-Dec-2021	13:38	163	0.00050	PLANNED OUTAGE
158	10-Dec-2021	PARTS OF T- BLK - M. PURI PARTIALY-B-1,2,3,4,5,A-1,2,3,4,5 BLKS.S. PURI MANGOLPURI	469	400 kVA	Planned Outage	10-Dec-2021	10:56	10-Dec-2021	12:32	96	0.00013	PLANNED OUTAGE
159	10-Dec-2021	PARTS OF T- BLK - M. PURI PARTIALY-B-1,2,3,4,5,A-1,2,3,4,5 BLKS.S. PURI MANGOLPURI	397	Other Outage	Planned Outage	10-Dec-2021	11:14	10-Dec-2021	13:31	137	0.00023	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unscheduled (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
160	11-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	273	Other Outage	Planned Outage	11-Dec-2021	10:27	11-Dec-2021	11:09	42	0.00004	PLANNED OUTAGE
161	11-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	Other Outage	63 kVA	Planned Outage	11-Dec-2021	10:57	11-Dec-2021	13:05	128	0.00028	PLANNED OUTAGE
162	11-Dec-2021	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5, MANDIR WALI GALI MANGOLPURI	421	Other Outage	Planned Outage	11-Dec-2021	11:04	11-Dec-2021	13:41	157	0.00035	PLANNED OUTAGE
163	11-Dec-2021	PARTS OF C-6,7,8,9, BLKS. S. PURI, DSDIC SHED C-8 BLK S. PURI MANGOLPURI	862	400 kVA	Planned Outage	11-Dec-2021	14:07	11-Dec-2021	16:24	137	0.00034	PLANNED OUTAGE
164	11-Dec-2021	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 MANGOLPURI	153	400 kVA	Planned Outage	11-Dec-2021	14:37	11-Dec-2021	15:37	60	0.00003	PLANNED OUTAGE
165	11-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	273	Other Outage	Planned Outage	11-Dec-2021	16:24	11-Dec-2021	16:57	33	0.00003	PLANNED OUTAGE
166	13-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	278	Other Outage	Planned Outage	13-Dec-2021	10:45	13-Dec-2021	11:52	67	0.00007	PLANNED OUTAGE
167	13-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	142	Other Outage	Planned Outage	13-Dec-2021	11:58	13-Dec-2021	17:40	342	0.00019	PLANNED OUTAGE
168	13-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	125	Other Outage	Planned Outage	13-Dec-2021	16:04	13-Dec-2021	17:40	96	0.00005	PLANNED OUTAGE
169	13-Dec-2021	PART OF PKT-09 SEC-21 MANGOLPURI	11	Other Outage	Planned Outage	13-Dec-2021	16:17	13-Dec-2021	17:40	83	0.00002	PLANNED OUTAGE
170	15-Dec-2021	PARTS OF POOTHKALAN NO.7, 12, D-4 SEC-20 MANGOLPURI	22	630 kVA	Planned Outage	15-Dec-2021	14:28	15-Dec-2021	16:07	99	0.00005	PLANNED OUTAGE
171	16-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	1058	Other Outage	Planned Outage	16-Dec-2021	10:37	16-Dec-2021	11:28	51	0.00013	PLANNED OUTAGE
172	16-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	171	Other Outage	Planned Outage	16-Dec-2021	11:31	16-Dec-2021	16:38	307	0.00017	PLANNED OUTAGE
173	16-Dec-2021	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5, MANDIR WALI GALI MANGOLPURI	872	Other Outage	Planned Outage	16-Dec-2021	15:54	16-Dec-2021	16:38	44	0.00010	PLANNED OUTAGE
174	17-Dec-2021	PARTS OF T-BLK - M. PURI PARTIALLY, B-1,2,3,4,5, A-1,2,3,4,5 BLKS. S. PURI MANGOLPURI	1149	990 kVA	Planned Outage	17-Dec-2021	11:04	17-Dec-2021	13:25	141	0.00047	PLANNED OUTAGE
175	17-Dec-2021	PART OF POOTHKALAN NO.1 MANGOLPURI	7	25 kVA	Unplanned Outage	17-Dec-2021	15:03	17-Dec-2021	16:08	65	0.00002	SYSTEM SCHEDULE OUTAGE
176	18-Dec-2021	PARTS OF C-6,7,8,9, BLKS. S. PURI, DSDIC SHED C-8 BLK S. PURI MANGOLPURI	1061	990 kVA	Planned Outage	18-Dec-2021	11:00	18-Dec-2021	13:17	137	0.00042	PLANNED OUTAGE
177	18-Dec-2021	PARTS OF F-1,2,3,4,5 BLKS. S. PURI, GH BLK S. PURI, RATAN VIHAR, KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI MANGOLPURI	1372	Other Outage	Planned Outage	18-Dec-2021	11:06	18-Dec-2021	13:44	158	0.00132	PLANNED OUTAGE
178	18-Dec-2021	PARTS OF MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY), B LOCK MIA MANGOLPURI	32	Other Outage	Planned Outage	18-Dec-2021	11:18	18-Dec-2021	13:26	128	0.00018	PLANNED OUTAGE
179	20-Dec-2021	PARTS OF C-6,7,8,9, BLKS. S. PURI, DSDIC SHED C-8 BLK S. PURI MANGOLPURI	820	990 kVA	Planned Outage	20-Dec-2021	11:01	20-Dec-2021	13:23	142	0.00028	PLANNED OUTAGE
180	23-Dec-2021	PARTS OF P-1,2,3, BLKS. S. PURI & P-1 J.C. (JHANEWALA PARK, BALMIKI PARK. MANGOLPURI	679	Other Outage	Planned Outage	23-Dec-2021	11:14	23-Dec-2021	13:14	120	0.00023	PLANNED OUTAGE
181	24-Dec-2021	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	269	630 kVA	Planned Outage	24-Dec-2021	10:38	24-Dec-2021	11:59	81	0.00023	PLANNED OUTAGE
182	24-Dec-2021	PARTS OF PKT-09 SEC-21 MANGOLPURI	70	630 kVA	Planned Outage	24-Dec-2021	13:30	24-Dec-2021	14:48	78	0.00004	PLANNED OUTAGE
183	26-Dec-2021	PARTS OF F-1, T-2 & T-5 MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	75	Other Outage	Planned Outage	26-Dec-2021	11:02	26-Dec-2021	15:30	268	0.00015	PLANNED OUTAGE
184	27-Dec-2021	PARTS OF E-1,2,3,4,5 BLKS. S. PURI, DSDIC SHED SHANI BAZAR ROAD, RAJ PARK, BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY, LOHA MKT. EAST FRIENDS ENCLAVE, MANGOLPURI	708	Other Outage	Planned Outage	27-Dec-2021	10:55	27-Dec-2021	13:18	143	0.00079	PLANNED OUTAGE
185	27-Dec-2021	PART OF 55-7 BUDHVHAR PH-1 MANGOLPURI	1	Other Outage	Planned Outage	27-Dec-2021	11:05	27-Dec-2021	16:49	344	0.00010	PLANNED OUTAGE
186	27-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	1032	Other Outage	Planned Outage	27-Dec-2021	11:20	27-Dec-2021	12:40	80	0.00022	PLANNED OUTAGE
187	27-Dec-2021	PARTS OF POOTHKALAN MARKET MANGOLPURI	190	630 kVA	Planned Outage	27-Dec-2021	13:55	27-Dec-2021	14:46	51	0.00001	PLANNED OUTAGE
188	28-Dec-2021	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	568	Other Outage	Planned Outage	28-Dec-2021	10:58	28-Dec-2021	13:40	162	0.00113	PLANNED OUTAGE
189	28-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	220	630 kVA	Planned Outage	28-Dec-2021	11:06	28-Dec-2021	13:15	129	0.00007	PLANNED OUTAGE
190	29-Dec-2021	PARTS OF F-1,2,3,4,5 BLKS. S. PURI, DSDIC SHED SHANI BAZAR ROAD, RAJ PARK, BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY, LOHA MKT. EAST FRIENDS ENCLAVE, MANGOLPURI	519	Other Outage	Planned Outage	29-Dec-2021	11:04	29-Dec-2021	13:44	160	0.00031	PLANNED OUTAGE
191	29-Dec-2021	PARTS OF RMU OUTDOOR JAL BOARD PUMP HOUSE, MANGOLPURI	28	630 kVA	Planned Outage	29-Dec-2021	13:44	29-Dec-2021	15:10	86	0.00002	PLANNED OUTAGE
192	29-Dec-2021	PART OF PKT-16 SEC-20 NO-1 MANGOLPURI	11	160 kVA	Unplanned Outage	29-Dec-2021	14:30	29-Dec-2021	14:51	21	0.00001	SYSTEM SCHEDULE OUTAGE
193	30-Dec-2021	PART OF PKT-16 SEC-20 NO-1 MANGOLPURI	17	160 kVA	Unplanned Outage	30-Dec-2021	15:33	30-Dec-2021	16:03	30	0.00001	SYSTEM SCHEDULE OUTAGE
MODEL TOWN												
1	01-Dec-2021	PART OF JAHANGIRPURI MKT MODEL TOWN	14	Other Outage	Unplanned Outage	01-Dec-2021	11:48	01-Dec-2021	12:46	58	0.00016	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PART OF BHALASWA VILLAGE MODEL TOWN	6	Other Outage	Unplanned Outage	01-Dec-2021	14:02	01-Dec-2021	14:14	12	0.00003	INTERRUPTION DUE TO FAULT
3	01-Dec-2021	PART OF JAHANGIRPURI MKT MODEL TOWN	16	Other Outage	Unplanned Outage	01-Dec-2021	14:22	01-Dec-2021	17:24	182	0.00051	FORCE MAJEURE DUE TO SABOTAGE
4	02-Dec-2021	PARTS OF C BLK, CD PARK JJ CLUSTER, CD PARK JAL BOARD & C BLK DSDIC MODEL TOWN	225	Other Outage	Unplanned Outage	02-Dec-2021	10:59	02-Dec-2021	13:03	124	0.00103	FORCE MAJEURE DUE TO SABOTAGE
5	02-Dec-2021	PARTS OF 336 SFS FLAT NO-2, 336 SFS FLAT NO-1, 336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	271	Other Outage	Unplanned Outage	02-Dec-2021	15:31	02-Dec-2021	16:15	44	0.00049	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARG, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	457	Other Outage	Unplanned Outage	02-Dec-2021	16:03	02-Dec-2021	18:52	169	0.000329	FORCE MAJEURE DUE TO SABOTAGE
7	02-Dec-2021	PARTS OF BIR HOSPITAL, BIR HOSPITAL RESIDENCE, MIG FLATS (JAHANGIR PURI), ITI (JAHANGIR PURI), POLICE STATION (JAHANGIR PURI), POLICE RESIDENTIAL COMPLEX, FIRE STATION (JAHANGIR PURI), EE BLOCK, PUMPING STATION (JAHANGIR PURI), DIS SEWAGE PUMPING STATION & PRAYAS, ITO PLANT MODEL TOWN	277	Other Outage	Unplanned Outage	02-Dec-2021	21:31	02-Dec-2021	23:05	94	0.00078	INTERRUPTION DUE TO FAULT
8	04-Dec-2021	PART OF BHALASWA VILLAGE MODEL TOWN	13	Other Outage	Unplanned Outage	04-Dec-2021	08:30	04-Dec-2021	13:30	300	0.00167	FORCE MAJEURE DUE TO SABOTAGE
9	04-Dec-2021	PART OF BHALASWA VILLAGE MODEL TOWN	12	Other Outage	Unplanned Outage	04-Dec-2021	08:45	04-Dec-2021	13:40	295	0.00164	FORCE MAJEURE DUE TO SABOTAGE
10	04-Dec-2021	PART OF A-BLK JINDAL WALA MODEL TOWN	7	Other Outage	Unplanned Outage	04-Dec-2021	10:39	04-Dec-2021	14:37	238	0.001198	FORCE MAJEURE DUE TO SABOTAGE
11	04-Dec-2021	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL MODEL TOWN	288	Other Outage	Unplanned Outage	04-Dec-2021	12:32	04-Dec-2021	16:20	228	0.00038	FORCE MAJEURE DUE TO SABOTAGE
12	04-Dec-2021	PART OF A BLOCK DDA SLUM FLATS MODEL TOWN	16	Other Outage	Unplanned Outage	04-Dec-2021	15:14	04-Dec-2021	15:29	15	0.00008	INTERRUPTION DUE TO FAULT
13	04-Dec-2021	PART OF E BLOCK JAHANGIRPURI MODEL TOWN	14	Other Outage	Unplanned Outage	04-Dec-2021	15:50	04-Dec-2021	18:06	136	0.00075	FORCE MAJEURE DUE TO SABOTAGE
14	05-Dec-2021	PART OF EE BLOCK PUMPING STATION MODEL TOWN	10	Other Outage	Unplanned Outage	05-Dec-2021	10:30	05-Dec-2021	11:15	45	0.00038	INTERRUPTION DUE TO FAULT
15	06-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	35	Other Outage	Unplanned Outage	06-Dec-2021	11:25	06-Dec-2021	11:39	14	0.00004	INTERRUPTION DUE TO FAULT
16	06-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	347	Other Outage	Unplanned Outage	06-Dec-2021	12:05	06-Dec-2021	12:51	46	0.00051	INTERRUPTION DUE TO FAULT
17	06-Dec-2021	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	1780	Other Outage	Unplanned Outage	06-Dec-2021	15:05	06-Dec-2021	15:21	16	0.000076	SYSTEM SCHEDULE OUTAGE
18	06-Dec-2021	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	2819	Other Outage	Unplanned Outage	06-Dec-2021	16:49	06-Dec-2021	16:57	8	0.000085	INTERRUPTION DUE TO FAULT
19	06-Dec-2021	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTR MODEL TOWN	481	Other Outage	Unplanned Outage	06-Dec-2021	21:41	06-Dec-2021	22:08	27	0.00009	INTERRUPTION DUE TO FAULT
20	07-Dec-2021	PARTS OF MAHINDRA PARK & SANJAY NAGAR MODEL TOWN	21	Other Outage	Unplanned Outage	07-Dec-2021	10:01	07-Dec-2021	10:31	30	0.00008	INTERRUPTION DUE TO FAULT
21	07-Dec-2021	PARTS OF 336 SFS FLAT NO-2, 336 SFS FLAT NO-1, 336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	271	Other Outage	Unplanned Outage	07-Dec-2021	11:25	07-Dec-2021	14:49	204	0.000283	FORCE MAJEURE DUE TO SABOTAGE
22	08-Dec-2021	PARTS OF NEAR B-3 MARKET, A-BLK JINDAL WALA MODEL TOWN	309	Other Outage	Unplanned Outage	08-Dec-2021	10:11	08-Dec-2021	16:36	385	0.000535	FORCE MAJEURE DUE TO SABOTAGE
23	08-Dec-2021	PARTS OF ARIYABHATT POLYTECHNIC, PART OF B - BLOCK INDUSTRIAL AREA GTA MODEL TOWN	32	Other Outage	Unplanned Outage	08-Dec-2021	17:03	08-Dec-2021	17:12	9	0.000003	INTERRUPTION DUE TO FAULT
24	08-Dec-2021	PART OF A BLOCK DDA SLUM FLATS MODEL TOWN	16	Other Outage	Unplanned Outage	08-Dec-2021	19:22	08-Dec-2021	20:05	43	0.00012	INTERRUPTION DUE TO FAULT
25	08-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARG, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	1962	Other Outage	Unplanned Outage	08-Dec-2021	20:28	08-Dec-2021	21:05	37	0.000196	INTERRUPTION DUE TO FAULT
26	08-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARG, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	339	Other Outage	Unplanned Outage	08-Dec-2021	20:28	09-Dec-2021	01:20	292	0.000243	FORCE MAJEURE DUE TO SABOTAGE
27	09-Dec-2021	PARTS OF F BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	29	Other Outage	Unplanned Outage	09-Dec-2021	19:33	09-Dec-2021	19:47	14	0.000008	INTERRUPTION DUE TO FAULT
28	10-Dec-2021	PARTS OF MAHINDRA PARK & SANJAY NAGAR MODEL TOWN	23	Other Outage	Unplanned Outage	10-Dec-2021	18:07	10-Dec-2021	18:32	25	0.000007	INTERRUPTION DUE TO FAULT
29	12-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	284	Other Outage	Unplanned Outage	12-Dec-2021	10:43	12-Dec-2021	11:40	57	0.000048	INTERRUPTION DUE TO FAULT
30	12-Dec-2021	PARTS OF A BLOCK DDA SLUM FLATS, PUNIABI CAMP, PART OF I & J BLK., PART OF A BLK MODEL TOWN	2056	Other Outage	Unplanned Outage	12-Dec-2021	12:35	12-Dec-2021	14:10	95	0.000608	INTERRUPTION DUE TO FAULT
31	13-Dec-2021	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	413	Other Outage	Unplanned Outage	13-Dec-2021	07:05	13-Dec-2021	07:30	25	0.000035	INTERRUPTION DUE TO FAULT
32	14-Dec-2021	PARTS OF NEAR B-3 MARKET, A-BLK JINDAL WALA MODEL TOWN	36	Other Outage	Unplanned Outage	14-Dec-2021	14:16	14-Dec-2021	14:36	20	0.000006	INTERRUPTION DUE TO FAULT
33	14-Dec-2021	PART OF MCD QUARTER JAHANGIR PURI MODEL TOWN	14	Other Outage	Unplanned Outage	14-Dec-2021	15:29	14-Dec-2021	16:00	31	0.000009	INTERRUPTION DUE TO FAULT
34	14-Dec-2021	PARTS OF NEW TAGOR PAR, DHEERPUR KIOSK, NEW BHAI PERMA PERMANAND, 207 TAGOR PARK, BP COLONY MODEL TOWN	905	Other Outage	Unplanned Outage	14-Dec-2021	18:03	14-Dec-2021	18:40	37	0.000102	INTERRUPTION DUE TO FAULT
35	15-Dec-2021	PARTS OF B										

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unsed (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
40	17-Dec-2021	PARTS OF MAJLUS PARK GALI NO 13 MODEL TOWN	1054	Other Outage	Unplanned Outage	17-Dec-2021	07:41	17-Dec-2021	08:28	47	0.000103	INTERRUPTION DUE TO FAULT
41	17-Dec-2021	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC MODEL TOWN	73	Other Outage	Unplanned Outage	17-Dec-2021	10:09	17-Dec-2021	10:32	23	0.000006	INTERRUPTION DUE TO FAULT
42	17-Dec-2021	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA MODEL TOWN	35	Other Outage	Unplanned Outage	17-Dec-2021	18:09	17-Dec-2021	18:21	12	0.000027	INTERRUPTION DUE TO FAULT
43	17-Dec-2021	PARTS OF G BLOCK & G BLOCK JJ CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	156	Other Outage	Unplanned Outage	17-Dec-2021	19:39	17-Dec-2021	20:29	50	0.000167	INTERRUPTION DUE TO FAULT
44	18-Dec-2021	PARTS OF DHEERPUR VILLAGE, PART OF NIRANKARI COLONY, SWARG ASHRAM, PART OF WEST PARMANAD COLONY, PART OF WEST MUKHERJEE NAGAR, AIR TRAINING CENTER, ROSARY SCHOOL , PRADHAN MARKET, ROSARY SCHOOLROAD & 30 OTRS MODEL TOWN	519	Other Outage	Unplanned Outage	18-Dec-2021	13:02	18-Dec-2021	14:02	60	0.000083	INTERRUPTION DUE TO FAULT
45	18-Dec-2021	PARTS OF DHEERPUR VILLAGE, PART OF NIRANKARI COLONY, SWARG ASHRAM, PART OF WEST PARMANAD COLONY, PART OF WEST MUKHERJEE NAGAR, AIR TRAINING CENTER, ROSARY SCHOOL , PRADHAN MARKET, ROSARY SCHOOLROAD & 30 OTRS MODEL TOWN	1210	Other Outage	Unplanned Outage	18-Dec-2021	13:02	18-Dec-2021	14:17	75	0.000208	INTERRUPTION DUE TO FAULT
46	18-Dec-2021	PARTS OF DHEERPUR VILLAGE, PART OF NIRANKARI COLONY, SWARG ASHRAM, PART OF WEST PARMANAD COLONY, PART OF WEST MUKHERJEE NAGAR, AIR TRAINING CENTER, ROSARY SCHOOL , PRADHAN MARKET, ROSARY SCHOOLROAD & 30 OTRS MODEL TOWN	1320	Other Outage	Unplanned Outage	18-Dec-2021	14:20	18-Dec-2021	16:50	150	0.000333	FORCE MAJEURE DUE TO SABOTAGE
47	18-Dec-2021	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC MODEL TOWN	189	Other Outage	Unplanned Outage	18-Dec-2021	18:07	18-Dec-2021	18:52	45	0.000025	INTERRUPTION DUE TO FAULT
48	18-Dec-2021	PART OF J BLOCK JAHANGIR PURI MODEL TOWN	15	Other Outage	Unplanned Outage	18-Dec-2021	18:59	18-Dec-2021	19:37	38	0.000011	INTERRUPTION DUE TO FAULT
49	19-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	349	Other Outage	Unplanned Outage	19-Dec-2021	10:20	19-Dec-2021	10:48	28	0.000039	INTERRUPTION DUE TO FAULT
50	19-Dec-2021	PART OF JANTA VIHAR MODEL TOWN	20	Other Outage	Unplanned Outage	19-Dec-2021	15:09	19-Dec-2021	15:34	25	0.000014	INTERRUPTION DUE TO FAULT
51	19-Dec-2021	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN MODEL TOWN	267	Other Outage	Unplanned Outage	19-Dec-2021	20:43	19-Dec-2021	21:07	24	0.000013	INTERRUPTION DUE TO FAULT
52	20-Dec-2021	PARTS OF D BLOCK (HOUSE NO 1-1000) & E BLOCK (1000-2000) JAHANGIRPURI MODEL TOWN	33	Other Outage	Unplanned Outage	20-Dec-2021	12:09	20-Dec-2021	12:33	24	0.000027	INTERRUPTION DUE TO FAULT
53	20-Dec-2021	PART OF JANTA VIHAR MODEL TOWN	20	Other Outage	Unplanned Outage	20-Dec-2021	12:30	20-Dec-2021	13:40	70	0.000097	INTERRUPTION DUE TO FAULT
54	20-Dec-2021	PARTS OF BHALASWA VILLAGE, I, BLK MCD SCHOOL MODEL TOWN	40	Other Outage	Unplanned Outage	20-Dec-2021	14:51	20-Dec-2021	15:08	17	0.000019	INTERRUPTION DUE TO FAULT
55	22-Dec-2021	PARTS OF A - BLOCK GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK MODEL TOWN	681	Other Outage	Unplanned Outage	22-Dec-2021	06:01	22-Dec-2021	06:29	28	0.000178	INTERRUPTION DUE TO FAULT
56	22-Dec-2021	PARTS OF A - BLOCK, GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK MODEL TOWN	1149	Other Outage	Unplanned Outage	22-Dec-2021	06:01	22-Dec-2021	06:40	39	0.000129	INTERRUPTION DUE TO FAULT
57	22-Dec-2021	PART OF JAHANGIRPURI MKT MODEL TOWN	15	Other Outage	Unplanned Outage	22-Dec-2021	13:27	22-Dec-2021	13:44	17	0.000005	INTERRUPTION DUE TO FAULT
58	23-Dec-2021	PARTS OF BHALASWA VILLAGE, I, BLK MCD SCHOOL MODEL TOWN	42	Other Outage	Unplanned Outage	23-Dec-2021	08:51	23-Dec-2021	09:06	15	0.000016	INTERRUPTION DUE TO FAULT
59	23-Dec-2021	PART OF MCD QUARTER JAHANGIR PURI MODEL TOWN	17	Other Outage	Unplanned Outage	23-Dec-2021	11:17	23-Dec-2021	12:51	94	0.000226	INTERRUPTION DUE TO FAULT
60	23-Dec-2021	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	23	Other Outage	Unplanned Outage	23-Dec-2021	14:42	23-Dec-2021	15:50	68	0.000019	INTERRUPTION DUE TO FAULT
61	23-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	348	Other Outage	Unplanned Outage	23-Dec-2021	16:35	23-Dec-2021	17:14	39	0.000022	INTERRUPTION DUE TO FAULT
62	24-Dec-2021	PART OF K BLOCK JAHANGIR PURI MODEL TOWN	18	Other Outage	Unplanned Outage	24-Dec-2021	11:25	24-Dec-2021	11:59	34	0.000009	INTERRUPTION DUE TO FAULT
63	24-Dec-2021	PARTS OF D BLOCK (HOUSE NO 1-1000) & E BLOCK (1000-2000) JAHANGIRPURI MODEL TOWN	21	Other Outage	Unplanned Outage	24-Dec-2021	11:32	24-Dec-2021	14:51	199	0.000055	FORCE MAJEURE DUE TO SABOTAGE
64	24-Dec-2021	PARTS OF ARYABHATT, POLYTECHNIC, PART OF B - BLOCK INDUSTRIAL AREA GTK MODEL TOWN	623	Other Outage	Unplanned Outage	24-Dec-2021	12:29	24-Dec-2021	12:46	17	0.000042	INTERRUPTION DUE TO FAULT
65	25-Dec-2021	PART OF A BLOCK DDA SLUM FLATS MODEL TOWN	8	Other Outage	Unplanned Outage	25-Dec-2021	17:47	25-Dec-2021	18:02	15	0.000013	INTERRUPTION DUE TO FAULT
66	25-Dec-2021	PART OF SANJAY NAGAR MODEL TOWN	10	Other Outage	Unplanned Outage	25-Dec-2021	18:53	25-Dec-2021	21:12	139	0.000077	FORCE MAJEURE DUE TO SABOTAGE
67	26-Dec-2021	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	1027	Other Outage	Unplanned Outage	26-Dec-2021	06:44	26-Dec-2021	07:37	53	0.000297	INTERRUPTION DUE TO FAULT
68	26-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	2046	Other Outage	Unplanned Outage	26-Dec-2021	19:30	26-Dec-2021	20:16	46	0.000632	INTERRUPTION DUE TO FAULT
69	26-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	181	Other Outage	Unplanned Outage	26-Dec-2021	19:30	26-Dec-2021	21:21	111	0.000153	INTERRUPTION DUE TO FAULT
70	26-Dec-2021	PARTS OF TO CORONATION PILLAR -1, CORONATION PILLAR -2, SAMAGAM GROUND MODEL TOWN	23	Other Outage	Unplanned Outage	26-Dec-2021	19:43	26-Dec-2021	20:12	29	0.000032	INTERRUPTION DUE TO FAULT
71	26-Dec-2021	PARTS OF TO CORONATION PILLAR -1, CORONATION PILLAR -2, SAMAGAM GROUND MODEL TOWN	129	Other Outage	Unplanned Outage	26-Dec-2021	19:43	27-Dec-2021	00:48	305	0.000047	FORCE MAJEURE DUE TO RAINSTORM
72	26-Dec-2021	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	206	Other Outage	Unplanned Outage	26-Dec-2021	19:51	26-Dec-2021	22:50	179	0.000497	FORCE MAJEURE DUE TO RAINSTORM
73	26-Dec-2021	PARTS OF ADARSH NAGAR, C-BLOCK MAJLUSH PARK, RAJAN BABU ROAD , PART OF ADARSH NAGAR EXTN. MODEL TOWN	209	Other Outage	Unplanned Outage	26-Dec-2021	20:10	26-Dec-2021	21:08	58	0.000322	INTERRUPTION DUE TO FAULT
74	26-Dec-2021	PARTS OF ADARSH NAGAR, C-BLOCK MAJLUSH PARK, RAJAN BABU ROAD , PART OF ADARSH NAGAR EXTN. MODEL TOWN	1876	Other Outage	Unplanned Outage	26-Dec-2021	20:10	26-Dec-2021	21:44	94	0.000145	INTERRUPTION DUE TO FAULT
75	27-Dec-2021	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	410	Other Outage	Unplanned Outage	27-Dec-2021	10:03	27-Dec-2021	10:50	47	0.000155	INTERRUPTION DUE TO FAULT
76	27-Dec-2021	PART OF MKT JAHANGIR PURI MODEL TOWN	5	Other Outage	Unplanned Outage	27-Dec-2021	11:59	27-Dec-2021	12:36	37	0.000021	INTERRUPTION DUE TO FAULT
77	27-Dec-2021	PART OF C -BLK OLD ZONAL OFFICE MODEL TOWN	2	Other Outage	Unplanned Outage	27-Dec-2021	12:58	27-Dec-2021	19:23	385	0.000214	FORCE MAJEURE DUE TO SABOTAGE
78	27-Dec-2021	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA MODEL TOWN	163	Other Outage	Unplanned Outage	27-Dec-2021	17:21	27-Dec-2021	18:14	53	0.000059	INTERRUPTION DUE TO FAULT
79	27-Dec-2021	PART OF C-BLK OLD ZONAL OFFICE MODEL TOWN	19	Other Outage	Unplanned Outage	27-Dec-2021	19:16	27-Dec-2021	19:38	22	0.000012	INTERRUPTION DUE TO FAULT
80	27-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	31	Other Outage	Unplanned Outage	27-Dec-2021	20:26	27-Dec-2021	20:41	15	0.000008	INTERRUPTION DUE TO FAULT
81	28-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	33	Other Outage	Unplanned Outage	28-Dec-2021	08:01	28-Dec-2021	09:35	94	0.000026	INTERRUPTION DUE TO FAULT
82	28-Dec-2021	PART OF SANJAY NAGAR MODEL TOWN	14	Other Outage	Unplanned Outage	28-Dec-2021	09:49	28-Dec-2021	10:12	23	0.000006	INTERRUPTION DUE TO FAULT
83	28-Dec-2021	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC MODEL TOWN	196	Other Outage	Unplanned Outage	28-Dec-2021	11:31	28-Dec-2021	13:57	146	0.000081	FORCE MAJEURE DUE TO SABOTAGE
84	28-Dec-2021	PARTS OF 336 SFS FLAT NO-2, 336 SFS FLAT NO-1, 336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	117	Other Outage	Unplanned Outage	28-Dec-2021	18:16	28-Dec-2021	20:13	117	0.00013	INTERRUPTION DUE TO FAULT
85	28-Dec-2021	PARTS OF BHALASWA VILLAGE, I, BLK MCD SCHOOL MODEL TOWN	108	Other Outage	Unplanned Outage	28-Dec-2021	18:19	28-Dec-2021	20:45	146	0.000122	FORCE MAJEURE DUE TO RAINSTORM
86	28-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	76	Other Outage	Unplanned Outage	28-Dec-2021	18:56	28-Dec-2021	19:35	39	0.000043	INTERRUPTION DUE TO FAULT
87	28-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	232	Other Outage	Unplanned Outage	28-Dec-2021	22:42	28-Dec-2021	23:55	73	0.000061	INTERRUPTION DUE TO FAULT
88	29-Dec-2021	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	40	Other Outage	Unplanned Outage	29-Dec-2021	09:22	29-Dec-2021	09:58	36	0.00004	INTERRUPTION DUE TO FAULT
89	29-Dec-2021	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	366	Other Outage	Unplanned Outage	29-Dec-2021	09:22	29-Dec-2021	10:20	58	0.000129	INTERRUPTION DUE TO FAULT
90	29-Dec-2021	PART OF LAL BAGH MODEL TOWN	8	Other Outage	Unplanned Outage	29-Dec-2021	09:22	29-Dec-2021	15:15	353	0.000196	FORCE MAJEURE DUE TO SABOTAGE
91	29-Dec-2021	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLUS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAI ROAD , RANA PARTAP ROAD , SUSHHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP MODEL TOWN	2068	Other Outage	Unplanned Outage	29-Dec-2021	12:01	29-Dec-2021	12:35	34	0.000357	INTERRUPTION DUE TO FAULT
92	29-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	1217	Other Outage	Unplanned Outage	29-Dec-2021	12:10	29-Dec-2021	13:48	98	0.000492	INTERRUPTION DUE TO FAULT
93	29-Dec-2021	PART OF JAHANGIRPURI MKT MODEL TOWN	8	Other Outage	Unplanned Outage	29-Dec-2021	13:11	29-Dec-2021	13:22	11	0.000003	INTERRUPTION DUE TO FAULT
94	29-Dec-2021	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	40	Other Outage	Unplanned Outage	29-Dec-2021	14:24	29-Dec-2021	15:15	51	0.000028	INTERRUPTION DUE TO FAULT
95	29-Dec-2021	PART OF SANJAY NAGAR MODEL TOWN	14	Other Outage	Unplanned Outage	29-Dec-2021	15:41	29-Dec-2021	17:38	117	0.000065	INTERRUPTION DUE TO FAULT
96	29-Dec-2021	PART OF SHIV MANDIR KEWAL PARK MODEL TOWN	5	Other Outage	Unplanned Outage	29-Dec-2021	19:05	29-Dec-2021	21:36	151	0.000042	FORCE MAJEURE DUE TO SABOTAGE
97	29-Dec-2021	PARTS OF MULTI LEVEL CAR PARKING , F BLDK MDT MODEL TOWN	337	Other Outage	Unplanned Outage	29-Dec-2021	22:58	29-Dec-2021	23:36	38	0.000041	INTERRUPTION DUE TO FAULT
98	29-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	2679	Other Outage	Unplanned Outage	29-Dec-2021	23:12	29-Dec-2021	23:25	13	0.000091	INTERRUPTION DUE TO FAULT
99	29-Dec-2021	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	1447	Other Outage	Unplanned Outage	29-Dec-2021	23:12	29-Dec-2021	23:55	43	0.000178	INTERRUPTION DUE TO FAULT
100	30-Dec-2021	PART OF JANTA VIHAR MODEL TOWN	5	Other Outage	Unplanned Outage	30-Dec-2021	11:42	30-Dec-2021	12:37	55	0.000015	INTERRUPTION DUE TO FAULT
101	30-Dec-2021	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	176	Other Outage	Unplanned Outage	30-Dec-2021	15:02	30-Dec-2021	16:15	73	0.000081	INTERRUPTION DUE TO FAULT
102	30-Dec-2021	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	473	Other Outage	Unplanned Outage	30-Dec-2021	15:23	30-Dec-2021	16:16	53	0.000147	INTERRUPTION DUE TO FAULT
103	31-Dec-2021	PART OF JAHANGIRPURI MKT MODEL TOWN	6	Other Outage	Unplanned Outage	31-Dec-2021	12:03	31-Dec-2021	14:15	132	0.000073	FORCE MAJEURE DUE TO SABOTAGE
104	31-Dec-2021	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA MODEL TOWN	242	Other Outage	Unplanned Outage	31-Dec-2021	15:40	31-Dec-2021	16:44	64	0.000089	INTERRUPTION DUE TO FAULT
105	01-Dec-2021	PARTS OF FCI GODDOWN, PART OF B - BLOCK INDUSTRIAL AREA, SANGAM PARK, PART OF R. P. BAGH MODEL TOWN	42	Other Outage	Planned Outage	01-Dec-2021	11:39	01-Dec-2021	16:00	261	0.00007	PLANNED OUTAGE
106	02-Dec-2021	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	104	Other Outage	Planned Outage	02-Dec-2021	10:28	02-Dec-2021	16:13	345	0.00010	PLANNED OUTAGE
107	02-Dec-2021	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	188									

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
108	02-Dec-2021	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN MODEL TOWN	267	Other Outage	Planned Outage	02-Dec-2021	11:33	02-Dec-2021	16:04	271	0.00015	PLANNED OUTAGE
109	03-Dec-2021	PARTS OF D BLOCK, E BLOCK, EE BLOCK, JJ CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT MODEL TOWN	1034	Other Outage	Planned Outage	03-Dec-2021	10:08	03-Dec-2021	17:48	460	0.00128	PLANNED OUTAGE
110	03-Dec-2021	PARTS OF SABZI MANDI, SARAI EXTENSION, SARAI PEELI THALLA,APMC OFFICE(HY CONSUMER) MODEL TOWN	586	630 kVA	Planned Outage	03-Dec-2021	11:42	03-Dec-2021	13:44	122	0.00041	PLANNED OUTAGE
111	04-Dec-2021	PARTS OF T. B HOSPITAL, I.D.HOSPITAL, MUKHERJEE NAGAR (WEST)PART OF OUTRAM LINE,PART OF MALL ROAD, TAGOR PARK EXTN. PART OF DHAKA VILLAGE, 250 BEDDED HOSPITAL, AIR HOSTEL & PART OF NIRANKARI COLONY MODEL TOWN	262	630 kVA	Planned Outage	04-Dec-2021	11:04	04-Dec-2021	12:51	107	0.00009	PLANNED OUTAGE
112	04-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	1962	Other Outage	Planned Outage	04-Dec-2021	11:21	04-Dec-2021	12:40	79	0.00044	PLANNED OUTAGE
113	04-Dec-2021	PARTS OF MALUSI PARK GALL NO 13 MODEL TOWN	904	Other Outage	Planned Outage	04-Dec-2021	11:39	04-Dec-2021	14:11	152	0.00042	PLANNED OUTAGE
114	06-Dec-2021	PARTS OF MULTI LEVEL CAR PARKING , F BLOK MDT MODEL TOWN	337	Other Outage	Planned Outage	06-Dec-2021	11:00	06-Dec-2021	13:38	158	0.00018	PLANNED OUTAGE
115	06-Dec-2021	PARTS OF KEWAL PARK, A,B & C-BLOCK MALUSHI PARK, TIMBER MARKET, SOME PART OF KEWAL PARK EXTN., GOPAL NAGAR, SHANTI MARG KEWAL PARK MODEL TOWN	1344	Other Outage	Planned Outage	06-Dec-2021	11:34	06-Dec-2021	14:10	156	0.00065	PLANNED OUTAGE
116	08-Dec-2021	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	1044	Other Outage	Planned Outage	08-Dec-2021	10:15	08-Dec-2021	16:27	372	0.00114	PLANNED OUTAGE
117	08-Dec-2021	PARTS OF FCI GODDOWN, PART OF B - BLOCK INDUSTRIAL AREA, SANGAM PARK, PART OF R. P. BAGH MODEL TOWN	57	990 kVA	Planned Outage	08-Dec-2021	12:03	08-Dec-2021	13:48	105	0.00003	PLANNED OUTAGE
118	09-Dec-2021	PARTS OF MUKHERJEE NAGAR DASH MESH PARK , MUKHERJEE NGR NO-3 MODEL TOWN	975	Other Outage	Planned Outage	09-Dec-2021	11:05	09-Dec-2021	13:01	116	0.00032	PLANNED OUTAGE
119	09-Dec-2021	PARTS OF DERAWALA A BLOCK, BIJLEE APPARTMENTS MODEL TOWN	122	Other Outage	Planned Outage	09-Dec-2021	11:34	09-Dec-2021	14:03	149	0.00008	PLANNED OUTAGE
120	10-Dec-2021	PARTS OF B, D, H & F BLOCK MODEL TOWN AND PART OF K & Z BLOCK MODEL TOWN	209	Other Outage	Planned Outage	10-Dec-2021	11:13	10-Dec-2021	13:00	100	0.00018	PLANNED OUTAGE
121	11-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	1042	Other Outage	Planned Outage	11-Dec-2021	10:05	11-Dec-2021	12:55	170	0.00047	PLANNED OUTAGE
122	11-Dec-2021	PARTS OF INDRA VIKAS COLONY MODEL TOWN	601	1000 kVA	Planned Outage	11-Dec-2021	11:08	11-Dec-2021	12:51	103	0.00017	PLANNED OUTAGE
123	11-Dec-2021	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	204	Other Outage	Planned Outage	11-Dec-2021	13:07	11-Dec-2021	14:59	112	0.00006	PLANNED OUTAGE
124	11-Dec-2021	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	824	990 kVA	Planned Outage	11-Dec-2021	14:17	11-Dec-2021	15:45	88	0.00022	PLANNED OUTAGE
125	12-Dec-2021	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	166	630 kVA	Planned Outage	12-Dec-2021	14:00	12-Dec-2021	15:18	78	0.00007	PLANNED OUTAGE
126	13-Dec-2021	PARTS OF A BLOCK DDA SILUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A B BLOCK MODEL TOWN	2056	Other Outage	Planned Outage	13-Dec-2021	10:13	13-Dec-2021	15:24	311	0.00138	PLANNED OUTAGE
127	13-Dec-2021	PARTS OF DHEERPUR VILLAGE, PART OF NIRANKARI COLONY, SWARG ASHRAM, PART OF WEST PARMANAD COLONY, PART OF WEST MUKHERJEE NAGAR, AIR TRAINING CENTER, ROSARY SCHOOL, PRADHAN MARKET, ROSARY SCHOOLROAD, & 30 OTS MODEL TOWN	73	Other Outage	Planned Outage	13-Dec-2021	14:20	13-Dec-2021	15:42	82	0.00005	PLANNED OUTAGE
128	14-Dec-2021	PARTS OF OUTRAM LINES. HAKIKAT NAGAR. MALL ROAD MAIN ROAD MODEL TOWN	203	630 kVA	Planned Outage	14-Dec-2021	10:56	14-Dec-2021	12:22	86	0.00007	PLANNED OUTAGE
129	14-Dec-2021	PARTS OF MALUSI PARK GALL NO 13 MODEL TOWN	581	990 kVA	Planned Outage	14-Dec-2021	11:49	14-Dec-2021	13:47	118	0.00026	PLANNED OUTAGE
130	14-Dec-2021	PART OF ADARSH NAGAR MODEL TOWN	1	Other Outage	Planned Outage	14-Dec-2021	12:09	14-Dec-2021	13:14	65	0.00002	PLANNED OUTAGE
131	14-Dec-2021	PARTS OF MUKHERJEE NAGAR -3 MODEL TOWN	205	630 kVA	Planned Outage	14-Dec-2021	12:19	14-Dec-2021	13:55	96	0.00016	PLANNED OUTAGE
132	15-Dec-2021	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	487	990 kVA	Planned Outage	15-Dec-2021	11:05	15-Dec-2021	12:56	111	0.00012	PLANNED OUTAGE
133	15-Dec-2021	PARTS OF B BLK SHAKTI NAGAR MODEL TOWN	76	1000 kVA	Planned Outage	15-Dec-2021	11:30	15-Dec-2021	13:33	123	0.00007	PLANNED OUTAGE
134	16-Dec-2021	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN MODEL TOWN	267	Other Outage	Planned Outage	16-Dec-2021	11:37	16-Dec-2021	16:02	265	0.00022	PLANNED OUTAGE
135	17-Dec-2021	PARTS OF BUR HOSPITAL, BUR HOSPITAL RESIDENCE, MIG FLATS (JAHANGIR PURI), ITI (JAHANGIR PURI), POLICE STATION (JAHANGIR PURI), POLICE RESIDENTIAL COMPLEX, FIRE STATION (JAHANGIR PURI), EE BLOCK PUMPING STATION (JAHANGIR PURI), DJB SEWAGE PUMPING STATION & PRAYAS, ITD PLANT MODEL TOWN	278	Other Outage	Planned Outage	17-Dec-2021	10:08	17-Dec-2021	16:13	365	0.00030	PLANNED OUTAGE
136	17-Dec-2021	PARTS OF INDRA VIHAR, HAKIKAT NAGAR, PART OF OUTRAM LINES, DTC DEPOT, PART OF MALL ROAD, PG WOMEN HOSTEL MODEL TOWN	232	990 kVA	Planned Outage	17-Dec-2021	11:17	17-Dec-2021	13:10	113	0.00009	PLANNED OUTAGE
137	17-Dec-2021	PART OF DMRC STAFF FLAT MODEL TOWN	6	Other Outage	Planned Outage	17-Dec-2021	11:49	17-Dec-2021	14:12	143	0.00004	PLANNED OUTAGE
138	17-Dec-2021	PART OF J BLOCK JAHANGIR PURI MODEL TOWN	1	63 kVA	Unplanned Outage	17-Dec-2021	11:55	17-Dec-2021	12:47	52	0.00001	SYSTEM SCHEDULE OUTAGE
139	17-Dec-2021	PART OF DILKUSH BAGH INDUSTRIAL AREA MODEL TOWN	8	400 kVA	Unplanned Outage	17-Dec-2021	15:47	17-Dec-2021	17:20	93	0.00003	SYSTEM SCHEDULE OUTAGE
140	18-Dec-2021	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC MODEL TOWN	226	Other Outage	Planned Outage	18-Dec-2021	10:34	18-Dec-2021	16:00	326	0.00027	PLANNED OUTAGE
141	18-Dec-2021	PARTS OF KEWAL PARK, A,B & C-BLOCK MALUSHI PARK, TIMBER MARKET, SOME PART OF KEWAL PARK EXTN., GOPAL NAGAR, SHANTI MARG KEWAL PARK MODEL TOWN	331	630 kVA	Planned Outage	18-Dec-2021	11:16	18-Dec-2021	13:31	135	0.00015	PLANNED OUTAGE
142	18-Dec-2021	PARTS OF AAKASH CINEMA, NANIWALA BAGH COMMERCIAL COMPLEX (AZAD PURI), PART OF MCD COLONY, SHASTRI MARKET , DISTT. OFFICE MODEL TOWN	144	630 kVA	Planned Outage	18-Dec-2021	11:21	18-Dec-2021	13:15	114	0.00006	PLANNED OUTAGE
143	18-Dec-2021	PARTS OF LABOUR CHOWK, A - BLK MALUSI PARK, KEWAL PARK MODEL TOWN	560	Other Outage	Planned Outage	18-Dec-2021	11:22	18-Dec-2021	13:31	129	0.00022	PLANNED OUTAGE
144	18-Dec-2021	PARTS OF KEWAL PARK, A,B & C-BLOCK MALUSHI PARK, TIMBER MARKET, SOME PART OF KEWAL PARK EXTN., GOPAL NAGAR, SHANTI MARG KEWAL PARK MODEL TOWN	628	Other Outage	Planned Outage	18-Dec-2021	11:52	18-Dec-2021	14:08	136	0.00026	PLANNED OUTAGE
145	19-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	216	Other Outage	Planned Outage	19-Dec-2021	11:30	19-Dec-2021	12:46	76	0.00002	PLANNED OUTAGE
146	20-Dec-2021	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	150	630 kVA	Planned Outage	20-Dec-2021	11:04	20-Dec-2021	13:30	146	0.00020	PLANNED OUTAGE
147	20-Dec-2021	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	231	990 kVA	Planned Outage	20-Dec-2021	11:06	20-Dec-2021	13:32	146	0.00016	PLANNED OUTAGE
148	20-Dec-2021	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	129	630 kVA	Planned Outage	20-Dec-2021	11:09	20-Dec-2021	13:33	144	0.00012	PLANNED OUTAGE
149	20-Dec-2021	PARTS OF ADARSH NAGAR,C-BLOCK MALUSHI PARK,RAJAN BABU ROAD , PART OF ADARSH NAGAR EXTN. MODEL TOWN	482	990 kVA	Planned Outage	20-Dec-2021	11:40	20-Dec-2021	14:07	147	0.00061	PLANNED OUTAGE
150	20-Dec-2021	PARTS OF ADARSH NAGAR,C-BLOCK MALUSHI PARK,RAJAN BABU ROAD , PART OF ADARSH NAGAR EXTN. MODEL TOWN	477	630 kVA	Planned Outage	20-Dec-2021	11:44	20-Dec-2021	14:09	145	0.00060	PLANNED OUTAGE
151	21-Dec-2021	PARTS OF DERAWALA A BLOCK, BIJLEE APPARTMENTS MODEL TOWN	214	990 kVA	Planned Outage	21-Dec-2021	07:07	21-Dec-2021	08:59	112	0.00006	PLANNED OUTAGE
152	21-Dec-2021	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	754	Other Outage	Planned Outage	21-Dec-2021	10:06	21-Dec-2021	12:34	148	0.00029	PLANNED OUTAGE
153	21-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	21	25 kVA	Planned Outage	21-Dec-2021	11:14	21-Dec-2021	12:43	89	0.00005	PLANNED OUTAGE
154	21-Dec-2021	PARTS OF NEW TAGOR PAR,DHEERPUR KIOSK,NBHAI PERMA PERMA NAND,207 TAGOR PARK BP COLONY MODEL TOWN	699	990 kVA	Planned Outage	21-Dec-2021	11:30	21-Dec-2021	13:36	126	0.00021	PLANNED OUTAGE
155	21-Dec-2021	PARTS OF NEW TAGOR PAR,DHEERPUR KIOSK,NBHAI PERMA PERMA NAND,207 TAGOR PARK BP COLONY MODEL TOWN	353	990 kVA	Planned Outage	21-Dec-2021	11:33	21-Dec-2021	13:42	129	0.00011	PLANNED OUTAGE
156	21-Dec-2021	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL) MODEL TOWN	340	990 kVA	Planned Outage	21-Dec-2021	11:38	21-Dec-2021	13:39	121	0.00050	PLANNED OUTAGE
157	21-Dec-2021	PARTS OF OLD & NEW TAGORE PARK, MALIPUR VILLAGE, WEST PARMANAD COLONY. MODEL TOWN	305	990 kVA	Planned Outage	21-Dec-2021	11:38	21-Dec-2021	13:37	119	0.00010	PLANNED OUTAGE
158	21-Dec-2021	PART OF LAL BAGH MODEL TOWN	4	400 kVA	Unplanned Outage	21-Dec-2021	16:14	21-Dec-2021	16:44	30	0.00001	SYSTEM SCHEDULE OUTAGE
159	22-Dec-2021	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	372	Other Outage	Planned Outage	22-Dec-2021	10:27	22-Dec-2021	16:08	341	0.00057	PLANNED OUTAGE
160	22-Dec-2021	PART OF LAL BAGH MODEL TOWN	4	400 kVA	Unplanned Outage	22-Dec-2021	10:38	22-Dec-2021	11:28	50	0.00001	SYSTEM SCHEDULE OUTAGE
161	23-Dec-2021	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	849	Other Outage	Planned Outage	23-Dec-2021	10:15	23-Dec-2021	14:14	239	0.00060	PLANNED OUTAGE
162	23-Dec-2021	PARTS OF T. B HOSPITAL, I.D.HOSPITAL, MUKHERJEE NAGAR (WEST)PART OF OUTRAM LINE,PART OF MALL ROAD, TAGOR PARK EXTN. PART OF DHAKA VILLAGE, 250 BEDDED HOSPITAL, AIR HOSTEL & PART OF NIRANKARI COLONY MODEL TOWN	478	630 kVA	Planned Outage	23-Dec-2021	11:24	23-Dec-2021	12:50	86	0.00012	PLANNED OUTAGE
163	23-Dec-2021	PARTS OF MCD COLONY, R & C BLOCK (MODEL TOWN), DJB QUARTERS. MODEL TOWN	443	1000 kVA	Planned Outage	23-Dec-2021	11:26	23-Dec-2021	13:35	129	0.00018	PLANNED OUTAGE
164	23-Dec-2021	PARTS OF MUBARKBAGH, MODEL TOWN POLICE STATION, B-BLOCK DERA WALA,GRAND VENEZIA,NEW GUPTA COLONY, PART OF NEW POLICE LINE, SC-SD BHAMA SHAH MARG MODEL TOWN	564	Other Outage	Planned Outage	23-Dec-2021	11:38	23-Dec-2021	14:09	151	0.00021	PLANNED OUTAGE
165	23-Dec-2021	PARTS OF NORTH EX MODEL TOWN	71	990 kVA	Planned Outage	23-Dec-2021	14:12	23-Dec-2021	16:18	126	0.00004	PLANNED OUTAGE
166	24-Dec-2021	PARTS OF OUTRAM LINES. HAKIKAT NAGAR. MALL ROAD MAIN ROAD MODEL TOWN	334	990 kVA	Planned Outage	24-Dec-2021	10:55	24-Dec-2021	12:56	121	0.00034	PLANNED OUTAGE
167	24-Dec-2021	PARTS OF OUTRAM LINES. HAKIKAT NAGAR. MALL ROAD MAIN ROAD MODEL TOWN	122	990 kVA	Planned Outage	24-Dec-2021	11:28	24-Dec-2021	13:00	92	0.00026	PLANNED OUTAGE
168	24-Dec-2021	PART OF DILKUSH BAGH INDUSTRIAL AREA MODEL TOWN	3	250 kVA	Unplanned Outage	24-Dec-2021	12:21	24-Dec-2021	13:06	45	0.00001	SYSTEM SCHEDULE OUTAGE
169	26-Dec-2021	PARTS OF SUBZI MANDI AND D-BLK MODEL TOWN	921	Other Outage	Planned Outage	26-Dec-2021	11:29	26-Dec-2021	14:02	153	0.00102	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
170	27-Dec-2021	PARTS OF MUKHERJEE NAGAR DASH MESH PARK , MUKHERJEE NGAR NO-3 MODEL TOWN	885	Other Outage	Planned Outage	27-Dec-2021	10:57	27-Dec-2021	13:05	128	0.00028	PLANNED OUTAGE
171	28-Dec-2021	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J CLUSTER BEHIND ITI (JAHANGIR PURI), J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	1208	Other Outage	Planned Outage	28-Dec-2021	10:20	28-Dec-2021	16:22	362	0.00121	PLANNED OUTAGE
172	28-Dec-2021	PARTS OF MANIWALA BAGH, RAMESHWAR NAGAR MODEL TOWN	272	630 kVA	Planned Outage	28-Dec-2021	11:08	28-Dec-2021	13:19	131	0.00007	PLANNED OUTAGE
173	28-Dec-2021	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL) MODEL TOWN	360	990 kVA	Planned Outage	28-Dec-2021	11:13	28-Dec-2021	13:34	141	0.00059	PLANNED OUTAGE
174	28-Dec-2021	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL) MODEL TOWN	239	990 kVA	Planned Outage	28-Dec-2021	11:16	28-Dec-2021	13:37	141	0.00039	PLANNED OUTAGE
175	29-Dec-2021	PARTS OF HZ AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	26	Other Outage	Planned Outage	29-Dec-2021	10:20	29-Dec-2021	16:27	367	0.00010	PLANNED OUTAGE
176	29-Dec-2021	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	2213	Other Outage	Planned Outage	29-Dec-2021	10:51	29-Dec-2021	14:49	238	0.00198	PLANNED OUTAGE
177	29-Dec-2021	PARTS OF NEW TAGOR PAR,DHEERPUR KIOSK,NEW BHAI PERMA PERMA NAND,207 TAGOR PARK,BP COLONY MODEL TOWN	35	Other Outage	Planned Outage	29-Dec-2021	11:21	29-Dec-2021	13:14	113	0.00003	PLANNED OUTAGE
178	29-Dec-2021	PARTS OF NEW TAGOR PAR,DHEERPUR KIOSK,NEW BHAI PERMA PERMA NAND,207 TAGOR PARK,BP COLONY MODEL TOWN	296	630 kVA	Planned Outage	29-Dec-2021	14:12	29-Dec-2021	15:25	73	0.00006	PLANNED OUTAGE
179	30-Dec-2021	PARTS OF BIR HOSPITAL, BIR HOSPITAL RESIDENCE, MIG FLATS (JAHANGIR PURI), ITI (JAHANGIR PURI), POLICE STATION (JAHANGIR PURI), POLICE RESIDENTIAL COMPLEX, FIRE STATION (JAHANGIR PURI), EE BLOCK PUMPING STATION (JAHANGIR PURI), DIS SEWAGE PUMPING STATION & PRAYAS. ITD PLANT MODEL TOWN	346	Other Outage	Planned Outage	30-Dec-2021	10:33	30-Dec-2021	14:42	249	0.00021	PLANNED OUTAGE
180	30-Dec-2021	PARTS OF MALIUS PARK GALI NO 13 MODEL TOWN	148	630 kVA	Planned Outage	30-Dec-2021	11:48	30-Dec-2021	13:59	131	0.00011	PLANNED OUTAGE
181	30-Dec-2021	PARTS OF THEKE WALA AZADPUR MODEL TOWN	809	990 kVA	Planned Outage	30-Dec-2021	12:09	30-Dec-2021	14:34	145	0.00036	PLANNED OUTAGE
182	30-Dec-2021	PARTS OF THEKE WALA AZADPUR MODEL TOWN	308	990 kVA	Planned Outage	30-Dec-2021	12:14	30-Dec-2021	14:34	140	0.00016	PLANNED OUTAGE
183	31-Dec-2021	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	851	630 kVA	Planned Outage	31-Dec-2021	11:11	31-Dec-2021	13:20	129	0.00032	PLANNED OUTAGE
MOTI NAGAR												
1	01-Dec-2021	PARTS OF 7,BLOCK RAMESH NAGAR, B BLOCK RAJOURI GARDEN E BLOCK RAMESH NAGAR, 40 BLOCK RAMESH NAGAR MOTI NAGAR	198	Other Outage	Unplanned Outage	01-Dec-2021	04:45	01-Dec-2021	05:35	50	0.00014	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PARTS OF 5/31, 5/35 JJ CLUSTER HW, 3,4 BLOCK KIRTINAGAR INDUSTRIAL AREA, MOTI NAGAR	234	Other Outage	Unplanned Outage	01-Dec-2021	10:10	01-Dec-2021	10:23	13	0.00025	INTERRUPTION DUE TO FAULT
3	01-Dec-2021	PART OF 71/7 RAMA ROAD MOTI NAGAR	10	Other Outage	Unplanned Outage	01-Dec-2021	13:05	01-Dec-2021	13:45	40	0.00011	INTERRUPTION DUE TO FAULT
4	02-Dec-2021	PARTS OF F,E,D BLOCK MOTI NAGAR	538	Other Outage	Unplanned Outage	02-Dec-2021	13:00	02-Dec-2021	13:49	49	0.00134	INTERRUPTION DUE TO FAULT
5	02-Dec-2021	PARTS OF B, C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	72	Other Outage	Unplanned Outage	02-Dec-2021	16:03	02-Dec-2021	17:12	69	0.00096	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PARTS OF 5/31, 5/35 JJ CLUSTER,WZ, 3,4 BLOCK KIRTINAGAR INDUSTRIAL AREA, MOTI NAGAR	234	Other Outage	Unplanned Outage	02-Dec-2021	16:05	02-Dec-2021	17:32	87	0.000359	INTERRUPTION DUE TO FAULT
7	02-Dec-2021	PARTS OF 69/1 TO 69/6 NAJAF GANI ROAD & HARRETT FORD & INDIA EXPORT MOTI NAGAR	189	Other Outage	Unplanned Outage	02-Dec-2021	16:35	02-Dec-2021	17:15	40	0.000389	INTERRUPTION DUE TO FAULT
8	03-Dec-2021	PART OF B-BLOCK NARAINA INDUSTRIAL AREA PH-II MOTI NAGAR	6	Other Outage	Unplanned Outage	03-Dec-2021	12:42	03-Dec-2021	13:06	24	0.00013	INTERRUPTION DUE TO FAULT
9	03-Dec-2021	PARTS OF INDOOR MOTI NAGAR	655	Other Outage	Unplanned Outage	03-Dec-2021	13:07	03-Dec-2021	14:41	94	0.00131	INTERRUPTION DUE TO FAULT
10	03-Dec-2021	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	634	Other Outage	Unplanned Outage	03-Dec-2021	13:58	03-Dec-2021	14:20	22	0.000303	INTERRUPTION DUE TO FAULT
11	04-Dec-2021	PARTS OF 7,BLOCK RAMESH NAGAR, B BLOCK RAJOURI GARDEN E BLOCK RAMESH NAGAR, 40 BLOCK RAMESH NAGAR MOTI NAGAR	595	Other Outage	Unplanned Outage	04-Dec-2021	13:47	04-Dec-2021	14:25	38	0.00016	INTERRUPTION DUE TO FAULT
12	04-Dec-2021	PART OF MELA GATE MOTI NAGAR	7	Other Outage	Unplanned Outage	04-Dec-2021	14:16	04-Dec-2021	15:23	67	0.000019	INTERRUPTION DUE TO FAULT
13	04-Dec-2021	PART OF 63 RAMA HVDS ROAD BISLERI MOTI NAGAR	4	Other Outage	Unplanned Outage	04-Dec-2021	15:18	04-Dec-2021	15:40	22	0.00012	INTERRUPTION DUE TO FAULT
14	06-Dec-2021	PARTS OF 36 TO 70, 71/7 RAMA ROAD MOTI NAGAR	168	Other Outage	Unplanned Outage	06-Dec-2021	02:34	06-Dec-2021	03:10	36	0.0001	INTERRUPTION DUE TO FAULT
15	06-Dec-2021	PARTS OF 36 TO 70, 71/7 RAMA ROAD MOTI NAGAR	77	Other Outage	Unplanned Outage	06-Dec-2021	02:34	06-Dec-2021	03:15	41	0.000057	INTERRUPTION DUE TO FAULT
16	06-Dec-2021	PARTS OF A BLK NARAINA IND AREA PH-2 MOTI NAGAR	53	Other Outage	Unplanned Outage	06-Dec-2021	13:02	06-Dec-2021	14:06	64	0.000018	INTERRUPTION DUE TO FAULT
17	06-Dec-2021	PARTS OF WALMIKI MANDIR PANDAY NAGAR MOTI NAGAR	2852	Other Outage	Unplanned Outage	06-Dec-2021	13:05	06-Dec-2021	13:20	15	0.000121	INTERRUPTION DUE TO FAULT
18	06-Dec-2021	PARTS OF WALMIKI MANDIR PANDAY NAGAR MOTI NAGAR	1964	Other Outage	Unplanned Outage	06-Dec-2021	13:05	06-Dec-2021	14:35	90	0.000749	INTERRUPTION DUE TO FAULT
19	07-Dec-2021	PARTS OF F BLOCK BALI NAGAR, WZ AREA BASI DARA PUR MOTI NAGAR	995	Other Outage	Unplanned Outage	07-Dec-2021	16:21	07-Dec-2021	17:10	49	0.000136	INTERRUPTION DUE TO FAULT
20	07-Dec-2021	PARTS OF A - BLOCK M S GARDEN, B BLOCK M S GARDEN, C BLOCK M S GARDEN, D BLOCK M S GARDEN, BANK ENCLAV MOTI NAGAR	417	Other Outage	Unplanned Outage	07-Dec-2021	17:53	07-Dec-2021	18:47	54	0.000075	INTERRUPTION DUE TO FAULT
21	09-Dec-2021	PART OF MAGDO MOTI NAGAR	6	Other Outage	Unplanned Outage	09-Dec-2021	13:10	09-Dec-2021	13:24	14	0.000008	INTERRUPTION DUE TO FAULT
22	09-Dec-2021	PARTS OF MAIN INDERPURI (EA, EG, ER, EF, EB BLOCK INDERPURI) MOTI NAGAR	312	Other Outage	Unplanned Outage	09-Dec-2021	13:52	09-Dec-2021	15:41	109	0.000151	INTERRUPTION DUE TO FAULT
23	09-Dec-2021	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	185	Other Outage	Unplanned Outage	09-Dec-2021	20:42	09-Dec-2021	21:07	25	0.00007	INTERRUPTION DUE TO FAULT
24	09-Dec-2021	PART OF 53 RAMA ROAD MOTI NAGAR	20	Other Outage	Unplanned Outage	09-Dec-2021	20:42	09-Dec-2021	21:30	48	0.000027	INTERRUPTION DUE TO FAULT
25	09-Dec-2021	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	107	Other Outage	Unplanned Outage	09-Dec-2021	20:42	09-Dec-2021	22:35	113	0.000157	INTERRUPTION DUE TO FAULT
26	10-Dec-2021	PARTS OF B, C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	57	Other Outage	Unplanned Outage	10-Dec-2021	15:06	10-Dec-2021	16:00	54	0.000119	INTERRUPTION DUE TO FAULT
27	10-Dec-2021	PART OF NEERI PH-1 MOTI NAGAR	15	Other Outage	Unplanned Outage	10-Dec-2021	15:30	10-Dec-2021	16:00	30	0.000033	INTERRUPTION DUE TO FAULT
28	10-Dec-2021	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTI NAGAR	1100	Other Outage	Unplanned Outage	10-Dec-2021	19:35	10-Dec-2021	19:55	20	0.000065	INTERRUPTION DUE TO FAULT
29	10-Dec-2021	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTI NAGAR	51	Other Outage	Unplanned Outage	10-Dec-2021	19:54	10-Dec-2021	21:00	66	0.000092	INTERRUPTION DUE TO FAULT
30	11-Dec-2021	PARTS OF IARI PUSA (PARTLY), NRC PUSA FLATS, PARTS OF CHIRIYA COLONY(IAS QTR) KAVERI APPARTMENT, A-BLK PUSA JUGGI,BTC MOTI NAGAR	524	Other Outage	Unplanned Outage	11-Dec-2021	06:51	11-Dec-2021	08:03	72	0.00001	INTERRUPTION DUE TO FAULT
31	11-Dec-2021	PARTS OF B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	46	Other Outage	Unplanned Outage	11-Dec-2021	14:35	11-Dec-2021	16:00	85	0.000024	INTERRUPTION DUE TO FAULT
32	11-Dec-2021	PARTS OF DSIDC -1, DSIDC NO-2, WHS 2/82 SIDE, KAMAL NEHRU CAMP, 8,9 BLOCK RAMESH NAGAR MOTI NAGAR	454	Other Outage	Unplanned Outage	11-Dec-2021	19:08	11-Dec-2021	20:12	64	0.000088	INTERRUPTION DUE TO FAULT
33	11-Dec-2021	PARTS OF DSIDC -1, DSIDC NO-2, WHS 2/82 SIDE, KAMAL NEHRU CAMP, 8,9 BLOCK RAMESH NAGAR MOTI NAGAR	266	Other Outage	Unplanned Outage	11-Dec-2021	19:08	11-Dec-2021	21:55	167	0.000185	FORCE MAJEURE DUE TO SABOTAGE
34	11-Dec-2021	PARTS OF DSIDC -1, DSIDC NO-2, WHS 2/82 SIDE, KAMAL NEHRU CAMP, 8,9 BLOCK RAMESH NAGAR MOTI NAGAR	52	Other Outage	Unplanned Outage	11-Dec-2021	19:08	11-Dec-2021	21:55	167	0.000092	FORCE MAJEURE DUE TO SABOTAGE
35	11-Dec-2021	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	292	Other Outage	Unplanned Outage	11-Dec-2021	19:28	11-Dec-2021	20:30	62	0.000034	INTERRUPTION DUE TO FAULT
36	11-Dec-2021	PARTS OF 62,63, RAMA ROAD BISLERI MOTI NAGAR	342	Other Outage	Unplanned Outage	11-Dec-2021	23:43	12-Dec-2021	00:59	76	0.00023	INTERRUPTION DUE TO FAULT
37	12-Dec-2021	PARTS OF A & B BLOCK CHUNA BHATTI PH. - 2, Y-BLK, A-15 PH-1, COMMUNITY CENTER, MOTI NAGAR	88	Other Outage	Unplanned Outage	12-Dec-2021	00:33	12-Dec-2021	01:09	36	0.000039	INTERRUPTION DUE TO FAULT
38	12-Dec-2021	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	293	Other Outage	Unplanned Outage	12-Dec-2021	10:09	12-Dec-2021	11:00	51	0.000113	INTERRUPTION DUE TO FAULT
39	12-Dec-2021	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASA DARAPUR, SOME PORTION OF BASA DARAPUR MOTI NAGAR	532	Other Outage	Unplanned Outage	12-Dec-2021	21:19	12-Dec-2021	21:50	31	0.000043	INTERRUPTION DUE TO FAULT
40	13-Dec-2021	PARTS OF DSIDC -1, DSIDC NO-2, WHS 2/82 SIDE, KAMAL NEHRU CAMP, 8,9 BLOCK RAMESH NAGAR MOTI NAGAR	52	Other Outage	Unplanned Outage	13-Dec-2021	07:43	13-Dec-2021	08:50	67	0.000056	INTERRUPTION DUE TO FAULT
41	13-Dec-2021	PARTS OF DSIDC -1, DSIDC NO-2, WHS 2/82 SIDE, KAMAL NEHRU CAMP, 8,9 BLOCK RAMESH NAGAR MOTI NAGAR	266	Other Outage	Unplanned Outage	13-Dec-2021	07:57	13-Dec-2021	08:50	53	0.000044	INTERRUPTION DUE TO FAULT
42	13-Dec-2021	PARTS OF B, C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	193	Other Outage	Unplanned Outage	13-Dec-2021	08:04	13-Dec-2021	08:32	28	0.000039	INTERRUPTION DUE TO FAULT
43	14-Dec-2021	PARTS OF B, C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	193	Other Outage	Unplanned Outage	14-Dec-2021	06:35	14-Dec-2021	07:00	25	0.000036	INTERRUPTION DUE TO FAULT
44	16-Dec-2021	PARTS OF 36 TO 70, 71/7 RAMA ROAD MOTI NAGAR	53	Other Outage	Unplanned Outage	16-Dec-2021	19:18	16-Dec-2021	22:05	167	0.0000232	FORCE MAJEURE DUE TO SABOTAGE
45	17-Dec-2021	PART OF C-BLK MANSAROVAR GARDEN MOTI NAGAR	4	Other Outage	Unplanned Outage	17-Dec-2021	14:21	17-Dec-2021	14:58	37	0.000021	INTERRUPTION DUE TO FAULT
46	20-Dec-2021	PARTS OF 62,63, RAMA ROAD BISLERI MOTI NAGAR	557	Other Outage	Unplanned Outage	20-Dec-2021	15:16	20-Dec-2021	16:00	44	0.000183	INTERRUPTION DUE TO FAULT
47	22-Dec-2021	PARTS OF 62,63, RAMA ROAD BISLERI MOTI NAGAR	557	Other Outage	Unplanned Outage	22-Dec-2021	11:57	22-Dec-2021	12:48	51	0.000007	INTERRUPTION DUE TO FAULT
48	22-Dec-2021	PARTS OF A & B BLOCK NARAINA INDUSTRIAL AREA PH - II MOTI NAGAR	2717	Other Outage	Unplanned Outage	22-Dec-2021	13:12	22-Dec-2021	13:49	37	0.000301	INTERRUPTION DUE TO FAULT
49	22-Dec-2021	PARTS OF A & B BLOCK NARAINA INDUSTRIAL AREA PH - II MOTI NAGAR	49	Other Outage	Unplanned Outage	22-Dec-2021	13:12	22-Dec-2021	13:52	40	0.000022	INTERRUPTION DUE TO FAULT
50	22-Dec-2021	PART OF B-BLOCK NARAINA INDUSTRIAL AREA PH-II MOTI NAGAR	3	Other Outage	Unplanned Outage	22-Dec-2021	13:12	22-Dec-2021	15:20	128	0.000035	FORCE MAJEURE DUE TO SABOTAGE
51	22-Dec-2021	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASA DARAPUR, SOME PORTION OF BASA DARAPUR MOTI NAGAR	532	Other Outage	Unplanned Outage	22-Dec-2021	13:50	22-Dec-2021	14:25	35	0.000049	INTERRUPTION DUE TO FAULT
52	23-Dec-2021	PART OF C BLOCK NARAINA INDUSTRIAL AREA PH - 1 MOTI NAGAR	9	Other Outage	Unplanned Outage	23-Dec-2021	19:44	23-Dec-2021	20:10	26	0.000014	INTERRUPTION DUE TO FAULT
53	24-Dec-2021	PARTS OF DLF NO 3 KIRTI NAGAR MOTI NAGAR	314	Other Outage	Unplanned Outage	24-Dec-2021	11:05	24-Dec-2021	11:30	25	0.000556	INTERRUPTION DUE TO FAULT
54	24-Dec-2021	PARTS OF DLF NO 3 KIRTI NAGAR MOTI NAGAR	167	Other Outage	Unplanned Outage	24-Dec-2021	12:29	24-Dec-2021	13:20	51	0.000071	

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unsed (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
61	27-Dec-2021	PARTS OF B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	54	Other Outage	Unplanned Outage	27-Dec-2021	11:28	27-Dec-2021	13:30	122	0.00068	FORCE MAJEURE DUE TO SABOTAGE
62	27-Dec-2021	PARTS OF B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	46	Other Outage	Unplanned Outage	27-Dec-2021	13:06	27-Dec-2021	13:27	21	0.00029	INTERRUPTION DUE TO FAULT
63	27-Dec-2021	PART OF 41 RAMA ROAD MOTI NAGAR	7	Other Outage	Unplanned Outage	27-Dec-2021	15:42	27-Dec-2021	15:58	16	0.00009	SYSTEM SCHEDULE OUTAGE
64	28-Dec-2021	PART OF BALI NAGAR MOTI NAGAR	11	Other Outage	Unplanned Outage	28-Dec-2021	10:20	28-Dec-2021	10:55	35	0.00019	INTERRUPTION DUE TO FAULT
65	28-Dec-2021	PARTS OF BALI NAGAR MOTI NAGAR	1097	Other Outage	Unplanned Outage	28-Dec-2021	10:36	28-Dec-2021	10:55	19	0.00016	INTERRUPTION DUE TO FAULT
66	28-Dec-2021	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	635	Other Outage	Unplanned Outage	28-Dec-2021	17:11	28-Dec-2021	18:15	64	0.000657	INTERRUPTION DUE TO FAULT
67	29-Dec-2021	PART OF B BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	11	Other Outage	Unplanned Outage	29-Dec-2021	12:31	29-Dec-2021	13:05	34	0.000009	INTERRUPTION DUE TO FAULT
68	29-Dec-2021	PARTS OF A,B,D, BLOCK KIRTI NAGAR, TAGORE MARKET, KALRA HOSPITAL SCOOTER MARKET 42 DLF SIDE MOTI NAGAR	431	Other Outage	Unplanned Outage	29-Dec-2021	23:48	30-Dec-2021	00:20	32	0.000131	INTERRUPTION DUE TO FAULT
69	29-Dec-2021	PARTS OF A,B,D, BLOCK KIRTI NAGAR, TAGORE MARKET, KALRA HOSPITAL SCOOTER MARKET 42 DLF SIDE MOTI NAGAR	56	Other Outage	Unplanned Outage	29-Dec-2021	23:48	30-Dec-2021	01:10	82	0.000113	INTERRUPTION DUE TO FAULT
70	30-Dec-2021	PARTS OF C-BLK JJ COLONY INDER PURI MOTI NAGAR MOTI NAGAR	4294	Other Outage	Unplanned Outage	30-Dec-2021	06:33	30-Dec-2021	07:05	32	0.000373	INTERRUPTION DUE TO FAULT
71	30-Dec-2021	PARTS OF C-BLK JJ COLONY INDER PURI MOTI NAGAR MOTI NAGAR	1090	Other Outage	Unplanned Outage	30-Dec-2021	06:33	30-Dec-2021	07:12	39	0.000119	INTERRUPTION DUE TO FAULT
72	30-Dec-2021	PARTS OF F BLOCK M'S GARDEN, E BLOCK M'S GARDEN FA - 357 M S GARDEN & SHARDA PURI MOTI NAGAR	2012	Other Outage	Unplanned Outage	30-Dec-2021	08:02	30-Dec-2021	08:15	13	0.000075	INTERRUPTION DUE TO FAULT
73	30-Dec-2021	PARTS OF F BLOCK M'S GARDEN, E BLOCK M'S GARDEN FA - 357 M S GARDEN & SHARDA PURI MOTI NAGAR	128	Other Outage	Unplanned Outage	30-Dec-2021	08:02	30-Dec-2021	08:23	21	0.000069	INTERRUPTION DUE TO FAULT
74	30-Dec-2021	PART OF 71/7 RAMA ROAD MOTI NAGAR	14	Other Outage	Unplanned Outage	30-Dec-2021	12:59	30-Dec-2021	13:29	30	0.000008	INTERRUPTION DUE TO FAULT
75	30-Dec-2021	PART OF NEERI PH-1 MOTI NAGAR	2	Other Outage	Unplanned Outage	30-Dec-2021	19:12	30-Dec-2021	19:30	18	0.000005	INTERRUPTION DUE TO FAULT
76	31-Dec-2021	PARTS OF A,B,D, BLOCK KIRTI NAGAR, TAGORE MARKET, KALRA HOSPITAL SCOOTER MARKET 42 DLF SIDE MOTI NAGAR	56	Other Outage	Unplanned Outage	31-Dec-2021	15:31	31-Dec-2021	16:20	49	0.000014	INTERRUPTION DUE TO FAULT
77	02-Dec-2021	PARTS OF BLK JJ COLONY, PART OF INDER PURI MOTI NAGAR	277	630 kVA	Planned Outage	02-Dec-2021	10:23	02-Dec-2021	12:44	141	0.00012	PLANNED OUTAGE
78	02-Dec-2021	PART OF 59 RAMA ROAD MOTI NAGAR	10	400 kVA	Unplanned Outage	02-Dec-2021	11:51	02-Dec-2021	12:14	23	0.00001	SYSTEM SCHEDULE OUTAGE
79	02-Dec-2021	PART OF A BLK NARAINA IND AREA PH-2 MOTI NAGAR	3	160 kVA	Unplanned Outage	02-Dec-2021	12:07	02-Dec-2021	12:49	42	0.00001	SYSTEM SCHEDULE OUTAGE
80	02-Dec-2021	PARTS OF E BLK JJ COLONY, PART OF INDER PURI MOTI NAGAR	232	630 kVA	Planned Outage	02-Dec-2021	13:19	02-Dec-2021	15:34	135	0.00011	PLANNED OUTAGE
81	03-Dec-2021	PARTS OF BLK JJ COLONY, PART OF INDER PURI MOTI NAGAR	252	990 kVA	Planned Outage	03-Dec-2021	10:28	03-Dec-2021	12:34	126	0.00032	PLANNED OUTAGE
82	03-Dec-2021	PART OF A-BLK KHURANA NIA PH-1 MOTI NAGAR	5	250 kVA	Unplanned Outage	03-Dec-2021	11:29	03-Dec-2021	12:21	52	0.00001	SYSTEM SCHEDULE OUTAGE
83	03-Dec-2021	PARTS OF BLK JJ COLONY, PART OF INDER PURI MOTI NAGAR	184	630 kVA	Planned Outage	03-Dec-2021	13:28	03-Dec-2021	14:54	86	0.00005	PLANNED OUTAGE
84	06-Dec-2021	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	292	Other Outage	Planned Outage	06-Dec-2021	10:22	06-Dec-2021	17:20	418	0.00023	PLANNED OUTAGE
85	06-Dec-2021	PART OF B BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	8	250 kVA	Unplanned Outage	06-Dec-2021	11:27	06-Dec-2021	12:08	41	0.00001	SYSTEM SCHEDULE OUTAGE
86	07-Dec-2021	PARTS OF F, E & B BLOCK DDA FLAT RANJIT NAGAR, MUNSHI RAM BAGH RANJIT NAGAR, SATYAM CINEMA RANJIT NAGAR, MAIN PATEL ROAD, SHADI KHAM PUR VILLAGE,PART OF COMMUNITY CENTER RANJEET NAGAR DTC COLONY MOTI NAGAR	350	630 kVA	Planned Outage	07-Dec-2021	10:38	07-Dec-2021	13:29	171	0.00014	PLANNED OUTAGE
87	07-Dec-2021	PARTS OF WHS NO. 1, B-1 BLOCK WHS, A BLOCK WHS, A-1, A-2 WHS & JAWAR CAMP JJ CLUSTER MOTI NAGAR	483	Other Outage	Planned Outage	07-Dec-2021	11:18	07-Dec-2021	14:55	217	0.00036	PLANNED OUTAGE
88	07-Dec-2021	PART OF GOPINATH BAZAR MOTI NAGAR	1	Other Outage	Planned Outage	07-Dec-2021	11:23	07-Dec-2021	16:59	336	0.00009	PLANNED OUTAGE
89	07-Dec-2021	PART OF 53 RAMA ROAD MOTI NAGAR	5	400 kVA	Unplanned Outage	07-Dec-2021	11:30	07-Dec-2021	12:35	65	0.00002	SYSTEM SCHEDULE OUTAGE
90	07-Dec-2021	PARTS OF F, E & B BLOCK DDA FLAT RANJIT NAGAR, MUNSHI RAM BAGH RANJIT NAGAR, SATYAM CINEMA RANJIT NAGAR, MAIN PATEL ROAD, SHADI KHAM PUR VILLAGE,PART OF COMMUNITY CENTER RANJEET NAGAR DTC COLONY MOTI NAGAR	318	990 kVA	Planned Outage	07-Dec-2021	13:31	07-Dec-2021	15:47	136	0.00030	PLANNED OUTAGE
91	08-Dec-2021	PARTS OF DHOBII GHAT, MANDIR WALI GALI MOTI NAGAR	1498	Other Outage	Planned Outage	08-Dec-2021	10:30	08-Dec-2021	15:09	279	0.00116	PLANNED OUTAGE
92	08-Dec-2021	PART OF RAMA ROAD MOTI NAGAR MOTI NAGAR	8	315 kVA	Unplanned Outage	08-Dec-2021	13:30	08-Dec-2021	15:29	119	0.00007	SYSTEM SCHEDULE OUTAGE
93	09-Dec-2021	PARTS OF H,F,E,M,N,BLOCK KIRTI NAGAR MOTI NAGAR	403	990 kVA	Planned Outage	09-Dec-2021	10:12	09-Dec-2021	12:51	159	0.00022	PLANNED OUTAGE
94	09-Dec-2021	PARTS OF H,F,E,M,N,BLOCK KIRTI NAGAR MOTI NAGAR	323	990 kVA	Planned Outage	09-Dec-2021	10:13	09-Dec-2021	12:52	159	0.00018	PLANNED OUTAGE
95	10-Dec-2021	PARTS OF C, B, A, NAMDHARI, SD MANDIR KIRTI NAGAR,PART OF N BLOCK KIRTI NAGAR & TAGOR MKT. MOTI NAGAR	914	Other Outage	Planned Outage	10-Dec-2021	10:30	10-Dec-2021	13:54	204	0.00045	PLANNED OUTAGE
96	10-Dec-2021	PARTS OF IARI PUSA (PARTLY), PART OF PUSA RESIDENTIAL COMPLEX PHYATRON, NRL MOTI NAGAR	213	Other Outage	Planned Outage	10-Dec-2021	10:46	10-Dec-2021	14:38	232	0.00013	PLANNED OUTAGE
97	10-Dec-2021	PARTS OF IARI PUSA (PARTLY), NRC PUSA FLATS, PARTS OF CHIRYA COLONY(IAS QTR) KAVERI APPARTMENT, R-BLK PUSA JUGGI BLOTI MOTI NAGAR	123	Other Outage	Planned Outage	10-Dec-2021	14:41	10-Dec-2021	16:34	113	0.00006	PLANNED OUTAGE
98	11-Dec-2021	PART OF E BLK JJ COLONY MOTI NAGAR	4	Other Outage	Planned Outage	11-Dec-2021	09:25	11-Dec-2021	17:51	506	0.00014	PLANNED OUTAGE
99	11-Dec-2021	PARTS OF BALI NAGAR MOTI NAGAR	1103	Other Outage	Planned Outage	11-Dec-2021	10:23	11-Dec-2021	16:28	365	0.00122	PLANNED OUTAGE
100	13-Dec-2021	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	634	Other Outage	Planned Outage	13-Dec-2021	09:58	13-Dec-2021	16:43	405	0.00079	PLANNED OUTAGE
101	13-Dec-2021	PART OF 1/5 NAFJ GARH ROAD MOTI NAGAR	15	400 kVA	Unplanned Outage	13-Dec-2021	12:10	13-Dec-2021	12:37	27	0.00001	SYSTEM SCHEDULE OUTAGE
102	13-Dec-2021	PART OF A-17 NIA PH-2 MOTI NAGAR	4	160 kVA	Unplanned Outage	13-Dec-2021	12:22	13-Dec-2021	13:16	54	0.00002	SYSTEM SCHEDULE OUTAGE
103	14-Dec-2021	PART OF PUSA ITI FLATS MOTI NAGAR	1	Other Outage	Planned Outage	14-Dec-2021	12:29	14-Dec-2021	14:44	135	0.00004	PLANNED OUTAGE
104	15-Dec-2021	PARTS OF F, E, D, BLOCK MOTI NAGAR	665	990 kVA	Planned Outage	15-Dec-2021	10:44	15-Dec-2021	14:14	210	0.00029	PLANNED OUTAGE
105	15-Dec-2021	PARTS OF 24, 17, BLOCK MEDICAL SUPRENTENDENT MOTI NAGAR	281	630 kVA	Planned Outage	15-Dec-2021	10:49	15-Dec-2021	14:16	207	0.00012	PLANNED OUTAGE
106	15-Dec-2021	PART OF A-58 ASTIC ELECTRICALS MOTI NAGAR	2	250 kVA	Unplanned Outage	15-Dec-2021	14:04	15-Dec-2021	14:26	22	0.00001	SYSTEM SCHEDULE OUTAGE
107	16-Dec-2021	PART OF B BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	15	400 kVA	Unplanned Outage	16-Dec-2021	13:23	16-Dec-2021	14:36	73	0.00002	SYSTEM SCHEDULE OUTAGE
108	17-Dec-2021	PARTS OF WHS NO. 1, B-1 BLOCK WHS, A BLOCK WHS, A-1, A-2 WHS & JAWAR CAMP JJ CLUSTER MOTI NAGAR	1464	Other Outage	Planned Outage	17-Dec-2021	10:44	17-Dec-2021	16:38	354	0.00148	PLANNED OUTAGE
109	18-Dec-2021	PARTS OF C-BLK JJ COLONY INDER PURI MOTI NAGAR MOTI NAGAR	577	Other Outage	Planned Outage	18-Dec-2021	10:42	18-Dec-2021	15:32	290	0.00242	PLANNED OUTAGE
110	18-Dec-2021	PARTS OF 24, 17, BLOCK MEDICAL SUPRENTENDENT MOTI NAGAR	1171	Other Outage	Planned Outage	18-Dec-2021	10:50	18-Dec-2021	14:55	245	0.00170	PLANNED OUTAGE
111	19-Dec-2021	PARTS OF BALI NAGAR MOTI NAGAR	1103	Other Outage	Planned Outage	19-Dec-2021	11:13	19-Dec-2021	12:12	59	0.00016	PLANNED OUTAGE
112	20-Dec-2021	PARTS OF E-24 NARAINA VIHAR, KRISHI KUNI, Y - BLOCK LOHA MANDI, I - BLK NABAINA VIHAR MOTI NAGAR	92	Other Outage	Planned Outage	20-Dec-2021	10:21	20-Dec-2021	17:57	456	0.00025	PLANNED OUTAGE
113	20-Dec-2021	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK MOTI NAGAR	715	Other Outage	Planned Outage	20-Dec-2021	11:02	20-Dec-2021	13:28	146	0.00028	PLANNED OUTAGE
114	20-Dec-2021	PARTS OF LAKKAD MANDI AND BALI NAGAR MOTI NAGAR	250	990 kVA	Planned Outage	20-Dec-2021	11:05	20-Dec-2021	13:30	145	0.00008	PLANNED OUTAGE
115	20-Dec-2021	PARTS OF LAKKAD MANDI AND BALI NAGAR MOTI NAGAR	388	990 kVA	Planned Outage	20-Dec-2021	11:07	20-Dec-2021	15:23	256	0.00107	PLANNED OUTAGE
116	20-Dec-2021	PARTS OF E & B BLOCK KIRTI NAGAR, F BLOCK EXTN. MOTI NAGAR	213	630 kVA	Planned Outage	20-Dec-2021	11:20	20-Dec-2021	12:47	87	0.00024	PLANNED OUTAGE
117	21-Dec-2021	PARTS OF 7,BLOCK RAMESH NAGAR, B BLOCK RAJOURI GARDEN E BLOCK RAMESH NAGAR. 40 BLOCK RAMESH NAGAR MOTI NAGAR	316	630 kVA	Planned Outage	21-Dec-2021	10:59	21-Dec-2021	14:32	213	0.00036	PLANNED OUTAGE
118	21-Dec-2021	PARTS OF 7,BLOCK RAMESH NAGAR, B BLOCK RAJOURI GARDEN E BLOCK RAMESH NAGAR. 40 BLOCK RAMESH NAGAR MOTI NAGAR	495	630 kVA	Planned Outage	21-Dec-2021	11:08	21-Dec-2021	14:31	203	0.00039	PLANNED OUTAGE
119	21-Dec-2021	PARTS OF SHADI KHAM PUR, A & B BLOCK DDA FLAT RANJIT NAGAR & GURU ARIJUN NAGAR,PARTS OF MANDIR WALI GALI MOTI NAGAR	543	630 kVA	Planned Outage	21-Dec-2021	11:12	21-Dec-2021	12:49	97	0.00016	PLANNED OUTAGE
120	21-Dec-2021	PARTS OF 7,BLOCK RAMESH NAGAR, B BLOCK RAJOURI GARDEN E BLOCK RAMESH NAGAR. 40 BLOCK RAMESH NAGAR MOTI NAGAR	387	990 kVA	Planned Outage	21-Dec-2021	11:16	21-Dec-2021	14:34	198	0.00033	PLANNED OUTAGE
121	21-Dec-2021	PARTS OF 63 RAMIA HVDS ROAD BISLERI MOTI NAGAR	9	400 kVA	Unplanned Outage	21-Dec-2021	11:24	21-Dec-2021	12:00	36	0.00001	SYSTEM SCHEDULE OUTAGE
122	21-Dec-2021	PARTS OF RANJIT NAGAR,COMMUNITY CENTER MOTI NAGAR	384	630 kVA	Planned Outage	21-Dec-2021	13:15	21-Dec-2021	16:04	169	0.00028	PLANNED OUTAGE
123	22-Dec-2021	PARTS OF A128 QTR DDA FLAT, MAKAT LAL MOTI NAGAR	573	Other Outage	Planned Outage	22-Dec-2021	10:34	22-Dec-2021	14:56	262	0.00044	PLANNED OUTAGE
124	22-Dec-2021	PARTS OF SOUTH PATEL NAGAR (7, 8, 9 BLOCKS),COMMERCIAL MARKET SOUTH PATEL NAGAR, PARTS OF RANJIT NAGAR (GAI NO 3, 4, 5, 6, 7, 8, 9,21), KAB NO - 2, PUSA,MAAN, OLD PUSA GATE,VIVEK, HANUMAAN CHOWK. MOTI NAGAR	246	630 kVA	Planned Outage	22-Dec-2021	10:43	22-Dec-2021	14:55	252	0.00021	PLANNED OUTAGE
125	22-Dec-2021	PARTS OF H,F,E,M,N,BLOCK KIRTI NAGAR MOTI NAGAR	317	990 kVA	Planned Outage	22-Dec-2021	11:09	22-Dec-2021	13:41	152	0.00021	PLANNED OUTAGE
126	22-Dec-2021	PART OF A BLK NARAINA IND AREA PH-1 MOTI NAGAR	2	100 kVA	Unplanned Outage	22-Dec-2021	14:19	22-Dec-2021	15:48	89	0.00002	SYSTEM SCHEDULE OUTAGE
127	23-Dec-2021	PARTS OF IARI PUSA (PARTLY), NRC PUSA FLATS, PARTS OF CHIRYA COLONY(IAS QTR) KAVERI APPARTMENT, R-BLK PUSA JUGGI BLOTI MOTI NAGAR	527	Other Outage	Planned Outage	23-Dec-2021	11:11	23-Dec-2021	13:51	160	0.00022	PLANNED OUTAGE
128	24-Dec-2021	PARTS OF SARASWATI GARDEN, 58 BLOCK RAMESH NAGAR, 8 BLOCK, 9 BLOCK, 3 BLOCK, 4 BLOCK, C BLOCK RAMESH NAGAR, 5 BLOCK RAMESH NAGAR MOTI NAGAR	386	630 kVA	Planned Outage	24-Dec-2021	10:48	24-Dec-2021	14:26	218	0.00018	PLANNED OUTAGE
129	24-Dec-2021	PARTS OF SARASWATI GARDEN, 58 BLOCK RAMESH NAGAR, 8 BLOCK, 9 BLOCK, 3 BLOCK, 4 BLOCK, C BLOCK RAMESH NAGAR, 5 BLOCK RAMESH NAGAR MOTI NAGAR	488	990 kVA	Planned Outage	24-Dec-2021	10:51	24-Dec-2021	14:27	216	0.00024	PLANNED OUTAGE
130	24-Dec-2021	PART OF BLK-B NARAINA IND AREA PH-2 MOTI NAGAR	4	160 kVA	Unplanned Outage	24-Dec-2021	11:13	24-Dec-2021	11:33	20	0.00001	SYSTEM SCHEDULE OUTAGE
131	24-Dec-2021	PART OF COMMUNITY CENTER, MOTI NAGAR	6	160 kVA	Unplanned Outage	24-Dec-2021	12:19	24-Dec-2021	13:45	86	0.00002	SYSTEM SCHEDULE OUTAGE
132	24-Dec-2021	PARTS OF COLD HOLD, SHOPPING CENTER, KIRTI NAGAR INDUS.AREA. MOTI NAGAR	180	315 kVA	Unplanned Outage	24-Dec-2021	16:23	24-Dec-2021	16:51	28	0.00001	SYSTEM SCHEDULE OUTAGE
133	27-Dec-2021	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	154	Other Outage	Planned Outage	27-Dec-2021	10:24	27-Dec-2021	16:44	380	0.00021	PLANNED OUTAGE
134	27-Dec-2021	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASA DARAPUR, SOME PORTION OF BASA DARAPUR MOTI NAGAR	86	Other Outage	Planned Outage	27-Dec-2021	10:42	27-Dec-2021	15:02	260	0.00007	PLANNED OUTAGE
135	27-Dec-2021	PART OF 4 BLOCK KIRTI NAGAR INDUSTRIAL AREA. MOTI NAGAR	7	100 kVA	Unplanned Outage	27-Dec-2021	13:20	27-Dec-2021	13:42	22	0.	

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
142	30-Dec-2021	PARTS OF BLK- F SUDARSHAN PARK LANDMARK FUN CINEMA MOTI NAGAR	2261	Other Outage	Planned Outage	30-Dec-2021	11:45	30-Dec-2021	15:55	250	0.00125	PLANNED OUTAGE
143	30-Dec-2021	PART OF 63 RAMA HVDS ROAD BISLERI MOTI NAGAR	9	400 kVA	Unplanned Outage	30-Dec-2021	16:06	30-Dec-2021	16:40	34	0.00001	SYSTEM SCHEDULE OUTAGE
144	31-Dec-2021	PARTS OF E & G BLOCK KIRTI NAGAR, F BLOCK EXTN. MOTI NAGAR	172	Other Outage	Planned Outage	31-Dec-2021	10:37	31-Dec-2021	17:20	403	0.00022	PLANNED OUTAGE
145	31-Dec-2021	PARTS OF E & G BLOCK KIRTI NAGAR, F BLOCK EXTN. MOTI NAGAR	279	990 kVA	Planned Outage	31-Dec-2021	10:40	31-Dec-2021	17:21	401	0.00022	PLANNED OUTAGE
146	31-Dec-2021	PARTS OF A & B BLOCK NARAINA INDUSTRIAL AREA PH - II MOTI NAGAR	52	Other Outage	Planned Outage	31-Dec-2021	11:44	31-Dec-2021	12:42	58	0.00002	PLANNED OUTAGE
NARELA												
1	01-Dec-2021	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	734	Other Outage	Unplanned Outage	01-Dec-2021	07:30	01-Dec-2021	08:00	30	0.000092	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	725	Other Outage	Unplanned Outage	01-Dec-2021	07:51	01-Dec-2021	11:51	240	0.000733	FORCE MAJEURE DUE TO SABOTAGE
3	01-Dec-2021	PART OF NAFE SINGH NO-2 NARELA	16	Other Outage	Unplanned Outage	01-Dec-2021	08:15	01-Dec-2021	19:28	673	0.00187	FORCE MAJEURE DUE TO SABOTAGE
4	01-Dec-2021	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIUPUR NARELA	3715	Other Outage	Unplanned Outage	01-Dec-2021	09:44	01-Dec-2021	10:30	46	0.000648	INTERRUPTION DUE TO FAULT
5	01-Dec-2021	PART OF E BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	01-Dec-2021	11:37	01-Dec-2021	15:15	218	0.000661	FORCE MAJEURE DUE TO SABOTAGE
6	01-Dec-2021	PART OF D BLOCK NARELA	4	Other Outage	Unplanned Outage	01-Dec-2021	11:41	01-Dec-2021	13:36	115	0.000032	INTERRUPTION DUE TO FAULT
7	01-Dec-2021	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3978	Other Outage	Unplanned Outage	01-Dec-2021	11:43	01-Dec-2021	12:00	17	0.000241	INTERRUPTION DUE TO FAULT
8	01-Dec-2021	PART OF H BLOCK NARELA	2	Other Outage	Unplanned Outage	01-Dec-2021	12:23	01-Dec-2021	19:54	451	0.000125	FORCE MAJEURE DUE TO SABOTAGE
9	01-Dec-2021	PARTS OF F-2010 DSIDC NARELA	43	Other Outage	Unplanned Outage	01-Dec-2021	14:09	01-Dec-2021	14:24	15	0.000075	INTERRUPTION DUE TO FAULT
10	01-Dec-2021	PARTS OF C & E BLOCK DSIDC NARELA	37	Other Outage	Unplanned Outage	01-Dec-2021	16:17	01-Dec-2021	17:17	60	0.000005	INTERRUPTION DUE TO FAULT
11	01-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOJA VILLAGE NARELA	98	Other Outage	Unplanned Outage	01-Dec-2021	16:22	01-Dec-2021	19:28	186	0.000155	FORCE MAJEURE DUE TO SABOTAGE
12	01-Dec-2021	PARTS OF H BLOCK DSIDC NARELA	73	Other Outage	Unplanned Outage	01-Dec-2021	17:04	01-Dec-2021	19:54	170	0.000142	FORCE MAJEURE DUE TO SABOTAGE
13	01-Dec-2021	PART OF F BLOCK DSIDC NARELA	5	Other Outage	Unplanned Outage	01-Dec-2021	19:06	01-Dec-2021	19:52	46	0.000013	INTERRUPTION DUE TO FAULT
14	01-Dec-2021	PART OF DSIDC-1 INDS.AREA NARELA	4	Other Outage	Unplanned Outage	01-Dec-2021	20:00	01-Dec-2021	20:25	25	0.000013	INTERRUPTION DUE TO FAULT
15	01-Dec-2021	PART OF F BLOCK NARELA	3	Other Outage	Unplanned Outage	01-Dec-2021	22:03	01-Dec-2021	22:41	38	0.000021	SYSTEM SCHEDULE OUTAGE
16	02-Dec-2021	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1590	Other Outage	Unplanned Outage	02-Dec-2021	06:58	02-Dec-2021	07:10	12	0.00005	INTERRUPTION DUE TO FAULT
17	02-Dec-2021	PART OF NO-10 C BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	02-Dec-2021	07:10	02-Dec-2021	11:39	269	0.000149	FORCE MAJEURE DUE TO SABOTAGE
18	02-Dec-2021	PARTS OF NO-10 C BLOCK DSIDC NARELA	32	Other Outage	Unplanned Outage	02-Dec-2021	07:55	02-Dec-2021	11:39	224	0.000124	FORCE MAJEURE DUE TO SABOTAGE
19	02-Dec-2021	PART OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA NARELA	4	Other Outage	Unplanned Outage	02-Dec-2021	10:47	02-Dec-2021	11:19	32	0.000018	INTERRUPTION DUE TO FAULT
20	02-Dec-2021	PART OF BRAHAM PRAKASH SUNGER PUR NARELA	20	Other Outage	Unplanned Outage	02-Dec-2021	13:06	02-Dec-2021	16:41	215	0.000179	FORCE MAJEURE DUE TO SABOTAGE
21	02-Dec-2021	PART OF A BLOCK DSIDC NARELA	2	Other Outage	Unplanned Outage	02-Dec-2021	13:42	02-Dec-2021	15:07	85	0.000024	INTERRUPTION DUE TO FAULT
22	02-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	596	Other Outage	Unplanned Outage	02-Dec-2021	16:11	02-Dec-2021	16:42	31	0.000129	INTERRUPTION DUE TO FAULT
23	02-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	3593	Other Outage	Unplanned Outage	02-Dec-2021	17:16	02-Dec-2021	17:40	24	0.000167	INTERRUPTION DUE TO FAULT
24	02-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	2639	Other Outage	Unplanned Outage	02-Dec-2021	17:16	02-Dec-2021	18:05	49	0.000272	INTERRUPTION DUE TO FAULT
25	02-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	298	Other Outage	Unplanned Outage	02-Dec-2021	17:16	02-Dec-2021	19:05	109	0.000151	INTERRUPTION DUE TO FAULT
26	02-Dec-2021	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY PREM NAGAR, NARELA	130	Other Outage	Unplanned Outage	02-Dec-2021	18:36	02-Dec-2021	20:05	89	0.000124	INTERRUPTION DUE TO FAULT
27	02-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	596	Other Outage	Unplanned Outage	02-Dec-2021	18:43	02-Dec-2021	20:15	92	0.000383	INTERRUPTION DUE TO FAULT
28	02-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	163	Other Outage	Unplanned Outage	02-Dec-2021	19:18	02-Dec-2021	21:15	117	0.000162	INTERRUPTION DUE TO FAULT
29	02-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	116	Other Outage	Unplanned Outage	02-Dec-2021	19:31	02-Dec-2021	20:43	72	0.0001	INTERRUPTION DUE TO FAULT
30	02-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, IMP SCHOOL NARELA	111	Other Outage	Unplanned Outage	02-Dec-2021	20:36	02-Dec-2021	20:51	15	0.000004	INTERRUPTION DUE TO FAULT
31	02-Dec-2021	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIUPUR NARELA	3733	Other Outage	Unplanned Outage	02-Dec-2021	20:52	02-Dec-2021	22:20	88	0.000736	INTERRUPTION DUE TO FAULT
32	03-Dec-2021	PARTS OF F BLOCK DSIDC NARELA	26	Other Outage	Unplanned Outage	03-Dec-2021	11:08	03-Dec-2021	12:36	88	0.000122	INTERRUPTION DUE TO FAULT
33	03-Dec-2021	PART OF NO-58 H-BLOCK NARELA	2	Other Outage	Unplanned Outage	03-Dec-2021	11:26	03-Dec-2021	12:41	75	0.000042	INTERRUPTION DUE TO FAULT
34	03-Dec-2021	PARTS OF B BLOCK DSIDC NARELA	51	Other Outage	Unplanned Outage	03-Dec-2021	11:43	03-Dec-2021	12:15	32	0.000045	INTERRUPTION DUE TO FAULT
35	03-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGI PUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	65	Other Outage	Unplanned Outage	03-Dec-2021	12:38	03-Dec-2021	13:52	74	0.000062	INTERRUPTION DUE TO FAULT
36	03-Dec-2021	PART OF H BLOCK NARELA	2	Other Outage	Unplanned Outage	03-Dec-2021	14:39	03-Dec-2021	16:16	97	0.000027	INTERRUPTION DUE TO FAULT
37	03-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	530	Other Outage	Unplanned Outage	03-Dec-2021	16:05	03-Dec-2021	16:51	46	0.000256	INTERRUPTION DUE TO FAULT
38	03-Dec-2021	PARTS OF C & E BLOCK DSIDC NARELA	37	Other Outage	Unplanned Outage	03-Dec-2021	17:27	03-Dec-2021	17:45	18	0.000025	INTERRUPTION DUE TO FAULT
39	03-Dec-2021	PARTS OF C & E BLOCK DSIDC NARELA	52	Other Outage	Unplanned Outage	03-Dec-2021	18:14	03-Dec-2021	19:19	65	0.000181	INTERRUPTION DUE TO FAULT
40	03-Dec-2021	PART OF H BLOCK NARELA	6	Other Outage	Unplanned Outage	03-Dec-2021	19:19	03-Dec-2021	19:49	30	0.000017	INTERRUPTION DUE TO FAULT
41	04-Dec-2021	PART OF DSIDC B-2562 NARELA	3	Other Outage	Unplanned Outage	04-Dec-2021	12:05	04-Dec-2021	13:23	78	0.000022	INTERRUPTION DUE TO FAULT
42	04-Dec-2021	PART OF NO.35 F-BLOCK DSIDC NARELA	3	Other Outage	Unplanned Outage	04-Dec-2021	13:07	04-Dec-2021	13:45	38	0.000021	INTERRUPTION DUE TO FAULT
43	04-Dec-2021	PART OF B BLOCK DSIDC NARELA	2	Other Outage	Unplanned Outage	04-Dec-2021	14:44	04-Dec-2021	15:16	32	0.000018	INTERRUPTION DUE TO FAULT
44	04-Dec-2021	PART OF DSIDC FACTORY NO-E-664 NARELA	2	Other Outage	Unplanned Outage	04-Dec-2021	18:14	04-Dec-2021	19:11	57	0.000032	INTERRUPTION DUE TO FAULT
45	04-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	826	Other Outage	Unplanned Outage	04-Dec-2021	21:29	04-Dec-2021	23:09	100	0.000828	INTERRUPTION DUE TO FAULT
46	04-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	446	Other Outage	Unplanned Outage	04-Dec-2021	21:29	05-Dec-2021	02:04	275	0.000762	FORCE MAJEURE DUE TO SABOTAGE
47	05-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	786	Other Outage	Unplanned Outage	05-Dec-2021	01:29	05-Dec-2021	02:04	35	0.000097	INTERRUPTION DUE TO FAULT
48	05-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	1828	Other Outage	Unplanned Outage	05-Dec-2021	09:00	05-Dec-2021	09:26	26	0.000129	INTERRUPTION DUE TO FAULT
49	05-Dec-2021	PARTS OF C BLOCK, DSIDC NARELA	28	Other Outage	Unplanned Outage	05-Dec-2021	11:00	05-Dec-2021	12:39	99	0.000028	INTERRUPTION DUE TO FAULT
50	06-Dec-2021	PART OF C BLOCK NARELA	3	Other Outage	Unplanned Outage	06-Dec-2021	10:36	06-Dec-2021	12:40	124	0.000034	FORCE MAJEURE DUE TO SABOTAGE
51	06-Dec-2021	PARTS OF DSIDC FACTORY NO: F-1829 TO F-1863 AND A-1 TO A-34 NARELA	64	Other Outage	Unplanned Outage	06-Dec-2021	11:16	06-Dec-2021	12:10	54	0.000015	INTERRUPTION DUE TO FAULT
52	06-Dec-2021	PARTS OF ALL BLOCK OF DSIDC INDUSTRIAL AREA NARELA	31	Other Outage	Unplanned Outage	06-Dec-2021	11:51	06-Dec-2021	16:00	249	0.000138	FORCE MAJEURE DUE TO FIRE
53	06-Dec-2021	PARTS OF DSIDC FACTORY NO: F-1829 TO F-1863 AND A-1 TO A-34 NARELA	56	Other Outage	Unplanned Outage	06-Dec-2021	12:28	06-Dec-2021	13:14	46	0.000013	INTERRUPTION DUE TO FAULT
54	06-Dec-2021	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIUPUR NARELA	3733	Other Outage	Unplanned Outage	06-Dec-2021	13:16	06-Dec-2021	15:27	131	0.001817	FORCE MAJEURE DUE TO SABOTAGE
55	06-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGI PUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	45	Other Outage	Unplanned Outage	06-Dec-2021	14:18	06-Dec-2021	15:09	51	0.000028	SYSTEM SCHEDULE OUTAGE
56	06-Dec-2021	PARTS OF SDM OFFICE ALIUPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	39	Other Outage	Unplanned Outage	06-Dec-2021	15:59	06-Dec-2021	16:53	54	0.00003	INTERRUPTION DUE TO FAULT
57	06-Dec-2021	PART OF NO - 7 B-BLOCK NARELA	4	Other Outage	Unplanned Outage	06-Dec-2021	17:51	06-Dec-2021	18:14	23	0.000006	INTERRUPTION DUE TO FAULT
58	06-Dec-2021	PART OF DSIDC B-2562 NARELA	9	Other Outage	Unplanned Outage	06-Dec-2021	18:41	06-Dec-2021	19:25	44	0.000024	INTERRUPTION DUE TO FAULT
59	06-Dec-2021	PARTS OF E BLOCK DSIDC NARELA	112	Other Outage	Unplanned Outage	06-Dec-2021	21:40	06-Dec-2021	22:17	37	0.000021	INTERRUPTION DUE TO FAULT
60	06-Dec-2021	PARTS OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL DSIDC NARELA	51	Other Outage	Unplanned Outage	06-Dec-2021	22:41	06-Dec-2021	23:17	36	0.00001	INTERRUPTION DUE TO FAULT
61	06-Dec-2021	PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL NARELA	3	Other Outage	Unplanned Outage	06-Dec-2021	22:41	06-Dec-2021	23:17	36	0.00001	INTERRUPTION DUE TO FAULT
62	07-Dec-2021	PARTS OF DSIDC FACTORY NO: F-1829 TO F-1863 AND A-1 TO A-34 NARELA	124	Other Outage	Unplanned Outage	07-Dec-2021	04:17	07-Dec-2021	05:51	94	0.000026	INTERRUPTION DUE TO FAULT
63	07-Dec-2021	PART OF F-1884 DSIDC NARELA	2	Other Outage	Unplanned Outage	07-Dec-2021	09:15	07-Dec-2021	09:32	17	0.000005	SYSTEM SCHEDULE OUTAGE
64	07-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBI MANDI NARELA	303	Other Outage	Unplanned Outage	07-Dec-2021	12:43	07-Dec-2021	13:34	51	0.000113	INTERRUPTION DUE TO FAULT
65	07-Dec-2021	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	178	Other Outage	Unplanned Outage	07-Dec-2021	14:13	07-Dec-2021	15:43	90	0.000125	INTERRUPTION DUE TO FAULT
66	07-Dec-2021	PART OF BLOCK-B DSIDC NARELA INDUSTRIAL AREA NARELA	3	Other Outage	Unplanned Outage	07-Dec-2021	14:38	07-Dec-2021	15:38	60	0.000033	INTERRUPTION DUE TO FAULT
67	07-Dec-2021	PART OF POCKET - H NARELA	13	Other Outage	Unplanned Outage	07-Dec-2021	16:47	07-Dec-2021	18:42	115	0.000064	

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unsed (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
81	09-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	1501	Other Outage	Unplanned Outage	09-Dec-2021	07:30	09-Dec-2021	09:10	100	0.000554	INTERRUPTION DUE TO FAULT
82	09-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	89	Other Outage	Unplanned Outage	09-Dec-2021	07:30	09-Dec-2021	11:25	235	0.000326	FORCE MAJEURE DUE TO SABOTAGE
83	09-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	1961	Other Outage	Unplanned Outage	09-Dec-2021	08:11	09-Dec-2021	08:55	44	0.000305	INTERRUPTION DUE TO FAULT
84	09-Dec-2021	PART OF NAFE SINGH NO-2 NARELA	9	Other Outage	Unplanned Outage	09-Dec-2021	08:11	09-Dec-2021	11:25	194	0.000054	FORCE MAJEURE DUE TO SABOTAGE
85	09-Dec-2021	PARTS OF F BLOCK DSIDC NARELA	24	Other Outage	Unplanned Outage	09-Dec-2021	11:00	09-Dec-2021	12:24	84	0.000047	INTERRUPTION DUE TO FAULT
86	09-Dec-2021	PART OF F BLOCK NARELA	4	Other Outage	Unplanned Outage	09-Dec-2021	11:00	09-Dec-2021	17:17	377	0.000209	FORCE MAJEURE DUE TO SABOTAGE
87	09-Dec-2021	PART OF PARSHURAM CHOWK NARELA	5	Other Outage	Unplanned Outage	09-Dec-2021	11:35	09-Dec-2021	11:55	20	0.000011	INTERRUPTION DUE TO FAULT
88	09-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	1238	Other Outage	Unplanned Outage	09-Dec-2021	12:11	09-Dec-2021	12:51	40	0.000167	INTERRUPTION DUE TO FAULT
89	09-Dec-2021	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY PREEM NAGAR, NARELA	130	Other Outage	Unplanned Outage	09-Dec-2021	13:59	09-Dec-2021	14:37	38	0.000053	INTERRUPTION DUE TO FAULT
90	09-Dec-2021	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3978	Other Outage	Unplanned Outage	09-Dec-2021	15:31	09-Dec-2021	15:45	14	0.000233	INTERRUPTION DUE TO FAULT
91	09-Dec-2021	PARTS OF E BLOCK DSIDC NARELA	29	Other Outage	Unplanned Outage	09-Dec-2021	15:56	09-Dec-2021	16:25	29	0.000016	INTERRUPTION DUE TO FAULT
92	09-Dec-2021	PARTS OF F BLOCK DSIDC NARELA	24	Other Outage	Unplanned Outage	09-Dec-2021	16:40	09-Dec-2021	17:17	37	0.000021	INTERRUPTION DUE TO FAULT
93	10-Dec-2021	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY NARELA	799	Other Outage	Unplanned Outage	10-Dec-2021	09:19	10-Dec-2021	18:35	556	0.001545	FORCE MAJEURE DUE TO SABOTAGE
94	10-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	77	Other Outage	Unplanned Outage	10-Dec-2021	11:38	10-Dec-2021	14:31	173	0.000577	FORCE MAJEURE DUE TO SABOTAGE
95	10-Dec-2021	PART OF NO-10 C BLOCK DSIDC NARELA	3	Other Outage	Unplanned Outage	10-Dec-2021	16:53	10-Dec-2021	17:27	34	0.000009	INTERRUPTION DUE TO FAULT
96	10-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	91	Other Outage	Unplanned Outage	10-Dec-2021	18:24	10-Dec-2021	19:50	86	0.000095	INTERRUPTION DUE TO FAULT
97	11-Dec-2021	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	86	Other Outage	Unplanned Outage	11-Dec-2021	10:54	11-Dec-2021	12:47	113	0.000063	INTERRUPTION DUE TO FAULT
98	11-Dec-2021	PART OF DSIDC FACTORY NOJ-2293 NARELA	2	Other Outage	Unplanned Outage	11-Dec-2021	12:38	11-Dec-2021	12:58	20	0.000006	INTERRUPTION DUE TO FAULT
99	11-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA, PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL NARELA	3300	Other Outage	Unplanned Outage	11-Dec-2021	13:31	11-Dec-2021	14:00	29	0.000334	INTERRUPTION DUE TO FAULT
100	11-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	1121	Other Outage	Unplanned Outage	11-Dec-2021	16:06	11-Dec-2021	17:55	109	0.000303	INTERRUPTION DUE TO FAULT
101	11-Dec-2021	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMADPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	42	Other Outage	Unplanned Outage	11-Dec-2021	18:35	11-Dec-2021	20:09	94	0.000026	INTERRUPTION DUE TO FAULT
102	11-Dec-2021	PART OF NARELA	16	Other Outage	Unplanned Outage	11-Dec-2021	18:40	11-Dec-2021	20:09	89	0.000025	INTERRUPTION DUE TO FAULT
103	11-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	1018	Other Outage	Unplanned Outage	11-Dec-2021	19:52	11-Dec-2021	20:25	33	0.000073	INTERRUPTION DUE TO FAULT
104	11-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	31	Other Outage	Unplanned Outage	11-Dec-2021	19:52	11-Dec-2021	20:55	63	0.000017	INTERRUPTION DUE TO FAULT
105	11-Dec-2021	PARTS OF SEC-B AND SEC-C DSIDC BHORGARH NARELA	3194	Other Outage	Unplanned Outage	11-Dec-2021	20:43	11-Dec-2021	21:05	22	0.000295	INTERRUPTION DUE TO FAULT
106	11-Dec-2021	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMADPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	196	Other Outage	Unplanned Outage	11-Dec-2021	22:22	11-Dec-2021	22:42	20	0.000022	INTERRUPTION DUE TO FAULT
107	11-Dec-2021	PARTS OF F BLOCK 1272 DSIDC NARELA	93	Other Outage	Unplanned Outage	12-Dec-2021	13:36	12-Dec-2021	14:23	47	0.000016	INTERRUPTION DUE TO FAULT
108	12-Dec-2021	PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL NARELA	3	Other Outage	Unplanned Outage	12-Dec-2021	14:23	12-Dec-2021	14:49	26	0.000014	INTERRUPTION DUE TO FAULT
109	12-Dec-2021	PARTS OF DDA B-2, POCKET A, D, H NARELA NARELA	684	Other Outage	Unplanned Outage	12-Dec-2021	14:44	12-Dec-2021	15:05	21	0.000118	INTERRUPTION DUE TO FAULT
110	12-Dec-2021	PART OF F BLOCK DSIDC NARELA	3	Other Outage	Unplanned Outage	12-Dec-2021	15:15	12-Dec-2021	15:57	42	0.000012	INTERRUPTION DUE TO FAULT
111	12-Dec-2021	PARTS OF C BLOCK 1272 DSIDC NARELA	93	Other Outage	Unplanned Outage	12-Dec-2021	16:51	12-Dec-2021	17:10	19	0.000206	INTERRUPTION DUE TO FAULT
112	13-Dec-2021	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1593	Other Outage	Unplanned Outage	13-Dec-2021	03:42	13-Dec-2021	04:16	34	0.000076	INTERRUPTION DUE TO FAULT
113	13-Dec-2021	PARTS OF C BLOCK 1272 DSIDC NARELA	93	Other Outage	Unplanned Outage	13-Dec-2021	06:51	13-Dec-2021	08:02	71	0.00002	INTERRUPTION DUE TO FAULT
114	13-Dec-2021	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE, MCD GIRLS PRIMARY SCHOOL, CHHAJURAM PUBLIC SCHOOL NARELA	4054	Other Outage	Unplanned Outage	13-Dec-2021	07:05	13-Dec-2021	07:38	33	0.000089	INTERRUPTION DUE TO FAULT
115	13-Dec-2021	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1593	Other Outage	Unplanned Outage	13-Dec-2021	08:00	13-Dec-2021	08:57	57	0.000255	INTERRUPTION DUE TO FAULT
116	13-Dec-2021	PARTS OF C BLK DSIDC BHORGARH NARELA	95	Other Outage	Unplanned Outage	13-Dec-2021	08:15	13-Dec-2021	08:50	35	0.000144	INTERRUPTION DUE TO FAULT
117	13-Dec-2021	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	918	Other Outage	Unplanned Outage	13-Dec-2021	11:43	13-Dec-2021	18:04	381	0.001588	FORCE MAJEURE DUE TO SABOTAGE
118	13-Dec-2021	PART OF I BLOCK NARELA	5	Other Outage	Unplanned Outage	13-Dec-2021	15:32	13-Dec-2021	16:20	48	0.000027	INTERRUPTION DUE TO FAULT
119	13-Dec-2021	PART OF F-1884 DSIDC NARELA	2	Other Outage	Unplanned Outage	13-Dec-2021	20:24	13-Dec-2021	20:50	26	0.000007	INTERRUPTION DUE TO FAULT
120	14-Dec-2021	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3979	Other Outage	Unplanned Outage	14-Dec-2021	07:05	14-Dec-2021	07:38	33	0.000468	INTERRUPTION DUE TO FAULT
121	14-Dec-2021	PART OF I BLOCK NARELA	5	Other Outage	Unplanned Outage	14-Dec-2021	07:46	14-Dec-2021	10:06	140	0.000078	FORCE MAJEURE DUE TO SABOTAGE
122	14-Dec-2021	PARTS OF C BLOCK 1272 DSIDC NARELA	55	Other Outage	Unplanned Outage	14-Dec-2021	12:27	14-Dec-2021	12:55	28	0.000039	INTERRUPTION DUE TO FAULT
123	14-Dec-2021	PARTS OF F BLOCK DSIDC NARELA	29	Other Outage	Unplanned Outage	14-Dec-2021	14:56	14-Dec-2021	16:06	70	0.000039	INTERRUPTION DUE TO FAULT
124	14-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	558	Other Outage	Unplanned Outage	14-Dec-2021	15:18	14-Dec-2021	17:08	110	0.000367	INTERRUPTION DUE TO FAULT
125	14-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. I. COLONY (NARELA), RLV, ROAD NRL, LAMPUR ROAD, P/VI MANIHARI TO SINGHU BORDER NARELA	2817	Other Outage	Unplanned Outage	14-Dec-2021	15:51	14-Dec-2021	16:20	29	0.000244	INTERRUPTION DUE TO FAULT
126	14-Dec-2021	PART OF A BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	14-Dec-2021	20:54	14-Dec-2021	21:45	51	0.000028	INTERRUPTION DUE TO FAULT
127	15-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	1218	Other Outage	Unplanned Outage	15-Dec-2021	07:45	15-Dec-2021	08:30	45	0.000015	INTERRUPTION DUE TO FAULT
128	15-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	234	Other Outage	Unplanned Outage	15-Dec-2021	07:45	15-Dec-2021	08:39	54	0.000036	INTERRUPTION DUE TO FAULT
129	15-Dec-2021	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY PREEM NAGAR, NARELA	1290	Other Outage	Unplanned Outage	15-Dec-2021	11:10	15-Dec-2021	11:59	49	0.000681	INTERRUPTION DUE TO FAULT
130	15-Dec-2021	PARTS OF C & E BLOCK DSIDC NARELA	51	Other Outage	Unplanned Outage	15-Dec-2021	11:18	15-Dec-2021	12:12	54	0.00003	INTERRUPTION DUE TO FAULT
131	15-Dec-2021	PART OF F BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	15-Dec-2021	11:43	15-Dec-2021	12:50	67	0.000019	INTERRUPTION DUE TO FAULT
132	15-Dec-2021	PART OF GHOGHA COLONY NARELA	3	Other Outage	Unplanned Outage	15-Dec-2021	12:43	15-Dec-2021	14:00	77	0.000043	INTERRUPTION DUE TO FAULT
133	15-Dec-2021	PART OF NANGLU KIOSK NARELA	8	Other Outage	Unplanned Outage	15-Dec-2021	16:34	15-Dec-2021	17:44	70	0.000019	INTERRUPTION DUE TO FAULT
134	15-Dec-2021	PARTS OF SEC-B AND SEC-C DSIDC BHORGARH NARELA	1422	Other Outage	Unplanned Outage	15-Dec-2021	16:43	15-Dec-2021	16:55	12	0.000007	INTERRUPTION DUE TO FAULT
135	15-Dec-2021	PARTS OF SEC-B AND SEC-C DSIDC BHORGARH NARELA	1422	Other Outage	Unplanned Outage	16-Dec-2021	09:32	16-Dec-2021	10:45	73	0.000221	INTERRUPTION DUE TO FAULT
136	16-Dec-2021	PART OF A BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	16-Dec-2021	10:23	16-Dec-2021	12:32	129	0.000036	FORCE MAJEURE DUE TO SABOTAGE
137	16-Dec-2021	PARTS OF DSIDC B-2562 NARELA	35	Other Outage	Unplanned Outage	16-Dec-2021	14:58	16-Dec-2021	15:35	37	0.000011	INTERRUPTION DUE TO FAULT
138	16-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	2840	Other Outage	Unplanned Outage	16-Dec-2021	18:30	16-Dec-2021	19:04	34	0.000189	INTERRUPTION DUE TO FAULT
139	16-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	1670	Other Outage	Unplanned Outage	17-Dec-2021	02:09	17-Dec-2021	03:26	77	0.000384	INTERRUPTION DUE TO FAULT
140	17-Dec-2021	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	726	Other Outage	Unplanned Outage	17-Dec-2021	02:40	17-Dec-2021	03:33	53	0.000265	INTERRUPTION DUE TO FAULT
141	17-Dec-2021	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	734	Other Outage	Unplanned Outage	17-Dec-2021	02:40	17-Dec-2021	03:33	53	0.000235	INTERRUPTION DUE TO FAULT
142	17-Dec-2021	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	3	Other Outage	Unplanned Outage	17-Dec-2021	11:32	17-Dec-2021	12:49	77	0.000021	INTERRUPTION DUE TO FAULT
143	17-Dec-2021	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3981	Other Outage	Unplanned Outage	17-Dec-2021	12:32	17-Dec-2021	12:57	25	0.000287	INTERRUPTION DUE TO FAULT
144	17-Dec-2021	PARTS OF E BLOCK DSIDC NARELA	169	Other Outage	Unplanned Outage	17-Dec-2021	14:56	18-Dec-2021	09:35	1119	0.001554	FORCE MAJEURE DUE TO SABOTAGE
145	17-Dec-2021	PART OF RAJEEV COLONY NARELA	18	Other Outage	Unplanned Outage	17-Dec-2021	15:02	17-Dec-2021	16:08	66	0.000092	INTERRUPTION DUE TO FAULT
146	17-Dec-2021	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY NARELA	2928	Other Outage	Unplanned Outage	17-Dec-2021	15:02	17-Dec-2021	17:30	148	0.001439	FORCE MAJEURE DUE TO SABOTAGE
147	17-Dec-2021	PART OF GHOGHA COLONY NARELA	7	Other Outage	Unplanned Outage	17-Dec-2021	16:07	17-Dec-2021	17:01	54	0.00003	INTERRUPTION DUE TO FAULT
148	17-Dec-2021	PART OF DULIYA COLONY NARELA	3	Other Outage	Unplanned Outage	17-Dec-2021	16:39	17-Dec-2021	17:41	62	0.000017	INTERRUPTION DUE TO FAULT
149	17-Dec-2021	PARTS OF NANGLU, PART OF KHERAKALAN, BAKOLI STAND, NARELA	1219	Other Outage	Unplanned Outage	17-Dec-2021	16:47	17-Dec-2021	17:20	33	0.000458	INTERRUPTION DUE TO FAULT
150	17-Dec-2021	PARTS OF C BLOCK 1272 DSIDC NARELA	93	Other Outage	Unplanned Outage	17-Dec-2021	21:22	17-Dec-2021	21:50	28	0.000234	INTERRUPTION DUE TO FAULT
151	18-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	1049	Other Outage	Unplanned Outage	18-Dec-2021	00:19	18-Dec-2021	01:18	59	0.000164	INTERRUPTION DUE TO FAULT
152	18-Dec-2021	PARTS OF TIKRI, SWARN JAYANTI, GANGA RAM COLONY, TAJPUR NARELA	1154	Other Outage	Unplanned Outage	18-Dec-2021	02:14	18-Dec-2021	04:40	146	0.000406	FORCE MAJEURE DUE TO SABOTAGE
153	18-Dec-2021	PARTS OF TIKRI, SWARN JAYANTI, GANGA RAM COLONY, TAJPUR NARELA	4235	Other Outage	Unplanned Outage	18-Dec-2021	02:14	18-Dec-2021	04:40	146	0.001217	FORCE MAJEURE DUE TO SABOTAGE
154	18-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	597	Other Outage	Unplanned Outage	18-Dec-2021	02:14	18-Dec-2021	04:42	148	0.000411	FORCE MAJEURE DUE TO SABOTAGE
155	18-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	56	Other Outage	Unplanned Outage	18-Dec-2021	08:34	18-Dec-2021	09:31	57	0.000032	INTERRUPTION DUE TO FAULT
156	18-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	85	Other Outage	Unplanned Outage	18-Dec-2021	10:11	18-Dec-2021	10:30	19	0.000016	INTERRUPTION DUE TO FAULT
157	18-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	31	Other Outage	Unplanned Outage	18-Dec-2021	10:11	18-Dec-2021	13:44	213	0.000118	FORCE MAJEURE DUE TO SABOTAGE
158	18-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	1193	Other Outage</								

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (to MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
166	19-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	2683	Other Outage	Unplanned Outage	19-Dec-2021	04:56	19-Dec-2021	05:04	8	0.00064	INTERRUPTION DUE TO FAULT
167	19-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1904	Other Outage	Unplanned Outage	19-Dec-2021	04:56	19-Dec-2021	05:53	57	0.000315	INTERRUPTION DUE TO FAULT
168	19-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	2683	Other Outage	Unplanned Outage	19-Dec-2021	06:01	19-Dec-2021	06:14	13	0.000109	INTERRUPTION DUE TO FAULT
169	19-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1904	Other Outage	Unplanned Outage	19-Dec-2021	06:01	19-Dec-2021	06:14	13	0.000072	INTERRUPTION DUE TO FAULT
170	19-Dec-2021	PARTS OF F-1712 DSDIC NARELA	484	Other Outage	Unplanned Outage	19-Dec-2021	10:42	19-Dec-2021	11:18	36	0.00001	INTERRUPTION DUE TO FAULT
171	19-Dec-2021	PARTS OF HAMID PUR, PART OF BAKOLI, TAJI PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY NARELA	477	Other Outage	Unplanned Outage	19-Dec-2021	11:53	19-Dec-2021	12:49	56	0.000078	INTERRUPTION DUE TO FAULT
172	19-Dec-2021	PART OF F BLOCK DSDIC NARELA	5	Other Outage	Unplanned Outage	19-Dec-2021	13:12	19-Dec-2021	13:25	13	0.000004	INTERRUPTION DUE TO FAULT
173	19-Dec-2021	PARTS OF DSDIC B-2562 NARELA	47	Other Outage	Unplanned Outage	19-Dec-2021	14:33	19-Dec-2021	15:17	44	0.000048	INTERRUPTION DUE TO FAULT
174	19-Dec-2021	PART OF E BLOCK NARELA	4	Other Outage	Unplanned Outage	19-Dec-2021	15:42	19-Dec-2021	16:35	53	0.000029	INTERRUPTION DUE TO FAULT
175	19-Dec-2021	PARTS OF TEJISINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN NARELA	2689	Other Outage	Unplanned Outage	19-Dec-2021	16:17	19-Dec-2021	16:50	33	0.0000413	INTERRUPTION DUE TO FAULT
176	20-Dec-2021	PART OF C BLOCK DSDIC NARELA	4	Other Outage	Unplanned Outage	20-Dec-2021	06:42	20-Dec-2021	07:00	18	0.000005	INTERRUPTION DUE TO FAULT
177	20-Dec-2021	PART OF DSDIC B-2562 NARELA	3	Other Outage	Unplanned Outage	20-Dec-2021	07:22	20-Dec-2021	08:33	71	0.00002	INTERRUPTION DUE TO FAULT
178	20-Dec-2021	PART OF NO.-1 A BLOCK DSDIC NARELA	4	Other Outage	Unplanned Outage	20-Dec-2021	10:34	20-Dec-2021	14:36	242	0.000134	FORCE MAJEURE DUE TO SABOTAGE
179	20-Dec-2021	PART OF C BLOCK DSDIC NARELA	2	Other Outage	Unplanned Outage	20-Dec-2021	11:52	20-Dec-2021	12:20	28	0.000016	INTERRUPTION DUE TO FAULT
180	20-Dec-2021	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1594	Other Outage	Unplanned Outage	20-Dec-2021	12:08	20-Dec-2021	13:28	80	0.00111	INTERRUPTION DUE TO FAULT
181	20-Dec-2021	PART OF E BLOCK NARELA	5	Other Outage	Unplanned Outage	20-Dec-2021	15:26	20-Dec-2021	16:15	49	0.000027	SYSTEM SCHEDULED OUTAGE
182	20-Dec-2021	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY NARELA	2915	Other Outage	Unplanned Outage	20-Dec-2021	15:32	20-Dec-2021	16:25	53	0.000517	INTERRUPTION DUE TO FAULT
183	20-Dec-2021	PART OF J-3057 DSDIC NARELA	7	Other Outage	Unplanned Outage	20-Dec-2021	16:54	20-Dec-2021	18:10	76	0.000042	INTERRUPTION DUE TO FAULT
184	20-Dec-2021	PART OF DSDIC B-2562 NARELA	3	Other Outage	Unplanned Outage	20-Dec-2021	16:55	20-Dec-2021	17:28	33	0.000009	INTERRUPTION DUE TO FAULT
185	21-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	301	Other Outage	Unplanned Outage	21-Dec-2021	02:51	21-Dec-2021	03:19	28	0.000017	INTERRUPTION DUE TO FAULT
186	21-Dec-2021	PARTS OF NANGLU KIOSK ALUPUR NARELA	748	Other Outage	Unplanned Outage	21-Dec-2021	02:51	21-Dec-2021	03:24	33	0.000111	INTERRUPTION DUE TO FAULT
187	21-Dec-2021	PART OF GHOGHA DAIRY COLONY BLOCK-I NARELA	4	Other Outage	Unplanned Outage	21-Dec-2021	03:30	21-Dec-2021	03:55	25	0.000007	INTERRUPTION DUE TO FAULT
188	21-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	499	Other Outage	Unplanned Outage	21-Dec-2021	04:36	21-Dec-2021	05:05	29	0.00004	INTERRUPTION DUE TO FAULT
189	21-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	619	Other Outage	Unplanned Outage	21-Dec-2021	04:36	21-Dec-2021	05:06	30	0.000067	INTERRUPTION DUE TO FAULT
190	21-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	173	Other Outage	Unplanned Outage	21-Dec-2021	04:36	21-Dec-2021	05:21	45	0.000063	INTERRUPTION DUE TO FAULT
191	21-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	1005	Other Outage	Unplanned Outage	21-Dec-2021	04:36	21-Dec-2021	07:38	182	0.000607	FORCE MAJEURE DUE TO SABOTAGE
192	21-Dec-2021	PART OF ESS-12 DSDIC NARELA	12	Other Outage	Unplanned Outage	21-Dec-2021	09:25	21-Dec-2021	10:08	43	0.000012	INTERRUPTION DUE TO FAULT
193	21-Dec-2021	PARTS OF OD ESS-12 DSDIC NARELA	900	Other Outage	Unplanned Outage	21-Dec-2021	09:25	21-Dec-2021	10:19	54	0.000465	INTERRUPTION DUE TO FAULT
194	21-Dec-2021	PART OF G BLOCK NARELA	3	Other Outage	Unplanned Outage	21-Dec-2021	11:50	21-Dec-2021	14:19	149	0.000041	FORCE MAJEURE DUE TO SABOTAGE
195	21-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	3015	Other Outage	Unplanned Outage	21-Dec-2021	12:25	21-Dec-2021	13:01	36	0.000498	INTERRUPTION DUE TO FAULT
196	21-Dec-2021	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1573	Other Outage	Unplanned Outage	21-Dec-2021	12:25	21-Dec-2021	13:15	50	0.000287	INTERRUPTION DUE TO FAULT
197	21-Dec-2021	PART OF DSDIC FACTORY NO-E-864 NARELA	5	Other Outage	Unplanned Outage	21-Dec-2021	12:36	21-Dec-2021	13:17	41	0.000011	INTERRUPTION DUE TO FAULT
198	21-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	2884	Other Outage	Unplanned Outage	21-Dec-2021	13:13	21-Dec-2021	13:30	17	0.000137	INTERRUPTION DUE TO FAULT
199	21-Dec-2021	PART OF C BLOCK DSDIC NARELA	4	Other Outage	Unplanned Outage	21-Dec-2021	18:06	21-Dec-2021	19:14	68	0.000019	INTERRUPTION DUE TO FAULT
200	21-Dec-2021	PARTS OF J-3368 DSDIC NARELA	103	Other Outage	Unplanned Outage	21-Dec-2021	22:49	22-Dec-2021	00:07	78	0.000107	INTERRUPTION DUE TO FAULT
201	22-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	219	Other Outage	Unplanned Outage	22-Dec-2021	06:22	22-Dec-2021	06:51	29	0.000004	INTERRUPTION DUE TO FAULT
202	22-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	889	Other Outage	Unplanned Outage	22-Dec-2021	06:22	22-Dec-2021	07:25	63	0.000014	INTERRUPTION DUE TO FAULT
203	22-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	347	Other Outage	Unplanned Outage	22-Dec-2021	06:22	22-Dec-2021	09:13	171	0.000095	FORCE MAJEURE DUE TO SABOTAGE
204	22-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	167	Other Outage	Unplanned Outage	22-Dec-2021	06:48	22-Dec-2021	07:43	55	0.000307	INTERRUPTION DUE TO FAULT
205	22-Dec-2021	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1595	Other Outage	Unplanned Outage	22-Dec-2021	17:23	22-Dec-2021	18:09	46	0.000449	INTERRUPTION DUE TO FAULT
206	22-Dec-2021	PARTS OF DSDIC BORGARH INDS. AREA NARELA	749	Other Outage	Unplanned Outage	22-Dec-2021	20:05	22-Dec-2021	20:24	19	0.000061	INTERRUPTION DUE TO FAULT
207	23-Dec-2021	PARTS OF HAMID PUR, PART OF BAKOLI, TAJI PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY NARELA	478	Other Outage	Unplanned Outage	23-Dec-2021	05:59	23-Dec-2021	06:26	27	0.000038	INTERRUPTION DUE TO FAULT
208	23-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	2884	Other Outage	Unplanned Outage	23-Dec-2021	11:30	23-Dec-2021	12:10	40	0.000222	INTERRUPTION DUE TO FAULT
209	23-Dec-2021	PART OF E BLOCK NARELA	3	Other Outage	Unplanned Outage	23-Dec-2021	11:58	23-Dec-2021	13:02	64	0.000018	INTERRUPTION DUE TO FAULT
210	23-Dec-2021	PARTS OF H BLOCK DSDIC NARELA	45	Other Outage	Unplanned Outage	23-Dec-2021	13:24	23-Dec-2021	13:56	32	0.000018	INTERRUPTION DUE TO FAULT
211	23-Dec-2021	PARTS OF F & E BLOCK DSDIC NARELA	51	Other Outage	Unplanned Outage	23-Dec-2021	15:54	23-Dec-2021	16:59	65	0.000036	INTERRUPTION DUE TO FAULT
212	23-Dec-2021	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	70	Other Outage	Unplanned Outage	23-Dec-2021	18:09	23-Dec-2021	19:19	70	0.000097	INTERRUPTION DUE TO FAULT
213	24-Dec-2021	PARTS OF A BLOCK, DSDIC NARELA	63	Other Outage	Unplanned Outage	24-Dec-2021	00:32	24-Dec-2021	01:19	47	0.000065	INTERRUPTION DUE TO FAULT
214	24-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	680	Other Outage	Unplanned Outage	24-Dec-2021	06:47	24-Dec-2021	07:52	65	0.000216	INTERRUPTION DUE TO FAULT
215	24-Dec-2021	PARTS OF F-611 DSDIC NARELA	42	Other Outage	Unplanned Outage	24-Dec-2021	10:24	24-Dec-2021	12:02	98	0.000082	INTERRUPTION DUE TO FAULT
216	24-Dec-2021	PARTS OF AMAN VIHAR, SHANSHAN GHAT NANGLU POONA, MURGI FARM KADIPUR, GURUDHARA GT ROAD NANGLU, MOHAN VILAS, DALMILL NANGLU POONA NARELA	344	Other Outage	Unplanned Outage	24-Dec-2021	11:29	24-Dec-2021	14:53	204	0.000283	FORCE MAJEURE DUE TO SABOTAGE
217	24-Dec-2021	PART OF E BLOCK DSDIC NARELA	5	Other Outage	Unplanned Outage	24-Dec-2021	13:53	24-Dec-2021	15:39	106	0.000029	INTERRUPTION DUE TO FAULT
218	24-Dec-2021	PART OF G BLOCK NARELA	4	Other Outage	Unplanned Outage	24-Dec-2021	15:26	24-Dec-2021	16:58	92	0.000051	INTERRUPTION DUE TO FAULT
219	25-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	1456	Other Outage	Unplanned Outage	25-Dec-2021	06:43	25-Dec-2021	07:20	37	0.000391	INTERRUPTION DUE TO FAULT
220	25-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	1237	Other Outage	Unplanned Outage	25-Dec-2021	07:26	25-Dec-2021	07:50	24	0.000367	INTERRUPTION DUE TO FAULT
221	25-Dec-2021	PART OF GANGA RAM COLONY NARELA	12	Other Outage	Unplanned Outage	25-Dec-2021	10:30	25-Dec-2021	11:15	45	0.000013	INTERRUPTION DUE TO FAULT
222	25-Dec-2021	PARTS OF I BLOCK, DSDIC NARELA	96	Other Outage	Unplanned Outage	25-Dec-2021	15:09	25-Dec-2021	17:19	130	0.000433	FORCE MAJEURE DUE TO SABOTAGE
223	25-Dec-2021	PARTS OF C BLOCK 1272 DSDIC NARELA	94	Other Outage	Unplanned Outage	25-Dec-2021	15:09	25-Dec-2021	15:20	11	0.000046	INTERRUPTION DUE TO FAULT
224	25-Dec-2021	PART OF A BLOCK NARELA	6	Other Outage	Unplanned Outage	25-Dec-2021	19:24	25-Dec-2021	19:52	28	0.000008	INTERRUPTION DUE TO FAULT
225	26-Dec-2021	PARTS OF C BLOCK, DSDIC NARELA	83	Other Outage	Unplanned Outage	26-Dec-2021	00:11	26-Dec-2021	07:40	449	0.000249	FORCE MAJEURE DUE TO SABOTAGE
226	26-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	2888	Other Outage	Unplanned Outage	26-Dec-2021	12:52	26-Dec-2021	13:15	23	0.000184	INTERRUPTION DUE TO FAULT
227	26-Dec-2021	PART OF C BLOCK DSDIC NARELA	4	Other Outage	Unplanned Outage	26-Dec-2021	13:47	26-Dec-2021	14:12	25	0.000014	INTERRUPTION DUE TO FAULT
228	26-Dec-2021	PART OF I BLOCK NARELA	2	Other Outage	Unplanned Outage	26-Dec-2021	14:43	26-Dec-2021	15:06	23	0.000006	INTERRUPTION DUE TO FAULT
229	26-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	2888	Other Outage	Unplanned Outage	26-Dec-2021	14:50	26-Dec-2021	15:12	22	0.000117	INTERRUPTION DUE TO FAULT
230	26-Dec-2021	PARTS OF E BLOCK DSDIC NARELA	112	Other Outage	Unplanned Outage	26-Dec-2021	19:03	26-Dec-2021	19:30	27	0.0006	INTERRUPTION DUE TO FAULT
231	26-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	597	Other Outage	Unplanned Outage	26-Dec-2021	19:04	26-Dec-2021	19:32	28	0.000078	INTERRUPTION DUE TO FAULT
232	26-Dec-2021	PARTS OF DDA B-2, POCKET A, D, H NARELA NARELA	689	Other Outage	Unplanned Outage	26-Dec-2021	19:08	26-Dec-2021	19:37	29	0.000073	INTERRUPTION DUE TO FAULT
233	26-Dec-2021	PARTS OF TIKRI, SWARN JAYANTI, GANGA RAM COLONY, TAIPUR NARELA	5392	Other Outage	Unplanned Outage	26-Dec-2021	19:11	26-Dec-2021	20:03	52	0.002168	INTERRUPTION DUE TO FAULT
234	26-Dec-2021	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD NARELA	817	Other Outage	Unplanned Outage	26-Dec-2021	19:14	26-Dec-2021	20:10	56	0.000389	INTERRUPTION DUE TO FAULT
235	26-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	1844	Other Outage	Unplanned Outage	26-Dec-2021	19:17	26-Dec-2021	20:15	58	0.000475	INTERRUPTION DUE TO FAULT
236	26-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	808	Other Outage	Unplanned Outage	26-Dec-2021	19:17	26-Dec-2021	22:30	193	0.001067	FORCE MAJEURE DUE TO RAIN/STORM
237	26-Dec-2021	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALUPUR NARELA	3760	Other Outage	Unplanned Outage	26-Dec-2021	19:22	26-Dec-2021	21:04	102	0.001408	INTERRUPTION DUE TO FAULT
238	26-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	252	Other Outage	Unplanned Outage	26-Dec-2021	19:36	26-Dec-2021	22:40	184	0.000153	FORCE MAJEURE DUE TO RAIN/STORM
239	26-Dec-2021	PARTS OF H BLOCK DSDIC NARELA	73	Other Outage	Unplanned Outage	26-Dec-2021	19:46	26-Dec-2021	20:10	24	0.000333	INTERRUPTION DUE TO FAULT
240	26-Dec-2021	PARTS OF PANCHAYATGARH IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY, PREM NAGAR, NARELA	3997	Other Outage	Unplanned Outage	26-Dec-2021	19:46	26-Dec-2021	22:17	151	0.002086	FORCE MAJEURE DUE TO SABOTAGE
241	26-Dec-2021	PARTS OF DSDIC L BLOCK BORGARH NARELA	590	Other Outage	Unplanned Outage	26-Dec-2021	20:18	27-Dec-2021	00:31	253	0.004212	FORCE MAJEURE DUE TO RAIN/STORM
242	26-Dec-2021	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	4011	Other Outage	Unplanned Outage	26-Dec-2021	20:24	26-Dec-2021	21:34	70	0.000973	INTERRUPTION DUE TO FAULT
243	26-Dec-2021	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD NARELA	817	Other Outage								

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
253	27-Dec-2021	PARTS OF F BLOCK DSIC NARELA	35	Other Outage	Unplanned Outage	27-Dec-2021	10:01	27-Dec-2021	12:00	119	0.00066	INTERRUPTION DUE TO FAULT
254	27-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	1196	Other Outage	Unplanned Outage	27-Dec-2021	11:51	27-Dec-2021	13:14	83	0.000346	INTERRUPTION DUE TO FAULT
255	27-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	39	Other Outage	Unplanned Outage	27-Dec-2021	12:10	27-Dec-2021	13:10	60	0.000033	INTERRUPTION DUE TO FAULT
256	27-Dec-2021	PART OF ALIPUR VILLAGE NEAR MINI STADIUM NARELA	16	Other Outage	Unplanned Outage	27-Dec-2021	12:20	27-Dec-2021	14:50	150	0.000084	FORCE MAJEURE DUE TO SABOTAGE
257	27-Dec-2021	PARTS OF AMAN VIHAR, SHAMSHAN GHAT NANGLI POONA, MURGI FARM KADIPUR, GURUDWARA GT ROAD NANGLI, MOHAN VILAS, DALMILL NANGLI POONA NARELA	3457	Other Outage	Unplanned Outage	27-Dec-2021	12:52	27-Dec-2021	13:30	38	0.000532	INTERRUPTION DUE TO FAULT
258	27-Dec-2021	PART OF DEDICATED HT CONSUMER- RAJA HARISHCHAND GOVT. HOSPITAL NARELA	17	Other Outage	Unplanned Outage	27-Dec-2021	17:01	27-Dec-2021	17:40	39	0.000033	INTERRUPTION DUE TO FAULT
259	27-Dec-2021	PARTS OF NO-1 A BLOCK DSIC NARELA	57	Other Outage	Unplanned Outage	27-Dec-2021	21:36	27-Dec-2021	21:58	22	0.000369	INTERRUPTION DUE TO FAULT
260	28-Dec-2021	PART OF C BLOCK DSIC NARELA	2	Other Outage	Unplanned Outage	28-Dec-2021	11:11	28-Dec-2021	11:36	25	0.000007	INTERRUPTION DUE TO FAULT
261	28-Dec-2021	PART OF BLOCK-B DSIC NARELA INDUSTRIAL AREA NARELA	6	Other Outage	Unplanned Outage	28-Dec-2021	13:56	28-Dec-2021	14:54	58	0.000016	INTERRUPTION DUE TO FAULT
262	28-Dec-2021	PART OF BLOCK-B DSIC NARELA INDUSTRIAL AREA NARELA	2	Other Outage	Unplanned Outage	28-Dec-2021	14:50	28-Dec-2021	15:45	55	0.000015	INTERRUPTION DUE TO FAULT
263	28-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	39	Other Outage	Unplanned Outage	28-Dec-2021	16:05	28-Dec-2021	16:19	14	0.000058	INTERRUPTION DUE TO FAULT
264	28-Dec-2021	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE, MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	3390	Other Outage	Unplanned Outage	28-Dec-2021	17:15	28-Dec-2021	19:31	136	0.001544	FORCE MAJEURE DUE TO RAIN/STORM
265	28-Dec-2021	PARTS OF H BLOCK DSIC NARELA	45	Other Outage	Unplanned Outage	28-Dec-2021	17:50	28-Dec-2021	20:12	142	0.000237	FORCE MAJEURE DUE TO RAIN/STORM
266	28-Dec-2021	PARTS OF F BLOCK DSIC NARELA	67	Other Outage	Unplanned Outage	28-Dec-2021	20:29	28-Dec-2021	21:32	63	0.00014	INTERRUPTION DUE TO FAULT
267	28-Dec-2021	PART OF C BLOCK DSIC NARELA	4	Other Outage	Unplanned Outage	28-Dec-2021	20:52	28-Dec-2021	21:24	32	0.000009	INTERRUPTION DUE TO FAULT
268	28-Dec-2021	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	4794	Other Outage	Unplanned Outage	28-Dec-2021	22:45	28-Dec-2021	23:15	30	0.000392	INTERRUPTION DUE TO FAULT
269	29-Dec-2021	PART OF F BLOCK DSIC NARELA	8	Other Outage	Unplanned Outage	29-Dec-2021	10:51	29-Dec-2021	14:00	189	0.000105	FORCE MAJEURE DUE TO SABOTAGE
270	29-Dec-2021	PART OF C BLOCK DSIC NARELA	2	Other Outage	Unplanned Outage	29-Dec-2021	11:27	29-Dec-2021	12:09	42	0.000012	SYSTEM SCHEDULE OUTAGE
271	29-Dec-2021	PART OF I BLOCK NARELA	3	Other Outage	Unplanned Outage	29-Dec-2021	12:14	29-Dec-2021	13:03	49	0.000014	INTERRUPTION DUE TO FAULT
272	29-Dec-2021	PARTS OF NANGLI KIOSK ALIPUR NARELA	302	Other Outage	Unplanned Outage	29-Dec-2021	12:39	29-Dec-2021	20:30	471	0.001308	FORCE MAJEURE DUE TO SABOTAGE
273	29-Dec-2021	PART OF F-2010 DSIC NARELA	6	Other Outage	Unplanned Outage	29-Dec-2021	15:02	29-Dec-2021	17:10	128	0.000071	FORCE MAJEURE DUE TO SABOTAGE
274	29-Dec-2021	PARTS OF D BLOCK DSIC NARELA	65	Other Outage	Unplanned Outage	29-Dec-2021	15:28	29-Dec-2021	15:45	17	0.000024	INTERRUPTION DUE TO FAULT
275	29-Dec-2021	PART OF A BLOCK DSIC NARELA	2	Other Outage	Unplanned Outage	29-Dec-2021	19:03	29-Dec-2021	19:45	42	0.000011	INTERRUPTION DUE TO FAULT
276	29-Dec-2021	PARTS OF STAND WALA KUSHAK HIRANKI, RAGHUBER WALA RAMJANPUR, HIRANKI BUS STAND NO-1 NARELA	2044	Other Outage	Unplanned Outage	29-Dec-2021	23:52	30-Dec-2021	01:32	100	0.000556	INTERRUPTION DUE TO FAULT
277	30-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	1281	Other Outage	Unplanned Outage	30-Dec-2021	05:05	30-Dec-2021	05:20	15	0.000203	INTERRUPTION DUE TO FAULT
278	30-Dec-2021	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI SHAMPUR NARELA	70	Other Outage	Unplanned Outage	30-Dec-2021	06:20	30-Dec-2021	06:40	20	0.000028	INTERRUPTION DUE TO FAULT
279	30-Dec-2021	PART OF C BLK NARELA	2	Other Outage	Unplanned Outage	30-Dec-2021	08:12	30-Dec-2021	08:59	47	0.000013	INTERRUPTION DUE TO FAULT
280	30-Dec-2021	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	181	Other Outage	Unplanned Outage	30-Dec-2021	09:12	30-Dec-2021	10:32	80	0.000133	INTERRUPTION DUE TO FAULT
281	30-Dec-2021	PART OF C BLOCK DSIC NARELA	4	Other Outage	Unplanned Outage	30-Dec-2021	10:42	30-Dec-2021	13:50	188	0.000052	FORCE MAJEURE DUE TO SABOTAGE
282	30-Dec-2021	PART OF C BLOCK DSIC NARELA	2	Other Outage	Unplanned Outage	30-Dec-2021	14:24	30-Dec-2021	15:46	82	0.000023	INTERRUPTION DUE TO FAULT
283	30-Dec-2021	PARTS OF NDR COLONY, SOS BAWANA RAJEEV COLONY NARELA	2819	Other Outage	Unplanned Outage	30-Dec-2021	16:16	30-Dec-2021	16:40	24	0.000266	INTERRUPTION DUE TO FAULT
284	30-Dec-2021	PARTS OF NDR COLONY, SOS BAWANA RAJEEV COLONY NARELA	116	Other Outage	Unplanned Outage	30-Dec-2021	16:16	30-Dec-2021	17:55	99	0.000055	INTERRUPTION DUE TO FAULT
285	30-Dec-2021	PARTS OF NDR COLONY, SOS BAWANA RAJEEV COLONY NARELA	690	Other Outage	Unplanned Outage	30-Dec-2021	16:54	30-Dec-2021	17:55	61	0.000136	INTERRUPTION DUE TO FAULT
286	30-Dec-2021	PART OF C BLOCK NARELA	3	Other Outage	Unplanned Outage	30-Dec-2021	18:32	30-Dec-2021	19:28	56	0.000016	INTERRUPTION DUE TO FAULT
287	31-Dec-2021	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	181	Other Outage	Unplanned Outage	31-Dec-2021	07:35	31-Dec-2021	07:52	17	0.000022	INTERRUPTION DUE TO FAULT
288	31-Dec-2021	PART OF C BLOCK DSIC NARELA	2	Other Outage	Unplanned Outage	31-Dec-2021	10:34	31-Dec-2021	11:44	70	0.000019	INTERRUPTION DUE TO FAULT
289	31-Dec-2021	PARTS OF ALL BLOCK OF DSIC INDUSTRIAL AREA NARELA	31	Other Outage	Unplanned Outage	31-Dec-2021	11:22	31-Dec-2021	14:01	159	0.000044	FORCE MAJEURE DUE TO SABOTAGE
290	31-Dec-2021	PARTS OF A-10 GAS GODOWN NARELA	696	Other Outage	Unplanned Outage	31-Dec-2021	13:26	31-Dec-2021	13:44	18	0.00003	INTERRUPTION DUE TO FAULT
291	31-Dec-2021	PART OF H-1331 DSIC INDUSTRIAL AREA NARELA	2	Other Outage	Unplanned Outage	31-Dec-2021	14:18	31-Dec-2021	17:07	169	0.000047	FORCE MAJEURE DUE TO SABOTAGE
292	31-Dec-2021	PARTS OF H BLOCK DSIC NARELA	72	Other Outage	Unplanned Outage	31-Dec-2021	19:27	31-Dec-2021	19:57	30	0.000033	INTERRUPTION DUE TO FAULT
293	01-Dec-2021	PART OF DSIC FACTORY NO- F-1829 NARELA	4	315 kVA	Planned Outage	01-Dec-2021	07:28	01-Dec-2021	09:02	94	0.00003	PLANNED OUTAGE
294	01-Dec-2021	PART OF DSIC FACTORY NO- F-1829 NARELA	4	315 kVA	Planned Outage	01-Dec-2021	07:29	01-Dec-2021	10:05	156	0.00004	PLANNED OUTAGE
295	02-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	514	400 kVA	Planned Outage	02-Dec-2021	10:53	02-Dec-2021	13:16	143	0.00020	PLANNED OUTAGE
296	02-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	446	630 kVA	Planned Outage	02-Dec-2021	10:55	02-Dec-2021	15:38	283	0.00031	PLANNED OUTAGE
297	02-Dec-2021	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	115	Other Outage	Planned Outage	02-Dec-2021	10:56	02-Dec-2021	16:54	358	0.00010	PLANNED OUTAGE
298	02-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	243	400 kVA	Planned Outage	02-Dec-2021	10:57	02-Dec-2021	15:38	281	0.00016	PLANNED OUTAGE
299	02-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	825	Other Outage	Planned Outage	02-Dec-2021	11:56	02-Dec-2021	15:04	188	0.00042	PLANNED OUTAGE
300	02-Dec-2021	PARTS OF GHOGHA VILLAGE NARELA	40	Other Outage	Planned Outage	02-Dec-2021	12:03	02-Dec-2021	15:06	183	0.00005	PLANNED OUTAGE
301	03-Dec-2021	PART OF DEDICATED EXPRESS CONSUMER- IAMR NARELA	3	315 kVA	Planned Outage	03-Dec-2021	07:33	03-Dec-2021	09:42	129	0.00004	PLANNED OUTAGE
302	03-Dec-2021	PART OF DEDICATED EXPRESS CONSUMER- IAMR NARELA	5	400 kVA	Planned Outage	03-Dec-2021	07:34	03-Dec-2021	09:43	129	0.00004	PLANNED OUTAGE
303	03-Dec-2021	PART OF TRIVENI COLONY NARELA	6	Other Outage	Planned Outage	03-Dec-2021	10:13	03-Dec-2021	17:14	421	0.00012	PLANNED OUTAGE
304	03-Dec-2021	PARTS OF DSIC BORGARH INDS. AREA NARELA	354	630 kVA	Planned Outage	03-Dec-2021	11:04	03-Dec-2021	15:52	288	0.00024	PLANNED OUTAGE
305	03-Dec-2021	PARTS OF DSIC BORGARH INDS. AREA NARELA	394	Other Outage	Planned Outage	03-Dec-2021	11:05	03-Dec-2021	15:33	268	0.00030	PLANNED OUTAGE
306	03-Dec-2021	PART OF F BLOCK DSIC NARELA	4	250 kVA	Unplanned Outage	03-Dec-2021	11:08	03-Dec-2021	11:34	26	0.00001	SYSTEM SCHEDULE OUTAGE
307	03-Dec-2021	PART OF F BLOCK DSIC NARELA	1	63 kVA	Unplanned Outage	03-Dec-2021	11:52	03-Dec-2021	12:49	57	0.00002	SYSTEM SCHEDULE OUTAGE
308	03-Dec-2021	PARTS OF SEC-B AND SEC-C DSIC BORGARH NARELA	1774	Other Outage	Planned Outage	03-Dec-2021	12:38	03-Dec-2021	13:48	70	0.00031	PLANNED OUTAGE
309	03-Dec-2021	PART OF H-1331 DSIC INDUSTRIAL AREA NARELA	1	100 kVA	Unplanned Outage	03-Dec-2021	14:34	03-Dec-2021	15:44	70	0.00002	SYSTEM SCHEDULE OUTAGE
310	03-Dec-2021	PART OF DEDICATED EXPRESS CONSUMER- IAMR NARELA	4	400 kVA	Unplanned Outage	03-Dec-2021	14:59	03-Dec-2021	17:08	129	0.00004	FORCE MAJEURE DUE TO SABOTAGE
311	04-Dec-2021	PARTS OF D BLOCK DSIC NARELA	65	Other Outage	Planned Outage	04-Dec-2021	09:34	04-Dec-2021	17:17	463	0.00013	PLANNED OUTAGE
312	04-Dec-2021	PARTS OF E BLOCK DSIC NARELA	112	Other Outage	Planned Outage	04-Dec-2021	09:53	04-Dec-2021	17:08	435	0.00024	PLANNED OUTAGE
313	04-Dec-2021	PARTS OF C & E BLOCK DSIC NARELA	52	Other Outage	Planned Outage	04-Dec-2021	10:05	04-Dec-2021	17:00	415	0.00012	PLANNED OUTAGE
314	04-Dec-2021	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	1149	Other Outage	Planned Outage	04-Dec-2021	10:55	04-Dec-2021	14:44	229	0.00064	PLANNED OUTAGE
315	04-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	396	630 kVA	Planned Outage	04-Dec-2021	11:24	04-Dec-2021	14:35	191	0.00016	PLANNED OUTAGE
316	04-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	618	990 kVA	Planned Outage	04-Dec-2021	11:27	04-Dec-2021	14:35	188	0.00026	PLANNED OUTAGE
317	04-Dec-2021	PARTS OF BLOCK - G DSIC NARELA INDUSTRIAL AREA NARELA	58	Other Outage	Planned Outage	04-Dec-2021	11:43	04-Dec-2021	14:35	172	0.00005	PLANNED OUTAGE
318	04-Dec-2021	PART OF DSIC B-2562 NARELA	9	400 kVA	Unplanned Outage	04-Dec-2021	13:02	04-Dec-2021	14:39	97	0.00003	SYSTEM SCHEDULE OUTAGE
319	04-Dec-2021	PARTS OF KURENI VILLAGE, MANDI EXTN, PANIABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	368	630 kVA	Planned Outage	04-Dec-2021	14:11	04-Dec-2021	15:57	106	0.00024	PLANNED OUTAGE
320	04-Dec-2021	PARTS OF KURENI VILLAGE, MANDI EXTN, PANIABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	443	630 kVA	Planned Outage	04-Dec-2021	14:14	04-Dec-2021	15:57	103	0.00023	PLANNED OUTAGE
321	06-Dec-2021	PART OF DSIC FACTORY NO- F-1829 NARELA	3	315 kVA	Planned Outage	06-Dec-2021	08:01	06-Dec-2021	13:18	317	0.00009	PLANNED OUTAGE
322	06-Dec-2021	PART OF DSIC FACTORY NO- F-1829 NARELA	1	Other Outage	Planned Outage	06-Dec-2021	08:03	06-Dec-2021	13:18	315	0.00009	PLANNED OUTAGE
323	06-Dec-2021	PARTS OF PANCHAYATGARH IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY, PREM NAGAR NARELA	1054	Other Outage	Planned Outage	06-Dec-2021	11:15	06-Dec-2021	15:00	225	0.00063	PLANNED OUTAGE
324	06-Dec-2021	PART OF A BLOCK DSIC NARELA	7	400 kVA	Unplanned Outage							

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
335	08-Dec-2021	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, AS POLICE COLONY NARELA	397	630 kVA	Planned Outage	08-Dec-2021	11:15	08-Dec-2021	13:15	120	0.00010	PLANNED OUTAGE
336	08-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	453	Other Outage	Planned Outage	08-Dec-2021	11:19	08-Dec-2021	17:15	356	0.00040	PLANNED OUTAGE
337	08-Dec-2021	PART OF DSIDC FACTORY NO-E-664 NARELA	2	315 kVA	Unplanned Outage	08-Dec-2021	12:38	08-Dec-2021	14:00	82	0.00002	SYSTEM SCHEDULE OUTAGE
338	08-Dec-2021	PARTS OF RICHPAL WALA, NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI BIHARI, NPS SAFIYABAD ROAD NARELA	59	160 kVA	Planned Outage	08-Dec-2021	13:52	08-Dec-2021	15:06	74	0.00002	PLANNED OUTAGE
339	08-Dec-2021	PART OF DSIDC FACTORY NO-J-2293 NARELA	6	400 kVA	Unplanned Outage	08-Dec-2021	14:29	08-Dec-2021	15:19	50	0.00001	SYSTEM SCHEDULE OUTAGE
340	08-Dec-2021	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	2	400 kVA	Unplanned Outage	08-Dec-2021	16:05	08-Dec-2021	16:25	20	0.00001	SYSTEM SCHEDULE OUTAGE
341	08-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	199	Other Outage	Planned Outage	08-Dec-2021	16:34	08-Dec-2021	17:15	41	0.00002	PLANNED OUTAGE
342	09-Dec-2021	PART OF TRIVENI COLONY NARELA	6	Other Outage	Planned Outage	09-Dec-2021	10:08	09-Dec-2021	17:23	435	0.00012	PLANNED OUTAGE
343	09-Dec-2021	PARTS OF PUSHITA ROAD ALONG VILLAGES MUHAMMADPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	196	Other Outage	Planned Outage	09-Dec-2021	10:25	09-Dec-2021	17:07	402	0.00022	PLANNED OUTAGE
344	09-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL NARELA	173	Other Outage	Planned Outage	09-Dec-2021	11:05	09-Dec-2021	16:03	298	0.00017	PLANNED OUTAGE
345	09-Dec-2021	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	188	630 kVA	Planned Outage	09-Dec-2021	11:06	09-Dec-2021	13:26	140	0.00008	PLANNED OUTAGE
346	09-Dec-2021	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	366	630 kVA	Planned Outage	09-Dec-2021	11:09	09-Dec-2021	13:25	136	0.00011	PLANNED OUTAGE
347	09-Dec-2021	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	148	Other Outage	Planned Outage	09-Dec-2021	11:25	09-Dec-2021	17:45	380	0.00021	PLANNED OUTAGE
348	09-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	446	630 kVA	Planned Outage	09-Dec-2021	12:15	09-Dec-2021	16:44	269	0.00030	PLANNED OUTAGE
349	09-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	243	400 kVA	Planned Outage	09-Dec-2021	12:20	09-Dec-2021	16:44	264	0.00015	PLANNED OUTAGE
350	09-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	514	400 kVA	Planned Outage	09-Dec-2021	14:36	09-Dec-2021	16:25	109	0.00015	PLANNED OUTAGE
351	10-Dec-2021	PART OF E BLOCK DSIDC NARELA	5	250 kVA	Unplanned Outage	10-Dec-2021	11:54	10-Dec-2021	15:23	209	0.00006	FORCE MAJEURE DUE TO SABOTAGE
352	10-Dec-2021	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	5	250 kVA	Unplanned Outage	10-Dec-2021	12:55	10-Dec-2021	14:13	78	0.00002	SYSTEM SCHEDULE OUTAGE
353	10-Dec-2021	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	1	160 kVA	Unplanned Outage	10-Dec-2021	14:59	10-Dec-2021	15:48	49	0.00001	SYSTEM SCHEDULE OUTAGE
354	11-Dec-2021	PARTS OF G BLOCK DSIDC NARELA	37	Other Outage	Planned Outage	11-Dec-2021	09:39	11-Dec-2021	17:39	480	0.00013	PLANNED OUTAGE
355	11-Dec-2021	PART OF D BLOCK NARELA	3	500 kVA	Planned Outage	11-Dec-2021	09:43	11-Dec-2021	17:22	459	0.00013	PLANNED OUTAGE
356	11-Dec-2021	PARTS OF DSIDC BHORGARH VILLAGE NARELA	45	Other Outage	Planned Outage	11-Dec-2021	10:08	11-Dec-2021	17:29	441	0.00012	PLANNED OUTAGE
357	11-Dec-2021	PARTS OF B BLOCK DSIDC NARELA	66	Other Outage	Planned Outage	11-Dec-2021	10:20	11-Dec-2021	16:00	340	0.00009	PLANNED OUTAGE
358	11-Dec-2021	PARTS OF C BLOCK 1272 DSIDC NARELA	75	Other Outage	Planned Outage	11-Dec-2021	10:25	11-Dec-2021	16:56	391	0.00011	PLANNED OUTAGE
359	11-Dec-2021	PARTS OF B BLOCK DSIDC NARELA	27	Other Outage	Planned Outage	11-Dec-2021	10:46	11-Dec-2021	13:08	142	0.00004	PLANNED OUTAGE
360	11-Dec-2021	PARTS OF DSIDC FACTORY NO. F-1829 TO F-1863 AND A-1 TO A-34 NARELA	64	Other Outage	Planned Outage	11-Dec-2021	10:58	11-Dec-2021	16:38	340	0.00019	PLANNED OUTAGE
361	11-Dec-2021	PART OF NO - 7 B-BLOCK NARELA	4	400 kVA	Unplanned Outage	11-Dec-2021	11:01	11-Dec-2021	12:52	111	0.00003	SYSTEM SCHEDULE OUTAGE
362	11-Dec-2021	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	Other Outage	63 kVA	Planned Outage	11-Dec-2021	11:03	11-Dec-2021	14:28	205	0.00080	PLANNED OUTAGE
363	11-Dec-2021	PARTS OF NO-9-B-4 PTK-3 JANTA FLATS NARELA	62	Other Outage	Planned Outage	11-Dec-2021	11:27	11-Dec-2021	14:54	207	0.00006	PLANNED OUTAGE
364	11-Dec-2021	PARTS OF B BLOCK DSIDC NARELA	51	Other Outage	Planned Outage	11-Dec-2021	11:51	11-Dec-2021	15:04	193	0.00005	PLANNED OUTAGE
365	11-Dec-2021	PARTS OF E BLOCK DSIDC NARELA	169	Other Outage	Planned Outage	11-Dec-2021	12:23	11-Dec-2021	15:48	205	0.00017	PLANNED OUTAGE
366	11-Dec-2021	PART OF C BLK NARELA	2	63 kVA	Unplanned Outage	11-Dec-2021	13:25	11-Dec-2021	14:01	36	0.00001	SYSTEM SCHEDULE OUTAGE
367	11-Dec-2021	PART OF C BLK NARELA	2	63 kVA	Unplanned Outage	11-Dec-2021	14:45	11-Dec-2021	15:36	51	0.00001	SYSTEM SCHEDULE OUTAGE
368	13-Dec-2021	PART OF G BLOCK NARELA	3	315 kVA	Planned Outage	13-Dec-2021	08:38	13-Dec-2021	14:11	333	0.00009	PLANNED OUTAGE
369	13-Dec-2021	PARTS OF DDA B-2, POKKET A, D, H NARELA NARELA	53	Other Outage	Planned Outage	13-Dec-2021	10:19	13-Dec-2021	17:00	401	0.00022	PLANNED OUTAGE
370	13-Dec-2021	PARTS OF DDA B-2, POKKET A, D, H NARELA NARELA	5	Other Outage	Planned Outage	13-Dec-2021	10:21	13-Dec-2021	17:00	399	0.00055	PLANNED OUTAGE
371	13-Dec-2021	PARTS OF DD NO-58 H-BLOCK NARELA	105	400 kVA	Unplanned Outage	13-Dec-2021	15:20	13-Dec-2021	15:46	26	0.00001	SYSTEM SCHEDULE OUTAGE
372	14-Dec-2021	PARTS OF DDA B-2, POKKET A, D, H NARELA NARELA	84	Other Outage	Planned Outage	14-Dec-2021	10:28	14-Dec-2021	17:08	400	0.00011	PLANNED OUTAGE
373	14-Dec-2021	PARTS OF DDA B-2, POKKET A, D, H NARELA NARELA	90	Other Outage	Planned Outage	14-Dec-2021	10:31	14-Dec-2021	17:08	397	0.00011	PLANNED OUTAGE
374	14-Dec-2021	PART OF TRIVENI COLONY NARELA	6	Other Outage	Planned Outage	14-Dec-2021	10:47	14-Dec-2021	17:16	389	0.00011	PLANNED OUTAGE
375	14-Dec-2021	PART OF F-1712 DSIDC NARELA	1	160 kVA	Unplanned Outage	14-Dec-2021	11:57	14-Dec-2021	12:40	43	0.00001	SYSTEM SCHEDULE OUTAGE
376	14-Dec-2021	PART OF F-1712 DSIDC NARELA	3	315 kVA	Unplanned Outage	14-Dec-2021	12:59	14-Dec-2021	14:24	85	0.00002	SYSTEM SCHEDULE OUTAGE
377	14-Dec-2021	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATI WALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	246	Other Outage	Planned Outage	14-Dec-2021	14:05	14-Dec-2021	17:24	199	0.00017	PLANNED OUTAGE
378	14-Dec-2021	PART OF NO-35 F-BLOCK DSIDC NARELA	1	Other Outage	Unplanned Outage	14-Dec-2021	14:33	14-Dec-2021	14:57	24	0.00001	SYSTEM SCHEDULE OUTAGE
379	15-Dec-2021	PARTS OF DDA B-2, POKKET - C, F, G NARELA NARELA	54	Other Outage	Planned Outage	15-Dec-2021	10:07	15-Dec-2021	15:59	352	0.00010	PLANNED OUTAGE
380	15-Dec-2021	PARTS OF DDA B-2, POKKET - C, F, G NARELA NARELA	101	Other Outage	Planned Outage	15-Dec-2021	10:13	15-Dec-2021	16:02	349	0.00029	PLANNED OUTAGE
381	15-Dec-2021	PARTS OF PANCHAYATGARH IBRAHIMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY PREAM NAGAR, NARELA	130	Other Outage	Planned Outage	15-Dec-2021	11:38	15-Dec-2021	15:30	232	0.00013	PLANNED OUTAGE
382	15-Dec-2021	PART OF F BLOCK NARELA	3	400 kVA	Unplanned Outage	15-Dec-2021	11:50	15-Dec-2021	12:30	40	0.00001	SYSTEM SCHEDULE OUTAGE
383	15-Dec-2021	PARTS OF PANCHAYATGARH IBRAHIMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY PREAM NAGAR, NARELA	123	Other Outage	Planned Outage	15-Dec-2021	12:01	15-Dec-2021	15:30	209	0.00012	PLANNED OUTAGE
384	16-Dec-2021	PARTS OF SECTOR - AS, POKKET - B, J. COLONY (NARELA), AS POKKET - 13 DDA FLATS MAMUR PUR COLONY, SEWA ASHRAM, DDA MKT. A-5 NARELA	1132	Other Outage	Planned Outage	16-Dec-2021	10:36	16-Dec-2021	16:42	366	0.00122	PLANNED OUTAGE
385	16-Dec-2021	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	3746	Other Outage	Planned Outage	16-Dec-2021	10:57	16-Dec-2021	14:47	230	0.00147	PLANNED OUTAGE
386	16-Dec-2021	PART OF J-3368 DSIDC NARELA	3	160 kVA	Planned Outage	16-Dec-2021	11:00	16-Dec-2021	13:10	130	0.00004	PLANNED OUTAGE
387	16-Dec-2021	PART OF I BLOCK DSIDC NARELA	3	315 kVA	Unplanned Outage	16-Dec-2021	12:00	16-Dec-2021	12:57	57	0.00002	SYSTEM SCHEDULE OUTAGE
388	16-Dec-2021	PART OF DSIDC B-2562 NARELA	3	400 kVA	Unplanned Outage	16-Dec-2021	13:27	16-Dec-2021	14:29	62	0.00002	SYSTEM SCHEDULE OUTAGE
389	16-Dec-2021	PARTS OF DSIDC BHORGARH VILLAGE NARELA	263	400 kVA	Planned Outage	16-Dec-2021	13:33	16-Dec-2021	16:45	192	0.00021	PLANNED OUTAGE
390	16-Dec-2021	PART OF D-1543 DSIDC NARELA	3	400 kVA	Unplanned Outage	16-Dec-2021	15:40	16-Dec-2021	15:58	18	0.00001	SYSTEM SCHEDULE OUTAGE
391	17-Dec-2021	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	96	Other Outage	Planned Outage	17-Dec-2021	10:36	17-Dec-2021	16:45	369	0.00010	PLANNED OUTAGE
392	17-Dec-2021	PART OF TRIVENI COLONY NARELA	6	Other Outage	Planned Outage	17-Dec-2021	10:40	17-Dec-2021	17:32	412	0.00011	PLANNED OUTAGE
393	17-Dec-2021	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA, NARELA	539	Other Outage	Planned Outage	17-Dec-2021	11:23	17-Dec-2021	17:03	340	0.00057	PLANNED OUTAGE
394	17-Dec-2021	PART OF I BLOCK DSIDC NARELA	2	400 kVA	Unplanned Outage	17-Dec-2021	11:51	17-Dec-2021	12:48	57	0.00002	SYSTEM SCHEDULE OUTAGE
395	17-Dec-2021	PART OF TRIVENI COLONY NARELA	13	Other Outage	Planned Outage	17-Dec-2021	12:07	17-Dec-2021	12:48	41	0.00001	PLANNED OUTAGE
396	17-Dec-2021	PART OF G BLOCK DSIDC NARELA	3	500 kVA	Unplanned Outage	17-Dec-2021	14:22	17-Dec-2021	15:13	51	0.00001	SYSTEM SCHEDULE OUTAGE
397	17-Dec-2021	PART OF G BLOCK NARELA	2	250 kVA	Unplanned Outage	17-Dec-2021	15:42	17-Dec-2021	16:45	63	0.00002	SYSTEM SCHEDULE OUTAGE
398	18-Dec-2021	PARTS OF E BLOCK DSIDC NARELA	169	Other Outage	Planned Outage	18-Dec-2021	09:51	18-Dec-2021	16:53	422	0.00023	PLANNED OUTAGE
399	18-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	436	Other Outage	Planned Outage	18-Dec-2021	10:23	18-Dec-2021	16:11	348	0.00242	PLANNED OUTAGE
400	18-Dec-2021	PARTS OF A BLOCK DSIDC NARELA	116	Other Outage	Planned Outage	18-Dec-2021	10:53	18-Dec-2021	17:16	383	0.00021	PLANNED OUTAGE
401	18-Dec-2021	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	1	250 kVA	Unplanned Outage	18-Dec-2021	11:13	18-Dec-2021	12:09	56	0.00002	SYSTEM SCHEDULE OUTAGE
402	18-Dec-2021	PARTS OF D BLOCK DSIDC NARELA	65	Other Outage	Planned Outage	18-Dec-2021	11:14	18-Dec-2021	17:08	354	0.00010	PLANNED OUTAGE
403	18-Dec-2021	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3996	Other Outage	Planned Outage	18-Dec-2021	11:35	18-Dec-2021	17:31	356	0.00791	PLANNED OUTAGE
404	18-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL NARELA	311	400 kVA	Planned Outage	18-Dec-2021	11:36	18-Dec-2021	15:30	234	0.00026	PLANNED OUTAGE
405	18-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	173	Other Outage	Planned Outage	18-Dec-2021	11:41	18-Dec-2021	17:34	353	0.00098	PLANNED OUTAGE
406	18-Dec-2021	PARTS OF DSIDC FACTORY NOJ-2293 TO J-3116 AND J-2824 TO J-2846 AND J-3128 TO J-3141 NARELA	24	Other Outage	Planned Outage	18-Dec-2021	11:41	18-Dec-2021	13:51	130	0.00018	PLANNED OUTAGE
407	18-Dec-2021	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	82	Other Outage	Planned Outage	18-Dec-2021	11:48	18-Dec-2021	15:05	197	0.00055	PLANNED OUTAGE
408	18-Dec-2021	PART OF F BLOCK NARELA	5	400 kVA	Unplanned Outage	18-Dec-2021	13:00	18-Dec-2021	13:27	27	0.00001	SYSTEM SCHEDULE OUTAGE
409	18-Dec-2021	PART OF F BLOCK DSIDC NARELA	5	400 kVA	Unplanned Outage	18-Dec-2021	14:34	18-Dec-2021	16:03	89	0.00002	SYSTEM SCHEDULE OUTAGE
410	18-Dec-2021	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	400 kVA	Unplanned Outage	18-Dec-2021	16:00	18-Dec-2021	17:18	78	0.00002	SYSTEM SCHEDULE OUTAGE
411	20-Dec-2021	PART OF C BLOCK DSIDC NARELA	2	315 kVA	Planned Outage	20-Dec-2021	07:43	20-Dec-2021	09:26	103	0.00003	PLANNED OUTAGE
412	20-Dec-2021	PART OF C BLOCK DSIDC NARELA	4	315 kVA	Planned Outage	20-Dec-2021	07:44	20-Dec-2021	09:26	102	0.00003	PLANNED OUTAGE
413	20-Dec-2021	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	454	Other Outage	Planned Outage	20-Dec-2021	10:33	20-Dec-2021	16:50	377	0.00052	PLANNED OUTAGE
414	20-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL NARELA	469	400 kVA	Planned Outage	20-Dec-2021	10:53	20-Dec-2021	11:55	62	0.00043	PLANNED OUTAGE
415	20-Dec-2021	PARTS OF										

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
421	20-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRI, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	447	630 kVA	Planned Outage	20-Dec-2021	12:36	20-Dec-2021	16:14	218	0.00024	PLANNED OUTAGE
422	20-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL NARELA	377	400 kVA	Planned Outage	20-Dec-2021	14:05	20-Dec-2021	15:20	75	0.00021	PLANNED OUTAGE
423	20-Dec-2021	PART OF E BLOCK DSIC NARELA	4	250 kVA	Unplanned Outage	20-Dec-2021	14:23	20-Dec-2021	15:03	40	0.00001	SYSTEM SCHEDULE OUTAGE
424	20-Dec-2021	PART OF E BLOCK NARELA	4	315 kVA	Unplanned Outage	20-Dec-2021	14:52	20-Dec-2021	15:38	46	0.00001	SYSTEM SCHEDULE OUTAGE
425	21-Dec-2021	PART OF E BLOCK DSIC NARELA	3	315 kVA	Planned Outage	21-Dec-2021	07:36	21-Dec-2021	11:16	220	0.00006	PLANNED OUTAGE
426	21-Dec-2021	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY NARELA	638	Other Outage	Planned Outage	21-Dec-2021	10:40	21-Dec-2021	17:02	382	0.00085	PLANNED OUTAGE
427	21-Dec-2021	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR NARELA	1144	Other Outage	Planned Outage	21-Dec-2021	11:24	21-Dec-2021	16:28	304	0.00093	PLANNED OUTAGE
428	21-Dec-2021	PART OF E BLOCK NARELA	5	315 kVA	Unplanned Outage	21-Dec-2021	15:12	21-Dec-2021	16:39	87	0.00002	SYSTEM SCHEDULE OUTAGE
429	22-Dec-2021	PARTS OF AMAN VIHAR, SHAMSHAN GHAT NANGLI POONA, MURGI FARM KADIPUR, GURUDWARA GT ROAD NANGLI, MOHAN VILAS, DALMILL NANGLI POONA NARELA	827	Other Outage	Planned Outage	22-Dec-2021	10:43	22-Dec-2021	14:44	241	0.00134	PLANNED OUTAGE
430	22-Dec-2021	PART OF B BLOCK DSIC NARELA	6	250 kVA	Unplanned Outage	22-Dec-2021	11:07	22-Dec-2021	15:15	248	0.00007	FORCE MAJEURE DUE TO SABOTAGE
431	22-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRI, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	1217	Other Outage	Planned Outage	22-Dec-2021	11:25	22-Dec-2021	14:58	213	0.00077	PLANNED OUTAGE
432	23-Dec-2021	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	1010	Other Outage	Planned Outage	23-Dec-2021	10:59	23-Dec-2021	17:00	361	0.00100	PLANNED OUTAGE
433	23-Dec-2021	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	333	Other Outage	Planned Outage	23-Dec-2021	11:14	23-Dec-2021	17:09	355	0.00030	PLANNED OUTAGE
434	23-Dec-2021	PARTS OF A BLOCK DSIC NARELA	2380	Other Outage	Planned Outage	23-Dec-2021	11:33	23-Dec-2021	17:07	334	0.00278	PLANNED OUTAGE
435	23-Dec-2021	PART OF G BLOCK NARELA	3	315 kVA	Unplanned Outage	23-Dec-2021	12:52	23-Dec-2021	14:10	78	0.00002	SYSTEM SCHEDULE OUTAGE
436	23-Dec-2021	PART OF G BLOCK NARELA	3	315 kVA	Unplanned Outage	23-Dec-2021	15:08	23-Dec-2021	15:35	27	0.00001	SYSTEM SCHEDULE OUTAGE
437	24-Dec-2021	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	2653	Other Outage	Planned Outage	24-Dec-2021	11:06	24-Dec-2021	13:10	124	0.00083	PLANNED OUTAGE
438	24-Dec-2021	PARTS OF TEJISINGH KHERAKALAN, JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN NARELA	494	Other Outage	Planned Outage	24-Dec-2021	11:10	24-Dec-2021	14:14	184	0.00031	PLANNED OUTAGE
439	24-Dec-2021	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	128	Other Outage	Planned Outage	24-Dec-2021	11:30	24-Dec-2021	16:39	309	0.00017	PLANNED OUTAGE
440	24-Dec-2021	PART OF HARIZAN BASTI NARELA	3	250 kVA	Unplanned Outage	24-Dec-2021	11:30	24-Dec-2021	12:07	37	0.00001	SYSTEM SCHEDULE OUTAGE
441	24-Dec-2021	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	161	Other Outage	Planned Outage	24-Dec-2021	11:34	24-Dec-2021	17:47	373	0.00031	PLANNED OUTAGE
442	24-Dec-2021	PART OF H BLOCK NARELA	3	250 kVA	Unplanned Outage	24-Dec-2021	12:43	24-Dec-2021	13:10	27	0.00001	SYSTEM SCHEDULE OUTAGE
443	24-Dec-2021	PART OF J-3057 DSIC NARELA	2	160 kVA	Unplanned Outage	24-Dec-2021	14:09	24-Dec-2021	14:53	44	0.00001	SYSTEM SCHEDULE OUTAGE
444	27-Dec-2021	PART OF TRIVENI COLONY NARELA	5	Other Outage	Planned Outage	27-Dec-2021	10:43	27-Dec-2021	17:41	418	0.00012	PLANNED OUTAGE
445	27-Dec-2021	PARTS OF STAND WALA KUSHAK HIRANKI, RAGHUBEER WALA RAMJANPUR, HIRANKI BUS STAND NO-1 NARELA	224	Other Outage	Planned Outage	27-Dec-2021	10:46	27-Dec-2021	14:12	206	0.00023	PLANNED OUTAGE
446	27-Dec-2021	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRI, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	65	Other Outage	Planned Outage	27-Dec-2021	11:18	27-Dec-2021	16:56	338	0.00019	PLANNED OUTAGE
447	27-Dec-2021	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	1429	Other Outage	Planned Outage	27-Dec-2021	11:19	27-Dec-2021	17:25	366	0.00112	PLANNED OUTAGE
448	27-Dec-2021	PART OF E BLOCK DSIC NARELA	4	400 kVA	Unplanned Outage	27-Dec-2021	12:13	27-Dec-2021	13:02	49	0.00001	SYSTEM SCHEDULE OUTAGE
449	27-Dec-2021	PART OF C BLOCK DSIC NARELA	5	400 kVA	Unplanned Outage	27-Dec-2021	12:30	27-Dec-2021	12:59	29	0.00001	SYSTEM SCHEDULE OUTAGE
450	27-Dec-2021	PART OF A BLOCK DSIC NARELA	6	400 kVA	Unplanned Outage	27-Dec-2021	14:02	27-Dec-2021	14:18	16	0.00005	SYSTEM SCHEDULE OUTAGE
451	27-Dec-2021	PARTS OF STAND WALA KUSHAK HIRANKI, RAGHUBEER WALA RAMJANPUR, HIRANKI BUS STAND NO-1 NARELA	95	Other Outage	Planned Outage	27-Dec-2021	14:49	27-Dec-2021	16:37	108	0.00003	PLANNED OUTAGE
452	27-Dec-2021	PART OF G BLOCK DSIC NARELA	4	400 kVA	Unplanned Outage	27-Dec-2021	14:53	27-Dec-2021	16:02	69	0.00002	SYSTEM SCHEDULE OUTAGE
453	28-Dec-2021	PARTS OF NANGLI KIOSK ALUPUR NARELA	302	Other Outage	Planned Outage	28-Dec-2021	10:09	28-Dec-2021	11:48	99	0.00008	PLANNED OUTAGE
454	28-Dec-2021	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	74	Other Outage	Planned Outage	28-Dec-2021	11:38	28-Dec-2021	17:22	344	0.00019	PLANNED OUTAGE
455	28-Dec-2021	PARTS OF NANGLI KIOSK ALUPUR NARELA	32	Other Outage	Planned Outage	28-Dec-2021	12:29	28-Dec-2021	16:48	259	0.00007	PLANNED OUTAGE
456	28-Dec-2021	PART OF F BLOCK NARELA	2	250 kVA	Unplanned Outage	28-Dec-2021	12:32	28-Dec-2021	13:38	66	0.00002	SYSTEM SCHEDULE OUTAGE
457	28-Dec-2021	PART OF B BLOCK DSIC NARELA	5	400 kVA	Unplanned Outage	28-Dec-2021	14:56	28-Dec-2021	15:33	37	0.00001	SYSTEM SCHEDULE OUTAGE
458	28-Dec-2021	PART OF NO-10 C BLOCK DSIC NARELA	4	315 kVA	Unplanned Outage	28-Dec-2021	15:18	28-Dec-2021	16:13	55	0.00002	SYSTEM SCHEDULE OUTAGE
459	28-Dec-2021	PARTS OF NANGLI KIOSK ALUPUR NARELA	270	Other Outage	Planned Outage	28-Dec-2021	15:46	28-Dec-2021	16:48	62	0.00003	PLANNED OUTAGE
460	29-Dec-2021	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	230	Other Outage	Planned Outage	29-Dec-2021	10:59	29-Dec-2021	17:21	382	0.00032	PLANNED OUTAGE
461	29-Dec-2021	PARTS OF SDM OFFICE ALUPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	118	Other Outage	Planned Outage	29-Dec-2021	11:32	29-Dec-2021	14:47	195	0.00016	PLANNED OUTAGE
462	29-Dec-2021	PART OF TRIVENI COLONY NARELA	13	Other Outage	Planned Outage	29-Dec-2021	11:37	29-Dec-2021	17:33	356	0.00010	PLANNED OUTAGE
463	30-Dec-2021	PARTS OF NAF SINGH NO-2, KUSUM FARM, SINGHOVA VILLAGE NARELA	306	Other Outage	Planned Outage	30-Dec-2021	10:54	30-Dec-2021	15:57	303	0.00025	PLANNED OUTAGE
464	30-Dec-2021	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. NARELA	237	400 kVA	Planned Outage	30-Dec-2021	10:55	30-Dec-2021	11:43	48	0.00003	PLANNED OUTAGE
465	30-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL NARELA	1236	Other Outage	Planned Outage	30-Dec-2021	11:07	30-Dec-2021	13:39	152	0.00034	PLANNED OUTAGE
466	30-Dec-2021	PART OF G BLOCK NARELA	3	315 kVA	Unplanned Outage	30-Dec-2021	12:59	30-Dec-2021	14:08	69	0.00002	SYSTEM SCHEDULE OUTAGE
467	31-Dec-2021	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	2507	Other Outage	Planned Outage	31-Dec-2021	10:45	31-Dec-2021	17:08	383	0.00286	PLANNED OUTAGE
468	31-Dec-2021	PARTS OF SDM OFFICE ALUPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	139	Other Outage	Planned Outage	31-Dec-2021	11:12	31-Dec-2021	15:11	239	0.00013	PLANNED OUTAGE
469	31-Dec-2021	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL NARELA	174	Other Outage	Planned Outage	31-Dec-2021	11:41	31-Dec-2021	15:23	222	0.00012	PLANNED OUTAGE
470	31-Dec-2021	PART OF DSICD FACTORY NO. F-1829 NARELA	1	315 kVA	Unplanned Outage	31-Dec-2021	12:10	31-Dec-2021	12:39	29	0.00001	SYSTEM SCHEDULE OUTAGE
471	31-Dec-2021	PART OF A BLOCK NARELA	2	250 kVA	Unplanned Outage	31-Dec-2021	14:07	31-Dec-2021	14:33	26	0.00001	SYSTEM SCHEDULE OUTAGE
472	31-Dec-2021	PART OF DSICD B-2562 NARELA	5	400 kVA	Unplanned Outage	31-Dec-2021	16:09	31-Dec-2021	16:46	37	0.00001	SYSTEM SCHEDULE OUTAGE
PITAM PURA												
1	01-Dec-2021	PARTS OF OLD SABZI MANDI RISHI NAGAR, PHOOLARAM NO. - I, ROYAL MIRAZ PSS, JAGRITI APPT. PITAM PURA	2793	Other Outage	Unplanned Outage	01-Dec-2021	16:58	01-Dec-2021	17:22	24	0.000299	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PARTS OF OLD SABZI MANDI RISHI NAGAR, PHOOLARAM NO. - I, ROYAL MIRAZ PSS, JAGRITI APPT. PITAM PURA	161	Other Outage	Unplanned Outage	01-Dec-2021	16:58	01-Dec-2021	17:28	30	0.00001	INTERRUPTION DUE TO FAULT
3	02-Dec-2021	PARTS OF A, B, C, D BLOCK SARASWATI VIHAR PITAM PURA	1446	Other Outage	Unplanned Outage	02-Dec-2021	13:10	02-Dec-2021	13:33	23	0.000126	INTERRUPTION DUE TO FAULT
4	02-Dec-2021	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2 PITAM PURA	85	Other Outage	Unplanned Outage	02-Dec-2021	16:31	02-Dec-2021	17:00	29	0.00004	INTERRUPTION DUE TO FAULT
5	02-Dec-2021	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	55	Other Outage	Unplanned Outage	02-Dec-2021	21:00	02-Dec-2021	21:43	43	0.00006	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	86	Other Outage	Unplanned Outage	02-Dec-2021	21:00	02-Dec-2021	21:50	50	0.000028	INTERRUPTION DUE TO FAULT
7	02-Dec-2021	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	65	Other Outage	Unplanned Outage	02-Dec-2021	21:00	02-Dec-2021	23:08	128	0.000071	FORCE MAJEURE DUE TO RAIN/STORM
8	03-Dec-2021	PARTS OF SIDHARTHA APPARTMENTS, M,P ENCLAVE, JEEVAN JYOTI - I & II PITAM PURA	90	Other Outage	Unplanned Outage	03-Dec-2021	06:25	03-Dec-2021	06:35	10	0.000014	INTERRUPTION DUE TO FAULT
9	03-Dec-2021	PARTS OF SIDHARTHA APPARTMENTS, M,P ENCLAVE, JEEVAN JYOTI - I & II PITAM PURA	168	Other Outage	Unplanned Outage	03-Dec-2021	06:25	03-Dec-2021	06:43	18	0.000025	INTERRUPTION DUE TO FAULT
10	04-Dec-2021	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	11	Other Outage	Unplanned Outage	04-Dec-2021	07:30	04-Dec-2021	08:00	30	0.000008	INTERRUPTION DUE TO FAULT
11	04-Dec-2021	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	163	Other Outage	Unplanned Outage	04-Dec-2021	07:35	04-Dec-2021	08:00	25	0.000028	INTERRUPTION DUE TO FAULT
12	04-Dec-2021	PARTS OF C & D - BLOCK JJ COLONY, M-BLOCK RAJIV GANDHI MARKET PSS, SAMRAT CINEMA PITAM PURA	304	Other Outage	Unplanned Outage	04-Dec-2021	17:06	04-Dec-2021	18:10	64	0.000053	INTERRUPTION DUE TO FAULT
13	04-Dec-2021	PARTS OF C & D - BLOCK JJ COLONY, M-BLOCK RAJIV GANDHI MARKET PSS, SAMRAT CINEMA PITAM PURA	3527	Other Outage	Unplanned Outage	04-Dec-2021	17:06	04-Dec-2021	18:20	74	0.000715	INTERRUPTION DUE TO FAULT
14	06-Dec-2021	PART OF NO-8 MIA PH-2 PITAM PURA	4	Other Outage	Unplanned Outage	06-Dec-2021	11:30	06-Dec-2021	11:59	29	0.000008	INTERRUPTION DUE TO FAULT
15	07-Dec-2021	PARTS OF OLD SABZI MANDI RISHI NAGAR, PHOOLARAM NO. - I, ROYAL MIRAZ PSS, JAGRITI APPT. PITAM PURA	161	Other Outage	Unplanned Outage	07-Dec-2021	11:07	07-Dec-2021	11:31	24	0.000007	INTERRUPTION DUE TO FAULT
16	07-Dec-2021	PARTS OF M BLOCK SHAKURPUR, MOTHER DAIRY, ROAD NO - 43 PITAM PURA	1102	Other Outage	Unplanned Outage	07-Dec-2021	18:29	07-Dec-2021	19:03	34	0.000057	INTERRUPTION DUE TO FAULT
17	07-Dec-2021	PARTS OF M BLOCK SHAKURPUR, MOTHER DAIRY, ROAD NO - 43 PITAM PURA	528	Other Outage	Unplanned Outage	07-Dec-2021	18:29	07-Dec-2021	19:03	34	0.000047	INTERRUPTION DUE TO FAULT
18	08-Dec-2021	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT, LOK VIHAR A BLOCK, PART OF CHANDER LOK PITAM PURA	1813	Other Outage	Unplanned Outage	08-Dec-2021	08:27	08-Dec-2021	09:09	42	0.000235	INTERRUPTION DUE TO FAULT
19	08-Dec-2021	PARTS OF M BLOCK SHAKURPUR, MOTHER DAIRY, ROAD NO - 43 PITAM PURA	340	Other Outage	Unplanned Outage	08-Dec-2021	11:47	08-Dec-2021	12:22			

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
25	11-Dec-2021	PARTS OF A-BLOCK MANGOLPURI INDUSTRIAL AREA AND PARTS OF BC-BLOCK MANGOLPURI INDUSTRIAL AREA, PITAM PURA	41	Other Outage	Unplanned Outage	11-Dec-2021	11:18	11-Dec-2021	12:06	48	0.000107	INTERRUPTION DUE TO FAULT
26	11-Dec-2021	PARTS OF MULANA AZAD, BAL BHARTI SCHOOL, BRIJ VIHAR APPARTMENT, GUJRAT APPARTMENT, GALIB APPARTMENT, LORD BUDHA, SUBH ENCLAVE, DARA GAZIKHAN JJ CLUSTER, MAXFORT SCHOOLENCLAVE, DARA GAZIKHAN JJ CLUSTER, MAXFORT SCHOOL PITAM PURA	1034	Other Outage	Unplanned Outage	11-Dec-2021	14:45	11-Dec-2021	15:00	15	0.00008	INTERRUPTION DUE TO FAULT
27	11-Dec-2021	PARTS OF A BLOCK (MANGOL PURI), B BLOCK MANGOL PURI (PARTLY), BC BLOCK MANGOL PURI PH-2 PITAM PURA	107	Other Outage	Unplanned Outage	11-Dec-2021	15:19	11-Dec-2021	16:52	93	0.000078	INTERRUPTION DUE TO FAULT
28	14-Dec-2021	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL, KP PLINTH, PART OF MD,DPCC BLOCK PITAM PURA	172	Other Outage	Unplanned Outage	14-Dec-2021	08:24	14-Dec-2021	09:03	39	0.000086	INTERRUPTION DUE TO FAULT
29	14-Dec-2021	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	174	Other Outage	Unplanned Outage	14-Dec-2021	10:24	14-Dec-2021	13:10	166	0.000139	FORCE MAJEURE DUE TO SABOTAGE
30	14-Dec-2021	PART OF CB BLOCK EAST PITAM PURA	3	Other Outage	Unplanned Outage	14-Dec-2021	11:18	14-Dec-2021	11:59	41	0.000023	INTERRUPTION DUE TO FAULT
31	14-Dec-2021	PART OF B-1 MIA PHASE-2 PITAM PURA	5	Other Outage	Unplanned Outage	14-Dec-2021	13:43	14-Dec-2021	15:30	107	0.000003	INTERRUPTION DUE TO FAULT
32	15-Dec-2021	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	839	Other Outage	Unplanned Outage	15-Dec-2021	04:55	15-Dec-2021	05:15	20	0.000054	INTERRUPTION DUE TO FAULT
33	15-Dec-2021	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	1622	Other Outage	Unplanned Outage	15-Dec-2021	04:55	15-Dec-2021	05:40	45	0.000185	INTERRUPTION DUE TO FAULT
34	15-Dec-2021	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	92	Other Outage	Unplanned Outage	15-Dec-2021	04:55	15-Dec-2021	06:26	91	0.000025	INTERRUPTION DUE TO FAULT
35	15-Dec-2021	PARTS OF MULTANI MOHALLA, PART OF RANI BAGH, PART OF COMMERCIAL COMPLEX, PART OF MAHENDRA PARK PITAM PURA	3402	Other Outage	Unplanned Outage	15-Dec-2021	12:10	15-Dec-2021	12:19	9	0.000085	SYSTEM SCHEDULE OUTAGE
36	16-Dec-2021	PARTS OF SANDESH VIHAR PSS, NISHANT KUNI, POLICE COLONY, ROHIT KUNI, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS PITAM PURA	121	Other Outage	Unplanned Outage	16-Dec-2021	11:15	16-Dec-2021	11:50	35	0.000049	INTERRUPTION DUE TO FAULT
37	16-Dec-2021	PARTS OF SANDESH VIHAR PSS, NISHANT KUNI, POLICE COLONY, ROHIT KUNI, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS PITAM PURA	182	Other Outage	Unplanned Outage	16-Dec-2021	11:55	16-Dec-2021	12:48	53	0.000221	INTERRUPTION DUE TO FAULT
38	16-Dec-2021	PARTS OF JHULA LAL NO-1, A-BLOCK LOK VIHAR PITAM PURA	25	Other Outage	Unplanned Outage	16-Dec-2021	14:31	16-Dec-2021	15:30	59	0.000016	INTERRUPTION DUE TO FAULT
39	17-Dec-2021	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	92	Other Outage	Unplanned Outage	17-Dec-2021	05:29	17-Dec-2021	05:57	28	0.000008	INTERRUPTION DUE TO FAULT
40	17-Dec-2021	PARTS OF MULTANI MOHALLA, PART OF RANI BAGH, PART OF COMMERCIAL COMPLEX, PART OF MAHENDRA PARK PITAM PURA	92	Other Outage	Unplanned Outage	17-Dec-2021	06:32	17-Dec-2021	07:55	83	0.000023	INTERRUPTION DUE TO FAULT
41	17-Dec-2021	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	839	Other Outage	Unplanned Outage	17-Dec-2021	06:33	17-Dec-2021	07:09	36	0.000092	INTERRUPTION DUE TO FAULT
42	17-Dec-2021	PARTS OF RANI BAGH, PART OF MULTANI MOHALLA PITAM PURA	2403	Other Outage	Unplanned Outage	17-Dec-2021	06:53	17-Dec-2021	06:56	3	0.000018	INTERRUPTION DUE TO FAULT
43	17-Dec-2021	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2 PITAM PURA	306	Other Outage	Unplanned Outage	17-Dec-2021	14:57	17-Dec-2021	16:48	111	0.000062	INTERRUPTION DUE TO FAULT
44	19-Dec-2021	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT, LOK VIHAR A BLOCK, PART OF CHANDER LOK PITAM PURA	328	Other Outage	Unplanned Outage	19-Dec-2021	12:11	19-Dec-2021	14:45	154	0.000342	FORCE MAJEURE DUE TO SABOTAGE
45	20-Dec-2021	PARTS OF KALASH ENCLAVE, 112 MIG FLATS, MILANIUM PUBLIC SCHOOL, MAHARAJA AGARSEN BHAWAN, LOREN HIGH SCHOOL, PART OF IDPL, PART OF VILLAGE PITAM PURA & JANTA FLATS PITAM PURA	399	Other Outage	Unplanned Outage	20-Dec-2021	11:36	20-Dec-2021	12:17	41	0.000046	INTERRUPTION DUE TO FAULT
46	20-Dec-2021	PARTS OF 2P BLOCK SCHOOL, YP & TP BLOCK PITAM PURA	379	Other Outage	Unplanned Outage	20-Dec-2021	15:55	20-Dec-2021	16:29	34	0.000047	INTERRUPTION DUE TO FAULT
47	21-Dec-2021	PARTS OF KP COMMERCIAL COMPLEX, TU, MP, LP, JP, KP, HP BLOCK PITAM PURA	1802	Other Outage	Unplanned Outage	21-Dec-2021	10:45	21-Dec-2021	10:59	14	0.000155	INTERRUPTION DUE TO FAULT
48	21-Dec-2021	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	92	Other Outage	Unplanned Outage	21-Dec-2021	23:23	21-Dec-2021	23:50	27	0.000003	INTERRUPTION DUE TO FAULT
49	22-Dec-2021	PARTS OF SIRI NAGAR KHATTE WALA, M-BLOCK SHAKURPUR, SAMRAT ENCLAVE, A - BLOCK J.J. COLONY, RAJDHANI ENCLAVE, SIRI NAGAR GURUDWARA PITAM PURA	1333	Other Outage	Unplanned Outage	22-Dec-2021	12:06	22-Dec-2021	12:31	25	0.000124	INTERRUPTION DUE TO FAULT
50	22-Dec-2021	PARTS OF A-BLOCK MANGOLPURI INDUSTRIAL AREA AND PARTS OF BC-BLOCK MANGOLPURI INDUSTRIAL AREA, PITAM PURA	41	Other Outage	Unplanned Outage	22-Dec-2021	12:07	22-Dec-2021	13:14	67	0.000075	INTERRUPTION DUE TO FAULT
51	24-Dec-2021	PARTS OF B - BLK SARASWATI VIHAR, COMMUNITY CENTRE PITAM PURA	1304	Other Outage	Unplanned Outage	24-Dec-2021	11:34	24-Dec-2021	12:11	37	0.000158	INTERRUPTION DUE TO FAULT
52	28-Dec-2021	PART OF BHAGWAN MAHAVIR STAFF QTRS PITAM PURA	10	Other Outage	Unplanned Outage	26-Dec-2021	11:34	26-Dec-2021	13:02	88	0.000049	INTERRUPTION DUE TO FAULT
53	28-Dec-2021	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR PITAM PURA	300	Other Outage	Unplanned Outage	26-Dec-2021	16:38	26-Dec-2021	16:49	11	0.000015	INTERRUPTION DUE TO FAULT
54	28-Dec-2021	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL, KP PLINTH, PART OF MD,DPCC BLOCK PITAM PURA	1441	Other Outage	Unplanned Outage	26-Dec-2021	19:52	26-Dec-2021	20:46	54	0.000221	INTERRUPTION DUE TO FAULT
55	28-Dec-2021	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL, KP PLINTH, PART OF MD,DPCC BLOCK PITAM PURA	21	Other Outage	Unplanned Outage	26-Dec-2021	19:52	26-Dec-2021	21:50	118	0.000065	INTERRUPTION DUE TO FAULT
56	27-Dec-2021	PARTS OF DP, RP, QD, FP, MD, LD, PD PART OF GP BLOCK PITAM PURA	21	Other Outage	Unplanned Outage	27-Dec-2021	16:26	27-Dec-2021	17:20	54	0.000075	INTERRUPTION DUE TO FAULT
57	28-Dec-2021	PARTS OF VARUN NIKETAN, BU, AU BLOCK PITAM PURA	665	Other Outage	Unplanned Outage	28-Dec-2021	17:32	28-Dec-2021	18:21	49	0.000164	INTERRUPTION DUE TO FAULT
58	28-Dec-2021	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	137	Other Outage	Unplanned Outage	28-Dec-2021	17:33	28-Dec-2021	19:16	103	0.000343	INTERRUPTION DUE TO FAULT
59	28-Dec-2021	PARTS OF A, B, C, D BLOCK SARASWATI VIHAR PITAM PURA	786	Other Outage	Unplanned Outage	28-Dec-2021	23:48	29-Dec-2021	00:13	25	0.000034	INTERRUPTION DUE TO FAULT
60	28-Dec-2021	PARTS OF A, B, C, D BLOCK SARASWATI VIHAR PITAM PURA	684	Other Outage	Unplanned Outage	28-Dec-2021	23:48	29-Dec-2021	00:17	29	0.000004	INTERRUPTION DUE TO FAULT
61	29-Dec-2021	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	137	Other Outage	Unplanned Outage	29-Dec-2021	08:59	29-Dec-2021	10:00	61	0.000051	INTERRUPTION DUE TO FAULT
62	29-Dec-2021	PARTS OF DIB TU BLK, MU PARK, CD MARKET, BD PARK, MU BLOCK MCD SCHOOL, PITAM PURA	278	Other Outage	Unplanned Outage	29-Dec-2021	20:21	29-Dec-2021	20:56	35	0.000039	INTERRUPTION DUE TO FAULT
63	30-Dec-2021	PARTS OF KU, DU, AU, AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	326	Other Outage	Unplanned Outage	30-Dec-2021	10:30	30-Dec-2021	10:33	3	0.000003	SYSTEM SCHEDULE OUTAGE
64	30-Dec-2021	PARTS OF KU, DU, AU, AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	213	Other Outage	Unplanned Outage	30-Dec-2021	10:31	30-Dec-2021	10:33	2	0.000002	SYSTEM SCHEDULE OUTAGE
65	31-Dec-2021	PARTS OF SADBHAVANA APPARTMENT, BANK VIHAR, MCD PUMP HOUSE NEAR AJAY APPARTMENT, B-BLOCK PUSHPANJLI, TARUN ENCLAVE PITAM PURA	1041	Other Outage	Unplanned Outage	31-Dec-2021	08:26	31-Dec-2021	08:45	19	0.000066	INTERRUPTION DUE TO FAULT
66	31-Dec-2021	PARTS OF SADBHAVANA APPARTMENT, BANK VIHAR, MCD PUMP HOUSE NEAR AJAY APPARTMENT, B-BLOCK PUSHPANJLI, TARUN ENCLAVE PITAM PURA	1041	Other Outage	Unplanned Outage	31-Dec-2021	09:30	31-Dec-2021	10:25	55	0.000291	INTERRUPTION DUE TO FAULT
67	02-Dec-2021	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL, KP PLINTH, PART OF MD,DPCC BLOCK PITAM PURA	87	315 kVA	Planned Outage	02-Dec-2021	13:57	02-Dec-2021	15:52	115	0.00003	PLANNED OUTAGE
68	02-Dec-2021	PART OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	8	400 kVA	Unplanned Outage	02-Dec-2021	16:24	02-Dec-2021	17:02	38	0.00001	SYSTEM SCHEDULE OUTAGE
69	03-Dec-2021	PART OF BA BLOCK PITAM PURA	3	315 kVA	Planned Outage	03-Dec-2021	10:46	03-Dec-2021	12:27	101	0.00003	PLANNED OUTAGE
70	03-Dec-2021	PART OF BA BLOCK PITAM PURA	5	315 kVA	Planned Outage	03-Dec-2021	10:48	03-Dec-2021	12:28	100	0.00003	PLANNED OUTAGE
71	03-Dec-2021	PART OF B-1 MIA PHASE-2 PITAM PURA	2	160 kVA	Unplanned Outage	03-Dec-2021	10:59	03-Dec-2021	11:37	38	0.00001	SYSTEM SCHEDULE OUTAGE
72	03-Dec-2021	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT, LOK VIHAR A BLOCK, PART OF CHANDER LOK PITAM PURA	180	Other Outage	Planned Outage	03-Dec-2021	11:22	03-Dec-2021	12:58	95	0.00005	PLANNED OUTAGE
73	03-Dec-2021	PART OF A-BLOCK MANGOLPURI INDUSTRIAL PITAM PURA	4	315 kVA	Planned Outage	03-Dec-2021	14:26	03-Dec-2021	15:48	82	0.00002	PLANNED OUTAGE
74	03-Dec-2021	PART OF A-BLOCK MANGOLPURI INDUSTRIAL PITAM PURA	3	400 kVA	Planned Outage	03-Dec-2021	14:28	03-Dec-2021	15:47	79	0.00002	PLANNED OUTAGE
75	04-Dec-2021	PARTS OF POLICE COMPLEX, PUSHPANJLI, TARUN ENCLAVE PITAM PURA	73	Other Outage	Planned Outage	04-Dec-2021	11:00	04-Dec-2021	12:45	105	0.00003	PLANNED OUTAGE
76	04-Dec-2021	PARTS OF GALIB APTT AND E BLK SARASWATI VIHAR PITAM PURA	159	Other Outage	Planned Outage	04-Dec-2021	14:35	04-Dec-2021	16:06	91	0.00018	PLANNED OUTAGE
77	07-Dec-2021	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR PITAM PURA	129	Other Outage	Planned Outage	07-Dec-2021	11:02	07-Dec-2021	13:06	124	0.00007	PLANNED OUTAGE
78	07-Dec-2021	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2 PITAM PURA	85	Other Outage	Planned Outage	07-Dec-2021	13:52	07-Dec-2021	15:35	103	0.00003	PLANNED OUTAGE
79	08-Dec-2021	PART OF E-126 PITAM PURA	1	100 kVA	Unplanned Outage	08-Dec-2021	15:57	08-Dec-2021	16:39	42	0.00001	SYSTEM SCHEDULE OUTAGE
80	09-Dec-2021	PARTS OF FU, EU, CU & PART OF KP BLOCK COMMERCIAL COMPLEX PITAM PURA, HOTEL CITY PARK, NARSINGH SEWA SADAN, MRG DEVELOPERS PITAM PURA	649	Other Outage	Planned Outage	09-Dec-2021	10:30	09-Dec-2021	12:15	105	0.00020	PLANNED OUTAGE
81	09-Dec-2021	PARTS OF BU SFS, PU, NU, MU BLOCK PITAM PURA	351	Other Outage	Planned Outage	09-Dec-2021	13:56	09-Dec-2021	15:30	94	0.00010	PLANNED OUTAGE
82	09-Dec-2021	PARTS OF KALASH ENCLAVE, 112 MIG FLATS, MILANIUM PUBLIC SCHOOL, MAHARAJA AGARSEN BHAWAN, LOREN HIGH SCHOOL, PART OF IDPL, PART OF VILLAGE PITAM PURA & JANTA FLATS PITAM PURA	87	630 kVA	Planned Outage	09-Dec-2021	14:18	09-Dec-2021	16:00	102	0.00023	PLANNED OUTAGE
83	09-Dec-2021	PART OF NO-8 MIA PH-2 PITAM PURA	6	160 kVA	Unplanned Outage	09-Dec-2021	16:23	09-Dec-2021	16:37	14	0.000004	SYSTEM SCHEDULE OUTAGE
84	10-Dec-2021	PARTS OF AP-3 BLOCK PITAM PURA	632	Other Outage	Planned Outage	10-Dec-2021	10:20	10-Dec-2021	12:45	145	0.00024	PLANNED OUTAGE
85	10-Dec-2021	PARTS OF KALASH ENCLAVE, 112 MIG FLATS, MILANIUM PUBLIC SCHOOL, MAHARAJA AGARSEN BHAWAN, LOREN HIGH SCHOOL, PART OF IDPL, PART OF VILLAGE PITAM PURA & JANTA FLATS PITAM PURA	77	630 kVA	Planned Outage	10-Dec-2021	10:36	10-Dec-2021	12:38	122	0.00007	PLANNED OUTAGE
86	10-Dec-2021	PARTS OF KP COMMERCIAL COMPLEX, TU, MP, LP, JP, KP, HP BLOCK PITAM PURA	577	Other Outage	Planned Outage	10-Dec-2021	13:54	10-Dec-2021	16:13	139	0.00023	PLANNED OUTAGE
87	10-Dec-2021	PART OF ANAND VIHAR PITAM PURA	3	400 kVA	Planned Outage	10-Dec-2021	14:17	10-Dec-2021	14:31	14	0.000004	PLANNED OUTAGE
88	11-Dec-2021	PARTS OF GALIB APTT AND E BLK SARASWATI VIHAR PITAM PURA	99	630 kVA	Planned Outage	11-Dec-2021	10:32	11-Dec-2021	12:53	141	0.00008	PLANNED OUTAGE
89	11-Dec-2021	PARTS OF GALIB APTT AND E BLK SARASWATI VIHAR PITAM PURA	121	630 kVA	Planned Outage	11-Dec-2021	10:35	11-Dec-2021	12:55	140	0.00019	PLANNED OUTAGE
90	15-Dec-2021	PARTS OF FU, EU, CU & PART OF KP BLOCK COMMERCIAL COMPLEX PITAM PURA, HOTEL CITY PARK, NARSINGH SEWA SADAN, MRG DEVELOPERS PITAM PURA	151	Other Outage	Planned Outage	15-Dec-2021	10:34	15-Dec-2021	12:06	92	0.00008	PLANNED OUTAGE
91	15-Dec-2021	PARTS OF FU, EU, CU & PART OF KP BLOCK COMMERCIAL COMPLEX PITAM PURA, HOTEL CITY PARK, NARSINGH SEWA SADAN, MRG DEVELOPERS PITAM PURA	176	315 kVA	Planned Outage	15-Dec-2021	14:09	15-Dec-2021	15:31	82	0.00009	PLANNED OUTAGE

</

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unscheduled (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
92	17-Dec-2021	PARTS OF VARUN NIKETAN, BU, AU BLOCK PITAM PURA	30	315 kVA	Planned Outage	17-Dec-2021	10:17	17-Dec-2021	11:57	100	0.00003	PLANNED OUTAGE
93	17-Dec-2021	PARTS OF VARUN NIKETAN, BU, AU BLOCK PITAM PURA	186	630 kVA	Planned Outage	17-Dec-2021	13:59	17-Dec-2021	15:43	104	0.00006	PLANNED OUTAGE
94	18-Dec-2021	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	9	100 kVA	Unplanned Outage	18-Dec-2021	16:07	18-Dec-2021	16:31	24	0.00001	SYSTEM SCHEDULE OUTAGE
95	20-Dec-2021	PARTS OF BU SFS, PU, NU, MU BLOCK PITAM PURA	201	Other Outage	Planned Outage	20-Dec-2021	10:53	20-Dec-2021	13:01	128	0.00007	PLANNED OUTAGE
96	21-Dec-2021	PARTS OF ZP BLOCK SCHOOL, YP & TP BLOCK PITAM PURA	125	630 kVA	Planned Outage	21-Dec-2021	11:32	21-Dec-2021	12:59	87	0.00024	PLANNED OUTAGE
97	22-Dec-2021	PARTS OF AP-3 BLOCK PITAM PURA	236	630 kVA	Planned Outage	22-Dec-2021	10:27	22-Dec-2021	12:21	114	0.00006	PLANNED OUTAGE
98	22-Dec-2021	PARTS OF SIRI NAGAR, PART OF RAJA PARK, PART OF MAHENDRA PARK, PART OF RAU DHANI ENCLAVE PITAM PURA	419	Other Outage	Planned Outage	22-Dec-2021	11:10	22-Dec-2021	12:45	95	0.00053	PLANNED OUTAGE
99	22-Dec-2021	PARTS OF COMPLAINT CENTRE RANI BAGH PITAM PURA	627	990 kVA	Planned Outage	22-Dec-2021	14:12	22-Dec-2021	16:04	112	0.00016	PLANNED OUTAGE
100	23-Dec-2021	PARTS OF QU, SU, BD, AD & CD BLOCK PITAM PURA	485	Other Outage	Planned Outage	23-Dec-2021	10:35	23-Dec-2021	12:30	115	0.00013	PLANNED OUTAGE
101	27-Dec-2021	PARTS OF SABHAWANA APPARTMENT. BANK VIHAR, MCD PUMP HOUSE NEAR AJAY APPARTMENT, 8-BLOCK PUSHANJLI, TARUN ENCLAVE PITAM PURA	79	Other Outage	Planned Outage	27-Dec-2021	10:28	27-Dec-2021	12:18	110	0.00003	PLANNED OUTAGE
102	27-Dec-2021	PARTS OF DEEPAU VARDHMAN MAIL, TARUN ENCLAVE, DEEPAU PITAM PURA	12	630 kVA	Planned Outage	27-Dec-2021	14:19	27-Dec-2021	15:56	97	0.00027	PLANNED OUTAGE
103	27-Dec-2021	PART OF A-12 MIA PH-2 PITAM PURA	8	400 kVA	Unplanned Outage	27-Dec-2021	15:17	27-Dec-2021	16:51	94	0.00003	SYSTEM SCHEDULE OUTAGE
104	29-Dec-2021	PARTS OF SANDESH VIHAR PSS, NISHANT KUNI, POLICE COLONY, ROHIT KUNI, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS PITAM PURA	121	630 kVA	Planned Outage	29-Dec-2021	14:14	29-Dec-2021	16:14	120	0.00050	PLANNED OUTAGE
105	30-Dec-2021	PARTS OF RANI BAGH, PART OF RAJA PARK, PART OF SIRI NAGAR PITAM PURA	119	Other Outage	Planned Outage	30-Dec-2021	10:32	30-Dec-2021	12:20	108	0.00006	PLANNED OUTAGE
106	30-Dec-2021	PARTS OF OLD SABZI MANDI RISHI NAGAR, PHOOLARAM NO. -1, ROYAL MIRAZ PSS, JAGRITI APPT. PITAM PURA	801	990 kVA	Planned Outage	30-Dec-2021	14:22	30-Dec-2021	16:05	103	0.00017	PLANNED OUTAGE
107	31-Dec-2021	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	6	160 kVA	Unplanned Outage	31-Dec-2021	11:16	31-Dec-2021	11:48	32	0.00001	SYSTEM SCHEDULE OUTAGE
108	31-Dec-2021	PART OF E-126 PITAM PURA	3	250 kVA	Unplanned Outage	31-Dec-2021	13:27	31-Dec-2021	14:30	63	0.00002	SYSTEM SCHEDULE OUTAGE
ROHINI												
1	01-Dec-2021	PARTS OF PKT 4 & 5 SEC-23 ROHINI	579	Other Outage	Unplanned Outage	01-Dec-2021	13:44	01-Dec-2021	14:06	22	0.00003	INTERRUPTION DUE TO FAULT
2	02-Dec-2021	PARTS OF PKT 4 & 5 SEC-23 ROHINI	579	Other Outage	Unplanned Outage	02-Dec-2021	19:49	02-Dec-2021	20:25	36	0.00006	INTERRUPTION DUE TO FAULT
3	03-Dec-2021	PARTS OF S. T. PLANT RITHALA ROHINI	160	Other Outage	Unplanned Outage	03-Dec-2021	10:45	03-Dec-2021	11:56	71	0.00039	INTERRUPTION DUE TO FAULT
4	03-Dec-2021	PARTS OF SEC-1/25 RITHALA ROHINI	553	Other Outage	Unplanned Outage	03-Dec-2021	12:10	03-Dec-2021	13:08	58	0.000127	INTERRUPTION DUE TO FAULT
5	03-Dec-2021	PARTS OF SEC-1/25 RITHALA ROHINI	553	Other Outage	Unplanned Outage	03-Dec-2021	14:34	03-Dec-2021	14:59	25	0.00007	INTERRUPTION DUE TO FAULT
6	03-Dec-2021	PARTS OF SECTOR - 9 ROHINI	1223	Other Outage	Unplanned Outage	03-Dec-2021	21:11	03-Dec-2021	21:20	9	0.00005	INTERRUPTION DUE TO FAULT
7	05-Dec-2021	PARTS OF SECTOR 24 POCKET 28 ROHINI, POCKET 22 & 23 SECTOR 25 ROHINI	1369	Other Outage	Unplanned Outage	05-Dec-2021	03:36	05-Dec-2021	04:15	39	0.000141	INTERRUPTION DUE TO FAULT
8	06-Dec-2021	PARTS OF OLD VILLAGE BADLI, BADLI BUS STAND & PRIMARY SCHOOL ROHINI	530	Other Outage	Unplanned Outage	06-Dec-2021	15:38	06-Dec-2021	15:55	17	0.000033	INTERRUPTION DUE TO FAULT
9	07-Dec-2021	PARTS OF B BLOCK, PART OF D BLOCK, PART OF A BLOCK, PART OF C BLOCK, PART OF E BLOCK SEC-18 ROHINI	1208	Other Outage	Unplanned Outage	07-Dec-2021	00:55	07-Dec-2021	01:25	30	0.000127	INTERRUPTION DUE TO FAULT
10	07-Dec-2021	PARTS OF SEC-1/25 RITHALA ROHINI	553	Other Outage	Unplanned Outage	07-Dec-2021	18:49	07-Dec-2021	19:36	47	0.000144	INTERRUPTION DUE TO FAULT
11	08-Dec-2021	PARTS OF POCKET 1 AND POCKET 3 ROHINI	1147	Other Outage	Unplanned Outage	08-Dec-2021	12:23	08-Dec-2021	12:40	17	0.000069	INTERRUPTION DUE TO FAULT
12	08-Dec-2021	PARTS OF POCKET 1 AND POCKET 3 ROHINI	1093	Other Outage	Unplanned Outage	08-Dec-2021	12:23	08-Dec-2021	12:40	17	0.000055	INTERRUPTION DUE TO FAULT
13	08-Dec-2021	PARTS OF POCKET 1 AND POCKET 3 ROHINI	178	Other Outage	Unplanned Outage	08-Dec-2021	12:23	08-Dec-2021	12:40	17	0.000023	INTERRUPTION DUE TO FAULT
14	09-Dec-2021	PARTS OF JJ CLUSTER SEC 3, JAIPUR GOLDEN HOSPITAL, CRIMINOLOGY, NDPL DISPENSARY JJ CLUSTER SEC 3, ROHINI	762	Other Outage	Unplanned Outage	09-Dec-2021	08:13	09-Dec-2021	09:20	67	0.000168	INTERRUPTION DUE TO FAULT
15	09-Dec-2021	PARTS OF JJ CLUSTER SEC 3, JAIPUR GOLDEN HOSPITAL, CRIMINOLOGY, NDPL DISPENSARY JJ CLUSTER SEC 3, ROHINI	2510	Other Outage	Unplanned Outage	09-Dec-2021	14:34	09-Dec-2021	14:40	6	0.000036	INTERRUPTION DUE TO FAULT
16	10-Dec-2021	PART OF TELEPHONE EXCHANGE ROHINI	19	Other Outage	Unplanned Outage	10-Dec-2021	08:40	10-Dec-2021	09:25	45	0.000025	INTERRUPTION DUE TO FAULT
17	11-Dec-2021	PARTS OF SECTOR - 9 ROHINI	139	Other Outage	Unplanned Outage	11-Dec-2021	21:33	11-Dec-2021	22:03	30	0.000041	INTERRUPTION DUE TO FAULT
18	11-Dec-2021	PARTS OF SECTOR - 9 ROHINI	360	Other Outage	Unplanned Outage	11-Dec-2021	21:33	11-Dec-2021	22:07	34	0.000047	INTERRUPTION DUE TO FAULT
19	11-Dec-2021	PARTS OF SECTOR - IV AVANTIKA ROHINI	1488	Other Outage	Unplanned Outage	11-Dec-2021	23:31	11-Dec-2021	23:50	19	0.000103	INTERRUPTION DUE TO FAULT
20	12-Dec-2021	PARTS OF B BLOCK, PART OF D BLOCK, PART OF A BLOCK, PART OF C BLOCK, PART OF E BLOCK SEC-18 ROHINI	2053	Other Outage	Unplanned Outage	12-Dec-2021	06:13	12-Dec-2021	06:54	41	0.000563	INTERRUPTION DUE TO FAULT
21	12-Dec-2021	PARTS OF SECTOR - 7 ROHINI	1286	Other Outage	Unplanned Outage	12-Dec-2021	23:05	12-Dec-2021	23:17	12	0.000065	INTERRUPTION DUE TO FAULT
22	14-Dec-2021	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	773	Other Outage	Unplanned Outage	14-Dec-2021	07:50	14-Dec-2021	08:24	34	0.000047	INTERRUPTION DUE TO FAULT
23	14-Dec-2021	PARTS OF TPS & RITHALA KOSK ROHINI	558	Other Outage	Unplanned Outage	14-Dec-2021	12:58	14-Dec-2021	13:55	57	0.000157	INTERRUPTION DUE TO FAULT
24	15-Dec-2021	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	37	Other Outage	Unplanned Outage	15-Dec-2021	00:25	15-Dec-2021	01:15	50	0.000028	INTERRUPTION DUE TO FAULT
25	15-Dec-2021	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	41	Other Outage	Unplanned Outage	15-Dec-2021	00:40	15-Dec-2021	01:15	35	0.000019	INTERRUPTION DUE TO FAULT
26	16-Dec-2021	PARTS OF H-3 NO-2 SEC-18 ROHINI	517	Other Outage	Unplanned Outage	16-Dec-2021	14:44	16-Dec-2021	15:03	19	0.000053	INTERRUPTION DUE TO FAULT
27	16-Dec-2021	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	41	Other Outage	Unplanned Outage	16-Dec-2021	17:16	16-Dec-2021	17:31	15	0.000008	INTERRUPTION DUE TO FAULT
28	16-Dec-2021	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	37	Other Outage	Unplanned Outage	16-Dec-2021	17:16	16-Dec-2021	17:34	18	0.00001	INTERRUPTION DUE TO FAULT
29	17-Dec-2021	PARTS OF NESURARY IN FRONT OF HAIDERPUR WATER WORKS ROHINI	1434	Other Outage	Unplanned Outage	17-Dec-2021	14:57	17-Dec-2021	15:22	25	0.000084	INTERRUPTION DUE TO FAULT
30	18-Dec-2021	PARTS OF SECTOR 24 RITHALA ROHINI	1307	Other Outage	Unplanned Outage	18-Dec-2021	03:09	18-Dec-2021	03:25	16	0.000055	INTERRUPTION DUE TO FAULT
31	18-Dec-2021	PARTS OF SECTOR 24 RITHALA ROHINI	157	Other Outage	Unplanned Outage	18-Dec-2021	03:09	18-Dec-2021	04:10	61	0.000017	INTERRUPTION DUE TO FAULT
32	18-Dec-2021	PART OF B-BLOCK AVANTIKA ROHINI	13	Other Outage	Unplanned Outage	18-Dec-2021	23:16	19-Dec-2021	00:07	51	0.000014	INTERRUPTION DUE TO FAULT
33	20-Dec-2021	PARTS OF SECTOR 24 RITHALA ROHINI	112	Other Outage	Unplanned Outage	20-Dec-2021	13:17	20-Dec-2021	14:10	53	0.000074	INTERRUPTION DUE TO FAULT
34	21-Dec-2021	PARTS OF UTSAV APPT. BLK- F LIG FLATS SEC 18, BLK- E PKT 3 SEC 18 ROHINI	704	Other Outage	Unplanned Outage	21-Dec-2021	16:25	21-Dec-2021	17:12	47	0.000196	INTERRUPTION DUE TO FAULT
35	24-Dec-2021	PARTS OF SEC-1/25 RITHALA ROHINI	554	Other Outage	Unplanned Outage	24-Dec-2021	15:43	24-Dec-2021	16:10	27	0.000075	SYSTEM SCHEDULE OUTAGE
36	24-Dec-2021	PARTS OF D AND E BLK SEC-15 ROHINI	427	Other Outage	Unplanned Outage	24-Dec-2021	16:01	24-Dec-2021	16:50	49	0.000067	INTERRUPTION DUE TO FAULT
37	24-Dec-2021	PARTS OF D AND E BLK SEC-15 ROHINI	134	Other Outage	Unplanned Outage	24-Dec-2021	16:01	24-Dec-2021	16:50	49	0.000027	INTERRUPTION DUE TO FAULT
38	24-Dec-2021	PARTS OF D AND E BLK SEC-15 ROHINI	134	Other Outage	Unplanned Outage	24-Dec-2021	17:53	24-Dec-2021	19:03	70	0.000097	INTERRUPTION DUE TO FAULT
39	26-Dec-2021	PARTS OF C & B BLOCK SEC-16 ROHINI	2456	Other Outage	Unplanned Outage	26-Dec-2021	10:23	26-Dec-2021	11:58	95	0.001185	INTERRUPTION DUE TO FAULT
40	26-Dec-2021	PARTS OF A-BLOCK, PART OF F-BLOCK, PART OF E BLOCK, PART OF B, PART OF C, D & SARDAR COLONY SEC-16 ROHINI	2168	Other Outage	Unplanned Outage	26-Dec-2021	11:16	26-Dec-2021	11:20	4	0.000045	INTERRUPTION DUE TO FAULT
41	26-Dec-2021	PARTS OF A-BLOCK, PART OF F-BLOCK, PART OF E BLOCK, PART OF B, PART OF C, D & SARDAR COLONY SEC-16 ROHINI	571	Other Outage	Unplanned Outage	26-Dec-2021	12:00	26-Dec-2021	12:15	15	0.00002	INTERRUPTION DUE TO FAULT
42	26-Dec-2021	PARTS OF A-BLOCK, PART OF F-BLOCK, PART OF E BLOCK, PART OF B, PART OF C, D & SARDAR COLONY SEC-16 ROHINI	2168	Other Outage	Unplanned Outage	26-Dec-2021	12:00	26-Dec-2021	12:15	15	0.000081	INTERRUPTION DUE TO FAULT
43	26-Dec-2021	PARTS OF A-BLOCK, PART OF F-BLOCK, PART OF E BLOCK, PART OF B, PART OF C, D & SARDAR COLONY SEC-16 ROHINI	269	Other Outage	Unplanned Outage	26-Dec-2021	12:00	26-Dec-2021	12:25	25	0.000034	INTERRUPTION DUE TO FAULT
44	26-Dec-2021	PARTS OF A-BLOCK, PART OF F-BLOCK, PART OF E BLOCK, PART OF B, PART OF C, D & SARDAR COLONY SEC-16 ROHINI	1330	Other Outage	Unplanned Outage	26-Dec-2021	12:00	26-Dec-2021	12:32	32	0.00007	INTERRUPTION DUE TO FAULT
45	26-Dec-2021	PARTS OF A-BLOCK, PART OF F-BLOCK, PART OF E BLOCK, PART OF B, PART OF C, D & SARDAR COLONY SEC-16 ROHINI	286	Other Outage	Unplanned Outage	26-Dec-2021	12:00	26-Dec-2021	12:38	38	0.000031	INTERRUPTION DUE TO FAULT
46	26-Dec-2021	PARTS OF SPD VIJAY VIHAR PH-2, K-218, VIJAY VIHAR PH-2, J-BLK, VIJAY VIHAR, SPD VIJAY VIHAR J-BLK, ROHINI	316	Other Outage	Unplanned Outage	26-Dec-2021	17:57	26-Dec-2021	19:10	73	0.000242	INTERRUPTION DUE TO FAULT
47	26-Dec-2021	PARTS OF SECTOR - 7 ROHINI	1311	Other Outage	Unplanned Outage	26-Dec-2021	17:58	26-Dec-2021	18:18	20	0.000268	INTERRUPTION DUE TO FAULT
48	26-Dec-2021	PARTS OF DDA MARKET SEC-17, 464 LIG FLATS SEC-17, ROHINI	1930	Other Outage	Unplanned Outage	26-Dec-2021	18:10	26-Dec-2021	18:38	28	0.000093	INTERRUPTION DUE TO FAULT
49	26-Dec-2021	PARTS OF SECTOR 11, A, BLK, B, BLK AND C-BLK ROHINI	2637	Other Outage	Unplanned Outage	26-Dec-2021	18:54	26-Dec-2021	19:05	11	0.000084	INTERRUPTION DUE TO FAULT
50	27-Dec-2021	PARTS OF JJ CLUSTER SEC 3, JAIPUR GOLDEN HOSPITAL, CRIMINOLOGY, NDPL DISPENSARY JJ CLUSTER SEC 3, ROHINI	763	Other Outage	Unplanned Outage	27-Dec-2021	08:51	27-Dec-2021	09:30	39	0.000076	INTERRUPTION DUE TO FAULT
51	27-Dec-2021	PARTS OF S. T. PLANT RITHALA ROHINI	161	Other Outage	Unplanned Outage	27-Dec-2021	12:54	27-Dec-2021	15:12	138	0.000153	FORCE MAJEURE DUE TO SABOTAGE
52	27-Dec-2021	PARTS OF S. T. PLANT RITHALA ROHINI	260	Other Outage	Unplanned Outage	27-Dec-2021	12:54	27-Dec-2021	20:17	443	0.000738	FORCE MAJEURE DUE TO SABOTAGE
53	28-Dec-2021	PARTS OF VARUN KUNI SEC - 5 ROHINI	4006	Other Outage	Unplanned Outage	28-Dec-2021	16:06	28-Dec-2021	16:25	19	0.000159	INTERRUPTION DUE TO FAULT
54	28-Dec-2021	PARTS OF VARUN KUNI SEC - 5 ROHINI	4572	Other Outage	Unplanned Outage							

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unscheduled (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
69	04-Dec-2021	PARTS OF BOOSTER PUMP-C-BLOCK SEC-19 & J.J. CLUSTER SEC-19, E BLOCK SEC-18 ROHINI	904	Other Outage	Planned Outage	04-Dec-2021	10:00	04-Dec-2021	12:10	130	0.00036	PLANNED OUTAGE
70	04-Dec-2021	PARTS OF PKT 4 & 5 SEC-23 ROHINI	202	Other Outage	Planned Outage	04-Dec-2021	11:33	04-Dec-2021	16:02	269	0.00015	PLANNED OUTAGE
71	06-Dec-2021	PARTS OF TEMPO STAND WALA MANGOL PUR KALAN, KHATE WALA, MANGOLPUR POLICE STATION, PATHAR WALA, TALAB WALA ROHINI	242	Other Outage	Planned Outage	06-Dec-2021	10:24	06-Dec-2021	14:25	241	0.00013	PLANNED OUTAGE
72	07-Dec-2021	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT SEC-23 FLAT RHN TR NO 2 ROHINI	220	630 kVA	Planned Outage	07-Dec-2021	14:24	07-Dec-2021	16:08	104	0.00017	PLANNED OUTAGE
73	07-Dec-2021	PART OF VARUN KUNI SEC - 5 ROHINI	6	400 kVA	Planned Outage	07-Dec-2021	14:35	07-Dec-2021	16:03	88	0.00002	PLANNED OUTAGE
74	08-Dec-2021	PARTS OF PKT 4 & 5 SEC-23 ROHINI	266	Other Outage	Planned Outage	08-Dec-2021	11:39	08-Dec-2021	15:49	250	0.00014	PLANNED OUTAGE
75	08-Dec-2021	PART OF POCKET-17 SEC-4 ROHINI	1	Other Outage	Planned Outage	08-Dec-2021	13:16	08-Dec-2021	14:55	99	0.00003	PLANNED OUTAGE
76	09-Dec-2021	PART OF JAIL COLONY ROHINI	1	Other Outage	Planned Outage	09-Dec-2021	10:58	09-Dec-2021	15:19	261	0.00007	PLANNED OUTAGE
77	09-Dec-2021	PARTS OF BADLI JAI, JAIL COLONY, BADLI POLICE QTRS. SEWAGE PUMP SECTOR - 19 ROHINI	25	Other Outage	Planned Outage	09-Dec-2021	11:00	09-Dec-2021	15:20	260	0.00007	PLANNED OUTAGE
78	14-Dec-2021	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	97	Other Outage	Planned Outage	14-Dec-2021	11:26	14-Dec-2021	13:08	102	0.00003	PLANNED OUTAGE
79	14-Dec-2021	PARTS OF PKT - 26 SEC-24 RITHALA ROHINI	207	630 kVA	Planned Outage	14-Dec-2021	14:07	14-Dec-2021	16:00	113	0.00006	PLANNED OUTAGE
80	14-Dec-2021	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	37	630 kVA	Planned Outage	14-Dec-2021	14:27	14-Dec-2021	16:20	113	0.00003	PLANNED OUTAGE
81	15-Dec-2021	PARTS OF RITHALA AND SEC-24 ROHINI	61	Other Outage	Planned Outage	15-Dec-2021	11:29	15-Dec-2021	16:10	281	0.00008	PLANNED OUTAGE
82	17-Dec-2021	PART OF JAPANI PARK ROHINI	3	Other Outage	Planned Outage	17-Dec-2021	12:08	17-Dec-2021	15:13	185	0.00005	PLANNED OUTAGE
83	17-Dec-2021	PARTS OF LANCER CONVENT SCHOOL SEC-9 ROHINI	761	990 kVA	Planned Outage	17-Dec-2021	12:12	17-Dec-2021	13:03	51	0.00011	PLANNED OUTAGE
84	17-Dec-2021	PARTS OF LANCER CONVENT SCHOOL SEC-9 ROHINI	133	630 kVA	Planned Outage	17-Dec-2021	14:01	17-Dec-2021	14:59	58	0.00016	PLANNED OUTAGE
85	18-Dec-2021	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK VIJAY VIHAR SPD VIJAY VIHAR J-BLK ROHINI	90	Other Outage	Planned Outage	18-Dec-2021	10:48	18-Dec-2021	11:44	56	0.00002	PLANNED OUTAGE
86	18-Dec-2021	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK VIJAY VIHAR SPD VIJAY VIHAR J-BLK ROHINI	66	Other Outage	Planned Outage	18-Dec-2021	11:46	18-Dec-2021	17:21	335	0.00009	PLANNED OUTAGE
87	18-Dec-2021	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK VIJAY VIHAR SPD VIJAY VIHAR J-BLK ROHINI	24	Other Outage	Planned Outage	18-Dec-2021	16:08	18-Dec-2021	17:21	73	0.00010	PLANNED OUTAGE
88	21-Dec-2021	PARTS OF DELHI GOVERNMENT FLAT, DAMB COLONY ROHINI	87	400 kVA	Planned Outage	21-Dec-2021	11:27	21-Dec-2021	12:54	87	0.00002	PLANNED OUTAGE
89	21-Dec-2021	PARTS OF VILLAGE PRAHLAD PUR, ST. XAVIERS SCHOOL, JAIN COLONY, MATERNITY HOME. ROHINI	94	630 kVA	Planned Outage	21-Dec-2021	14:10	21-Dec-2021	15:47	97	0.00005	PLANNED OUTAGE
90	22-Dec-2021	PART OF B BLK SEC-16 ROHINI	5	16 kVA	Planned Outage	22-Dec-2021	10:47	22-Dec-2021	12:57	130	0.00004	PLANNED OUTAGE
91	22-Dec-2021	PARTS OF RITHALA AND SEC-24 ROHINI	151	Other Outage	Planned Outage	22-Dec-2021	11:32	22-Dec-2021	16:21	289	0.00016	PLANNED OUTAGE
92	22-Dec-2021	PARTS OF C & B BLOCK SEC-16 ROHINI	27	25 kVA	Planned Outage	22-Dec-2021	13:55	22-Dec-2021	15:58	123	0.00003	PLANNED OUTAGE
93	22-Dec-2021	PARTS OF SECTOR - 11, D,E1,E2,E3,E4 BLOCK, GARG TRADE CENTRE.	24	250 kVA	Unplanned Outage	22-Dec-2021	15:40	22-Dec-2021	16:56	76	0.00002	SYSTEM SCHEDULE OUTAGE
94	23-Dec-2021	PARTS OF H-3 NO-2 SEC-18 ROHINI	242	Other Outage	Planned Outage	23-Dec-2021	11:15	23-Dec-2021	13:37	142	0.00012	PLANNED OUTAGE
95	27-Dec-2021	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	349	Other Outage	Planned Outage	27-Dec-2021	11:25	27-Dec-2021	15:56	271	0.00023	PLANNED OUTAGE
96	28-Dec-2021	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,VIJAY VIHAR, A-BLOCK VIJAY VIHAR ROHINI	613	630 kVA	Planned Outage	28-Dec-2021	10:53	28-Dec-2021	13:44	171	0.00119	PLANNED OUTAGE
97	30-Dec-2021	PARTS OF C & B BLOCK SEC-16 ROHINI	23	25 kVA	Planned Outage	30-Dec-2021	10:42	30-Dec-2021	13:08	146	0.00004	PLANNED OUTAGE
98	30-Dec-2021	PARTS OF H.R.HOSPITA, POKET 4&7 PARSHANT VIHAR ROHINI	754	990 kVA	Planned Outage	30-Dec-2021	12:00	30-Dec-2021	13:08	68	0.00015	PLANNED OUTAGE
99	30-Dec-2021	PART OF B BLK SEC-16 ROHINI	17	25 kVA	Planned Outage	30-Dec-2021	13:54	30-Dec-2021	16:06	132	0.00004	PLANNED OUTAGE
100	30-Dec-2021	PARTS OF SECTOR - 7 ROHINI	655	990 kVA	Planned Outage	30-Dec-2021	14:22	30-Dec-2021	15:35	73	0.00014	PLANNED OUTAGE
101	31-Dec-2021	PARTS OF C & B BLOCK SEC-16 ROHINI	269	Other Outage	Planned Outage	31-Dec-2021	11:00	31-Dec-2021	14:05	185	0.00026	PLANNED OUTAGE
102	31-Dec-2021	PARTS OF S. T. PLANT RITHALA ROHINI	560	Other Outage	Planned Outage	31-Dec-2021	11:52	31-Dec-2021	15:39	227	0.00013	PLANNED OUTAGE
SHALIMAR BAGH												
1	01-Dec-2021	PARTS OF GOPI WALA , JHARODA SCHOOL , BHAGWAN PARK, SURNDER COLONY PART 1 & 2, KAYAKALP HOSPITAL, SHALIMAR BAGH	3032	Other Outage	Unplanned Outage	01-Dec-2021	13:03	01-Dec-2021	13:52	49	0.00049	INTERRUPTION DUE TO FAULT
2	01-Dec-2021	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B,C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR SHALIMAR BAGH	2422	Other Outage	Unplanned Outage	01-Dec-2021	15:37	01-Dec-2021	16:15	38	0.000212	INTERRUPTION DUE TO FAULT
3	01-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	1551	Other Outage	Unplanned Outage	01-Dec-2021	21:53	01-Dec-2021	22:53	60	0.000348	INTERRUPTION DUE TO FAULT
4	02-Dec-2021	PARTS OF INDIAN OIL, HP & BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, RELIANCE TOWER, PART OF PARVATIACHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN, SHALIMAR BAGH	1275	Other Outage	Unplanned Outage	02-Dec-2021	12:57	02-Dec-2021	13:40	43	0.000096	INTERRUPTION DUE TO FAULT
5	02-Dec-2021	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MARTA MANDIR SANT NAGAR, SHIV KUNI, GALI NO. 65,69 SANT NAGAR, GALI NO. 82, SHALIMAR BAGH	2706	Other Outage	Unplanned Outage	02-Dec-2021	16:04	02-Dec-2021	17:07	63	0.000442	INTERRUPTION DUE TO FAULT
6	02-Dec-2021	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	88	Other Outage	Unplanned Outage	02-Dec-2021	16:28	02-Dec-2021	17:28	58	0.000096	INTERRUPTION DUE TO FAULT
7	02-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	1742	Other Outage	Unplanned Outage	02-Dec-2021	22:06	02-Dec-2021	22:40	34	0.000161	INTERRUPTION DUE TO FAULT
8	02-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	3022	Other Outage	Unplanned Outage	02-Dec-2021	22:06	03-Dec-2021	00:25	139	0.001159	FORCE MAJEURE DUE TO RAIN/STORM
9	02-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	948	Other Outage	Unplanned Outage	02-Dec-2021	22:06	03-Dec-2021	01:05	179	0.000447	FORCE MAJEURE DUE TO RAIN/STORM
10	02-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	534	Other Outage	Unplanned Outage	02-Dec-2021	22:06	03-Dec-2021	03:00	294	0.000408	FORCE MAJEURE DUE TO RAIN/STORM
11	02-Dec-2021	PARTS OF SANT NAGAR POCKET B BLOCK SHALIMAR BAGH	813	Other Outage	Unplanned Outage	02-Dec-2021	22:16	02-Dec-2021	23:02	46	0.000103	INTERRUPTION DUE TO FAULT
12	03-Dec-2021	PARTS OF BHAGAT COLONY SHALIMAR BAGH	44	Other Outage	Unplanned Outage	03-Dec-2021	11:30	03-Dec-2021	14:22	172	0.000096	FORCE MAJEURE DUE TO SABOTAGE
13	03-Dec-2021	PARTS OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	159	Other Outage	Unplanned Outage	03-Dec-2021	15:54	03-Dec-2021	16:30	36	0.00003	INTERRUPTION DUE TO FAULT
14	04-Dec-2021	PART OF HOTEL PREMIER INN SHALIMAR BAGH	3	Other Outage	Unplanned Outage	04-Dec-2021	09:59	04-Dec-2021	10:34	35	0.000029	INTERRUPTION DUE TO FAULT
15	04-Dec-2021	PARTS OF HOTEL PREMIER INN, C BLOCK, U & V BLOCK UJIV J. J. CLUSTER, JASPAL KAUR PUBLIC SCHOOL, SHALIMAR BAGH	903	Other Outage	Unplanned Outage	04-Dec-2021	09:59	04-Dec-2021	10:40	41	0.000433	INTERRUPTION DUE TO FAULT
16	04-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	1795	Other Outage	Unplanned Outage	04-Dec-2021	14:17	04-Dec-2021	14:55	38	0.00038	INTERRUPTION DUE TO FAULT
17	04-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	2459	Other Outage	Unplanned Outage	04-Dec-2021	14:17	04-Dec-2021	16:37	140	0.001944	FORCE MAJEURE DUE TO SABOTAGE
18	05-Dec-2021	PARTS OF BM , BN (E), BR, AA, BN MARKET, BCE (J), KALI BARI MANDIR SHALIMAR BAGH	2274	Other Outage	Unplanned Outage	05-Dec-2021	01:59	05-Dec-2021	02:37	38	0.000127	INTERRUPTION DUE TO FAULT
19	05-Dec-2021	PARTS OF BM , BN (E), BR, AA, BN MARKET, BCE (J), KALI BARI MANDIR SHALIMAR BAGH	268	Other Outage	Unplanned Outage	05-Dec-2021	01:59	05-Dec-2021	05:30	211	0.000176	FORCE MAJEURE DUE TO SABOTAGE
20	07-Dec-2021	PART OF SMA INDUSTRIAL AREA SHALIMAR BAGH	2	Other Outage	Unplanned Outage	07-Dec-2021	12:00	07-Dec-2021	13:40	100	0.000028	INTERRUPTION DUE TO FAULT
21	07-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	1551	Other Outage	Unplanned Outage	07-Dec-2021	17:20	07-Dec-2021	17:35	15	0.000063	INTERRUPTION DUE TO FAULT
22	08-Dec-2021	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD SHALIMAR BAGH	897	Other Outage	Unplanned Outage	08-Dec-2021	15:43	08-Dec-2021	17:20	97	0.000217	INTERRUPTION DUE TO FAULT
23	08-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	1551	Other Outage	Unplanned Outage	08-Dec-2021	18:31	08-Dec-2021	19:08	37	0.000206	INTERRUPTION DUE TO FAULT
24	09-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	869	Other Outage	Unplanned Outage	09-Dec-2021	12:35	09-Dec-2021	13:43	68	0.000189	INTERRUPTION DUE TO FAULT
25	09-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	1796	Other Outage	Unplanned Outage	09-Dec-2021	12:52	09-Dec-2021	13:16	24	0.00024	INTERRUPTION DUE TO FAULT
26	09-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	2237	Other Outage	Unplanned Outage	09-Dec-2021	12:52	09-Dec-2021	13:40	48	0.000587	INTERRUPTION DUE TO FAULT
27	09-Dec-2021	PARTS OF HINDUSTAN PETROLEUM BURARI SHALIMAR BAGH	3471	Other Outage	Unplanned Outage	09-Dec-2021	17:41	09-Dec-2021	18:12	31	0.00003	INTERRUPTION DUE TO FAULT
28	09-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	1551	Other Outage	Unplanned Outage	09-Dec-2021	18:44	09-Dec-2021	19:08	24	0.000153	INTERRUPTION DUE TO FAULT
29	09-Dec-2021	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	1043	Other Outage	Unplanned Outage	09-Dec-2021	20:08	09-Dec-2021	20:50	42	0.000117	INTERRUPTION DUE TO FAULT
30	09-Dec-2021	PARTS OF HARJIAN BASTI-1, INDIAN OIL SHALIMAR BAGH	2867	Other Outage	Unplanned Outage	09-Dec-2021	23:04	10-Dec-2021	00:05	61	0.000473	INTERRUPTION DUE TO FAULT

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
31	09-Dec-2021	PARTS OF HINDUSTAN PETROLEUM BURARI SHALIMAR BAGH	984	Other Outage	Unplanned Outage	09-Dec-2021	23:04	10-Dec-2021	00:06	62	0.000174	INTERRUPTION DUE TO FAULT
32	09-Dec-2021	PARTS OF HARIJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	2487	Other Outage	Unplanned Outage	09-Dec-2021	23:39	10-Dec-2021	00:06	27	0.00018	INTERRUPTION DUE TO FAULT
33	10-Dec-2021	PARTS OF HARIJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	593	Other Outage	Unplanned Outage	10-Dec-2021	11:09	10-Dec-2021	12:18	69	0.000096	INTERRUPTION DUE TO FAULT
34	10-Dec-2021	PARTS OF HARIJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	1363	Other Outage	Unplanned Outage	10-Dec-2021	11:09	10-Dec-2021	18:31	442	0.001965	FORCE MAJEURE DUE TO SABOTAGE
35	10-Dec-2021	PARTS OF HARIJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	1364	Other Outage	Unplanned Outage	10-Dec-2021	11:17	10-Dec-2021	12:19	62	0.000172	INTERRUPTION DUE TO FAULT
36	10-Dec-2021	PART OF AD BLK WAZIRPUR SHALIMAR BAGH	5	Other Outage	Unplanned Outage	10-Dec-2021	13:11	10-Dec-2021	14:10	59	0.000016	INTERRUPTION DUE TO FAULT
37	10-Dec-2021	PARTS OF HARIJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	593	Other Outage	Unplanned Outage	10-Dec-2021	17:45	10-Dec-2021	18:31	46	0.000166	INTERRUPTION DUE TO FAULT
38	10-Dec-2021	PARTS OF HARIJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	1364	Other Outage	Unplanned Outage	10-Dec-2021	17:48	10-Dec-2021	18:36	48	0.000213	INTERRUPTION DUE TO FAULT
39	11-Dec-2021	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96,95,94, SHALIMAR BAGH	2591	Other Outage	Unplanned Outage	11-Dec-2021	08:00	11-Dec-2021	08:57	57	0.000472	INTERRUPTION DUE TO FAULT
40	12-Dec-2021	PARTS OF BADI AND LABOUR CHOWK AREA SHALIMAR BAGH	1521	Other Outage	Unplanned Outage	12-Dec-2021	08:50	12-Dec-2021	09:38	48	0.000244	INTERRUPTION DUE TO FAULT
41	12-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3336	Other Outage	Unplanned Outage	12-Dec-2021	10:51	12-Dec-2021	11:32	41	0.000398	INTERRUPTION DUE TO FAULT
42	13-Dec-2021	PARTS OF HINDUSTAN PETROLEUM BURARI SHALIMAR BAGH	3482	Other Outage	Unplanned Outage	13-Dec-2021	13:32	13-Dec-2021	14:32	60	0.000573	INTERRUPTION DUE TO FAULT
43	14-Dec-2021	PART OF SHALIMAR BAGH INDUSTRIAL AREA SHALIMAR BAGH	20	Other Outage	Unplanned Outage	14-Dec-2021	12:18	14-Dec-2021	12:50	32	0.000009	INTERRUPTION DUE TO FAULT
44	14-Dec-2021	PARTS OF SMA INDUSTRIAL AREA SHALIMAR BAGH	40	Other Outage	Unplanned Outage	14-Dec-2021	12:18	14-Dec-2021	14:38	140	0.000039	FORCE MAJEURE DUE TO SABOTAGE
45	15-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	1366	Other Outage	Unplanned Outage	15-Dec-2021	03:19	15-Dec-2021	04:17	58	0.000193	INTERRUPTION DUE TO FAULT
46	15-Dec-2021	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96,95,94, SHALIMAR BAGH	2434	Other Outage	Unplanned Outage	15-Dec-2021	05:37	15-Dec-2021	06:20	43	0.000299	INTERRUPTION DUE TO FAULT
47	15-Dec-2021	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR SHALIMAR BAGH	338	Other Outage	Unplanned Outage	15-Dec-2021	14:09	15-Dec-2021	15:03	54	0.000075	INTERRUPTION DUE TO FAULT
48	15-Dec-2021	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR SHALIMAR BAGH	4233	Other Outage	Unplanned Outage	15-Dec-2021	14:09	15-Dec-2021	15:55	106	0.000884	INTERRUPTION DUE TO FAULT
49	15-Dec-2021	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR SHALIMAR BAGH	30	Other Outage	Unplanned Outage	15-Dec-2021	14:09	15-Dec-2021	17:55	226	0.000063	FORCE MAJEURE DUE TO SABOTAGE
50	15-Dec-2021	PARTS OF BURARI GARHUTTARNCHAL ENCLAVE, KAMAL VIHAR A,B,C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR SHALIMAR BAGH	2424	Other Outage	Unplanned Outage	15-Dec-2021	16:12	15-Dec-2021	16:25	13	0.000076	INTERRUPTION DUE TO FAULT
51	16-Dec-2021	PARTS OF ISHU VIHAR BHALSWA SHALIMAR BAGH	3102	Other Outage	Unplanned Outage	16-Dec-2021	04:06	16-Dec-2021	04:55	49	0.000429	INTERRUPTION DUE TO FAULT
52	16-Dec-2021	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	5084	Other Outage	Unplanned Outage	16-Dec-2021	08:03	16-Dec-2021	08:40	37	0.000403	INTERRUPTION DUE TO FAULT
53	16-Dec-2021	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	30	Other Outage	Unplanned Outage	16-Dec-2021	08:03	16-Dec-2021	17:21	558	0.000155	FORCE MAJEURE DUE TO SABOTAGE
54	16-Dec-2021	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	3356	Other Outage	Unplanned Outage	16-Dec-2021	10:44	16-Dec-2021	11:46	62	0.000511	INTERRUPTION DUE TO FAULT
55	16-Dec-2021	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	5745	Other Outage	Unplanned Outage	16-Dec-2021	10:44	16-Dec-2021	11:55	71	0.000788	INTERRUPTION DUE TO FAULT
56	16-Dec-2021	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A, C, D, E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	1230	Other Outage	Unplanned Outage	16-Dec-2021	17:30	16-Dec-2021	19:16	106	0.000381	INTERRUPTION DUE TO FAULT
57	16-Dec-2021	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A, C, D, E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	553	Other Outage	Unplanned Outage	16-Dec-2021	19:18	16-Dec-2021	20:26	68	0.000095	INTERRUPTION DUE TO FAULT
58	17-Dec-2021	PART OF SMA INDUSTRIAL AREA SHALIMAR BAGH	2	Other Outage	Unplanned Outage	17-Dec-2021	10:59	17-Dec-2021	12:50	111	0.000031	INTERRUPTION DUE TO FAULT
59	17-Dec-2021	PARTS OF RAJEEV NAGAR SHALIMAR BAGH	2255	Other Outage	Unplanned Outage	17-Dec-2021	13:21	17-Dec-2021	13:58	37	0.000154	INTERRUPTION DUE TO FAULT
60	17-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	1366	Other Outage	Unplanned Outage	17-Dec-2021	21:04	17-Dec-2021	21:35	31	0.000217	INTERRUPTION DUE TO FAULT
61	17-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3337	Other Outage	Unplanned Outage	17-Dec-2021	23:26	17-Dec-2021	23:40	14	0.000175	INTERRUPTION DUE TO FAULT
62	17-Dec-2021	PARTS OF INDIAN OIL, HP & BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, RELIANCE TOWER, PART OF PARVATIACHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN, SHALIMAR BAGH	1057	Other Outage	Unplanned Outage	17-Dec-2021	23:56	18-Dec-2021	00:39	43	0.00025	INTERRUPTION DUE TO FAULT
63	18-Dec-2021	PARTS OF INDIAN OIL, HP & BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, RELIANCE TOWER, PART OF PARVATIACHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN, SHALIMAR BAGH	1057	Other Outage	Unplanned Outage	18-Dec-2021	01:03	18-Dec-2021	01:52	49	0.0003	INTERRUPTION DUE TO FAULT
64	18-Dec-2021	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A, C, D, E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	1991	Other Outage	Unplanned Outage	18-Dec-2021	17:25	18-Dec-2021	18:09	44	0.000245	INTERRUPTION DUE TO FAULT
65	19-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AIT VIHAR,GANDIA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D,E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	6396	Other Outage	Unplanned Outage	19-Dec-2021	06:43	19-Dec-2021	07:10	27	0.000263	INTERRUPTION DUE TO FAULT
66	19-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO. 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR, SHALIMAR BAGH	150	Other Outage	Unplanned Outage	19-Dec-2021	09:45	19-Dec-2021	10:25	40	0.000044	INTERRUPTION DUE TO FAULT
67	19-Dec-2021	PART OF JAGAT PURVILLAGE SHALIMAR BAGH	11	Other Outage	Unplanned Outage	19-Dec-2021	09:45	19-Dec-2021	15:56	371	0.000103	FORCE MAJEURE DUE TO SABOTAGE
68	19-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO. 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR, SHALIMAR BAGH	150	Other Outage	Unplanned Outage	19-Dec-2021	15:31	19-Dec-2021	15:56	25	0.000028	INTERRUPTION DUE TO FAULT
69	20-Dec-2021	PARTS OF BHALASWA AND PEPSI GODOWN SHALIMAR BAGH	1747	Other Outage	Unplanned Outage	20-Dec-2021	12:34	20-Dec-2021	12:55	21	0.0002	INTERRUPTION DUE TO FAULT
70	20-Dec-2021	PARTS OF BHALASWA AND PEPSI GODOWN SHALIMAR BAGH	1059	Other Outage	Unplanned Outage	20-Dec-2021	12:34	20-Dec-2021	13:05	31	0.000192	INTERRUPTION DUE TO FAULT
71	20-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	3234	Other Outage	Unplanned Outage	20-Dec-2021	21:28	20-Dec-2021	22:05	37	0.000411	INTERRUPTION DUE TO FAULT
72	20-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	1044	Other Outage	Unplanned Outage	20-Dec-2021	21:28	20-Dec-2021	22:35	67	0.000335	INTERRUPTION DUE TO FAULT
73	21-Dec-2021	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE, SHALIMAR BAGH	21	Other Outage	Unplanned Outage	21-Dec-2021	08:00	21-Dec-2021	09:35	95	0.000053	INTERRUPTION DUE TO FAULT
74	21-Dec-2021	PARTS OF BANGALI COLONY SHALIMAR BAGH	87	Other Outage	Unplanned Outage	21-Dec-2021	10:36	21-Dec-2021	11:07	31	0.000034	INTERRUPTION DUE TO FAULT
75	22-Dec-2021	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	3171	Other Outage	Unplanned Outage	22-Dec-2021	13:54	22-Dec-2021	14:29	35	0.00017	INTERRUPTION DUE TO FAULT
76	22-Dec-2021	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	2997	Other Outage	Unplanned Outage	22-Dec-2021	13:54	22-Dec-2021	15:05	71	0.000292	INTERRUPTION DUE TO FAULT
77	22-Dec-2021	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	961	Other Outage	Unplanned Outage	22-Dec-2021	13:54	22-Dec-2021	15:08	74	0.000101	INTERRUPTION DUE TO FAULT
78	22-Dec-2021	PARTS OF WAZIRABAD VILLAGE, GALI NO. 1,2,3,4,5,6,8, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	662	Other Outage	Unplanned Outage	22-Dec-2021	23:11	22-Dec-2021	23:48	37	0.000123	INTERRUPTION DUE TO FAULT
79	24-Dec-2021	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A, C, D, E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	1992	Other Outage	Unplanned Outage	24-Dec-2021	07:36	24-Dec-2021	08:23	47	0.000262	INTERRUPTION DUE TO FAULT
80	24-Dec-2021	PART OF HIRANKI SHALIMAR BAGH	3	Other Outage	Unplanned Outage	24-Dec-2021	11:30	24-Dec-2021	12:50	80	0.000044	INTERRUPTION DUE TO FAULT
81	24-Dec-2021	PARTS OF WAZIRABAD VILLAGE, GALI NO. 1,2,3,4,5,6,8, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	662	Other Outage	Unplanned Outage	24-Dec-2021	12:56	24-Dec-2021	13:25	29	0.000072	INTERRUPTION DUE TO FAULT
82	24-Dec-2021	PARTS OF WAZIRABAD VILLAGE, GALI NO. 1,2,3,4,5,6,8, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	662	Other Outage	Unplanned Outage	24-Dec-2021	14:46	24-Dec-2021	16:15	89	0.000173	INTERRUPTION DUE TO FAULT
83	24-Dec-2021	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96,95,94, SHALIMAR BAGH	1783	Other Outage	Unplanned Outage	24-Dec-2021	21:13	24-Dec-2021	22:20	67	0.000279	INTERRUPTION DUE TO FAULT
84	24-Dec-2021	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96,95,94, SHALIMAR BAGH	937	Other Outage	Unplanned Outage	24-Dec-2021	21:13	24-Dec-2021	22:45	92	0.000256	INTERRUPTION DUE TO FAULT
85	25-Dec-2021	PART OF HIRANKI SHALIMAR BAGH	3	Other Outage	Unplanned Outage	25-Dec-2021	15:11	25-Dec-2021	16:37	86	0.000048	INTERRUPTION DUE TO FAULT
86	26-Dec-2021	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N.PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART -1&2, PART -2, HIMGIRI, SAMTA VIHAR, JI PUNARWASI COLONY, RAJEEV NAGAR SHALIMAR BAGH	2204	Other Outage	Unplanned Outage	26-Dec-2021	08:42	26-Dec-2021	09:28	46	0.000384	INTERRUPTION DUE TO FAULT
87	26-Dec-2021	PARTS OF BG & BI BLOCKS, BM, BN EAST, POLIC COLONY, BF BLOCK AND BF MARKET SHALIMAR BAGH	1117	Other Outage	Unplanned Outage	26-Dec-2021	11:20	26-Dec-2021	11:58	38	0.000474	INTERRUPTION DUE TO FAULT
88	26-Dec-2021	PARTS OF BG & BI BLOCKS, BM, BN EAST, POLIC COLONY, BF BLOCK AND BF MARKET SHALIMAR BAGH	1117	Other Outage	Unplanned Outage	26-Dec-2021	12:10	26-Dec-2021	12:24	14	0.000112	INTERRUPTION DUE TO FAULT
89	26-Dec-2021	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	88	Other Outage	Unplanned Outage	26-Dec-2021	18:26	26-Dec-2021	19:15	49	0.000027	INTERRUPTION DUE TO FAULT
90	26-Dec-2021	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	37	Other Outage	Unplanned Outage	26-Dec-2021	18:26	27-Dec-2021	01:44	438	0.000243	FORCE MAJEURE DUE TO RAINSTORM

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
91	26-Dec-2021	PARTS OF AMBEDKAR NAGAR & J. J. CLUSTER (HAIDER PUR), GALAXY TOYOTA, AGGRAWAL AUTO MALL AND PWD STREET LIGHT SHALIMAR BAGH	145	Other Outage	Unplanned Outage	26-Dec-2021	18:27	26-Dec-2021	20:15	108	0.000149	INTERRUPTION DUE TO FAULT
92	26-Dec-2021	PARTS OF SMA INDUSTRIAL AREA SHALIMAR BAGH	46	Other Outage	Unplanned Outage	26-Dec-2021	19:37	26-Dec-2021	23:30	233	0.00013	FORCE MAJEURE DUE TO RAIN/STORM
93	26-Dec-2021	PARTS OF ISHU VIHAR BHALSWA SHALIMAR BAGH	7135	Other Outage	Unplanned Outage	26-Dec-2021	19:46	26-Dec-2021	22:09	143	0.001985	FORCE MAJEURE DUE TO RAIN/STORM
94	26-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3342	Other Outage	Unplanned Outage	26-Dec-2021	19:52	26-Dec-2021	22:33	161	0.001793	FORCE MAJEURE DUE TO RAIN/STORM
95	26-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL/PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	6297	Other Outage	Unplanned Outage	26-Dec-2021	20:23	26-Dec-2021	21:00	37	0.000708	INTERRUPTION DUE TO FAULT
96	27-Dec-2021	PARTS OF NEEL KANTH APPARTMENT. SHALIMAR BAGH	1226	Other Outage	Unplanned Outage	27-Dec-2021	03:15	27-Dec-2021	04:20	65	0.000271	INTERRUPTION DUE TO FAULT
97	27-Dec-2021	PARTS OF WAZIRABAD VILLAGE, GALI NO. 1,2,3 4,5, 6, 8, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	1313	Other Outage	Unplanned Outage	27-Dec-2021	04:39	27-Dec-2021	05:23	44	0.000183	INTERRUPTION DUE TO FAULT
98	27-Dec-2021	PART OF SMA INDUSTRIAL AREA SHALIMAR BAGH	3	Other Outage	Unplanned Outage	27-Dec-2021	06:30	27-Dec-2021	07:19	49	0.000014	INTERRUPTION DUE TO FAULT
99	27-Dec-2021	PARTS OF SMA INDUSTRIAL AREA SHALIMAR BAGH	43	Other Outage	Unplanned Outage	27-Dec-2021	06:49	27-Dec-2021	07:21	32	0.000044	INTERRUPTION DUE TO FAULT
100	27-Dec-2021	PARTS OF WAZIRABAD VILLAGE, GALI NO. 1,2,3 4,5, 6, 8, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	72	Other Outage	Unplanned Outage	27-Dec-2021	13:47	27-Dec-2021	15:30	103	0.000086	INTERRUPTION DUE TO FAULT
101	27-Dec-2021	PARTS OF BHAGAT COLONY SHALIMAR BAGH	775	Other Outage	Unplanned Outage	27-Dec-2021	16:45	27-Dec-2021	17:30	45	0.000075	INTERRUPTION DUE TO FAULT
102	27-Dec-2021	PART OF TRANSPORT AUTHORITY SHALIMAR BAGH	20	Other Outage	Unplanned Outage	27-Dec-2021	17:40	27-Dec-2021	23:12	332	0.000184	FORCE MAJEURE DUE TO SABOTAGE
103	27-Dec-2021	PARTS OF INDIAN OIL, HP & BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, RELIANCE TOWER, PART OF PARVATIACHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN, SHALIMAR BAGH	31	Other Outage	Unplanned Outage	27-Dec-2021	17:48	27-Dec-2021	18:20	32	0.000018	INTERRUPTION DUE TO FAULT
104	28-Dec-2021	PARTS OF AMBEDKAR NAGAR & J. J. CLUSTER (HAIDER PUR), GALAXY TOYOTA, AGGRAWAL AUTO MALL AND PWD STREET LIGHT SHALIMAR BAGH	145	Other Outage	Unplanned Outage	28-Dec-2021	14:37	28-Dec-2021	17:49	192	0.000266	FORCE MAJEURE DUE TO SABOTAGE
105	28-Dec-2021	PARTS OF JJ CLUSTER HAIDER PUR, HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE SHALIMAR BAGH	46	Other Outage	Unplanned Outage	28-Dec-2021	15:45	28-Dec-2021	17:29	104	0.000058	INTERRUPTION DUE TO FAULT
106	28-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3138	Other Outage	Unplanned Outage	28-Dec-2021	16:48	28-Dec-2021	19:33	165	0.001605	FORCE MAJEURE DUE TO RAIN/STORM
107	28-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	204	Other Outage	Unplanned Outage	28-Dec-2021	16:48	28-Dec-2021	19:59	191	0.000212	FORCE MAJEURE DUE TO RAIN/STORM
108	28-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3138	Other Outage	Unplanned Outage	28-Dec-2021	19:47	28-Dec-2021	19:59	12	0.000117	INTERRUPTION DUE TO FAULT
109	28-Dec-2021	PARTS OF AMBEDKAR NAGAR & J. J. CLUSTER (HAIDER PUR), GALAXY TOYOTA, AGGRAWAL AUTO MALL AND PWD STREET LIGHT SHALIMAR BAGH	979	Other Outage	Unplanned Outage	28-Dec-2021	23:54	29-Dec-2021	01:12	78	0.000433	INTERRUPTION DUE TO FAULT
110	29-Dec-2021	PART OF JAGAT PURVILLAGE SHALIMAR BAGH	16	Other Outage	Unplanned Outage	29-Dec-2021	10:33	29-Dec-2021	10:54	21	0.000012	INTERRUPTION DUE TO FAULT
111	29-Dec-2021	PARTS OF SANT NAGAR POCKET B BLOCK SHALIMAR BAGH	4352	Other Outage	Unplanned Outage	29-Dec-2021	10:45	29-Dec-2021	11:33	48	0.000497	INTERRUPTION DUE TO FAULT
112	29-Dec-2021	PARTS OF SANT NAGAR POCKET B BLOCK SHALIMAR BAGH	177	Other Outage	Unplanned Outage	29-Dec-2021	10:45	29-Dec-2021	14:30	225	0.000249	FORCE MAJEURE DUE TO SABOTAGE
113	29-Dec-2021	PARTS OF BHALSWA SMA INDUSTRIAL AREA SHALIMAR BAGH	126	Other Outage	Unplanned Outage	29-Dec-2021	12:58	29-Dec-2021	13:20	22	0.000049	INTERRUPTION DUE TO FAULT
114	29-Dec-2021	PARTS OF AMBEDKAR NAGAR & J. J. CLUSTER (HAIDER PUR), GALAXY TOYOTA, AGGRAWAL AUTO MALL AND PWD STREET LIGHT SHALIMAR BAGH	145	Other Outage	Unplanned Outage	29-Dec-2021	16:05	29-Dec-2021	17:00	55	0.000121	INTERRUPTION DUE TO FAULT
115	30-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3343	Other Outage	Unplanned Outage	30-Dec-2021	08:20	30-Dec-2021	09:51	91	0.00096	INTERRUPTION DUE TO FAULT
116	30-Dec-2021	PARTS OF BHALSWA SMA INDUSTRIAL AREA SHALIMAR BAGH	126	Other Outage	Unplanned Outage	30-Dec-2021	10:44	30-Dec-2021	11:35	51	0.000255	INTERRUPTION DUE TO FAULT
117	30-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO. 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	1554	Other Outage	Unplanned Outage	30-Dec-2021	11:52	30-Dec-2021	12:29	37	0.000185	INTERRUPTION DUE TO FAULT
118	30-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO. 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	2721	Other Outage	Unplanned Outage	30-Dec-2021	11:56	30-Dec-2021	12:29	33	0.000348	INTERRUPTION DUE TO FAULT
119	30-Dec-2021	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N. PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART - 1& PART - 2, HIMGIRI, SAMTA VIHAR, JJ PUNARWASH COLONY, RAJEEV NAGAR SHALIMAR BAGH	3196	Other Outage	Unplanned Outage	30-Dec-2021	16:51	30-Dec-2021	17:15	24	0.0004	INTERRUPTION DUE TO FAULT
120	30-Dec-2021	PARTS OF BHALSWA AND PEPSI GODOWN SHALIMAR BAGH	2812	Other Outage	Unplanned Outage	30-Dec-2021	17:35	30-Dec-2021	17:42	7	0.000074	INTERRUPTION DUE TO FAULT
121	31-Dec-2021	PARTS OF BHALSWA SMA INDUSTRIAL AREA SHALIMAR BAGH	126	Other Outage	Unplanned Outage	31-Dec-2021	09:36	31-Dec-2021	10:20	44	0.000611	INTERRUPTION DUE TO FAULT
122	31-Dec-2021	PARTS OF HARDEV NAGAR, SURRENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPSANHU COLONY. SHALIMAR BAGH	4508	Other Outage	Unplanned Outage	31-Dec-2021	13:34	31-Dec-2021	14:50	76	0.001149	INTERRUPTION DUE TO FAULT
123	31-Dec-2021	PARTS OF PRAGYA MALL NEAR SHALIMAR BAGH CLUB SHALIMAR BAGH	116	Other Outage	Unplanned Outage	31-Dec-2021	19:42	31-Dec-2021	21:33	111	0.000123	INTERRUPTION DUE TO FAULT
124	31-Dec-2021	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	174	Other Outage	Unplanned Outage	31-Dec-2021	22:06	31-Dec-2021	22:57	51	0.000042	INTERRUPTION DUE TO FAULT
125	01-Dec-2021	PARTS OF NEEL KANTH APPARTMENT. SHALIMAR BAGH	806	Other Outage	Planned Outage	01-Dec-2021	10:58	01-Dec-2021	11:06	8	0.00002	PLANNED OUTAGE
126	01-Dec-2021	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	3342	Other Outage	Planned Outage	01-Dec-2021	10:59	01-Dec-2021	17:18	379	0.00316	PLANNED OUTAGE
127	01-Dec-2021	PART OF JJ PUNARWASH COLONY SHALIMAR BAGH	4	Other Outage	Planned Outage	01-Dec-2021	12:08	01-Dec-2021	15:50	221	0.00006	PLANNED OUTAGE
128	02-Dec-2021	PARTS OF BURARI PRADHAN ENCLAVE SHALIMAR BAGH	49	Other Outage	Planned Outage	02-Dec-2021	11:03	02-Dec-2021	16:22	319	0.00035	PLANNED OUTAGE
129	03-Dec-2021	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N. PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART - 1& PART - 2, HIMGIRI, SAMTA VIHAR, JJ PUNARWASH COLONY, RAJEEV NAGAR SHALIMAR BAGH	2197	Other Outage	Planned Outage	03-Dec-2021	10:52	03-Dec-2021	15:54	302	0.00185	PLANNED OUTAGE
130	03-Dec-2021	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI SHALIMAR BAGH	737	630 kVA	Planned Outage	03-Dec-2021	11:34	03-Dec-2021	12:31	57	0.00011	PLANNED OUTAGE
131	04-Dec-2021	PART OF TRANSPORT AUTHORITY SHALIMAR BAGH	20	Other Outage	Planned Outage	04-Dec-2021	10:51	04-Dec-2021	16:32	341	0.00019	PLANNED OUTAGE
132	04-Dec-2021	PARTS OF WAZIRABAD VILLAGE, GALI NO. 1,2,3 4,5, 6, 8, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	402	400 kVA	Planned Outage	04-Dec-2021	11:29	04-Dec-2021	13:12	103	0.00014	PLANNED OUTAGE
133	04-Dec-2021	PARTS OF BURARI ROAD SWAROOP NAGAR, A BLOCK SWAROOP NAGAR, KHADDA COLONY, RAVI ICE FACTORY, SAYA WALA, XYZ COLONY SHALIMAR BAGH	775	Other Outage	Planned Outage	04-Dec-2021	11:56	04-Dec-2021	16:00	244	0.00047	PLANNED OUTAGE
134	06-Dec-2021	PARTS OF SANT NAGAR POCKET B BLOCK SHALIMAR BAGH	308	Other Outage	Planned Outage	06-Dec-2021	11:03	06-Dec-2021	13:25	142	0.00012	PLANNED OUTAGE
135	06-Dec-2021	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A, B, C & A1 BLK & SWAROOP NAGAR ROAD SHALIMAR BAGH	1947	Other Outage	Planned Outage	06-Dec-2021	11:23	06-Dec-2021	16:42	319	0.00133	PLANNED OUTAGE
136	06-Dec-2021	PARTS OF HINDUSTAN PETROLEUM BURARI SHALIMAR BAGH	111	315 kVA	Planned Outage	06-Dec-2021	11:44	06-Dec-2021	16:12	268	0.00037	PLANNED OUTAGE
137	07-Dec-2021	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT. JAGAT PUR VILLAGE, GALI NO. 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR. SHALIMAR BAGH	1022	990 kVA	Planned Outage	07-Dec-2021	12:20	07-Dec-2021	14:21	121	0.00034	PLANNED OUTAGE
138	08-Dec-2021	PARTS OF BADLI AND LABOUR CHOWK AREA SHALIMAR BAGH	858	Other Outage	Planned Outage	08-Dec-2021	11:07	08-Dec-2021	15:55	288	0.00072	PLANNED OUTAGE
139	10-Dec-2021	PARTS OF AK BLOCK, AD BLOCK JJ CLUSTER NO-2 SHALIMAR BAGH	94	630 kVA	Planned Outage	10-Dec-2021	10:48	10-Dec-2021	12:13	85	0.00002	PLANNED OUTAGE
140	10-Dec-2021	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	721	Other Outage	Planned Outage	10-Dec-2021	11:01	10-Dec-2021	16:37	336	0.00075	PLANNED OUTAGE
141	10-Dec-2021	PART OF SHALIMAR BAGH INDUSTRIAL AREA SHALIMAR BAGH	3	315 kVA	Unplanned Outage	10-Dec-2021	16:16	10-Dec-2021	16:32	16	0.000005	SYSTEM SCHEDULE OUTAGE
142	14-Dec-2021	PARTS OF HARJAN BASTI-1, INDIAN OIL SHALIMAR BAGH	582	990 kVA	Planned Outage	14-Dec-2021	11:11	14-Dec-2021	15:39	268	0.00037	PLANNED OUTAGE
143	14-Dec-2021	PARTS OF BABA COLONY A BLK VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	453	Other Outage	Planned Outage	14-Dec-2021	11:15	14-Dec-2021	16:25	310	0.00043	PLANNED OUTAGE
144	14-Dec-2021	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR SHALIMAR BAGH	30	Other Outage	Planned Outage	14-Dec-2021	11:38	14-Dec-2021	16:13	275	0.00008	PLANNED OUTAGE
145	16-Dec-2021	PARTS OF BHALSWA, SANT NAGAR, MURGI FARM, KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHMI KUMAR,ASHARAM, CHAKU FACTORY SHALIMAR BAGH	1271	Other Outage	Planned Outage	16-Dec-2021	10:50	16-Dec-2021	17:12	382	0.00138	PLANNED OUTAGE
146	17-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	610	Other Outage	Planned Outage	17-Dec-2021	10:17	17-Dec-2021	16:05	348	0.00068	PLANNED OUTAGE
147	17-Dec-2021	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	43	Other Outage	Planned Outage	17-Dec-2021	11:12	17-Dec-2021	16:23	310	0.00009	PLANNED OUTAGE
148	17-Dec-2021	PART OF BN MARKET SHALIMAR BAGH	5	Other Outage	Planned Outage	17-Dec-2021	12:19	17-Dec-2021	13:10	51	0.00001	PLANNED OUTAGE
149	17-Dec-2021	PARTS OF BC, BD, BFH, WEST SHALIMAR BAGH, BH, BI, BG BF EAST SHALIMAR BAGH, SAHI PUR VILLAGE SHALIMAR BAGH	576	990 kVA	Planned Outage	17-Dec-2021	14:06	17-Dec-2021	15:58	112	0.00019	PLANNED OUTAGE
150	18-Dec-2021	PARTS OF BHAGAT COLONY SHALIMAR BAGH	68	160 kVA	Planned Outage	18-Dec-2021	10:32	18-Dec-2021	16:34	362	0.00010	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
151	18-Dec-2021	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL/PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D,E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	31	250 kVA	Planned Outage	18-Dec-2021	11:53	18-Dec-2021	13:48	115	0.00003	PLANNED OUTAGE
152	20-Dec-2021	PARTS OF KAUSHIK ENCLAVE AND BURARI SHALIMAR BAGH	1303	Other Outage	Planned Outage	20-Dec-2021	10:40	20-Dec-2021	15:03	263	0.00183	PLANNED OUTAGE
153	20-Dec-2021	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	848	400 kVA	Planned Outage	20-Dec-2021	10:59	20-Dec-2021	16:08	309	0.00172	PLANNED OUTAGE
154	20-Dec-2021	PARTS OF AK BLOCK, AD BLOCK JJ CLUSTER NO-2 SHALIMAR BAGH	360	1000 kVA	Planned Outage	20-Dec-2021	11:35	20-Dec-2021	13:25	110	0.00009	PLANNED OUTAGE
155	21-Dec-2021	PARTS OF INDIAN OIL, HP & BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, RELIANCE TOWER, PART OF PARVATIACHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN, SHALIMAR BAGH	1057	Other Outage	Planned Outage	21-Dec-2021	11:34	21-Dec-2021	16:55	321	0.00107	PLANNED OUTAGE
156	22-Dec-2021	PARTS OF SMA INDUSTRIAL AREA SHALIMAR BAGH	60	Other Outage	Planned Outage	22-Dec-2021	10:15	22-Dec-2021	17:00	405	0.00023	PLANNED OUTAGE
157	23-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	784	990 kVA	Planned Outage	23-Dec-2021	11:01	23-Dec-2021	13:10	129	0.00072	PLANNED OUTAGE
158	23-Dec-2021	PARTS OF BK & BL BLOCKS , SHALIMAR CLUB, AP BLOCK, BI BLOCK, AMBIENS MALL SHALIMAR BAGH	693	Other Outage	Planned Outage	23-Dec-2021	14:16	23-Dec-2021	16:02	106	0.00018	PLANNED OUTAGE
159	24-Dec-2021	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH.	547	630 kVA	Planned Outage	24-Dec-2021	10:18	24-Dec-2021	15:50	332	0.00046	PLANNED OUTAGE
160	24-Dec-2021	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY, SHALIMAR BAGH	4504	Other Outage	Planned Outage	24-Dec-2021	10:30	24-Dec-2021	17:42	432	0.00300	PLANNED OUTAGE
161	24-Dec-2021	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	506	990 kVA	Planned Outage	24-Dec-2021	10:47	24-Dec-2021	13:15	148	0.00021	PLANNED OUTAGE
162	24-Dec-2021	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	536	990 kVA	Planned Outage	24-Dec-2021	14:24	24-Dec-2021	16:24	120	0.00017	PLANNED OUTAGE
163	27-Dec-2021	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR SHALIMAR BAGH	1632	Other Outage	Planned Outage	27-Dec-2021	10:41	27-Dec-2021	14:14	213	0.00065	PLANNED OUTAGE
164	27-Dec-2021	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	895	990 kVA	Planned Outage	27-Dec-2021	11:13	27-Dec-2021	14:51	218	0.00048	PLANNED OUTAGE
165	27-Dec-2021	PARTS OF BHAGAT COLONY SHALIMAR BAGH	775	990 kVA	Planned Outage	27-Dec-2021	11:34	27-Dec-2021	15:59	265	0.00184	PLANNED OUTAGE
166	28-Dec-2021	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH.	1502	Other Outage	Planned Outage	28-Dec-2021	10:31	28-Dec-2021	15:51	320	0.00107	PLANNED OUTAGE
167	28-Dec-2021	PARTS OF GALI NO-12 SWAROOP NAGAR AND BHALSWA SHALIMAR BAGH	2011	Other Outage	Planned Outage	28-Dec-2021	11:03	28-Dec-2021	16:36	333	0.00185	PLANNED OUTAGE
168	29-Dec-2021	PARTS OF RUN - 27, D - 22, CETP PLANT, RUN - 32, RUN - 33 SHALIMAR BAGH	30	Other Outage	Planned Outage	29-Dec-2021	10:52	29-Dec-2021	17:29	397	0.00011	PLANNED OUTAGE
169	29-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	166	630 kVA	Planned Outage	29-Dec-2021	11:05	29-Dec-2021	13:00	115	0.00006	PLANNED OUTAGE
170	29-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	104	Other Outage	Planned Outage	29-Dec-2021	14:28	29-Dec-2021	16:08	100	0.00006	PLANNED OUTAGE
171	29-Dec-2021	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	2	400 kVA	Unplanned Outage	29-Dec-2021	15:19	29-Dec-2021	16:04	45	0.00001	SYSTEM SCHEDULE OUTAGE
172	30-Dec-2021	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	2397	Other Outage	Planned Outage	30-Dec-2021	11:04	30-Dec-2021	13:46	162	0.00104	PLANNED OUTAGE
173	30-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	146	630 kVA	Planned Outage	30-Dec-2021	11:09	30-Dec-2021	13:05	116	0.00006	PLANNED OUTAGE
174	30-Dec-2021	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	172	630 kVA	Planned Outage	30-Dec-2021	14:12	30-Dec-2021	16:24	132	0.00007	PLANNED OUTAGE
175	31-Dec-2021	PARTS OF BHALASWA AND PEPSI GODOWN SHALIMAR BAGH	1851	Other Outage	Planned Outage	31-Dec-2021	11:46	31-Dec-2021	15:00	194	0.00102	PLANNED OUTAGE
176	31-Dec-2021	PART OF AMBEDKAR NAGAR SHALIMAR BAGH	6	160 kVA	Unplanned Outage	31-Dec-2021	14:10	31-Dec-2021	15:08	58	0.00002	SYSTEM SCHEDULE OUTAGE