

Name Of Distribution Licensee: TATA POWER DDL Period Of Outage: FEB-2024												
Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
BADLI												
1	01-Feb-2024	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY BADLI	4136	Other Outage	Unplanned Outage	01-Feb-2024	05:29	01-Feb-2024	07:47	138	0.00157	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF KRISHAN COLONY BADLI	1457	Other Outage	Unplanned Outage	01-Feb-2024	05:35	01-Feb-2024	07:08	92	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	445	Other Outage	Unplanned Outage	01-Feb-2024	05:39	01-Feb-2024	06:30	51	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF BADLI INDS. AREA PAHSE-2 & 5 BADLI	136	Other Outage	Unplanned Outage	01-Feb-2024	08:02	01-Feb-2024	12:32	270	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF AIR NANGLI BADLI	2994	Other Outage	Unplanned Outage	01-Feb-2024	09:10	01-Feb-2024	09:33	23	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	130	Other Outage	Unplanned Outage	01-Feb-2024	09:36	01-Feb-2024	10:35	59	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF GALI NO 9 SAMAYPUR BADLI	74	Other Outage	Unplanned Outage	01-Feb-2024	10:09	01-Feb-2024	11:11	62	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
8	01-Feb-2024	PARTS OF KALI MATA MANDIR, MASTER PROPERTY. BADLI	279	Other Outage	Unplanned Outage	01-Feb-2024	10:55	01-Feb-2024	13:37	162	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
9	01-Feb-2024	PART OF BADLI INDUSTRIAL AREA BADLI	3	400 kVA	Planned Outage	01-Feb-2024	11:01	01-Feb-2024	14:05	184	0.00010	PLANNED OUTAGE
10	01-Feb-2024	PARTS OF APPOLO CONVENT SCHOOL, SHIV MANDIR , NURSERY WALA NO-2, MAAN PUBLIC SCHOOL NO-2 BADLI	2939	Other Outage	Unplanned Outage	01-Feb-2024	11:14	01-Feb-2024	12:30	76	0.00063	FORCE MAJEURE/EXTERNAL FACTORS
11	01-Feb-2024	PARTS OF APPOLO CONVENT SCHOOL, SHIV MANDIR , NURSERY WALA NO-2, MAAN PUBLIC SCHOOL NO-2 BADLI	3573	Other Outage	Unplanned Outage	01-Feb-2024	11:14	01-Feb-2024	13:50	156	0.00152	FORCE MAJEURE/EXTERNAL FACTORS
12	01-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	1916	Other Outage	Unplanned Outage	01-Feb-2024	12:05	01-Feb-2024	13:30	86	0.00048	FORCE MAJEURE/EXTERNAL FACTORS
13	01-Feb-2024	PART OF AIR NANGLI BADLI	17	Other Outage	Unplanned Outage	01-Feb-2024	13:04	01-Feb-2024	20:32	448	0.00125	FORCE MAJEURE/EXTERNAL FACTORS
14	01-Feb-2024	PARTS OF AIR NANGLI, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	153	Other Outage	Unplanned Outage	01-Feb-2024	13:55	01-Feb-2024	15:15	79	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
15	01-Feb-2024	PARTS OF BADLI AND PARK WALA SAMAYPUR BADLI	559	Other Outage	Unplanned Outage	01-Feb-2024	13:59	01-Feb-2024	16:06	127	0.00035	FORCE MAJEURE/EXTERNAL FACTORS
16	01-Feb-2024	PARTS OF PRAHLAD VIHAR BADLI	1217	Other Outage	Unplanned Outage	01-Feb-2024	14:16	01-Feb-2024	15:48	91	0.00051	FORCE MAJEURE/EXTERNAL FACTORS
17	01-Feb-2024	PARTS OF PRAHLAD VIHAR BADLI	201	Other Outage	Unplanned Outage	01-Feb-2024	14:16	01-Feb-2024	16:12	115	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
18	01-Feb-2024	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY BADLI	206	Other Outage	Unplanned Outage	01-Feb-2024	17:05	01-Feb-2024	20:00	174	0.00048	FORCE MAJEURE/EXTERNAL FACTORS
19	01-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	198	Other Outage	Unplanned Outage	01-Feb-2024	17:25	01-Feb-2024	19:05	100	0.00056	FORCE MAJEURE/EXTERNAL FACTORS
20	01-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	94	Other Outage	Unplanned Outage	01-Feb-2024	17:25	01-Feb-2024	19:05	100	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
21	01-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	30	Other Outage	Unplanned Outage	01-Feb-2024	18:26	01-Feb-2024	19:05	39	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
22	01-Feb-2024	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADLI	6923	Other Outage	Unplanned Outage	01-Feb-2024	18:27	01-Feb-2024	18:48	21	0.00058	INTERRUPTION DUE TO FAULT
23	01-Feb-2024	PARTS OF PRAHLAD VIHAR BADLI	494	Other Outage	Unplanned Outage	01-Feb-2024	20:51	01-Feb-2024	21:45	54	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
24	02-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	94	Other Outage	Planned Outage	02-Feb-2024	10:29	02-Feb-2024	14:43	254	0.00071	PLANNED OUTAGE
25	02-Feb-2024	PARTS OF ESS NO -1 SAMAYPUR BADLI	2268	Other Outage	Unplanned Outage	02-Feb-2024	10:49	02-Feb-2024	11:25	36	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
26	02-Feb-2024	PARTS OF KALI MATA MANDIR, MASTER PROPERTY. BADLI	428	Other Outage	Planned Outage	02-Feb-2024	10:57	02-Feb-2024	16:57	360	0.00230	PLANNED OUTAGE
27	02-Feb-2024	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY BADLI	104	Other Outage	Planned Outage	02-Feb-2024	11:38	02-Feb-2024	14:38	180	0.00010	PLANNED OUTAGE
28	02-Feb-2024	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	35	Other Outage	Unplanned Outage	02-Feb-2024	13:49	02-Feb-2024	15:33	104	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
29	02-Feb-2024	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADLI	4065	Other Outage	Unplanned Outage	02-Feb-2024	14:30	02-Feb-2024	15:05	35	0.00034	INTERRUPTION DUE TO FAULT

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
30	02-Feb-2024	PART OF BIA PHASE 6 BADLI	3	250 kVA	Unplanned Outage	02-Feb-2024	15:44	02-Feb-2024	16:28	44	0.00001	EODB COMPLIANCE
31	02-Feb-2024	PART OF SHAHBAD DAIRY B - BLK BADLI	4	Other Outage	Unplanned Outage	02-Feb-2024	22:53	03-Feb-2024	00:59	126	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
32	03-Feb-2024	PARTS OF BADLI INDUSTRIAL AREA BADLI	40	Other Outage	Planned Outage	03-Feb-2024	10:19	03-Feb-2024	16:46	386	0.00118	PSD ON INDUSTRIAL WEEKLY OFF
33	03-Feb-2024	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA BADLI	200	Other Outage	Unplanned Outage	03-Feb-2024	10:43	03-Feb-2024	11:25	42	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
34	03-Feb-2024	PART OF YADAV NAGAR BADLI	13	400 kVA	Unplanned Outage	03-Feb-2024	13:21	03-Feb-2024	14:56	95	0.00003	EODB COMPLIANCE
35	03-Feb-2024	PARTS OF BADLI INDS. AREA PAHSE-2 & 5 BADLI	65	Other Outage	Unplanned Outage	03-Feb-2024	14:00	03-Feb-2024	16:20	140	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
36	03-Feb-2024	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY BADLI	3871	Other Outage	Unplanned Outage	03-Feb-2024	14:41	03-Feb-2024	15:35	54	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
37	03-Feb-2024	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY BADLI	1482	Other Outage	Unplanned Outage	03-Feb-2024	14:41	03-Feb-2024	15:55	73	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
38	03-Feb-2024	PARTS OF BADLI INDS. AREA PAHSE-2 & 5 BADLI	45	Other Outage	Unplanned Outage	03-Feb-2024	15:03	03-Feb-2024	16:31	88	0.00025	FORCE MAJEURE/EXTERNAL FACTORS
39	03-Feb-2024	PART OF AMAR JYOTI COLONY BADLI	6	100 kVA	Unplanned Outage	03-Feb-2024	15:34	03-Feb-2024	16:13	39	0.00001	EODB COMPLIANCE
40	04-Feb-2024	PARTS OF DJB-1 KHERA KHURD BADLI	829	Other Outage	Unplanned Outage	04-Feb-2024	11:55	04-Feb-2024	12:10	15	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
41	04-Feb-2024	PART OF DJB KHERA KHURD VILLAGE BADLI	11	Other Outage	Unplanned Outage	04-Feb-2024	11:55	04-Feb-2024	12:30	35	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
42	04-Feb-2024	PART OF BADLI INDUSTRIAL AREA BADLI	1	Other Outage	Unplanned Outage	04-Feb-2024	15:28	04-Feb-2024	16:40	72	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
43	04-Feb-2024	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6 JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD,66 FOOTA ROAD BADLI	453	Other Outage	Unplanned Outage	04-Feb-2024	20:10	04-Feb-2024	20:30	20	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
44	04-Feb-2024	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	73	Other Outage	Unplanned Outage	04-Feb-2024	21:42	04-Feb-2024	22:45	62	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
45	05-Feb-2024	PARTS OF BADLI INDS. AREA PAHSE-2 & 5 BADLI	65	Other Outage	Unplanned Outage	05-Feb-2024	08:45	05-Feb-2024	09:06	21	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
46	05-Feb-2024	PARTS OF BADLI INDS. AREA PAHSE-2 & 5 BADLI	45	Other Outage	Unplanned Outage	05-Feb-2024	09:30	05-Feb-2024	10:24	54	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
47	05-Feb-2024	PARTS OF PRAHLADPUR CHOWK BADLI	532	Other Outage	Planned Outage	05-Feb-2024	10:16	05-Feb-2024	16:30	374	0.00156	PLANNED OUTAGE
48	05-Feb-2024	PARTS OF SIRAS PUR GALI NO-7 BADLI	498	Other Outage	Planned Outage	05-Feb-2024	10:43	05-Feb-2024	15:17	274	0.00038	PLANNED OUTAGE
49	05-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	214	Other Outage	Planned Outage	05-Feb-2024	11:03	05-Feb-2024	15:05	242	0.00175	PLANNED OUTAGE
50	05-Feb-2024	PART OF KHERA KHLAN BADLI	13	Other Outage	Planned Outage	05-Feb-2024	11:27	05-Feb-2024	16:57	330	0.00046	PLANNED OUTAGE
51	05-Feb-2024	PART OF A- BLOCK SECTOR 34 BADLI	13	Other Outage	Planned Outage	05-Feb-2024	12:17	05-Feb-2024	13:48	91	0.00005	PLANNED OUTAGE
52	05-Feb-2024	PART OF BIA PHASE 6 BADLI	18	Other Outage	Unplanned Outage	05-Feb-2024	13:47	05-Feb-2024	14:44	57	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
53	05-Feb-2024	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	215	Other Outage	Unplanned Outage	05-Feb-2024	16:44	05-Feb-2024	17:42	58	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
54	05-Feb-2024	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	73	Other Outage	Unplanned Outage	05-Feb-2024	17:23	05-Feb-2024	18:17	54	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
55	06-Feb-2024	PARTS OF BADLI AND PARK WALA SAMAYPUR BADLI	96	Other Outage	Planned Outage	06-Feb-2024	10:16	06-Feb-2024	14:39	263	0.00015	PLANNED OUTAGE
56	06-Feb-2024	PART OF PRAHALADPUR INDUSTRIAL AREA BADLI	5	63 kVA	Planned Outage	06-Feb-2024	11:14	06-Feb-2024	17:40	386	0.00021	PLANNED OUTAGE
57	06-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	608	Other Outage	Planned Outage	06-Feb-2024	11:15	06-Feb-2024	16:23	308	0.00222	PLANNED OUTAGE
58	06-Feb-2024	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	850	Other Outage	Planned Outage	06-Feb-2024	12:06	06-Feb-2024	16:53	287	0.00072	PLANNED OUTAGE
59	06-Feb-2024	PARTS OF GALI NO-3 SAMAYPUR BADLI	548	Other Outage	Unplanned Outage	06-Feb-2024	12:32	06-Feb-2024	13:51	79	0.00022	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
60	06-Feb-2024	PARTS OF BADLI INDUSTRIAL AREA BADLI	23	Other Outage	Unplanned Outage	06-Feb-2024	15:13	06-Feb-2024	18:26	193	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
61	06-Feb-2024	PARTS OF AIR NAGLI, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	28	Other Outage	Unplanned Outage	06-Feb-2024	16:48	06-Feb-2024	17:47	59	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
62	06-Feb-2024	PART OF SHAHBAD DAIRY B - BLK BADLI	12	Other Outage	Unplanned Outage	06-Feb-2024	20:25	06-Feb-2024	21:55	90	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
63	07-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALI MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	659	Other Outage	Planned Outage	07-Feb-2024	10:25	07-Feb-2024	15:55	330	0.00064	PSD ON INDUSTRIAL WEEKLY OFF
64	07-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	314	Other Outage	Planned Outage	07-Feb-2024	11:32	07-Feb-2024	16:30	298	0.00124	PLANNED OUTAGE
65	07-Feb-2024	PART OF KANKER KHERA VILLAGE BADLI	7	Other Outage	Planned Outage	07-Feb-2024	11:56	07-Feb-2024	14:29	153	0.00008	PLANNED OUTAGE
66	07-Feb-2024	PART OF METRO VIHAR PH-2 BADLI	6	Other Outage	Unplanned Outage	07-Feb-2024	12:02	07-Feb-2024	18:20	378	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
67	07-Feb-2024	PART OF METRO VIHAR PH - 2 BADLI	2	Other Outage	Unplanned Outage	07-Feb-2024	12:09	07-Feb-2024	18:07	358	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
68	07-Feb-2024	PARTS OF GALI NO 9 SAMAYPUR BADLI	300	Other Outage	Unplanned Outage	07-Feb-2024	12:46	07-Feb-2024	13:07	21	0.00015	INTERRUPTION DUE TO FAULT
69	07-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	11	250 kVA	Unplanned Outage	07-Feb-2024	14:30	07-Feb-2024	15:15	45	0.00001	EODB COMPLIANCE
70	07-Feb-2024	PARTS OF GALI NO 9 SAMAYPUR BADLI	523	Other Outage	Unplanned Outage	07-Feb-2024	14:39	07-Feb-2024	15:01	22	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
71	07-Feb-2024	PART OF ALIPUR -4 BADLI	20	Other Outage	Unplanned Outage	07-Feb-2024	15:26	07-Feb-2024	15:55	29	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
72	08-Feb-2024	PARTS OF GALI NO 9 SAMAYPUR BADLI	154	Other Outage	Planned Outage	08-Feb-2024	10:15	08-Feb-2024	13:57	222	0.00074	PLANNED OUTAGE
73	08-Feb-2024	PARTS OF ESS NO -1 SAMAYPUR BADLI	36	Other Outage	Planned Outage	08-Feb-2024	10:30	08-Feb-2024	14:03	213	0.00089	PLANNED OUTAGE
74	08-Feb-2024	PART OF SURAJ PARK COLONY BADLI	2	Other Outage	Unplanned Outage	08-Feb-2024	10:36	08-Feb-2024	11:41	64	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
75	08-Feb-2024	PARTS OF SANNOOTH VILLAGE BADLI	703	Other Outage	Planned Outage	08-Feb-2024	10:37	08-Feb-2024	16:13	336	0.00065	PLANNED OUTAGE
76	08-Feb-2024	PART OF METRO VIHAR PH-2 BADLI	6	Other Outage	Unplanned Outage	08-Feb-2024	12:06	08-Feb-2024	14:00	114	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
77	08-Feb-2024	PART OF METRO VIHAR PH-2 BADLI	2	Other Outage	Unplanned Outage	08-Feb-2024	12:22	08-Feb-2024	13:47	85	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
78	08-Feb-2024	PART OF GALI NO-05 BADLI	11	315 kVA	Unplanned Outage	08-Feb-2024	12:30	08-Feb-2024	13:11	41	0.00001	EODB COMPLIANCE
79	08-Feb-2024	PART OF AMBEY GARDEN BADLI	9	Other Outage	Unplanned Outage	08-Feb-2024	13:02	08-Feb-2024	14:27	85	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
80	08-Feb-2024	PART OF PARK WALA BADLI	7	250 kVA	Unplanned Outage	08-Feb-2024	14:47	08-Feb-2024	15:49	62	0.00002	EODB COMPLIANCE
81	08-Feb-2024	PART OF SIRAS PUR VILLAGE. BADLI	17	Other Outage	Unplanned Outage	08-Feb-2024	15:10	08-Feb-2024	17:59	169	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
82	09-Feb-2024	PART OF DEEP VIHAR BADLI	18	Other Outage	Planned Outage	09-Feb-2024	10:46	09-Feb-2024	16:26	340	0.00057	PLANNED OUTAGE
83	09-Feb-2024	PARTS OF BUTTON FACTORY BADLI	343	630 kVA	Planned Outage	09-Feb-2024	11:05	09-Feb-2024	13:44	159	0.00022	PLANNED OUTAGE
84	09-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	6	160 kVA	Unplanned Outage	09-Feb-2024	11:58	09-Feb-2024	13:01	63	0.00002	EODB COMPLIANCE
85	09-Feb-2024	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	194	Other Outage	Unplanned Outage	09-Feb-2024	12:58	09-Feb-2024	13:25	27	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
86	09-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	130	Other Outage	Unplanned Outage	09-Feb-2024	14:17	09-Feb-2024	15:14	57	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
87	09-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	2	160 kVA	Unplanned Outage	09-Feb-2024	14:31	09-Feb-2024	15:29	58	0.00002	EODB COMPLIANCE
88	09-Feb-2024	PARTS OF METRO VIHAR HOLAMBI KHURD, BADLI	120	630 kVA	Planned Outage	09-Feb-2024	14:50	09-Feb-2024	16:00	70	0.00025	PLANNED OUTAGE
89	09-Feb-2024	PART OF DJB KHERA KHURD VILLAGE BADLI	2	Other Outage	Unplanned Outage	09-Feb-2024	17:30	09-Feb-2024	18:28	58	0.00003	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
90	09-Feb-2024	PART OF DJB KHERA KHURD VILLAGE BADLI	9	Other Outage	Unplanned Outage	09-Feb-2024	17:43	09-Feb-2024	18:28	46	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
91	10-Feb-2024	PART OF SAMAY PUR GALI NO.3 BADLI	4	400 kVA	Planned Outage	10-Feb-2024	10:09	10-Feb-2024	12:45	156	0.00009	PLANNED OUTAGE
92	10-Feb-2024	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND. BADLI	399	Other Outage	Planned Outage	10-Feb-2024	11:08	10-Feb-2024	13:19	131	0.00018	PLANNED OUTAGE
93	10-Feb-2024	PARTS OF POCKET C-2 ESS-6 AND A-BLOCK SECTOR-34 BADLI	53	Other Outage	Planned Outage	10-Feb-2024	11:20	10-Feb-2024	16:26	306	0.00068	PLANNED OUTAGE
94	10-Feb-2024	PARTS OF AIR NANGLI BADLI	415	Other Outage	Unplanned Outage	10-Feb-2024	12:33	10-Feb-2024	14:50	137	0.00095	FORCE MAJEURE/EXTERNAL FACTORS
95	10-Feb-2024	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	783	Other Outage	Unplanned Outage	10-Feb-2024	12:52	10-Feb-2024	13:35	43	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
96	10-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	1917	Other Outage	Unplanned Outage	10-Feb-2024	14:54	10-Feb-2024	16:26	91	0.00063	FORCE MAJEURE/EXTERNAL FACTORS
97	10-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	1784	Other Outage	Unplanned Outage	10-Feb-2024	14:54	10-Feb-2024	16:27	92	0.00090	FORCE MAJEURE/EXTERNAL FACTORS
98	10-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	706	Other Outage	Unplanned Outage	10-Feb-2024	14:54	10-Feb-2024	19:09	254	0.00106	FORCE MAJEURE/EXTERNAL FACTORS
99	10-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	452	Other Outage	Unplanned Outage	10-Feb-2024	14:54	10-Feb-2024	19:10	255	0.00177	FORCE MAJEURE/EXTERNAL FACTORS
100	10-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	10	400 kVA	Unplanned Outage	10-Feb-2024	16:05	10-Feb-2024	16:31	26	0.00001	EODB COMPLIANCE
101	12-Feb-2024	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	80	Other Outage	Unplanned Outage	12-Feb-2024	07:17	12-Feb-2024	07:43	26	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
102	12-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	15	400 kVA	Planned Outage	12-Feb-2024	10:12	12-Feb-2024	12:46	154	0.00009	PLANNED OUTAGE
103	12-Feb-2024	PARTS OF RAMA ENCLAVE, SAHAHBAD DULAT PUR, SAHAHBAD INDS.AREA. BADLI	158	Other Outage	Planned Outage	12-Feb-2024	10:43	12-Feb-2024	16:21	338	0.00019	PLANNED OUTAGE
104	12-Feb-2024	PARTS OF METRO VIHAR PH - 2, J. J. SLUM COLONY (HOLAMBI KALAN) BADLI	3750	Other Outage	Unplanned Outage	12-Feb-2024	11:22	12-Feb-2024	12:12	50	0.00042	FORCE MAJEURE/EXTERNAL FACTORS
105	12-Feb-2024	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	55	Other Outage	Unplanned Outage	12-Feb-2024	12:12	12-Feb-2024	14:12	120	0.00017	INTERRUPTION DUE TO FAULT
106	12-Feb-2024	PARTS OF RAM BABU SPD SAMAYPUR BADLI	448	Other Outage	Unplanned Outage	12-Feb-2024	16:07	12-Feb-2024	16:56	49	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
107	12-Feb-2024	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	1048	Other Outage	Unplanned Outage	12-Feb-2024	23:56	13-Feb-2024	00:10	14	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
108	12-Feb-2024	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	21	Other Outage	Unplanned Outage	12-Feb-2024	23:56	13-Feb-2024	00:30	34	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
109	12-Feb-2024	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA BADLI	23	Other Outage	Unplanned Outage	12-Feb-2024	23:56	13-Feb-2024	01:13	77	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
110	13-Feb-2024	PART OF RAM BABU SPD BADLI	11	400 kVA	Planned Outage	13-Feb-2024	10:31	13-Feb-2024	12:16	105	0.00009	PLANNED OUTAGE
111	13-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	224	Other Outage	Planned Outage	13-Feb-2024	10:32	13-Feb-2024	16:49	377	0.00042	PLANNED OUTAGE
112	13-Feb-2024	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY BADLI	76	Other Outage	Planned Outage	13-Feb-2024	10:40	13-Feb-2024	16:30	350	0.00019	PLANNED OUTAGE
113	13-Feb-2024	PART OF GALI NO-05 BADLI	6	315 kVA	Planned Outage	13-Feb-2024	12:27	13-Feb-2024	16:16	229	0.00019	PLANNED OUTAGE
114	13-Feb-2024	PART OF LIBASPUR BADLI	10	400 kVA	Planned Outage	13-Feb-2024	12:48	13-Feb-2024	15:50	182	0.00025	PLANNED OUTAGE
115	13-Feb-2024	PART OF YADAV NAGAR BADLI	2	250 kVA	Planned Outage	13-Feb-2024	14:07	13-Feb-2024	16:10	123	0.00003	PLANNED OUTAGE
116	13-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	1201	Other Outage	Unplanned Outage	13-Feb-2024	16:12	13-Feb-2024	17:06	54	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
117	13-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	104	Other Outage	Unplanned Outage	13-Feb-2024	16:12	13-Feb-2024	18:02	110	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
118	14-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	116	Other Outage	Unplanned Outage	14-Feb-2024	09:41	14-Feb-2024	10:26	45	0.00001	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
119	14-Feb-2024	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	783	Other Outage	Unplanned Outage	14-Feb-2024	10:52	14-Feb-2024	17:25	393	0.00076	FORCE MAJEURE/EXTERNAL FACTORS
120	14-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	50	Other Outage	Planned Outage	14-Feb-2024	11:04	14-Feb-2024	14:05	181	0.00025	PLANNED OUTAGE
121	14-Feb-2024	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	2917	Other Outage	Unplanned Outage	14-Feb-2024	13:46	14-Feb-2024	14:22	36	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
122	14-Feb-2024	PART OF ALIPUR -4 BADLI	1	Other Outage	Unplanned Outage	14-Feb-2024	13:46	14-Feb-2024	17:04	198	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
123	14-Feb-2024	PARTS OF GALI NO-3 SAMAYPUR BADLI	548	Other Outage	Unplanned Outage	14-Feb-2024	14:48	14-Feb-2024	15:12	24	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
124	14-Feb-2024	PARTS OF GALI NO-3 SAMAYPUR BADLI	302	Other Outage	Unplanned Outage	14-Feb-2024	15:32	14-Feb-2024	16:35	63	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
125	14-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	69	Other Outage	Unplanned Outage	14-Feb-2024	15:36	14-Feb-2024	17:55	139	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
126	14-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	1622	Other Outage	Unplanned Outage	14-Feb-2024	17:15	14-Feb-2024	17:55	40	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
127	14-Feb-2024	PARTS OF SANNOOTH VILLAGE BADLI	5294	Other Outage	Unplanned Outage	14-Feb-2024	19:05	14-Feb-2024	19:47	41	0.00172	FORCE MAJEURE/EXTERNAL FACTORS
128	14-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	171	Other Outage	Unplanned Outage	14-Feb-2024	21:29	14-Feb-2024	23:20	111	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
129	15-Feb-2024	PARTS OF GALI NO-23 LIBAS PUR, PART OF E BLK YADAV NGR, PART OF MAIN ROAD SIRASPUR LIBAS PUR BADLI	30	400 kVA	Planned Outage	15-Feb-2024	10:00	15-Feb-2024	12:50	170	0.00024	PLANNED OUTAGE
130	15-Feb-2024	PART OF KHERA KHURD VILLAGE BADLI	1	Other Outage	Planned Outage	15-Feb-2024	10:27	15-Feb-2024	16:52	385	0.00032	PLANNED OUTAGE
131	15-Feb-2024	PART OF YADAV NAGAR BADLI	9	400 kVA	Planned Outage	15-Feb-2024	10:36	15-Feb-2024	13:16	160	0.00013	PLANNED OUTAGE
132	15-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	326	Other Outage	Planned Outage	15-Feb-2024	10:47	15-Feb-2024	15:57	310	0.00129	PLANNED OUTAGE
133	15-Feb-2024	PART OF SULMS QUARTER SHAHABAD DAIRY BADLI	15	Other Outage	Unplanned Outage	15-Feb-2024	11:24	15-Feb-2024	12:26	62	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
134	15-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	15	315 kVA	Unplanned Outage	15-Feb-2024	11:46	15-Feb-2024	12:24	38	0.00001	EODB COMPLIANCE
135	15-Feb-2024	PART OF BHAGWANPURA JJ CLUSTER SAMAYPUR BADLI	1	315 kVA	Planned Outage	15-Feb-2024	12:30	15-Feb-2024	16:00	210	0.00012	PLANNED OUTAGE
136	15-Feb-2024	PART OF YADAV NAGAR BADLI	13	400 kVA	Planned Outage	15-Feb-2024	13:26	15-Feb-2024	16:21	175	0.00049	PLANNED OUTAGE
137	15-Feb-2024	PART OF YADAV NAGAR BADLI	13	400 kVA	Planned Outage	15-Feb-2024	13:29	15-Feb-2024	16:02	153	0.00026	PLANNED OUTAGE
138	15-Feb-2024	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	680	Other Outage	Unplanned Outage	15-Feb-2024	14:25	15-Feb-2024	14:58	33	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
139	15-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	2147	Other Outage	Unplanned Outage	15-Feb-2024	17:37	15-Feb-2024	18:23	46	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
140	15-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	343	Other Outage	Unplanned Outage	15-Feb-2024	17:37	15-Feb-2024	18:29	52	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
141	15-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	324	Other Outage	Unplanned Outage	15-Feb-2024	17:37	15-Feb-2024	18:30	53	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
142	15-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	194	Other Outage	Unplanned Outage	15-Feb-2024	17:48	15-Feb-2024	18:31	43	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
143	15-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	312	Other Outage	Unplanned Outage	15-Feb-2024	17:48	15-Feb-2024	18:31	43	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
144	16-Feb-2024	PARTS OF MTNL, BIA PHASE I & PRAHLADPUR BADLI	54	Other Outage	Unplanned Outage	16-Feb-2024	08:07	16-Feb-2024	08:30	23	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
145	16-Feb-2024	PART OF DDA COMMAND TANK BADLI	1	Other Outage	Planned Outage	16-Feb-2024	10:30	16-Feb-2024	14:39	249	0.00007	EODB COMPLIANCE
146	16-Feb-2024	PARTS OF AIR NAGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	730	Other Outage	Planned Outage	16-Feb-2024	11:08	16-Feb-2024	16:07	299	0.00058	PLANNED OUTAGE
147	16-Feb-2024	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR. BADLI	134	Other Outage	Planned Outage	16-Feb-2024	11:42	16-Feb-2024	15:12	210	0.00018	PLANNED OUTAGE
148	16-Feb-2024	PARTS OF ESS NO -1 SAMAYPUR BADLI	189	Other Outage	Unplanned Outage	16-Feb-2024	18:37	16-Feb-2024	19:20	44	0.00024	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
149	17-Feb-2024	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	25	Other Outage	Planned Outage	17-Feb-2024	10:02	17-Feb-2024	16:22	380	0.00053	PSD ON INDUSTRIAL WEEKLY OFF
150	17-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	52	Other Outage	Planned Outage	17-Feb-2024	10:47	17-Feb-2024	16:20	333	0.00102	PSD ON INDUSTRIAL WEEKLY OFF
151	17-Feb-2024	PART OF METRO VIHAR PH-2 BADLI	1	Other Outage	Planned Outage	17-Feb-2024	11:59	17-Feb-2024	16:40	281	0.00008	PLANNED OUTAGE
152	17-Feb-2024	PART OF S. P. S. DDA SECTOR - 25 BADLI	5	Other Outage	Unplanned Outage	17-Feb-2024	13:58	17-Feb-2024	15:08	70	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
153	17-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	21	Other Outage	Unplanned Outage	17-Feb-2024	13:58	17-Feb-2024	14:42	44	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
154	17-Feb-2024	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION BADLI	1757	Other Outage	Unplanned Outage	17-Feb-2024	16:44	17-Feb-2024	17:05	21	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
155	18-Feb-2024	PARTS OF JINDAL NIRYAT SEC-28 BADLI	336	Other Outage	Unplanned Outage	18-Feb-2024	14:25	18-Feb-2024	15:05	40	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
156	18-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	389	Other Outage	Unplanned Outage	18-Feb-2024	22:41	19-Feb-2024	00:25	104	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
157	18-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	700	Other Outage	Unplanned Outage	18-Feb-2024	22:45	19-Feb-2024	00:15	90	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
158	18-Feb-2024	PARTS OF AIR NANGLI BADLI	103	Other Outage	Unplanned Outage	18-Feb-2024	23:44	19-Feb-2024	00:30	46	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
159	19-Feb-2024	PART OF ALIPUR -4 BADLI	1	Other Outage	Planned Outage	19-Feb-2024	09:29	19-Feb-2024	17:36	487	0.00014	PLANNED OUTAGE
160	19-Feb-2024	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY BADLI	2407	Other Outage	Unplanned Outage	19-Feb-2024	10:38	19-Feb-2024	11:19	40	0.00045	FORCE MAJEURE/EXTERNAL FACTORS
161	19-Feb-2024	PART OF S. P. S. DDA SECTOR - 25 BADLI	17	Other Outage	Unplanned Outage	19-Feb-2024	10:40	19-Feb-2024	11:36	56	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
162	19-Feb-2024	PARTS OF PRAHLADPUR CHOWK BADLI	249	630 kVA	Planned Outage	19-Feb-2024	11:04	19-Feb-2024	14:53	229	0.00032	PLANNED OUTAGE
163	19-Feb-2024	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR. BADLI	173	Other Outage	Planned Outage	19-Feb-2024	11:08	19-Feb-2024	15:30	262	0.00029	PLANNED OUTAGE
164	19-Feb-2024	PARTS OF PRAHLADPUR CHOWK BADLI	532	Other Outage	Unplanned Outage	19-Feb-2024	11:35	19-Feb-2024	12:00	25	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
165	19-Feb-2024	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD. BADLI	1484	Other Outage	Unplanned Outage	19-Feb-2024	11:40	19-Feb-2024	12:30	50	0.00055	FORCE MAJEURE/EXTERNAL FACTORS
166	19-Feb-2024	PART OF KANKER KHERA VILLAGE BADLI	1	Other Outage	Planned Outage	19-Feb-2024	11:56	19-Feb-2024	16:06	250	0.00014	EODB COMPLIANCE
167	19-Feb-2024	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION BADLI	149	Other Outage	Unplanned Outage	19-Feb-2024	12:16	19-Feb-2024	12:49	33	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
168	19-Feb-2024	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION BADLI	1757	Other Outage	Unplanned Outage	19-Feb-2024	12:16	19-Feb-2024	12:34	18	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
169	19-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	489	Other Outage	Unplanned Outage	19-Feb-2024	12:35	19-Feb-2024	13:15	40	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
170	19-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	130	Other Outage	Unplanned Outage	19-Feb-2024	12:38	19-Feb-2024	14:15	97	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
171	19-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	697	Other Outage	Unplanned Outage	19-Feb-2024	13:58	19-Feb-2024	16:05	127	0.00035	FORCE MAJEURE/EXTERNAL FACTORS
172	19-Feb-2024	PART OF KHADDA BASTI BADLI	1	63 kVA	Unplanned Outage	19-Feb-2024	16:13	19-Feb-2024	17:16	63	0.00002	EODB COMPLIANCE
173	19-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	226	Other Outage	Unplanned Outage	19-Feb-2024	16:15	19-Feb-2024	18:14	119	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
174	19-Feb-2024	PARTS OF SURAJ PARK, PART OF BIA PHASE I BADLI	55	Other Outage	Unplanned Outage	19-Feb-2024	16:27	19-Feb-2024	17:09	43	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
175	19-Feb-2024	PARTS OF NEHRU ENCLAVE BADLI	986	Other Outage	Unplanned Outage	19-Feb-2024	19:05	19-Feb-2024	19:50	45	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
176	20-Feb-2024	PARTS OF KRISHAN COLONY BADLI	1457	Other Outage	Unplanned Outage	20-Feb-2024	02:56	20-Feb-2024	03:15	19	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
177	20-Feb-2024	PARTS OF LIG SEC-28 BADLI	1824	Other Outage	Unplanned Outage	20-Feb-2024	04:10	20-Feb-2024	04:24	14	0.00008	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
178	20-Feb-2024	PARTS OF AIR NANGLI BADLI	210	Other Outage	Unplanned Outage	20-Feb-2024	07:44	20-Feb-2024	08:47	64	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
179	20-Feb-2024	PART OF KANKER KHERA VILLAGE BADLI	1	Other Outage	Planned Outage	20-Feb-2024	11:45	20-Feb-2024	14:34	169	0.00005	EODB COMPLIANCE
180	21-Feb-2024	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	1810	Other Outage	Unplanned Outage	21-Feb-2024	09:45	21-Feb-2024	10:20	35	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
181	21-Feb-2024	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	332	Other Outage	Unplanned Outage	21-Feb-2024	09:45	21-Feb-2024	10:40	55	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
182	21-Feb-2024	PART OF BIA PHASE 6 BADLI	17	Other Outage	Planned Outage	21-Feb-2024	10:38	21-Feb-2024	17:52	434	0.00036	PLANNED OUTAGE
183	21-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	354	Other Outage	Unplanned Outage	21-Feb-2024	10:46	21-Feb-2024	18:12	446	0.00124	FORCE MAJEURE/EXTERNAL FACTORS
184	21-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	57	Other Outage	Unplanned Outage	21-Feb-2024	11:06	21-Feb-2024	18:17	431	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
185	21-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	134	Other Outage	Unplanned Outage	21-Feb-2024	11:14	21-Feb-2024	18:05	411	0.00114	FORCE MAJEURE/EXTERNAL FACTORS
186	21-Feb-2024	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE BADLI	513	Other Outage	Planned Outage	21-Feb-2024	11:46	21-Feb-2024	15:36	230	0.00166	PLANNED OUTAGE
187	21-Feb-2024	PART OF BIA PHASE 6 BADLI	3	400 kVA	Planned Outage	21-Feb-2024	12:00	21-Feb-2024	16:04	244	0.00014	PLANNED OUTAGE
188	21-Feb-2024	PARTS OF AIR NANGLI, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD,NEW BADLI	87	Other Outage	Unplanned Outage	21-Feb-2024	13:02	21-Feb-2024	13:40	38	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
189	21-Feb-2024	PART OF YADAV NAGAR BADLI	13	400 kVA	Unplanned Outage	21-Feb-2024	14:47	21-Feb-2024	15:31	44	0.00001	EODB COMPLIANCE
190	21-Feb-2024	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	68	Other Outage	Unplanned Outage	21-Feb-2024	15:44	21-Feb-2024	17:25	101	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
191	21-Feb-2024	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	466	Other Outage	Unplanned Outage	21-Feb-2024	15:52	21-Feb-2024	17:25	93	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
192	22-Feb-2024	PARTS OF RAM BABU SPD SAMAYPUR BADLI	444	Other Outage	Unplanned Outage	22-Feb-2024	09:26	22-Feb-2024	10:05	39	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
193	22-Feb-2024	PARTS OF GIVAN PARK SIRASPUR, PART OF BAGHAT SINGH PARK, PART OF SIRASPUR VILLAGE. BADLI	23	400 kVA	Planned Outage	22-Feb-2024	09:42	22-Feb-2024	12:45	183	0.00061	PLANNED OUTAGE
194	22-Feb-2024	PART OF BHAGWANPURA JJ CLUSTER SAMAYPUR BADLI	9	Other Outage	Unplanned Outage	22-Feb-2024	10:17	22-Feb-2024	11:55	98	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
195	22-Feb-2024	PART OF LIBASPUR BADLI	13	400 kVA	Planned Outage	22-Feb-2024	10:24	22-Feb-2024	13:00	156	0.00009	PLANNED OUTAGE
196	22-Feb-2024	PARTS OF SEC 28 PRAHLADPUR BADLI	200	Other Outage	Planned Outage	22-Feb-2024	10:37	22-Feb-2024	15:50	313	0.00070	PLANNED OUTAGE
197	22-Feb-2024	PART OF SIRAS PUR VILLAGE. BADLI	6	400 kVA	Unplanned Outage	22-Feb-2024	12:09	22-Feb-2024	12:55	46	0.00001	EODB COMPLIANCE
198	22-Feb-2024	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY BADLI	2303	Other Outage	Unplanned Outage	22-Feb-2024	12:53	22-Feb-2024	13:23	29	0.00049	FORCE MAJEURE/EXTERNAL FACTORS
199	22-Feb-2024	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY BADLI	104	Other Outage	Unplanned Outage	22-Feb-2024	12:53	22-Feb-2024	13:57	63	0.00035	FORCE MAJEURE/EXTERNAL FACTORS
200	22-Feb-2024	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	27	400 kVA	Planned Outage	22-Feb-2024	13:14	22-Feb-2024	15:43	149	0.00008	PLANNED OUTAGE
201	22-Feb-2024	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA, BADLI	27	315 kVA	Planned Outage	22-Feb-2024	13:25	22-Feb-2024	16:04	159	0.00009	PLANNED OUTAGE
202	22-Feb-2024	PART OF YADAV NAGAR BADLI	6	250 kVA	Unplanned Outage	22-Feb-2024	14:22	22-Feb-2024	15:15	53	0.00001	EODB COMPLIANCE
203	23-Feb-2024	PARTS OF RAM BABU SPD SAMAYPUR BADLI	133	Other Outage	Unplanned Outage	23-Feb-2024	08:25	23-Feb-2024	09:03	38	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
204	23-Feb-2024	PARTS OF ESS NO -1 SAMAYPUR BADLI	189	Other Outage	Unplanned Outage	23-Feb-2024	09:14	23-Feb-2024	10:24	70	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
205	23-Feb-2024	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA, BADLI	189	Other Outage	Unplanned Outage	23-Feb-2024	09:24	23-Feb-2024	10:16	52	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
206	23-Feb-2024	PART OF RAM BABU SPD BADLI	6	400 kVA	Planned Outage	23-Feb-2024	09:28	23-Feb-2024	12:25	177	0.00005	PLANNED OUTAGE
207	23-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	106	Other Outage	Unplanned Outage	23-Feb-2024	09:37	23-Feb-2024	09:55	19	0.00001	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
208	23-Feb-2024	PARTS OF GALI NO 9 SAMAYPUR BADLI	534	Other Outage	Unplanned Outage	23-Feb-2024	09:44	23-Feb-2024	10:15	31	0.00004	INTERRUPTION DUE TO FAULT
209	23-Feb-2024	PARTS OF KRISHAN COLONY BADLI	1457	Other Outage	Unplanned Outage	23-Feb-2024	09:49	23-Feb-2024	11:35	106	0.00044	FORCE MAJEURE/EXTERNAL FACTORS
210	23-Feb-2024	PART OF RAM BABU SPD BADLI	9	400 kVA	Planned Outage	23-Feb-2024	09:58	23-Feb-2024	12:35	157	0.00009	PLANNED OUTAGE
211	23-Feb-2024	PARTS OF POCKET C-2 ESS-6 AND A-BLOCK SECTOR-34 BADLI	53	Other Outage	Unplanned Outage	23-Feb-2024	11:29	23-Feb-2024	13:17	108	0.00045	FORCE MAJEURE/EXTERNAL FACTORS
212	23-Feb-2024	PARTS OF GALI NO 9 SAMAYPUR BADLI	364	Other Outage	Unplanned Outage	23-Feb-2024	11:32	23-Feb-2024	11:45	13	0.00001	INTERRUPTION DUE TO FAULT
213	23-Feb-2024	PART OF PRAHLADPUR VILLAGE BADLI	2	250 kVA	Planned Outage	23-Feb-2024	12:23	23-Feb-2024	15:30	187	0.00010	PLANNED OUTAGE
214	23-Feb-2024	PART OF RAM BABU SPD BADLI	9	400 kVA	Planned Outage	23-Feb-2024	12:50	23-Feb-2024	15:44	174	0.00015	PLANNED OUTAGE
215	23-Feb-2024	PART OF SANJAY GANDHI PHASE-2 BADLI	10	250 kVA	Unplanned Outage	23-Feb-2024	13:03	23-Feb-2024	14:18	75	0.00002	EODB COMPLIANCE
216	23-Feb-2024	PARTS OF RAM BABU SPD SAMAYPUR BADLI	43	400 kVA	Planned Outage	23-Feb-2024	13:14	23-Feb-2024	16:01	167	0.00009	PLANNED OUTAGE
217	23-Feb-2024	PART OF RAM BABU SPD BADLI	9	400 kVA	Unplanned Outage	23-Feb-2024	14:50	23-Feb-2024	15:31	41	0.00001	EODB COMPLIANCE
218	24-Feb-2024	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	67	630 kVA	Planned Outage	24-Feb-2024	10:03	24-Feb-2024	12:59	176	0.00015	PLANNED OUTAGE
219	24-Feb-2024	PART OF ESS NO -1 ONLY BADLI	10	315 kVA	Planned Outage	24-Feb-2024	10:17	24-Feb-2024	13:08	171	0.00009	PLANNED OUTAGE
220	24-Feb-2024	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING BADLI	178	Other Outage	Planned Outage	24-Feb-2024	10:30	24-Feb-2024	17:16	406	0.00056	PLANNED OUTAGE
221	24-Feb-2024	PARTS OF BADLI INDS. AREA PAHSE-2 & 5 BADLI	26	Other Outage	Planned Outage	24-Feb-2024	10:39	24-Feb-2024	16:44	365	0.00020	PSD ON INDUSTRIAL WEEKLY OFF
222	24-Feb-2024	PARTS OF MTNL, BIA PHASE I & PRAHLADPUR BADLI	54	Other Outage	Planned Outage	24-Feb-2024	10:59	24-Feb-2024	16:45	346	0.00106	PSD ON INDUSTRIAL WEEKLY OFF
223	24-Feb-2024	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE BADLI	81	630 kVA	Planned Outage	24-Feb-2024	13:20	24-Feb-2024	16:08	168	0.00009	PLANNED OUTAGE
224	24-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	122	Other Outage	Unplanned Outage	24-Feb-2024	16:26	24-Feb-2024	16:55	28	0.00152	FORCE MAJEURE/EXTERNAL FACTORS
225	24-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	23	Other Outage	Unplanned Outage	24-Feb-2024	16:26	24-Feb-2024	17:25	58	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
226	24-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	110	Other Outage	Unplanned Outage	24-Feb-2024	16:26	24-Feb-2024	17:26	59	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
227	24-Feb-2024	PARTS OF AIR NANGLI BADLI	2272	Other Outage	Unplanned Outage	24-Feb-2024	16:32	24-Feb-2024	17:10	37	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
228	24-Feb-2024	PART OF AIR NANGLI BADLI	19	Other Outage	Unplanned Outage	24-Feb-2024	16:38	25-Feb-2024	15:00	1341	0.00075	FORCE MAJEURE/EXTERNAL FACTORS
229	24-Feb-2024	PARTS OF AIR NANGLI BADLI	75	Other Outage	Unplanned Outage	24-Feb-2024	16:38	24-Feb-2024	18:40	121	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
230	24-Feb-2024	PARTS OF AIR NANGLI BADLI	286	Other Outage	Unplanned Outage	24-Feb-2024	16:38	24-Feb-2024	20:55	256	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
231	25-Feb-2024	PART OF SULMS QUARTER SHAHABAD DAIRY BADLI	15	Other Outage	Unplanned Outage	25-Feb-2024	08:59	25-Feb-2024	09:43	44	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
232	25-Feb-2024	PARTS OF AIR NANGLI BADLI	361	Other Outage	Unplanned Outage	25-Feb-2024	14:16	25-Feb-2024	15:00	44	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
233	25-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	389	Other Outage	Unplanned Outage	25-Feb-2024	15:02	25-Feb-2024	16:18	75	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
234	25-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	2941	Other Outage	Unplanned Outage	25-Feb-2024	15:02	25-Feb-2024	16:25	83	0.00069	FORCE MAJEURE/EXTERNAL FACTORS
235	25-Feb-2024	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	1375	Other Outage	Unplanned Outage	25-Feb-2024	15:49	25-Feb-2024	16:47	57	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
236	26-Feb-2024	PART OF ALIPUR -4 BADLI	3	Other Outage	Unplanned Outage	26-Feb-2024	01:36	26-Feb-2024	03:24	108	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
237	26-Feb-2024	PART OF AMBEY GARDEN BADLI	13	400 kVA	Planned Outage	26-Feb-2024	09:54	26-Feb-2024	12:25	151	0.00008	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
238	26-Feb-2024	PART OF SANNOOTH VILLAGE BADLI	6	Other Outage	Planned Outage	26-Feb-2024	10:26	26-Feb-2024	17:04	398	0.00011	PLANNED OUTAGE
239	26-Feb-2024	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK BADLI	86	630 kVA	Planned Outage	26-Feb-2024	11:09	26-Feb-2024	13:35	146	0.00065	PLANNED OUTAGE
240	26-Feb-2024	PARTS OF 560 HIGSEC-29 BADLI	90	630 kVA	Planned Outage	26-Feb-2024	11:34	26-Feb-2024	12:40	66	0.00020	PLANNED OUTAGE
241	26-Feb-2024	PARTS OF KALI MATA MANDIR, MASTER PROPERTY. BADLI	707	Other Outage	Planned Outage	26-Feb-2024	11:35	26-Feb-2024	14:02	147	0.00061	PLANNED OUTAGE
242	26-Feb-2024	PARTS OF AIR NANGI, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	112	Other Outage	Unplanned Outage	26-Feb-2024	12:44	26-Feb-2024	13:15	31	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
243	26-Feb-2024	PARTS OF BADLI AND PARK WALA SAMAYPUR BADLI	22	630 kVA	Planned Outage	26-Feb-2024	12:56	26-Feb-2024	15:40	164	0.00046	PLANNED OUTAGE
244	26-Feb-2024	PART OF BHAGWANPURA JJ CLUSTER SAMAYPUR BADLI	1	315 kVA	Planned Outage	26-Feb-2024	13:28	26-Feb-2024	15:57	149	0.00004	PLANNED OUTAGE
245	26-Feb-2024	PARTS OF 560 HIGSEC-29 BADLI	164	630 kVA	Planned Outage	26-Feb-2024	14:11	26-Feb-2024	15:42	91	0.00066	PLANNED OUTAGE
246	26-Feb-2024	PARTS OF PRAHLADPUR CHOWK BADLI	484	Other Outage	Unplanned Outage	26-Feb-2024	14:14	26-Feb-2024	17:30	196	0.00082	FORCE MAJEURE/EXTERNAL FACTORS
247	26-Feb-2024	PARTS OF AIR NANGLI BADLI	2105	Other Outage	Unplanned Outage	26-Feb-2024	16:07	26-Feb-2024	17:00	52	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
248	26-Feb-2024	PARTS OF AG, AW BLOCK SGT NAGAR BADLI	210	Other Outage	Unplanned Outage	26-Feb-2024	23:19	27-Feb-2024	00:53	94	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
249	26-Feb-2024	PARTS OF AG, AW BLOCK SGT NAGAR BADLI	380	Other Outage	Unplanned Outage	26-Feb-2024	23:19	27-Feb-2024	00:54	95	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
250	26-Feb-2024	PARTS OF AG, AW BLOCK SGT NAGAR BADLI	313	Other Outage	Unplanned Outage	26-Feb-2024	23:19	27-Feb-2024	00:55	96	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
251	27-Feb-2024	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6 JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD BADLI	405	Other Outage	Unplanned Outage	27-Feb-2024	09:10	27-Feb-2024	09:20	10	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
252	27-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	79	Other Outage	Unplanned Outage	27-Feb-2024	09:16	27-Feb-2024	09:45	30	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
253	27-Feb-2024	PARTS OF BIA PHASE I AND PHASE 2 BADLI	27	Other Outage	Unplanned Outage	27-Feb-2024	09:16	27-Feb-2024	09:45	30	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
254	27-Feb-2024	PARTS OF BADLI AND PARK WALA SAMAYPUR BADLI	96	Other Outage	Planned Outage	27-Feb-2024	10:07	27-Feb-2024	16:39	392	0.00033	PLANNED OUTAGE
255	27-Feb-2024	PARTS OF BUTTON FACTORY BADLI	393	630 kVA	Planned Outage	27-Feb-2024	10:20	27-Feb-2024	13:49	209	0.00029	PLANNED OUTAGE
256	27-Feb-2024	PARTS OF BARWALA VILLAGE, PAPPU COLONY, SRI ENCLAVE, DEEP VIHAR, DRISHNA COLONY, PRAHLAD VIHAR. BADLI	813	Other Outage	Planned Outage	27-Feb-2024	10:41	27-Feb-2024	16:28	347	0.00116	PLANNED OUTAGE
257	27-Feb-2024	PART OF SHAHBAD DAIRY B-BLOCK BADLI	10	Other Outage	Unplanned Outage	27-Feb-2024	11:59	27-Feb-2024	13:34	95	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
258	27-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	2644	Other Outage	Unplanned Outage	27-Feb-2024	12:11	27-Feb-2024	12:59	47	0.00079	FORCE MAJEURE/EXTERNAL FACTORS
259	27-Feb-2024	PARTS OF GALI NO. 14 SIRASPUR, DEEPAK DALL MILL SIRASPUR, SIRASPUR-2 (TALAB WALA) BADLI	134	Other Outage	Unplanned Outage	27-Feb-2024	12:11	27-Feb-2024	13:28	76	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
260	27-Feb-2024	PARTS OF AIR NANGI, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW BADLI	114	Other Outage	Unplanned Outage	27-Feb-2024	12:49	27-Feb-2024	13:56	67	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
261	28-Feb-2024	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA, BADLI	199	Other Outage	Planned Outage	28-Feb-2024	10:12	28-Feb-2024	16:52	400	0.00056	PSD ON INDUSTRIAL WEEKLY OFF
262	28-Feb-2024	PARTS OF BADLI INDUSTRIAL AREA BADLI	23	Other Outage	Unplanned Outage	28-Feb-2024	10:41	28-Feb-2024	11:10	29	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
263	28-Feb-2024	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 BADLI	505	Other Outage	Planned Outage	28-Feb-2024	10:49	28-Feb-2024	17:26	397	0.00287	PLANNED OUTAGE
264	28-Feb-2024	PARTS OF PKT 4 SEC-34 BADLI	53	Other Outage	Planned Outage	28-Feb-2024	11:06	28-Feb-2024	17:49	403	0.00123	PLANNED OUTAGE
265	28-Feb-2024	PARTS OF RAM BABU SPD SAMAYPUR BADLI	450	Other Outage	Unplanned Outage	28-Feb-2024	12:04	28-Feb-2024	13:32	87	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
266	28-Feb-2024	PART OF JINDAL NIRYAT BADLI	7	Other Outage	Unplanned Outage	28-Feb-2024	12:07	28-Feb-2024	16:50	283	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
267	28-Feb-2024	PART OF AMBEY GARDEN BADLI	11	160 kVA	Unplanned Outage	28-Feb-2024	12:45	28-Feb-2024	13:27	42	0.00001	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
268	28-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	6	100 kVA	Unplanned Outage	28-Feb-2024	14:13	28-Feb-2024	15:46	93	0.00003	EODB COMPLIANCE
269	28-Feb-2024	PART OF GALI NO 9 SAMAYPUR BADLI	5	315 kVA	Unplanned Outage	28-Feb-2024	15:04	28-Feb-2024	15:45	41	0.00001	EODB COMPLIANCE
270	29-Feb-2024	PARTS OF APPOLO CONVENT SCHOOL, SHIV MANDIR , NURSERY WALA NO-2, MAAN PUBLIC SCHOOL NO-2 BADLI	386	Other Outage	Planned Outage	29-Feb-2024	10:20	29-Feb-2024	17:07	407	0.00079	PLANNED OUTAGE
271	29-Feb-2024	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY BADLI	73	Other Outage	Planned Outage	29-Feb-2024	10:41	29-Feb-2024	16:33	352	0.00108	PLANNED OUTAGE
272	29-Feb-2024	PARTS OF POCKET B-3 ESS-1 SECT-35 PRAHLADPUR BADLI	445	Other Outage	Planned Outage	29-Feb-2024	11:22	29-Feb-2024	16:33	311	0.00043	PLANNED OUTAGE
273	29-Feb-2024	PART OF JINDAL NIRYAT BADLI	7	Other Outage	Unplanned Outage	29-Feb-2024	11:50	29-Feb-2024	13:31	101	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
274	29-Feb-2024	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE. BADLI	365	Other Outage	Unplanned Outage	29-Feb-2024	12:05	29-Feb-2024	12:38	33	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
275	29-Feb-2024	PART OF SHAHBAD DAIRY B-BLOCK BADLI	10	Other Outage	Unplanned Outage	29-Feb-2024	19:28	29-Feb-2024	21:20	111	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
BAWANA												
1	01-Feb-2024	PARTS OF G BLK SEC-02 POOTH KHURD BAWANA	81	Other Outage	Unplanned Outage	01-Feb-2024	02:53	01-Feb-2024	03:35	41	0.00078	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF DJB RAW WATER PUMP HOUSE BAWANA	313	Other Outage	Unplanned Outage	01-Feb-2024	03:52	01-Feb-2024	05:10	77	0.00296	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF FG BLOCK SEC-3 DSIDC BAWANA	179	Other Outage	Unplanned Outage	01-Feb-2024	06:01	01-Feb-2024	06:32	31	0.00059	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF LM BLOCK SEC-3 DSIDC BAWANA	76	Other Outage	Unplanned Outage	01-Feb-2024	07:43	01-Feb-2024	08:30	47	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF B BLOCK SEC-4 POOTH KHURD BAWANA	87	Other Outage	Unplanned Outage	01-Feb-2024	09:28	01-Feb-2024	14:16	288	0.00120	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PART OF PUNJAB KHOD BAWANA	2	Other Outage	Unplanned Outage	01-Feb-2024	09:45	01-Feb-2024	11:23	98	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF O BLOCK SEC-1 POOTH KHURD BAWANA	236	Other Outage	Unplanned Outage	01-Feb-2024	10:05	01-Feb-2024	10:21	16	0.00133	FORCE MAJEURE/EXTERNAL FACTORS
8	01-Feb-2024	PARTS OF O BLOCK SEC-1 POOTH KHURD BAWANA	151	Other Outage	Unplanned Outage	01-Feb-2024	10:05	01-Feb-2024	10:22	17	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
9	01-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	Other Outage	Unplanned Outage	01-Feb-2024	10:40	01-Feb-2024	13:05	145	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
10	01-Feb-2024	PART OF DIVYA JYOTI APPARTMENT BAWANA	2	Other Outage	Planned Outage	01-Feb-2024	10:58	01-Feb-2024	15:45	287	0.00016	PLANNED OUTAGE
11	01-Feb-2024	PART OF F-167 SEC-2 DSIDC BAWANA	6	Other Outage	Unplanned Outage	01-Feb-2024	11:00	01-Feb-2024	14:51	231	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
12	01-Feb-2024	PART OF TUBEWELL NO - 1322 BAWANA	6	315 kVA	Unplanned Outage	01-Feb-2024	11:03	01-Feb-2024	11:39	36	0.00001	EODB COMPLIANCE
13	01-Feb-2024	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	31	Other Outage	Planned Outage	01-Feb-2024	11:12	01-Feb-2024	15:51	279	0.00070	PLANNED OUTAGE
14	01-Feb-2024	PART OF I BLK SEC-1 BAWANA	7	315 kVA	Unplanned Outage	01-Feb-2024	11:12	01-Feb-2024	12:14	62	0.00002	EODB COMPLIANCE
15	01-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	4	250 kVA	Unplanned Outage	01-Feb-2024	11:35	01-Feb-2024	12:55	80	0.00002	EODB COMPLIANCE
16	01-Feb-2024	PART OF I BLK SEC-5 BAWANA	6	Other Outage	Unplanned Outage	01-Feb-2024	12:15	01-Feb-2024	12:35	20	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
17	01-Feb-2024	PART OF TUBEWELL NO - 1322 BAWANA	5	315 kVA	Unplanned Outage	01-Feb-2024	12:38	01-Feb-2024	13:29	51	0.00001	EODB COMPLIANCE
18	01-Feb-2024	PARTS OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	276	Other Outage	Unplanned Outage	01-Feb-2024	12:48	01-Feb-2024	13:30	42	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
19	01-Feb-2024	PARTS OF M-BLOCK SEC-2 POOTH KHURD BAWANA	218	Other Outage	Unplanned Outage	01-Feb-2024	13:08	01-Feb-2024	13:50	41	0.00040	FORCE MAJEURE/EXTERNAL FACTORS
20	01-Feb-2024	PARTS OF B BLOCK SEC-4 POOTH KHURD BAWANA	220	Other Outage	Unplanned Outage	01-Feb-2024	13:45	01-Feb-2024	14:15	30	0.00029	INTERRUPTION DUE TO FAULT
21	01-Feb-2024	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	01-Feb-2024	14:18	01-Feb-2024	14:35	17	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
22	01-Feb-2024	PART OF M BLOCK SEC-3 DSIDC BAWANA	9	400 kVA	Unplanned Outage	01-Feb-2024	14:22	01-Feb-2024	15:13	51	0.00001	EODB COMPLIANCE
23	01-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	3	315 kVA	Unplanned Outage	01-Feb-2024	14:26	01-Feb-2024	16:24	118	0.00003	EODB COMPLIANCE
24	01-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	Other Outage	Unplanned Outage	01-Feb-2024	14:45	01-Feb-2024	19:21	276	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
25	01-Feb-2024	PART OF I1- BLOCK SEC-5 BAWANA	3	160 kVA	Unplanned Outage	01-Feb-2024	15:16	01-Feb-2024	16:15	59	0.00002	EODB COMPLIANCE
26	01-Feb-2024	PART OF E BLK SEC-02 BAWANA	8	Other Outage	Unplanned Outage	01-Feb-2024	15:41	01-Feb-2024	15:55	14	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
27	01-Feb-2024	PART OF K-31 SEC-5 BAWANA	5	315 kVA	Unplanned Outage	01-Feb-2024	16:09	01-Feb-2024	16:37	28	0.00001	EODB COMPLIANCE
28	01-Feb-2024	PART OF LM BLOCK SEC-3 DSIDC BAWANA	4	160 kVA	Unplanned Outage	01-Feb-2024	16:15	01-Feb-2024	17:15	60	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
29	01-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	12	Other Outage	Unplanned Outage	01-Feb-2024	16:19	01-Feb-2024	17:45	86	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
30	01-Feb-2024	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	907	Other Outage	Unplanned Outage	01-Feb-2024	16:22	01-Feb-2024	17:44	82	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
31	01-Feb-2024	PARTS OF M-BLOCK SEC-2 POOTH KHURD BAWANA	139	Other Outage	Unplanned Outage	01-Feb-2024	16:27	01-Feb-2024	17:07	40	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
32	01-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	6	Other Outage	Unplanned Outage	01-Feb-2024	16:46	01-Feb-2024	17:05	19	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
33	01-Feb-2024	PART OF PUNJAB KHOR BAWANA	6	Other Outage	Unplanned Outage	01-Feb-2024	17:36	01-Feb-2024	18:27	51	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
34	01-Feb-2024	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	146	Other Outage	Unplanned Outage	01-Feb-2024	17:46	01-Feb-2024	18:25	39	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
35	01-Feb-2024	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	281	Other Outage	Unplanned Outage	01-Feb-2024	20:59	01-Feb-2024	21:40	41	0.00077	FORCE MAJEURE/EXTERNAL FACTORS
36	02-Feb-2024	PARTS OF G BLK SEC-02 POOTH KHURD BAWANA	299	Other Outage	Unplanned Outage	02-Feb-2024	00:31	02-Feb-2024	01:14	43	0.00045	FORCE MAJEURE/EXTERNAL FACTORS
37	02-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	125	Other Outage	Planned Outage	02-Feb-2024	06:45	02-Feb-2024	09:06	141	0.00071	PLANNED OUTAGE
38	02-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	190	Other Outage	Unplanned Outage	02-Feb-2024	08:10	02-Feb-2024	08:59	49	0.00052	FORCE MAJEURE/EXTERNAL FACTORS
39	02-Feb-2024	PART OF LM BLOCK SEC-1 BAWANA	7	Other Outage	Unplanned Outage	02-Feb-2024	09:41	02-Feb-2024	11:24	103	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
40	02-Feb-2024	PART OF SEC-4 C,D,I BLOCK BAWANA	3	Other Outage	Unplanned Outage	02-Feb-2024	10:55	02-Feb-2024	13:08	133	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
41	02-Feb-2024	PART OF D-BLOCK SEC-1 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	02-Feb-2024	11:04	02-Feb-2024	11:48	44	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
42	02-Feb-2024	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	942	Other Outage	Planned Outage	02-Feb-2024	11:22	02-Feb-2024	16:10	288	0.00256	PLANNED OUTAGE
43	02-Feb-2024	PART OF D BLOCK SEC-2 BAWANA	6	Other Outage	Unplanned Outage	02-Feb-2024	11:49	02-Feb-2024	14:21	152	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
44	02-Feb-2024	PART OF E-1 SEC-5 BAWANA	8	400 kVA	Unplanned Outage	02-Feb-2024	12:12	02-Feb-2024	13:09	57	0.00002	EODB COMPLIANCE
45	02-Feb-2024	PART OF B BLOCK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	02-Feb-2024	12:34	02-Feb-2024	14:25	111	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
46	02-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	3	63 kVA	Unplanned Outage	02-Feb-2024	12:45	02-Feb-2024	13:30	45	0.00001	EODB COMPLIANCE
47	02-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	3	315 kVA	Unplanned Outage	02-Feb-2024	13:13	02-Feb-2024	14:34	81	0.00002	EODB COMPLIANCE
48	02-Feb-2024	PART OF SEC-4 C,D,I BLOCK BAWANA	6	Other Outage	Unplanned Outage	02-Feb-2024	13:39	02-Feb-2024	18:29	290	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
49	02-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	1	100 kVA	Unplanned Outage	02-Feb-2024	14:36	02-Feb-2024	15:16	40	0.00001	EODB COMPLIANCE
50	02-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	02-Feb-2024	15:06	02-Feb-2024	17:27	141	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
51	02-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	9	315 kVA	Unplanned Outage	02-Feb-2024	15:35	02-Feb-2024	16:13	38	0.00001	EODB COMPLIANCE
52	02-Feb-2024	PART OF I-19 SEC-2 NEAR GOL CHAKKAR. BAWANA	4	400 kVA	Unplanned Outage	02-Feb-2024	15:39	02-Feb-2024	16:01	22	0.00001	EODB COMPLIANCE
53	02-Feb-2024	PART OF LM BLOCK SEC-1 DSIDC BAWANA	4	Other Outage	Unplanned Outage	02-Feb-2024	16:08	02-Feb-2024	18:28	140	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
54	03-Feb-2024	PARTS OF NEAR COMMUNITY CENTER(AUCHANDI VILLAGE), MUNGESHPUR BAWANA	1751	Other Outage	Unplanned Outage	03-Feb-2024	02:16	03-Feb-2024	02:57	41	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
55	03-Feb-2024	PARTS OF F BLOCK SEC-2 POOTH KHURD BAWANA	162	Other Outage	Planned Outage	03-Feb-2024	08:09	03-Feb-2024	17:52	582	0.00065	PSD ON INDUSTRIAL WEEKLY OFF
56	03-Feb-2024	PARTS OF B BLK SEC-2 POOTH KHURD BAWANA	183	Other Outage	Planned Outage	03-Feb-2024	08:14	03-Feb-2024	17:57	582	0.00081	PSD ON INDUSTRIAL WEEKLY OFF
57	03-Feb-2024	PARTS OF MANGALAM HOSPITAL BAWANA	334	Other Outage	Unplanned Outage	03-Feb-2024	08:59	03-Feb-2024	13:06	247	0.00137	FORCE MAJEURE/EXTERNAL FACTORS
58	03-Feb-2024	PARTS OF K-1 BLK SEC-1 POOTH KHURD BAWANA	91	Other Outage	Planned Outage	03-Feb-2024	09:54	03-Feb-2024	17:32	458	0.00038	PSD ON INDUSTRIAL WEEKLY OFF
59	03-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	302	Other Outage	Planned Outage	03-Feb-2024	10:07	03-Feb-2024	17:38	451	0.00075	PSD ON INDUSTRIAL WEEKLY OFF
60	03-Feb-2024	PARTS OF G BLK SEC-1 BAWANA	144	Other Outage	Planned Outage	03-Feb-2024	10:25	03-Feb-2024	17:47	442	0.00196	PSD ON INDUSTRIAL WEEKLY OFF
61	03-Feb-2024	PARTS OF G BLK SEC-02 POOTH KHURD BAWANA	299	Other Outage	Planned Outage	03-Feb-2024	11:02	03-Feb-2024	17:58	416	0.00069	PSD ON INDUSTRIAL WEEKLY OFF
62	03-Feb-2024	PARTS OF L BLOCK SEC-2 DSIDC BAWANA	236	Other Outage	Planned Outage	03-Feb-2024	11:08	03-Feb-2024	17:48	400	0.00056	PSD ON INDUSTRIAL WEEKLY OFF
63	03-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	3	315 kVA	Unplanned Outage	03-Feb-2024	11:12	03-Feb-2024	11:56	44	0.00001	EODB COMPLIANCE
64	03-Feb-2024	PARTS OF MANGALAM HOSPITAL BAWANA	1700	Other Outage	Unplanned Outage	03-Feb-2024	12:35	03-Feb-2024	13:06	31	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
65	03-Feb-2024	PART OF J-BLOCK SEC-3 POOTH KHURD BAWANA	6	500 kVA	Unplanned Outage	03-Feb-2024	12:36	03-Feb-2024	13:07	31	0.00001	EODB COMPLIANCE
66	03-Feb-2024	PARTS OF ARIHANT SQUARE SHOPING COMPLEX,SEC- 4, D & I BLK SEC-4 BAWANA	256	Other Outage	Planned Outage	03-Feb-2024	13:19	03-Feb-2024	17:31	252	0.00161	PSD ON INDUSTRIAL WEEKLY OFF

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
67	03-Feb-2024	PART OF I BLK SEC-5 BAWANA	2	160 kVA	Planned Outage	03-Feb-2024	14:13	03-Feb-2024	17:39	206	0.00011	PSD ON INDUSTRIAL WEEKLY OFF
68	03-Feb-2024	PART OF C-BLK SEC-4 BAWANA	3	315 kVA	Unplanned Outage	03-Feb-2024	14:50	03-Feb-2024	15:20	30	0.00001	EODB COMPLIANCE
69	03-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	400 kVA	Unplanned Outage	03-Feb-2024	15:44	03-Feb-2024	16:19	35	0.00001	EODB COMPLIANCE
70	03-Feb-2024	PARTS OF NEAR COMMUNITY CENTER(AUCHANDI VILLAGE), MUNGESHPUR BAWANA	30	Other Outage	Unplanned Outage	03-Feb-2024	17:15	03-Feb-2024	18:30	75	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
71	04-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	91	Other Outage	Unplanned Outage	04-Feb-2024	03:57	04-Feb-2024	04:48	51	0.00043	FORCE MAJEURE/EXTERNAL FACTORS
72	04-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	61	Other Outage	Unplanned Outage	04-Feb-2024	07:40	04-Feb-2024	08:35	55	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
73	04-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	30	Other Outage	Unplanned Outage	04-Feb-2024	07:50	04-Feb-2024	08:35	45	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
74	04-Feb-2024	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	281	Other Outage	Unplanned Outage	04-Feb-2024	08:20	04-Feb-2024	08:47	27	0.00060	FORCE MAJEURE/EXTERNAL FACTORS
75	04-Feb-2024	PARTS OF J-32 SECTOR-5 POOTH KHURD BAWANA	179	Other Outage	Planned Outage	04-Feb-2024	12:25	04-Feb-2024	14:00	95	0.00013	PLANNED OUTAGE
76	04-Feb-2024	PARTS OF F-167 SEC-2 DSIDC BAWANA	350	Other Outage	Unplanned Outage	04-Feb-2024	15:23	04-Feb-2024	17:16	112	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
77	04-Feb-2024	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	60	Other Outage	Unplanned Outage	04-Feb-2024	17:24	04-Feb-2024	17:40	16	0.000004	FORCE MAJEURE/EXTERNAL FACTORS
78	05-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	302	Other Outage	Unplanned Outage	05-Feb-2024	08:40	05-Feb-2024	09:15	34	0.00033	FORCE MAJEURE/EXTERNAL FACTORS
79	05-Feb-2024	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA	265	Other Outage	Planned Outage	05-Feb-2024	10:22	05-Feb-2024	17:08	406	0.00293	PSD ON INDUSTRIAL WEEKLY OFF
80	05-Feb-2024	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA	121	Other Outage	Planned Outage	05-Feb-2024	10:46	05-Feb-2024	16:37	351	0.00029	PSD ON INDUSTRIAL WEEKLY OFF
81	05-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	7	Other Outage	Unplanned Outage	05-Feb-2024	10:55	05-Feb-2024	12:51	116	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
82	05-Feb-2024	PART OF G BLK SEC-1 BAWANA	6	250 kVA	Unplanned Outage	05-Feb-2024	11:01	05-Feb-2024	11:35	34	0.00001	EODB COMPLIANCE
83	05-Feb-2024	PART OF DE BLOCK SEC-3 DSIDC BAWANA	3	Other Outage	Unplanned Outage	05-Feb-2024	11:21	05-Feb-2024	13:09	108	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
84	05-Feb-2024	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	05-Feb-2024	12:23	05-Feb-2024	12:42	19	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
85	05-Feb-2024	PART OF I BLK SEC-1 BAWANA	4	315 kVA	Unplanned Outage	05-Feb-2024	12:28	05-Feb-2024	13:21	53	0.00001	EODB COMPLIANCE
86	05-Feb-2024	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	872	Other Outage	Unplanned Outage	05-Feb-2024	12:56	05-Feb-2024	14:48	112	0.00056	FORCE MAJEURE/EXTERNAL FACTORS
87	05-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	7	Other Outage	Unplanned Outage	05-Feb-2024	13:06	05-Feb-2024	15:11	125	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
88	05-Feb-2024	PART OF DE BLOCK SEC-3 DSIDC BAWANA	6	Other Outage	Unplanned Outage	05-Feb-2024	13:55	05-Feb-2024	16:47	172	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
89	05-Feb-2024	PART OF FG BLOCK SEC-3 DSIDC BAWANA	4	Other Outage	Unplanned Outage	05-Feb-2024	14:19	05-Feb-2024	16:15	116	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
90	05-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	347	Other Outage	Unplanned Outage	05-Feb-2024	16:01	05-Feb-2024	16:18	17	0.00065	FORCE MAJEURE/EXTERNAL FACTORS
91	05-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	185	Other Outage	Unplanned Outage	05-Feb-2024	16:01	05-Feb-2024	16:18	17	0.00056	FORCE MAJEURE/EXTERNAL FACTORS
92	05-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	211	Other Outage	Unplanned Outage	05-Feb-2024	17:21	05-Feb-2024	17:44	23	0.00057	FORCE MAJEURE/EXTERNAL FACTORS
93	05-Feb-2024	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	241	Other Outage	Unplanned Outage	05-Feb-2024	23:36	06-Feb-2024	00:48	72	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
94	05-Feb-2024	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	185	Other Outage	Unplanned Outage	05-Feb-2024	23:45	06-Feb-2024	00:47	62	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
95	06-Feb-2024	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	337	Other Outage	Unplanned Outage	06-Feb-2024	01:09	06-Feb-2024	01:30	21	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
96	06-Feb-2024	PARTS OF WATER SUPPLY DARIYA PUR, DTC DEPOT AUCHANDI RD BAWANA	2582	Other Outage	Unplanned Outage	06-Feb-2024	02:21	06-Feb-2024	02:40	19	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
97	06-Feb-2024	PARTS OF WATER SUPPLY DARIYA PUR, DTC DEPOT AUCHANDI RD BAWANA	584	Other Outage	Unplanned Outage	06-Feb-2024	08:00	06-Feb-2024	17:14	554	0.00077	FORCE MAJEURE/EXTERNAL FACTORS
98	06-Feb-2024	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	265	Other Outage	Unplanned Outage	06-Feb-2024	10:10	06-Feb-2024	11:11	60	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
99	06-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	3	63 kVA	Unplanned Outage	06-Feb-2024	10:48	06-Feb-2024	11:21	33	0.00001	EODB COMPLIANCE
100	06-Feb-2024	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	565	Other Outage	Planned Outage	06-Feb-2024	11:02	06-Feb-2024	17:26	383	0.00277	PLANNED OUTAGE
101	06-Feb-2024	PART OF B BLK SEC-1 POOTH KHURD BAWANA	3	315 kVA	Unplanned Outage	06-Feb-2024	11:12	06-Feb-2024	11:32	20	0.00001	EODB COMPLIANCE
102	06-Feb-2024	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	06-Feb-2024	11:17	06-Feb-2024	13:21	124	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
103	06-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	3	Other Outage	Unplanned Outage	06-Feb-2024	11:45	06-Feb-2024	14:18	153	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
104	06-Feb-2024	PART OF K-31 SEC-5 BAWANA	8	315 kVA	Unplanned Outage	06-Feb-2024	12:35	06-Feb-2024	13:55	80	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
105	06-Feb-2024	PART OF B BLK SEC-2 BAWANA	3	250 kVA	Unplanned Outage	06-Feb-2024	12:53	06-Feb-2024	14:04	71	0.00002	EODB COMPLIANCE
106	06-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	5	Other Outage	Unplanned Outage	06-Feb-2024	14:26	06-Feb-2024	16:47	141	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
107	06-Feb-2024	PART OF I BLK SEC-5 BAWANA	3	315 kVA	Unplanned Outage	06-Feb-2024	14:34	06-Feb-2024	17:08	154	0.00004	EODB COMPLIANCE
108	06-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	6	Other Outage	Unplanned Outage	06-Feb-2024	14:48	06-Feb-2024	16:45	117	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
109	06-Feb-2024	PART OF FG-27 SEC-3 BAWANA	2	Other Outage	Unplanned Outage	06-Feb-2024	15:02	06-Feb-2024	16:17	75	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
110	06-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	91	Other Outage	Unplanned Outage	06-Feb-2024	15:08	06-Feb-2024	15:18	10	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
111	06-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	91	Other Outage	Unplanned Outage	06-Feb-2024	15:10	06-Feb-2024	16:04	54	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
112	06-Feb-2024	PARTS OF LM BLOCK SEC-3 DSIDC BAWANA	429	Other Outage	Unplanned Outage	06-Feb-2024	15:16	06-Feb-2024	15:43	27	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
113	06-Feb-2024	PART OF G BLOCK SEC-4 POOTH KHURD BAWANA	11	500 kVA	Unplanned Outage	06-Feb-2024	16:31	06-Feb-2024	16:57	26	0.00001	EODB COMPLIANCE
114	07-Feb-2024	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	265	Other Outage	Planned Outage	07-Feb-2024	06:12	07-Feb-2024	09:15	183	0.00010	PLANNED OUTAGE
115	07-Feb-2024	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB	1709	Other Outage	Unplanned Outage	07-Feb-2024	06:35	07-Feb-2024	07:40	65	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
116	07-Feb-2024	PARTS OF CHANDPUR MAJRA BAWANA	82	Other Outage	Unplanned Outage	07-Feb-2024	08:03	07-Feb-2024	08:28	25	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
117	07-Feb-2024	PART OF B BLK SEC-2 BAWANA	3	Other Outage	Unplanned Outage	07-Feb-2024	09:31	07-Feb-2024	11:29	118	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
118	07-Feb-2024	PARTS OF PUNJAB KHOD BAWANA	651	Other Outage	Planned Outage	07-Feb-2024	10:34	07-Feb-2024	19:06	512	0.00256	FORCE MAJEURE DUE TO SABOTAGE
119	07-Feb-2024	PART OF CHANPUR MAJRA BAWANA	20	Other Outage	Planned Outage	07-Feb-2024	10:38	07-Feb-2024	17:00	382	0.00053	PLANNED OUTAGE
120	07-Feb-2024	PART OF E BLK SEC-5 BAWANA	4	100 kVA	Unplanned Outage	07-Feb-2024	10:40	07-Feb-2024	11:39	59	0.00002	EODB COMPLIANCE
121	07-Feb-2024	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	1957	Other Outage	Unplanned Outage	07-Feb-2024	10:50	07-Feb-2024	11:13	23	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
122	07-Feb-2024	PARTS OF JYONTI VILLAGE BAWANA	1692	Other Outage	Planned Outage	07-Feb-2024	11:00	07-Feb-2024	17:10	370	0.00185	PLANNED OUTAGE
123	07-Feb-2024	PART OF O,N,L BLOCK SEC-3 BAWANA	4	Other Outage	Unplanned Outage	07-Feb-2024	11:02	07-Feb-2024	13:14	132	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
124	07-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	07-Feb-2024	11:35	07-Feb-2024	12:05	30	0.00001	EODB COMPLIANCE
125	07-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	1367	Other Outage	Planned Outage	07-Feb-2024	11:59	07-Feb-2024	16:53	294	0.00114	PLANNED OUTAGE
126	07-Feb-2024	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	160	Other Outage	Unplanned Outage	07-Feb-2024	12:09	07-Feb-2024	14:57	168	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
127	07-Feb-2024	PART OF BULLA COLONY BAWANA	2	Other Outage	Planned Outage	07-Feb-2024	12:11	07-Feb-2024	16:42	271	0.00008	PLANNED OUTAGE
128	07-Feb-2024	PART OF POOTH VILLAGE BAWANA	2	160 kVA	Unplanned Outage	07-Feb-2024	12:19	07-Feb-2024	12:43	24	0.00001	EODB COMPLIANCE
129	07-Feb-2024	PART OF E BLK SEC-1 BAWANA	2	Other Outage	Unplanned Outage	07-Feb-2024	12:51	07-Feb-2024	17:18	267	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
130	07-Feb-2024	PART OF RAW WATER BAWANA	7	100 kVA	Unplanned Outage	07-Feb-2024	13:17	07-Feb-2024	14:34	77	0.00002	EODB COMPLIANCE
131	07-Feb-2024	PART OF B BLK SEC-2 BAWANA	3	Other Outage	Unplanned Outage	07-Feb-2024	13:24	07-Feb-2024	14:28	64	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
132	07-Feb-2024	PART OF POOTH VILLAGE BAWANA	4	160 kVA	Unplanned Outage	07-Feb-2024	13:27	07-Feb-2024	14:18	51	0.00001	EODB COMPLIANCE
133	07-Feb-2024	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	281	Other Outage	Unplanned Outage	07-Feb-2024	13:57	07-Feb-2024	14:47	50	0.00053	FORCE MAJEURE/EXTERNAL FACTORS
134	07-Feb-2024	PART OF SEC-4 C,D,I BLOCK BAWANA	9	400 kVA	Unplanned Outage	07-Feb-2024	15:10	07-Feb-2024	15:50	40	0.00001	EODB COMPLIANCE
135	07-Feb-2024	PART OF N BLOCK SEC-2 BAWANA	3	63 kVA	Unplanned Outage	07-Feb-2024	15:45	07-Feb-2024	16:31	46	0.00001	EODB COMPLIANCE
136	07-Feb-2024	PARTS OF VIJAY NAGAR, SKV DARYA PUR, MAIN BUS STAND BAWANA	89	Other Outage	Unplanned Outage	07-Feb-2024	20:28	07-Feb-2024	21:14	46	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
137	08-Feb-2024	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	265	Other Outage	Planned Outage	08-Feb-2024	05:54	08-Feb-2024	09:09	195	0.00135	PLANNED OUTAGE
138	08-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	3	Other Outage	Unplanned Outage	08-Feb-2024	09:52	08-Feb-2024	11:23	91	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
139	08-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	91	Other Outage	Unplanned Outage	08-Feb-2024	09:53	08-Feb-2024	11:19	86	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
140	08-Feb-2024	PARTS OF CHANDPUR MAJRA BAWANA	1942	Other Outage	Planned Outage	08-Feb-2024	10:13	08-Feb-2024	16:58	405	0.00405	PLANNED OUTAGE
141	08-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	9	Other Outage	Unplanned Outage	08-Feb-2024	10:32	08-Feb-2024	13:23	171	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
142	08-Feb-2024	PARTS OF FG-27 SEC-3 BAWANA	284	Other Outage	Unplanned Outage	08-Feb-2024	10:33	08-Feb-2024	11:02	29	0.00060	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
143	08-Feb-2024	PART OF C-BLK SEC-4 BAWANA	6	Other Outage	Unplanned Outage	08-Feb-2024	10:52	08-Feb-2024	14:45	233	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
144	08-Feb-2024	PART OF J-32 SECTOR-5 POOTH KHURD BAWANA	4	160 kVA	Unplanned Outage	08-Feb-2024	11:16	08-Feb-2024	11:42	26	0.00001	EODB COMPLIANCE
145	08-Feb-2024	PARTS OF E-BLOCK SEC-4 POOTH KHURD BAWANA	281	Other Outage	Unplanned Outage	08-Feb-2024	11:34	08-Feb-2024	11:57	23	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
146	08-Feb-2024	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	690	Other Outage	Planned Outage	08-Feb-2024	11:50	08-Feb-2024	16:46	296	0.00164	PLANNED OUTAGE
147	08-Feb-2024	PART OF J-32 SECTOR-5 POOTH KHURD BAWANA	6	250 kVA	Unplanned Outage	08-Feb-2024	12:22	08-Feb-2024	13:35	73	0.00002	EODB COMPLIANCE
148	08-Feb-2024	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	5	400 kVA	Unplanned Outage	08-Feb-2024	12:38	08-Feb-2024	14:15	97	0.00003	EODB COMPLIANCE
149	08-Feb-2024	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	08-Feb-2024	13:10	08-Feb-2024	15:53	163	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
150	08-Feb-2024	PART OF I1- BLOCK SEC-5 BAWANA	2	100 kVA	Unplanned Outage	08-Feb-2024	13:30	08-Feb-2024	14:08	38	0.00001	EODB COMPLIANCE
151	08-Feb-2024	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	616	Other Outage	Planned Outage	08-Feb-2024	13:43	08-Feb-2024	15:10	87	0.00029	PLANNED OUTAGE
152	08-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	08-Feb-2024	13:57	08-Feb-2024	20:32	395	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
153	08-Feb-2024	PART OF HI BLOCK SEC 5 DSIDC BAWANA	6	400 kVA	Unplanned Outage	08-Feb-2024	14:35	08-Feb-2024	16:15	100	0.00003	EODB COMPLIANCE
154	08-Feb-2024	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	08-Feb-2024	14:57	08-Feb-2024	17:50	173	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
155	08-Feb-2024	PART OF H-BLOCK SEC-1 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	08-Feb-2024	15:46	08-Feb-2024	16:12	26	0.00001	EODB COMPLIANCE
156	08-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	08-Feb-2024	16:25	08-Feb-2024	16:50	25	0.00001	EODB COMPLIANCE
157	08-Feb-2024	PARTS OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	270	Other Outage	Unplanned Outage	08-Feb-2024	16:26	08-Feb-2024	16:42	16	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
158	09-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	317	Other Outage	Planned Outage	09-Feb-2024	06:19	09-Feb-2024	11:00	281	0.00125	PLANNED OUTAGE
159	09-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	32	Other Outage	Planned Outage	09-Feb-2024	06:31	09-Feb-2024	11:00	268	0.00082	PLANNED OUTAGE
160	09-Feb-2024	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	146	Other Outage	Unplanned Outage	09-Feb-2024	07:05	09-Feb-2024	07:36	31	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
161	09-Feb-2024	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	4887	Other Outage	Unplanned Outage	09-Feb-2024	07:17	09-Feb-2024	08:47	90	0.00171	FORCE MAJEURE/EXTERNAL FACTORS
162	09-Feb-2024	PART OF M BLOCK SEC-3 DSIDC BAWANA	6	400 kVA	Planned Outage	09-Feb-2024	10:12	09-Feb-2024	12:36	144	0.00004	PLANNED OUTAGE
163	09-Feb-2024	PART OF VILL. KANJHAWLA BAWANA	19	Other Outage	Planned Outage	09-Feb-2024	10:17	09-Feb-2024	16:41	384	0.00128	PLANNED OUTAGE
164	09-Feb-2024	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1157	Other Outage	Planned Outage	09-Feb-2024	10:26	09-Feb-2024	16:50	384	0.00384	PLANNED OUTAGE
165	09-Feb-2024	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	630	Other Outage	Planned Outage	09-Feb-2024	10:30	09-Feb-2024	16:19	349	0.00068	PLANNED OUTAGE
166	09-Feb-2024	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	688	Other Outage	Planned Outage	09-Feb-2024	10:33	09-Feb-2024	14:19	226	0.00050	PLANNED OUTAGE
167	09-Feb-2024	PART OF M BLOCK SEC-3 DSIDC BAWANA	5	400 kVA	Planned Outage	09-Feb-2024	10:37	09-Feb-2024	13:34	177	0.00015	PLANNED OUTAGE
168	09-Feb-2024	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	2748	Other Outage	Planned Outage	09-Feb-2024	10:38	09-Feb-2024	16:18	340	0.00170	PLANNED OUTAGE
169	09-Feb-2024	PART OF J-BLOCK SEC-3 POOTH KHURD BAWANA	2	63 kVA	Planned Outage	09-Feb-2024	11:02	09-Feb-2024	13:25	143	0.00004	PLANNED OUTAGE
170	09-Feb-2024	PARTS OF N-3 SEC-5 AND N-4,SEC- 5 BAWANA	1310	Other Outage	Planned Outage	09-Feb-2024	11:16	09-Feb-2024	14:03	167	0.00065	PLANNED OUTAGE
171	09-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	2	315 kVA	Unplanned Outage	09-Feb-2024	11:21	09-Feb-2024	12:05	44	0.00001	EODB COMPLIANCE
172	09-Feb-2024	PART OF E BLK SEC-02 BAWANA	4	315 kVA	Unplanned Outage	09-Feb-2024	12:17	09-Feb-2024	16:01	224	0.00006	EODB COMPLIANCE
173	09-Feb-2024	PART OF B BLK SEC-1 POOTH KHURD BAWANA	6	250 kVA	Unplanned Outage	09-Feb-2024	12:49	09-Feb-2024	13:48	59	0.00002	EODB COMPLIANCE
174	09-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	211	Other Outage	Unplanned Outage	09-Feb-2024	13:23	09-Feb-2024	14:11	49	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
175	09-Feb-2024	PART OF M BLOCK SEC-3 DSIDC BAWANA	2	160 kVA	Planned Outage	09-Feb-2024	14:16	09-Feb-2024	17:03	167	0.00009	PLANNED OUTAGE
176	09-Feb-2024	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	2	Other Outage	Unplanned Outage	09-Feb-2024	14:46	09-Feb-2024	16:08	82	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
177	09-Feb-2024	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	09-Feb-2024	14:48	09-Feb-2024	15:47	59	0.00002	EODB COMPLIANCE
178	09-Feb-2024	PART OF F-167 SEC-2 DSIDC BAWANA	4	315 kVA	Unplanned Outage	09-Feb-2024	16:19	09-Feb-2024	17:41	82	0.00002	EODB COMPLIANCE
179	09-Feb-2024	PART OF D BLOCK SEC-2 BAWANA	1	160 kVA	Unplanned Outage	09-Feb-2024	16:28	09-Feb-2024	17:16	48	0.00001	EODB COMPLIANCE
180	09-Feb-2024	PARTS OF VIJAY NAGAR, SKV DARYA PUR, MAIN BUS STAND BAWANA	89	Other Outage	Unplanned Outage	09-Feb-2024	16:58	09-Feb-2024	17:40	42	0.00049	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
181	09-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	317	Other Outage	Unplanned Outage	09-Feb-2024	18:48	09-Feb-2024	19:15	28	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
182	10-Feb-2024	PARTS OF G BLOCK SEC-4 POOTH KHURD BAWANA	41	Other Outage	Unplanned Outage	10-Feb-2024	00:40	10-Feb-2024	00:56	16	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
183	10-Feb-2024	PARTS OF G BLOCK SEC-4 POOTH KHURD BAWANA	549	Other Outage	Unplanned Outage	10-Feb-2024	01:10	10-Feb-2024	01:32	22	0.00042	FORCE MAJEURE/EXTERNAL FACTORS
184	10-Feb-2024	PARTS OF G BLK SEC-1 BAWANA	231	Other Outage	Unplanned Outage	10-Feb-2024	02:07	10-Feb-2024	02:24	17	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
185	10-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	302	Other Outage	Planned Outage	10-Feb-2024	08:05	10-Feb-2024	17:06	541	0.00075	PSD ON INDUSTRIAL WEEKLY OFF
186	10-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	324	Other Outage	Planned Outage	10-Feb-2024	09:47	10-Feb-2024	17:39	471	0.00393	PSD ON INDUSTRIAL WEEKLY OFF
187	10-Feb-2024	PARTS OF B BLK SEC-2 POOTH KHURD BAWANA	183	Other Outage	Planned Outage	10-Feb-2024	09:54	10-Feb-2024	17:41	467	0.00195	PSD ON INDUSTRIAL WEEKLY OFF
188	10-Feb-2024	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	241	Other Outage	Planned Outage	10-Feb-2024	10:03	10-Feb-2024	17:22	439	0.00061	PSD ON INDUSTRIAL WEEKLY OFF
189	10-Feb-2024	PARTS OF F BLOCK SEC-4 DSIDC BAWANA	198	Other Outage	Planned Outage	10-Feb-2024	10:12	10-Feb-2024	17:13	420	0.00234	PSD ON INDUSTRIAL WEEKLY OFF
190	10-Feb-2024	PARTS OF C-20 SEC-4, O-BLOCK SEC-2 POOTH KHURD BAWANA	213	Other Outage	Planned Outage	10-Feb-2024	10:19	10-Feb-2024	17:31	432	0.00252	PSD ON INDUSTRIAL WEEKLY OFF
191	10-Feb-2024	PART OF B BLK SEC-1 POOTH KHURD BAWANA	2	315 kVA	Unplanned Outage	10-Feb-2024	10:34	10-Feb-2024	11:30	56	0.00002	EODB COMPLIANCE
192	10-Feb-2024	PARTS OF F-167 SEC-2 DSIDC BAWANA	183	Other Outage	Planned Outage	10-Feb-2024	10:43	10-Feb-2024	17:25	402	0.00022	PSD ON INDUSTRIAL WEEKLY OFF
193	10-Feb-2024	PART OF D BLOCK SEC-2 BAWANA	4	315 kVA	Unplanned Outage	10-Feb-2024	10:58	10-Feb-2024	13:02	124	0.00003	EODB COMPLIANCE
194	10-Feb-2024	PARTS OF BAWANA STADIUM AND INDS. AREA BAWANA	84	Other Outage	Planned Outage	10-Feb-2024	11:00	10-Feb-2024	14:00	180	0.00055	PLANNED OUTAGE
195	10-Feb-2024	PARTS OF A,F BLK SEC-2 DSIDC, DJB-TW NO-17 BAWANA	336	Other Outage	Planned Outage	10-Feb-2024	11:22	10-Feb-2024	17:56	394	0.00252	PSD ON INDUSTRIAL WEEKLY OFF
196	10-Feb-2024	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	5	400 kVA	Unplanned Outage	10-Feb-2024	11:23	10-Feb-2024	15:31	248	0.00007	EODB COMPLIANCE
197	10-Feb-2024	PART OF E BLK SEC-02 BAWANA	5	315 kVA	Unplanned Outage	10-Feb-2024	12:04	10-Feb-2024	12:21	17	0.000005	EODB COMPLIANCE
198	10-Feb-2024	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	1	63 kVA	Unplanned Outage	10-Feb-2024	14:08	10-Feb-2024	15:05	57	0.00002	EODB COMPLIANCE
199	10-Feb-2024	PART OF C BLK SEC-02 BAWANA	1	400 kVA	Unplanned Outage	10-Feb-2024	14:33	10-Feb-2024	16:21	108	0.00003	EODB COMPLIANCE
200	10-Feb-2024	PART OF POOTH VILLAGE BAWANA	2	160 kVA	Unplanned Outage	10-Feb-2024	16:00	10-Feb-2024	16:27	27	0.00001	EODB COMPLIANCE
201	10-Feb-2024	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	337	Other Outage	Unplanned Outage	10-Feb-2024	16:07	10-Feb-2024	16:20	13	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
202	10-Feb-2024	PARTS OF G BLK SEC-1 BAWANA	235	Other Outage	Unplanned Outage	10-Feb-2024	20:46	10-Feb-2024	21:07	21	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
203	11-Feb-2024	PART OF GARTHI RINDHALA BAWANA	8	Other Outage	Unplanned Outage	11-Feb-2024	08:01	11-Feb-2024	09:09	68	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
204	11-Feb-2024	PARTS OF D BLOCK SEC-2 POOTH KHRD BAWANA	83	Other Outage	Unplanned Outage	11-Feb-2024	14:32	11-Feb-2024	15:40	68	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
205	11-Feb-2024	PARTS OF D BLOCK SEC-2 POOTH KHRD BAWANA	166	Other Outage	Unplanned Outage	11-Feb-2024	15:40	11-Feb-2024	16:01	21	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
206	12-Feb-2024	PARTS OF KANJHAWLA VILLAGE BAWANA	269	Other Outage	Planned Outage	12-Feb-2024	10:06	12-Feb-2024	17:27	440	0.00147	PLANNED OUTAGE
207	12-Feb-2024	PART OF FG-27 SEC-3 BAWANA	4	63 kVA	Planned Outage	12-Feb-2024	10:31	12-Feb-2024	13:11	160	0.00004	PLANNED OUTAGE
208	12-Feb-2024	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA	120	Other Outage	Planned Outage	12-Feb-2024	10:49	12-Feb-2024	17:13	384	0.00128	PSD ON INDUSTRIAL WEEKLY OFF
209	12-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	5	315 kVA	Planned Outage	12-Feb-2024	10:50	12-Feb-2024	12:34	104	0.00006	PLANNED OUTAGE
210	12-Feb-2024	PART OF FG-27 SEC-3 BAWANA	3	Other Outage	Unplanned Outage	12-Feb-2024	11:11	12-Feb-2024	14:08	177	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
211	12-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	2	63 kVA	Unplanned Outage	12-Feb-2024	11:22	12-Feb-2024	12:00	38	0.00001	EODB COMPLIANCE
212	12-Feb-2024	PART OF G BLOCK BAWANA	8	315 kVA	Unplanned Outage	12-Feb-2024	11:35	12-Feb-2024	12:12	37	0.00001	EODB COMPLIANCE
213	12-Feb-2024	PARTS OF B-BLOCK SEC-3 POOTH KHURD BAWANA	353	Other Outage	Unplanned Outage	12-Feb-2024	13:07	12-Feb-2024	13:44	37	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
214	12-Feb-2024	PARTS OF N-3 SEC-5 AND N-4,SEC- 5 BAWANA	2469	Other Outage	Unplanned Outage	12-Feb-2024	14:02	12-Feb-2024	15:16	74	0.00049	FORCE MAJEURE/EXTERNAL FACTORS
215	12-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	2	160 kVA	Planned Outage	12-Feb-2024	14:04	12-Feb-2024	14:50	46	0.00001	PLANNED OUTAGE
216	12-Feb-2024	PART OF D BLOCK SEC-2 BAWANA	4	Other Outage	Unplanned Outage	12-Feb-2024	14:30	12-Feb-2024	16:32	122	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
217	12-Feb-2024	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	5	100 kVA	Planned Outage	12-Feb-2024	14:39	12-Feb-2024	17:03	144	0.00004	PLANNED OUTAGE
218	12-Feb-2024	PART OF I BLK SEC-1 BAWANA	8	315 kVA	Unplanned Outage	12-Feb-2024	14:39	12-Feb-2024	15:38	59	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
219	12-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	12-Feb-2024	15:20	12-Feb-2024	16:32	72	0.00002	EODB COMPLIANCE
220	12-Feb-2024	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	281	Other Outage	Unplanned Outage	12-Feb-2024	15:45	12-Feb-2024	16:56	71	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
221	12-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	7	250 kVA	Unplanned Outage	12-Feb-2024	16:11	12-Feb-2024	16:34	23	0.00001	EODB COMPLIANCE
222	12-Feb-2024	PARTS OF KANJHAWLA VILLAGE BAWANA	269	Other Outage	Unplanned Outage	12-Feb-2024	17:27	12-Feb-2024	18:01	34	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
223	12-Feb-2024	PART OF B BLK SEC-1 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	12-Feb-2024	18:30	12-Feb-2024	19:06	36	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
224	13-Feb-2024	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	5	400 kVA	Planned Outage	13-Feb-2024	06:09	13-Feb-2024	09:25	196	0.00011	PLANNED OUTAGE
225	13-Feb-2024	PART OF G BLK SEC-02 BAWANA	1	160 kVA	Planned Outage	13-Feb-2024	06:15	13-Feb-2024	09:19	184	0.00005	PLANNED OUTAGE
226	13-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	302	Other Outage	Unplanned Outage	13-Feb-2024	08:30	13-Feb-2024	08:57	27	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
227	13-Feb-2024	PARTS OF K-31 SEC-5 POOTH KHURD BAWANA	51	Other Outage	Unplanned Outage	13-Feb-2024	09:27	13-Feb-2024	10:03	35	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
228	13-Feb-2024	PARTS OF K-31 SEC-5 POOTH KHURD BAWANA	101	Other Outage	Unplanned Outage	13-Feb-2024	10:03	13-Feb-2024	10:29	26	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
229	13-Feb-2024	PARTS OF BULLA COLONY BAWANA	920	Other Outage	Planned Outage	13-Feb-2024	10:12	13-Feb-2024	17:20	427	0.00427	PLANNED OUTAGE
230	13-Feb-2024	PART OF E BLK SEC-5 BAWANA	6	Other Outage	Unplanned Outage	13-Feb-2024	10:39	13-Feb-2024	15:31	292	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
231	13-Feb-2024	PART OF POOTH VILLAGE BAWANA	2	63 kVA	Unplanned Outage	13-Feb-2024	10:52	13-Feb-2024	11:36	44	0.00001	EODB COMPLIANCE
232	13-Feb-2024	PART OF SEC-4 C,D,I BLOCK BAWANA	5	315 kVA	Unplanned Outage	13-Feb-2024	10:56	13-Feb-2024	11:47	51	0.00001	EODB COMPLIANCE
233	13-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	3	Other Outage	Unplanned Outage	13-Feb-2024	11:04	13-Feb-2024	11:55	51	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
234	13-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	9	315 kVA	Unplanned Outage	13-Feb-2024	11:08	13-Feb-2024	11:44	36	0.00001	EODB COMPLIANCE
235	13-Feb-2024	PART OF O BLOCK SEC-1 POOTH KHURD BAWANA	5	400 kVA	Unplanned Outage	13-Feb-2024	11:17	13-Feb-2024	12:31	74	0.00002	EODB COMPLIANCE
236	13-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	3	Other Outage	Unplanned Outage	13-Feb-2024	11:20	13-Feb-2024	12:35	75	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
237	13-Feb-2024	PARTS OF I-BLOCK SEC-4 POOTH KHURD BAWANA	368	Other Outage	Unplanned Outage	13-Feb-2024	12:01	13-Feb-2024	12:50	49	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
238	13-Feb-2024	PARTS OF NMO BLOCK SEC-5 POOTH KHURD BAWANA	109	Other Outage	Unplanned Outage	13-Feb-2024	12:02	13-Feb-2024	12:26	24	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
239	13-Feb-2024	PART OF G BLOCK SEC-4 POOTH KHURD BAWANA	14	315 kVA	Unplanned Outage	13-Feb-2024	12:05	13-Feb-2024	12:57	52	0.00001	EODB COMPLIANCE
240	13-Feb-2024	PART OF B BLK SEC-1 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	13-Feb-2024	12:16	13-Feb-2024	12:43	27	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
241	13-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	5	Other Outage	Unplanned Outage	13-Feb-2024	13:41	13-Feb-2024	15:02	81	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
242	13-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	6	Other Outage	Unplanned Outage	13-Feb-2024	14:04	13-Feb-2024	15:30	86	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
243	13-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	2	63 kVA	Unplanned Outage	13-Feb-2024	15:14	13-Feb-2024	16:13	59	0.00002	EODB COMPLIANCE
244	13-Feb-2024	PART OF O BLOCK SEC-3 BAWANA	7	160 kVA	Unplanned Outage	13-Feb-2024	15:29	13-Feb-2024	15:56	27	0.00001	EODB COMPLIANCE
245	13-Feb-2024	PART OF H-BLOCK SEC-1 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	13-Feb-2024	16:19	13-Feb-2024	17:10	51	0.00001	EODB COMPLIANCE
246	14-Feb-2024	PART OF F BLK SEC-1 BAWANA	10	Other Outage	Unplanned Outage	14-Feb-2024	07:24	14-Feb-2024	10:10	166	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
247	14-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	7	Other Outage	Unplanned Outage	14-Feb-2024	10:38	14-Feb-2024	13:16	158	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
248	14-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	268	Other Outage	Unplanned Outage	14-Feb-2024	10:43	14-Feb-2024	12:32	109	0.00115	FORCE MAJEURE/EXTERNAL FACTORS
249	14-Feb-2024	PARTS OF ESS-1 & 2 BAWANA	1096	Other Outage	Planned Outage	14-Feb-2024	10:58	14-Feb-2024	16:03	305	0.00102	PLANNED OUTAGE
250	14-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	7	Other Outage	Unplanned Outage	14-Feb-2024	11:02	14-Feb-2024	13:33	151	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
251	14-Feb-2024	PART OF TUBEWELL NO - 1322 BAWANA	5	400 kVA	Unplanned Outage	14-Feb-2024	11:37	14-Feb-2024	12:09	32	0.00001	EODB COMPLIANCE
252	14-Feb-2024	PART OF D-BLK SEC-4 BAWANA	4	63 kVA	Unplanned Outage	14-Feb-2024	12:35	14-Feb-2024	13:32	57	0.00002	EODB COMPLIANCE
253	14-Feb-2024	PARTS OF A,F BLK SEC-2 DSIDC, DJB-TW NO-17 BAWANA	299	Other Outage	Unplanned Outage	14-Feb-2024	13:34	14-Feb-2024	15:37	123	0.00273	FORCE MAJEURE/EXTERNAL FACTORS
254	14-Feb-2024	PARTS OF A,F BLK SEC-2 DSIDC, DJB-TW NO-17 BAWANA	29	Other Outage	Unplanned Outage	14-Feb-2024	13:34	14-Feb-2024	17:45	251	0.00139	FORCE MAJEURE/EXTERNAL FACTORS
255	14-Feb-2024	PART OF E BLK SEC-5 BAWANA	6	315 kVA	Unplanned Outage	14-Feb-2024	14:38	14-Feb-2024	15:08	30	0.00001	EODB COMPLIANCE
256	14-Feb-2024	PARTS OF SEC-4 C,D,I BLOCK BAWANA	368	Other Outage	Unplanned Outage	14-Feb-2024	15:00	14-Feb-2024	15:34	34	0.00152	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
257	14-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	9	Other Outage	Unplanned Outage	14-Feb-2024	15:13	14-Feb-2024	17:09	116	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
258	14-Feb-2024	PARTS OF E BLK SEC-1 POOTH KHURD BAEANA BAWANA	191	Other Outage	Unplanned Outage	14-Feb-2024	15:31	14-Feb-2024	16:34	63	0.00210	FORCE MAJEURE/EXTERNAL FACTORS
259	14-Feb-2024	PART OF E-1 SEC-5 BAWANA	10	315 kVA	Unplanned Outage	14-Feb-2024	15:34	14-Feb-2024	15:47	13	0.000004	EODB COMPLIANCE
260	14-Feb-2024	PARTS OF ESS-1 & 2 BAWANA	203	Other Outage	Unplanned Outage	14-Feb-2024	18:07	14-Feb-2024	21:10	183	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
261	14-Feb-2024	PARTS OF ESS-1 & 2 BAWANA	203	Other Outage	Unplanned Outage	14-Feb-2024	18:07	14-Feb-2024	21:10	183	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
262	14-Feb-2024	PARTS OF E BLK SEC-1 POOTH KHURD BAEANA BAWANA	188	Other Outage	Unplanned Outage	14-Feb-2024	21:05	14-Feb-2024	21:41	36	0.00043	FORCE MAJEURE/EXTERNAL FACTORS
263	15-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	1	Other Outage	Unplanned Outage	15-Feb-2024	04:50	15-Feb-2024	05:05	15	0.000004	FORCE MAJEURE/EXTERNAL FACTORS
264	15-Feb-2024	PARTS OF POOTH KHURD VILLAGE BAWANA	659	Other Outage	Unplanned Outage	15-Feb-2024	04:50	15-Feb-2024	05:44	54	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
265	15-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	339	Other Outage	Unplanned Outage	15-Feb-2024	05:29	15-Feb-2024	05:44	14	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
266	15-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	309	Other Outage	Unplanned Outage	15-Feb-2024	05:29	15-Feb-2024	05:44	15	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
267	15-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	1191	Other Outage	Unplanned Outage	15-Feb-2024	05:50	15-Feb-2024	06:40	50	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
268	15-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	31	Other Outage	Unplanned Outage	15-Feb-2024	05:55	15-Feb-2024	06:10	15	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
269	15-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	31	Other Outage	Unplanned Outage	15-Feb-2024	06:18	15-Feb-2024	06:40	22	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
270	15-Feb-2024	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	265	Other Outage	Planned Outage	15-Feb-2024	06:20	15-Feb-2024	09:55	215	0.00018	PLANNED OUTAGE
271	15-Feb-2024	PARTS OF I-BLOCK SEC-4 POOTH KHURD BAWANA	168	Other Outage	Unplanned Outage	15-Feb-2024	08:28	15-Feb-2024	09:40	72	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
272	15-Feb-2024	PART OF F BLK SEC-1 BAWANA	3	Other Outage	Unplanned Outage	15-Feb-2024	10:02	15-Feb-2024	11:31	89	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
273	15-Feb-2024	PART OF C-BLK SEC-4 BAWANA	4	315 kVA	Unplanned Outage	15-Feb-2024	11:01	15-Feb-2024	11:29	28	0.00001	EODB COMPLIANCE
274	15-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	2	Other Outage	Unplanned Outage	15-Feb-2024	11:18	15-Feb-2024	13:16	118	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
275	15-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	2	Other Outage	Unplanned Outage	15-Feb-2024	11:22	15-Feb-2024	12:55	93	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
276	15-Feb-2024	PARTS OF A,F,G, H, I BLOCKS OF SEC.- 1 DSIDC BAWANA	317	Other Outage	Planned Outage	15-Feb-2024	11:39	15-Feb-2024	17:18	339	0.00283	PLANNED OUTAGE
277	15-Feb-2024	PARTS OF WATER SUPPLY DARIYA PUR, DTC DEPOT AUCHANDI RD BAWANA	584	Other Outage	Planned Outage	15-Feb-2024	12:10	15-Feb-2024	17:54	344	0.00143	PLANNED OUTAGE
278	15-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	9	315 kVA	Unplanned Outage	15-Feb-2024	12:53	15-Feb-2024	13:30	37	0.00001	EODB COMPLIANCE
279	15-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	3	250 kVA	Unplanned Outage	15-Feb-2024	13:32	15-Feb-2024	14:51	79	0.00002	EODB COMPLIANCE
280	15-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	15-Feb-2024	14:03	15-Feb-2024	15:21	78	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
281	15-Feb-2024	PART OF BULLA COLONY BAWANA	8	Other Outage	Unplanned Outage	15-Feb-2024	14:12	15-Feb-2024	16:38	146	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
282	15-Feb-2024	PART OF N BLOCK SEC-2 BAWANA	3	160 kVA	Unplanned Outage	15-Feb-2024	14:38	15-Feb-2024	15:02	24	0.00001	EODB COMPLIANCE
283	15-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	2	Other Outage	Unplanned Outage	15-Feb-2024	14:39	15-Feb-2024	16:30	111	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
284	15-Feb-2024	PART OF G BLOCK BAWANA	2	100 kVA	Unplanned Outage	15-Feb-2024	15:30	15-Feb-2024	15:49	19	0.00001	EODB COMPLIANCE
285	15-Feb-2024	PART OF O,N,I BLOCK SEC-3 BAWANA	9	315 kVA	Unplanned Outage	15-Feb-2024	15:34	15-Feb-2024	16:09	35	0.00001	EODB COMPLIANCE
286	15-Feb-2024	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	7	Other Outage	Unplanned Outage	15-Feb-2024	16:19	15-Feb-2024	16:40	21	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
287	15-Feb-2024	PART OF I BLK SEC-1 BAWANA	7	400 kVA	Unplanned Outage	15-Feb-2024	16:26	15-Feb-2024	16:49	23	0.00001	EODB COMPLIANCE
288	15-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	4	315 kVA	Unplanned Outage	15-Feb-2024	16:29	15-Feb-2024	17:12	43	0.00001	EODB COMPLIANCE
289	16-Feb-2024	PARTS OF SEC-2 O,N,J BLOCK BAWANA	148	Other Outage	Unplanned Outage	16-Feb-2024	05:12	16-Feb-2024	06:05	53	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
290	16-Feb-2024	PARTS OF SEC-2 O,N,J BLOCK BAWANA	87	Other Outage	Unplanned Outage	16-Feb-2024	05:12	16-Feb-2024	06:34	82	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
291	16-Feb-2024	PART OF FG BLOCK SEC-3 DSIDC BAWANA	7	Other Outage	Unplanned Outage	16-Feb-2024	10:42	16-Feb-2024	11:01	19	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
292	16-Feb-2024	PART OF E-1 SEC-5 BAWANA	4	315 kVA	Unplanned Outage	16-Feb-2024	10:47	16-Feb-2024	11:09	22	0.00001	EODB COMPLIANCE
293	16-Feb-2024	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	16-Feb-2024	10:51	16-Feb-2024	13:05	134	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
294	16-Feb-2024	PART OF I-BLOCK SEC-4 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	16-Feb-2024	11:06	16-Feb-2024	15:37	271	0.00008	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
295	16-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	16-Feb-2024	11:25	16-Feb-2024	13:22	117	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
296	16-Feb-2024	PART OF G BLK SEC-02 BAWANA	3	250 kVA	Unplanned Outage	16-Feb-2024	12:09	16-Feb-2024	12:48	39	0.00001	EODB COMPLIANCE
297	16-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	2	63 kVA	Unplanned Outage	16-Feb-2024	12:29	16-Feb-2024	12:52	23	0.00001	EODB COMPLIANCE
298	16-Feb-2024	PART OF E BLK SEC-02 BAWANA	7	250 kVA	Unplanned Outage	16-Feb-2024	13:31	16-Feb-2024	14:08	37	0.00001	EODB COMPLIANCE
299	16-Feb-2024	PART OF D-BLK SEC-4 BAWANA	5	Other Outage	Unplanned Outage	16-Feb-2024	14:16	16-Feb-2024	16:18	122	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
300	16-Feb-2024	PART OF G BLOCK SEC-4 POOTH KHURD BAWANA	3	Other Outage	Unplanned Outage	16-Feb-2024	14:30	16-Feb-2024	16:23	113	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
301	16-Feb-2024	PART OF K-1 BLK SEC-1. BAWANA	3	160 kVA	Unplanned Outage	16-Feb-2024	14:34	16-Feb-2024	15:00	26	0.00001	EODB COMPLIANCE
302	16-Feb-2024	PARTS OF KANJHAWLA VILLAGE BAWANA	63	Other Outage	Unplanned Outage	16-Feb-2024	16:06	16-Feb-2024	17:27	81	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
303	16-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	9	400 kVA	Unplanned Outage	16-Feb-2024	16:19	16-Feb-2024	16:53	34	0.00001	EODB COMPLIANCE
304	16-Feb-2024	PART OF I BLK SEC-1 BAWANA	5	Other Outage	Unplanned Outage	16-Feb-2024	16:34	16-Feb-2024	17:12	38	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
305	17-Feb-2024	PARTS OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	276	Other Outage	Unplanned Outage	17-Feb-2024	00:55	17-Feb-2024	01:33	38	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
306	17-Feb-2024	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	67	Other Outage	Unplanned Outage	17-Feb-2024	02:16	17-Feb-2024	02:43	27	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
307	17-Feb-2024	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	241	Other Outage	Planned Outage	17-Feb-2024	08:22	17-Feb-2024	17:05	523	0.00073	PSD ON INDUSTRIAL WEEKLY OFF
308	17-Feb-2024	PARTS OF A,B,G,E,F,H,J BLOCKS OF SEC - 4 DSIDC BAWANA	249	Other Outage	Planned Outage	17-Feb-2024	09:12	17-Feb-2024	17:58	526	0.00073	PLANNED OUTAGE
309	17-Feb-2024	PARTS OF SEC-2 O,N,J BLOCK BAWANA	86	Other Outage	Planned Outage	17-Feb-2024	09:33	17-Feb-2024	16:16	403	0.00134	PSD ON INDUSTRIAL WEEKLY OFF
310	17-Feb-2024	PARTS OF E BLK SEC-02 BAWANA	264	Other Outage	Planned Outage	17-Feb-2024	09:41	17-Feb-2024	17:45	484	0.00081	PSD ON INDUSTRIAL WEEKLY OFF
311	17-Feb-2024	PARTS OF DD MALL SECT-5 BAWANA	181	Other Outage	Planned Outage	17-Feb-2024	10:07	17-Feb-2024	17:59	472	0.00210	PSD ON INDUSTRIAL WEEKLY OFF
312	17-Feb-2024	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	386	Other Outage	Unplanned Outage	17-Feb-2024	10:09	17-Feb-2024	13:08	179	0.00055	FORCE MAJEURE/EXTERNAL FACTORS
313	17-Feb-2024	PARTS OF KANJHAWLA VILLAGE BAWANA	63	Other Outage	Unplanned Outage	17-Feb-2024	10:17	17-Feb-2024	12:09	112	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
314	17-Feb-2024	PARTS OF B BLOCK SEC-4 POOTH KHURD BAWANA	309	Other Outage	Planned Outage	17-Feb-2024	10:25	17-Feb-2024	17:02	397	0.00254	PSD ON INDUSTRIAL WEEKLY OFF
315	17-Feb-2024	PARTS OF A,F BLK SEC-2 DSIDC, DJB-TW NO-17 BAWANA	328	Other Outage	Planned Outage	17-Feb-2024	10:28	17-Feb-2024	17:18	410	0.00296	PSD ON INDUSTRIAL WEEKLY OFF
316	17-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	3	160 kVA	Unplanned Outage	17-Feb-2024	10:49	17-Feb-2024	11:35	46	0.00001	EODB COMPLIANCE
317	17-Feb-2024	PARTS OF B BLK SEC-2 POOTH KHURD BAWANA	183	Other Outage	Planned Outage	17-Feb-2024	11:12	17-Feb-2024	18:00	407	0.00113	PSD ON INDUSTRIAL WEEKLY OFF
318	17-Feb-2024	PARTS OF I BLK SEC-5 POOTH KHURD BAWANA	159	Other Outage	Planned Outage	17-Feb-2024	11:52	17-Feb-2024	12:49	57	0.00041	PSD ON INDUSTRIAL WEEKLY OFF
319	17-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	324	Other Outage	Planned Outage	17-Feb-2024	12:08	17-Feb-2024	17:07	298	0.00216	PSD ON INDUSTRIAL WEEKLY OFF
320	17-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	17-Feb-2024	12:43	17-Feb-2024	16:07	204	0.00006	EODB COMPLIANCE
321	17-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	7	315 kVA	Unplanned Outage	17-Feb-2024	14:00	17-Feb-2024	14:22	22	0.00001	EODB COMPLIANCE
322	17-Feb-2024	PART OF LM BLOCK SEC-3 DSIDC BAWANA	6	400 kVA	Unplanned Outage	17-Feb-2024	14:17	17-Feb-2024	14:50	33	0.00001	EODB COMPLIANCE
323	17-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	211	Other Outage	Unplanned Outage	17-Feb-2024	14:32	17-Feb-2024	18:32	240	0.00067	FORCE MAJEURE/EXTERNAL FACTORS
324	17-Feb-2024	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	163	Other Outage	Unplanned Outage	17-Feb-2024	14:45	17-Feb-2024	15:00	15	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
325	17-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	54	Other Outage	Unplanned Outage	17-Feb-2024	15:12	17-Feb-2024	18:31	199	0.00055	FORCE MAJEURE/EXTERNAL FACTORS
326	17-Feb-2024	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	67	Other Outage	Unplanned Outage	17-Feb-2024	22:08	17-Feb-2024	22:43	35	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
327	18-Feb-2024	PARTS OF VIJAY NAGAR, SKV DARYA PUR, MAIN BUS STAND BAWANA	647	Other Outage	Unplanned Outage	18-Feb-2024	13:00	18-Feb-2024	17:06	246	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
328	18-Feb-2024	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	3968	Other Outage	Unplanned Outage	18-Feb-2024	15:54	18-Feb-2024	16:30	36	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
329	18-Feb-2024	PARTS OF G BLK SEC-1 BAWANA	144	Other Outage	Unplanned Outage	18-Feb-2024	16:28	18-Feb-2024	17:28	60	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
330	19-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	324	Other Outage	Planned Outage	19-Feb-2024	06:05	19-Feb-2024	09:20	194	0.00141	PLANNED OUTAGE
331	19-Feb-2024	PART OF F BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	19-Feb-2024	09:35	19-Feb-2024	10:47	72	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
332	19-Feb-2024	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL BAWANA	937	Other Outage	Unplanned Outage	19-Feb-2024	10:00	19-Feb-2024	10:41	41	0.00017	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
333	19-Feb-2024	PART OF PUNJAB KHOR BAWANA	18	Other Outage	Planned Outage	19-Feb-2024	10:08	19-Feb-2024	17:41	453	0.00025	PLANNED OUTAGE
334	19-Feb-2024	PARTS OF E BLK SEC-02 BAWANA	217	Other Outage	Unplanned Outage	19-Feb-2024	10:17	19-Feb-2024	13:20	183	0.00061	FORCE MAJEURE/EXTERNAL FACTORS
335	19-Feb-2024	PARTS OF VIJAY NAGAR, SKV DARYA PUR, MAIN BUS STAND BAWANA	647	Other Outage	Unplanned Outage	19-Feb-2024	10:51	19-Feb-2024	16:26	335	0.00093	FORCE MAJEURE/EXTERNAL FACTORS
336	19-Feb-2024	PARTS OF K-1 BLK SEC-1 POOTH KHURD BAWANA	54	Other Outage	Unplanned Outage	19-Feb-2024	11:04	19-Feb-2024	11:30	26	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
337	19-Feb-2024	PART OF SEC-5 B BLOCK BAWANA	5	Other Outage	Unplanned Outage	19-Feb-2024	11:08	19-Feb-2024	16:43	335	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
338	19-Feb-2024	PART OF INTERCONNECTOR-1 BAWANA	1	100 kVA	Planned Outage	19-Feb-2024	11:21	19-Feb-2024	13:55	154	0.00009	PLANNED OUTAGE
339	19-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	7	400 kVA	Unplanned Outage	19-Feb-2024	11:21	19-Feb-2024	12:48	87	0.00002	EODB COMPLIANCE
340	19-Feb-2024	PARTS OF F-167 SEC-2 DSIDC BAWANA	350	Other Outage	Unplanned Outage	19-Feb-2024	11:40	19-Feb-2024	11:55	15	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
341	19-Feb-2024	PART OF NMO BLOCK SEC-5 POOTH KHURD BAWANA	4	160 kVA	Planned Outage	19-Feb-2024	11:48	19-Feb-2024	14:20	152	0.00004	PLANNED OUTAGE
342	19-Feb-2024	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	936	Other Outage	Unplanned Outage	19-Feb-2024	12:03	19-Feb-2024	13:10	66	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
343	19-Feb-2024	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	936	Other Outage	Unplanned Outage	19-Feb-2024	13:30	19-Feb-2024	15:43	133	0.00037	FORCE MAJEURE/EXTERNAL FACTORS
344	19-Feb-2024	PARTS OF CISF DMRC FAMILY DSIDC FLATS CNG ROAD SEC 4 BAWANA	178	Other Outage	Unplanned Outage	19-Feb-2024	14:21	19-Feb-2024	15:35	74	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
345	19-Feb-2024	PARTS OF CISF DMRC FAMILY DSIDC FLATS CNG ROAD SEC 4 BAWANA	259	Other Outage	Unplanned Outage	19-Feb-2024	14:21	19-Feb-2024	17:55	214	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
346	19-Feb-2024	PARTS OF SEC-5 B, N & O BLOCK BAWANA	108	Other Outage	Unplanned Outage	19-Feb-2024	14:23	19-Feb-2024	15:14	51	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
347	19-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	4	315 kVA	Planned Outage	19-Feb-2024	14:38	19-Feb-2024	16:37	119	0.00007	PLANNED OUTAGE
348	19-Feb-2024	PART OF PUNJAB KHOR BAWANA	1	63 kVA	Unplanned Outage	19-Feb-2024	14:47	19-Feb-2024	15:07	20	0.00001	EODB COMPLIANCE
349	19-Feb-2024	PART OF E-1 SEC-5 BAWANA	6	100 kVA	Unplanned Outage	19-Feb-2024	15:01	19-Feb-2024	15:58	57	0.00002	EODB COMPLIANCE
350	19-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	8	160 kVA	Unplanned Outage	19-Feb-2024	15:28	19-Feb-2024	15:55	27	0.00001	EODB COMPLIANCE
351	19-Feb-2024	PARTS OF F-167 SEC-2 DSIDC BAWANA	347	Other Outage	Unplanned Outage	19-Feb-2024	16:44	19-Feb-2024	17:22	38	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
352	20-Feb-2024	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	1319	Other Outage	Unplanned Outage	20-Feb-2024	00:20	20-Feb-2024	01:27	66	0.00064	FORCE MAJEURE/EXTERNAL FACTORS
353	20-Feb-2024	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	341	Other Outage	Unplanned Outage	20-Feb-2024	00:20	20-Feb-2024	02:33	132	0.00055	FORCE MAJEURE/EXTERNAL FACTORS
354	20-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	347	Other Outage	Unplanned Outage	20-Feb-2024	00:21	20-Feb-2024	01:48	86	0.00060	FORCE MAJEURE/EXTERNAL FACTORS
355	20-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	211	Other Outage	Unplanned Outage	20-Feb-2024	00:23	20-Feb-2024	01:10	46	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
356	20-Feb-2024	PARTS OF E BLK SEC-02 BAWANA	217	Other Outage	Unplanned Outage	20-Feb-2024	00:41	20-Feb-2024	01:54	73	0.00091	FORCE MAJEURE/EXTERNAL FACTORS
357	20-Feb-2024	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	302	Other Outage	Planned Outage	20-Feb-2024	05:57	20-Feb-2024	11:06	309	0.00275	PLANNED OUTAGE
358	20-Feb-2024	PARTS OF E-1 SEC-5 POOTH KHURD BAWANA	328	Other Outage	Planned Outage	20-Feb-2024	06:18	20-Feb-2024	09:26	188	0.00120	PLANNED OUTAGE
359	20-Feb-2024	PARTS OF INTERCONNECTOR - 1 AND POOTH KHURD VILLAGE BAWANA	317	Other Outage	Unplanned Outage	20-Feb-2024	07:40	20-Feb-2024	08:16	36	0.00035	FORCE MAJEURE/EXTERNAL FACTORS
360	20-Feb-2024	PART OF E-1 SEC-5 BAWANA	5	Other Outage	Unplanned Outage	20-Feb-2024	09:40	20-Feb-2024	11:32	112	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
361	20-Feb-2024	PARTS OF C BLOCK SEC-3 POOTH KHURD BAWANA	246	Other Outage	Unplanned Outage	20-Feb-2024	09:47	20-Feb-2024	11:29	103	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
362	20-Feb-2024	PARTS OF BULLA COLONY BAWANA	1320	Other Outage	Planned Outage	20-Feb-2024	10:06	20-Feb-2024	17:58	472	0.00341	PLANNED OUTAGE
363	20-Feb-2024	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	18	Other Outage	Unplanned Outage	20-Feb-2024	10:13	20-Feb-2024	11:28	75	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
364	20-Feb-2024	PART OF BULLA COLONY BAWANA	18	Other Outage	Planned Outage	20-Feb-2024	10:15	20-Feb-2024	17:52	457	0.00025	PLANNED OUTAGE
365	20-Feb-2024	PART OF TUBEWELL NO - 1322 BAWANA	4	315 kVA	Unplanned Outage	20-Feb-2024	11:28	20-Feb-2024	12:04	36	0.00001	EODB COMPLIANCE
366	20-Feb-2024	PART OF G BLK SEC-1 BAWANA	6	250 kVA	Unplanned Outage	20-Feb-2024	11:49	20-Feb-2024	12:21	32	0.00001	EODB COMPLIANCE
367	20-Feb-2024	PART OF G-BLOCK SEC-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	20-Feb-2024	11:52	20-Feb-2024	14:03	131	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
368	20-Feb-2024	PART OF M BLOCK SEC-3 DSIDC BAWANA	3	Other Outage	Unplanned Outage	20-Feb-2024	12:02	20-Feb-2024	14:00	118	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
369	20-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	6	Other Outage	Unplanned Outage	20-Feb-2024	12:30	20-Feb-2024	16:34	244	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
370	20-Feb-2024	PART OF FG-27 SEC-3 BAWANA	7	250 kVA	Unplanned Outage	20-Feb-2024	14:12	20-Feb-2024	16:12	120	0.00003	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
371	20-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	3	Other Outage	Unplanned Outage	20-Feb-2024	15:00	20-Feb-2024	16:57	117	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
372	20-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	3	Other Outage	Unplanned Outage	20-Feb-2024	15:52	20-Feb-2024	17:20	88	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
373	20-Feb-2024	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	918	Other Outage	Unplanned Outage	20-Feb-2024	16:00	20-Feb-2024	16:57	57	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
374	20-Feb-2024	PART OF SEC-5 B BLOCK BAWANA	2	Other Outage	Unplanned Outage	20-Feb-2024	16:12	20-Feb-2024	16:40	28	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
375	20-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	18	Other Outage	Unplanned Outage	20-Feb-2024	21:45	20-Feb-2024	22:13	28	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
376	20-Feb-2024	PARTS OF A,F,G, H, I BLOCKS OF SEC.- 1 DSIDC BAWANA	172	Other Outage	Unplanned Outage	20-Feb-2024	21:45	20-Feb-2024	22:14	29	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
377	20-Feb-2024	PARTS OF A,F,G, H, I BLOCKS OF SEC.- 1 DSIDC BAWANA	323	Other Outage	Unplanned Outage	20-Feb-2024	21:45	20-Feb-2024	22:35	50	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
378	21-Feb-2024	PART OF CHANPUR MAJRA BAWANA	20	Other Outage	Planned Outage	21-Feb-2024	04:51	21-Feb-2024	06:26	95	0.00005	PLANNED OUTAGE
379	21-Feb-2024	PARTS OF JYONTI VILLAGE BAWANA	1752	Other Outage	Planned Outage	21-Feb-2024	04:59	21-Feb-2024	11:05	366	0.00142	PLANNED OUTAGE
380	21-Feb-2024	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	152	Other Outage	Planned Outage	21-Feb-2024	06:02	21-Feb-2024	09:41	219	0.00024	PLANNED OUTAGE
381	21-Feb-2024	PART OF INTERCONNECTOR-1 BAWANA	1	Other Outage	Unplanned Outage	21-Feb-2024	10:07	21-Feb-2024	10:56	49	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
382	21-Feb-2024	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	7	100 kVA	Unplanned Outage	21-Feb-2024	10:37	21-Feb-2024	11:44	67	0.00002	EODB COMPLIANCE
383	21-Feb-2024	PART OF DJB RAW WATER PUMP HOUSE BAWANA	3	160 kVA	Planned Outage	21-Feb-2024	10:42	21-Feb-2024	13:22	160	0.00009	PLANNED OUTAGE
384	21-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	4	250 kVA	Unplanned Outage	21-Feb-2024	10:47	21-Feb-2024	11:07	20	0.00001	EODB COMPLIANCE
385	21-Feb-2024	PART OF E-1 SEC-5 BAWANA	5	400 kVA	Unplanned Outage	21-Feb-2024	10:59	21-Feb-2024	11:46	47	0.00001	EODB COMPLIANCE
386	21-Feb-2024	PART OF G BLK SEC-02 BAWANA	3	Other Outage	Planned Outage	21-Feb-2024	11:03	21-Feb-2024	17:54	411	0.00011	PLANNED OUTAGE
387	21-Feb-2024	PARTS OF JYONTI VILLAGE BAWANA	1692	Other Outage	Unplanned Outage	21-Feb-2024	11:09	21-Feb-2024	11:46	37	0.00036	INTERRUPTION DUE TO FAULT
388	21-Feb-2024	PART OF D BLOCK SEC-5 BAWANA	5	250 kVA	Unplanned Outage	21-Feb-2024	11:13	21-Feb-2024	11:39	26	0.00001	EODB COMPLIANCE
389	21-Feb-2024	PART OF DJB RAW WATER PUMP HOUSE BAWANA	1	100 kVA	Planned Outage	21-Feb-2024	11:40	21-Feb-2024	13:24	104	0.00006	PLANNED OUTAGE
390	21-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	4	63 kVA	Planned Outage	21-Feb-2024	11:51	21-Feb-2024	13:27	96	0.00008	PLANNED OUTAGE
391	21-Feb-2024	PART OF M-BLOCK SEC-2 POOTH KHURD BAWANA	4	400 kVA	Unplanned Outage	21-Feb-2024	12:17	21-Feb-2024	12:41	24	0.00001	EODB COMPLIANCE
392	21-Feb-2024	PART OF E-1 SEC-5 BAWANA	4	250 kVA	Unplanned Outage	21-Feb-2024	12:24	21-Feb-2024	12:56	32	0.00001	EODB COMPLIANCE
393	21-Feb-2024	PART OF FG-27 SEC-3 BAWANA	7	315 kVA	Unplanned Outage	21-Feb-2024	12:46	21-Feb-2024	13:27	41	0.00001	EODB COMPLIANCE
394	21-Feb-2024	PART OF D BLK SEC-5 BAWANA	7	315 kVA	Unplanned Outage	21-Feb-2024	13:00	21-Feb-2024	13:28	28	0.00001	EODB COMPLIANCE
395	21-Feb-2024	PART OF UPKAR COLONY NO-2 BAWANA	1	Other Outage	Unplanned Outage	21-Feb-2024	13:17	21-Feb-2024	16:21	184	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
396	21-Feb-2024	PART OF C-BLK SEC-4 BAWANA	3	250 kVA	Unplanned Outage	21-Feb-2024	13:21	21-Feb-2024	13:41	20	0.00001	EODB COMPLIANCE
397	21-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	2	250 kVA	Planned Outage	21-Feb-2024	14:05	21-Feb-2024	16:56	171	0.00009	PLANNED OUTAGE
398	21-Feb-2024	PART OF POOTH VILLAGE BAWANA	6	400 kVA	Unplanned Outage	21-Feb-2024	14:14	21-Feb-2024	15:01	47	0.00001	EODB COMPLIANCE
399	21-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	3	250 kVA	Planned Outage	21-Feb-2024	14:18	21-Feb-2024	15:54	96	0.00003	PLANNED OUTAGE
400	21-Feb-2024	PART OF L BLOCK SEC-2 DSIDC BAWANA	3	100 kVA	Planned Outage	21-Feb-2024	14:20	21-Feb-2024	17:30	190	0.00011	PLANNED OUTAGE
401	21-Feb-2024	PART OF FG-27 SEC-3 BAWANA	7	315 kVA	Unplanned Outage	21-Feb-2024	14:21	21-Feb-2024	15:12	51	0.00001	EODB COMPLIANCE
402	21-Feb-2024	PART OF I BLK SEC-5 BAWANA	4	160 kVA	Unplanned Outage	21-Feb-2024	14:37	21-Feb-2024	15:20	43	0.00001	EODB COMPLIANCE
403	21-Feb-2024	PART OF INTERCONNECTOR-1 BAWANA	7	315 kVA	Unplanned Outage	21-Feb-2024	14:57	21-Feb-2024	15:36	39	0.00001	EODB COMPLIANCE
404	21-Feb-2024	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	6	Other Outage	Unplanned Outage	21-Feb-2024	14:58	21-Feb-2024	15:12	14	0.000004	FORCE MAJEURE/EXTERNAL FACTORS
405	21-Feb-2024	PART OF POOTH VILLAGE BAWANA	7	250 kVA	Unplanned Outage	21-Feb-2024	15:05	21-Feb-2024	15:34	29	0.00001	EODB COMPLIANCE
406	21-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	2	250 kVA	Unplanned Outage	21-Feb-2024	16:00	21-Feb-2024	16:32	32	0.00001	EODB COMPLIANCE
407	22-Feb-2024	PARTS OF C BLOCK SEC-3 POOTH KHURD BAWANA	264	Other Outage	Planned Outage	22-Feb-2024	07:05	22-Feb-2024	08:46	101	0.00017	EODB COMPLIANCE
408	22-Feb-2024	PART OF SEC-2 O,N,J BLOCK BAWANA	6	Other Outage	Unplanned Outage	22-Feb-2024	10:34	22-Feb-2024	13:00	146	0.00004	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
409	22-Feb-2024	PART OF O,N,L BLOCK SEC-3 BAWANA	5	315 kVA	Unplanned Outage	22-Feb-2024	10:59	22-Feb-2024	11:57	58	0.00002	EODB COMPLIANCE
410	22-Feb-2024	PART OF B BLK SEC-1 POOTH KHURD BAWANA	6	315 kVA	Unplanned Outage	22-Feb-2024	11:18	22-Feb-2024	11:48	30	0.00001	EODB COMPLIANCE
411	22-Feb-2024	PARTS OF A,F BLK SEC-2 DSIDC, DJB-TW NO-17 BAWANA	37	Other Outage	Planned Outage	22-Feb-2024	11:29	22-Feb-2024	15:57	268	0.00015	PLANNED OUTAGE
412	22-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	3	63 kVA	Unplanned Outage	22-Feb-2024	11:38	22-Feb-2024	12:04	26	0.00001	EODB COMPLIANCE
413	22-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	18	Other Outage	Unplanned Outage	22-Feb-2024	11:55	22-Feb-2024	15:55	240	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
414	22-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	2	Other Outage	Unplanned Outage	22-Feb-2024	11:56	22-Feb-2024	15:55	239	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
415	22-Feb-2024	PART OF DD MALL SEC-5 BAWANA	3	315 kVA	Unplanned Outage	22-Feb-2024	12:29	22-Feb-2024	13:25	56	0.00002	EODB COMPLIANCE
416	22-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	3	63 kVA	Unplanned Outage	22-Feb-2024	12:35	22-Feb-2024	12:56	21	0.00001	EODB COMPLIANCE
417	22-Feb-2024	PART OF D-BLK SEC-4 BAWANA	5	100 kVA	Unplanned Outage	22-Feb-2024	12:49	22-Feb-2024	14:00	71	0.00002	EODB COMPLIANCE
418	22-Feb-2024	PART OF C BLOCK SEC-3 POOTH KHURD BAWANA	10	400 kVA	Unplanned Outage	22-Feb-2024	13:09	22-Feb-2024	14:31	82	0.00002	EODB COMPLIANCE
419	22-Feb-2024	PART OF POOTH VILLAGE BAWANA	8	63 kVA	Unplanned Outage	22-Feb-2024	14:26	22-Feb-2024	14:47	21	0.00001	EODB COMPLIANCE
420	22-Feb-2024	PART OF D BLOCK SEC-2 BAWANA	1	63 kVA	Unplanned Outage	22-Feb-2024	14:38	22-Feb-2024	15:20	42	0.00001	EODB COMPLIANCE
421	22-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	2	160 kVA	Unplanned Outage	22-Feb-2024	14:56	22-Feb-2024	15:28	32	0.00001	EODB COMPLIANCE
422	22-Feb-2024	PART OF K-31 SEC-5 BAWANA	5	315 kVA	Unplanned Outage	22-Feb-2024	15:11	22-Feb-2024	15:47	36	0.00001	EODB COMPLIANCE
423	22-Feb-2024	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	6	315 kVA	Unplanned Outage	22-Feb-2024	15:23	22-Feb-2024	15:51	28	0.00001	EODB COMPLIANCE
424	22-Feb-2024	PART OF D BLOCK SEC-2 BAWANA	6	100 kVA	Unplanned Outage	22-Feb-2024	15:43	22-Feb-2024	16:37	54	0.00002	EODB COMPLIANCE
425	22-Feb-2024	PART OF K-31 SEC-5 BAWANA	2	315 kVA	Unplanned Outage	22-Feb-2024	15:53	22-Feb-2024	16:56	63	0.00002	EODB COMPLIANCE
426	22-Feb-2024	PART OF E BLK SEC-02 BAWANA	10	500 kVA	Unplanned Outage	22-Feb-2024	16:19	22-Feb-2024	17:18	59	0.00002	EODB COMPLIANCE
427	22-Feb-2024	PARTS OF G BLK SEC-1 BAWANA	144	Other Outage	Unplanned Outage	22-Feb-2024	19:21	22-Feb-2024	20:15	54	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
428	23-Feb-2024	PARTS OF FG- 27 SEC-3 POOTH KHURD BAWANA	284	Other Outage	Planned Outage	23-Feb-2024	06:11	23-Feb-2024	08:50	158	0.00044	PLANNED OUTAGE
429	23-Feb-2024	PARTS OF AIR FORCE, CRPF & TUBEWELL NO - 1322 BAWANA	191	Other Outage	Planned Outage	23-Feb-2024	07:05	23-Feb-2024	08:35	90	0.00025	PLANNED OUTAGE
430	23-Feb-2024	PARTS OF JYONTI VILLAGE BAWANA	1752	Other Outage	Planned Outage	23-Feb-2024	10:06	23-Feb-2024	17:57	471	0.00471	PLANNED OUTAGE
431	23-Feb-2024	PART OF CHANPUR MAJRA BAWANA	20	Other Outage	Planned Outage	23-Feb-2024	10:17	23-Feb-2024	17:13	416	0.00116	PLANNED OUTAGE
432	23-Feb-2024	PART OF K-31 SEC-5 BAWANA	8	250 kVA	Planned Outage	23-Feb-2024	10:40	23-Feb-2024	13:25	165	0.00014	PLANNED OUTAGE
433	23-Feb-2024	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD BAWANA	289	Other Outage	Planned Outage	23-Feb-2024	10:55	23-Feb-2024	15:56	301	0.00042	PLANNED OUTAGE
434	23-Feb-2024	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1 BAWANA	1053	Other Outage	Planned Outage	23-Feb-2024	11:01	23-Feb-2024	18:50	469	0.00261	FORCE MAJEURE DUE TO SABOTAGE
435	23-Feb-2024	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	7	Other Outage	Unplanned Outage	23-Feb-2024	11:21	23-Feb-2024	15:35	254	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
436	23-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	4	315 kVA	Unplanned Outage	23-Feb-2024	11:45	23-Feb-2024	12:11	26	0.00001	EODB COMPLIANCE
437	23-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	4	Other Outage	Unplanned Outage	23-Feb-2024	12:03	23-Feb-2024	12:25	22	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
438	23-Feb-2024	PART OF P BLOCKS OF SEC.-1 DSIDC BAWANA	7	Other Outage	Unplanned Outage	23-Feb-2024	12:30	23-Feb-2024	16:45	255	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
439	23-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	5	Other Outage	Unplanned Outage	23-Feb-2024	12:38	23-Feb-2024	13:14	36	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
440	23-Feb-2024	PART OF LM BLOCK SEC-3 DSIDC BAWANA	4	315 kVA	Unplanned Outage	23-Feb-2024	12:39	23-Feb-2024	13:19	40	0.00001	EODB COMPLIANCE
441	23-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	3	160 kVA	Unplanned Outage	23-Feb-2024	12:44	23-Feb-2024	13:14	30	0.00001	EODB COMPLIANCE
442	23-Feb-2024	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	112	Other Outage	Unplanned Outage	23-Feb-2024	13:09	23-Feb-2024	14:00	51	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
443	23-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	3	160 kVA	Unplanned Outage	23-Feb-2024	14:12	23-Feb-2024	14:35	23	0.00001	EODB COMPLIANCE
444	23-Feb-2024	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	6	315 kVA	Unplanned Outage	23-Feb-2024	14:58	23-Feb-2024	15:13	15	0.000004	EODB COMPLIANCE
445	23-Feb-2024	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	1	160 kVA	Unplanned Outage	23-Feb-2024	15:15	23-Feb-2024	15:42	27	0.00001	EODB COMPLIANCE
446	23-Feb-2024	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	926	Other Outage	Unplanned Outage	23-Feb-2024	15:23	23-Feb-2024	16:35	72	0.00040	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
447	23-Feb-2024	PART OF K-31 SEC-5 BAWANA	5	400 kVA	Unplanned Outage	23-Feb-2024	16:12	23-Feb-2024	16:37	25	0.00001	EODB COMPLIANCE
448	23-Feb-2024	PART OF G BLK SEC-1 BAWANA	1	315 kVA	Unplanned Outage	23-Feb-2024	16:19	23-Feb-2024	17:13	54	0.00002	EODB COMPLIANCE
449	23-Feb-2024	PARTS OF MANGALAM HOSPITAL BAWANA	430	Other Outage	Unplanned Outage	23-Feb-2024	16:40	23-Feb-2024	23:52	432	0.00120	FORCE MAJEURE/EXTERNAL FACTORS
450	23-Feb-2024	PARTS OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	386	Other Outage	Unplanned Outage	23-Feb-2024	17:55	23-Feb-2024	19:10	75	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
451	24-Feb-2024	PARTS OF SEC-3 G,C & F BLOCK, HASSH MUSIC MAHAL, GANGA TOLI ROAD, TBD BAWANA	221	Other Outage	Unplanned Outage	24-Feb-2024	07:19	24-Feb-2024	12:47	328	0.00100	FORCE MAJEURE/EXTERNAL FACTORS
452	24-Feb-2024	PARTS OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	276	Other Outage	Planned Outage	24-Feb-2024	09:14	24-Feb-2024	17:36	502	0.00502	PSD ON INDUSTRIAL WEEKLY OFF
453	24-Feb-2024	PARTS OF I-BLOCK SEC-4 POOTH KHURD BAWANA	200	Other Outage	Planned Outage	24-Feb-2024	09:26	24-Feb-2024	17:06	460	0.00064	PSD ON INDUSTRIAL WEEKLY OFF
454	24-Feb-2024	PARTS OF I-BLOCK SEC-4 POOTH KHURD BAWANA	168	Other Outage	Planned Outage	24-Feb-2024	09:44	24-Feb-2024	17:14	450	0.00050	PSD ON INDUSTRIAL WEEKLY OFF
455	24-Feb-2024	PART OF C BLK SEC-02 BAWANA	5	315 kVA	Unplanned Outage	24-Feb-2024	10:23	24-Feb-2024	11:39	76	0.00002	EODB COMPLIANCE
456	24-Feb-2024	PARTS OF G-BLOCK SEC-3 POOTH KHURD BAWANA	307	Other Outage	Planned Outage	24-Feb-2024	10:29	24-Feb-2024	17:45	435	0.00278	PSD ON INDUSTRIAL WEEKLY OFF
457	24-Feb-2024	PARTS OF INTERCONNECTOR - 3 AND POOTH KHURD VILLAGE BAWANA	255	Other Outage	Planned Outage	24-Feb-2024	10:50	24-Feb-2024	18:35	464	0.00039	PSD ON INDUSTRIAL WEEKLY OFF
458	24-Feb-2024	PARTS OF B BLK SEC-2 POOTH KHURD BAWANA	183	Other Outage	Planned Outage	24-Feb-2024	11:03	24-Feb-2024	17:54	411	0.00057	PSD ON INDUSTRIAL WEEKLY OFF
459	24-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	2	160 kVA	Unplanned Outage	24-Feb-2024	11:09	24-Feb-2024	11:56	47	0.00001	EODB COMPLIANCE
460	24-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	32	Other Outage	Planned Outage	24-Feb-2024	11:11	24-Feb-2024	17:10	359	0.00100	PSD ON INDUSTRIAL WEEKLY OFF
461	24-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	92	Other Outage	Planned Outage	24-Feb-2024	11:19	24-Feb-2024	17:27	368	0.00112	PSD ON INDUSTRIAL WEEKLY OFF
462	24-Feb-2024	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	157	Other Outage	Planned Outage	24-Feb-2024	11:34	24-Feb-2024	17:48	374	0.00052	PSD ON INDUSTRIAL WEEKLY OFF
463	24-Feb-2024	PART OF E BLK SEC-02 BAWANA	7	250 kVA	Unplanned Outage	24-Feb-2024	12:04	24-Feb-2024	12:28	24	0.00001	EODB COMPLIANCE
464	24-Feb-2024	PARTS OF A,B,G,E,F,H,J BLOCKS OF SEC - 4 DSIDC BAWANA	249	Other Outage	Planned Outage	24-Feb-2024	12:06	24-Feb-2024	18:18	371	0.00052	FORCE MAJEURE DUE TO SABOTAGE
465	24-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	3	315 kVA	Unplanned Outage	24-Feb-2024	12:59	24-Feb-2024	14:00	61	0.00002	EODB COMPLIANCE
466	24-Feb-2024	PART OF E-BLOCK SEC-4 POOTH KHURD BAWANA	9	315 kVA	Unplanned Outage	24-Feb-2024	13:03	24-Feb-2024	13:35	32	0.00001	EODB COMPLIANCE
467	24-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	9	315 kVA	Unplanned Outage	24-Feb-2024	13:28	24-Feb-2024	14:05	37	0.00001	EODB COMPLIANCE
468	24-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	5	250 kVA	Unplanned Outage	24-Feb-2024	14:25	24-Feb-2024	14:53	28	0.00001	EODB COMPLIANCE
469	24-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	2	100 kVA	Unplanned Outage	24-Feb-2024	15:30	24-Feb-2024	16:04	34	0.00001	EODB COMPLIANCE
470	24-Feb-2024	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL BAWANA	242	Other Outage	Unplanned Outage	24-Feb-2024	15:44	24-Feb-2024	16:00	16	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
471	24-Feb-2024	PARTS OF UMRAD FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	60	Other Outage	Unplanned Outage	24-Feb-2024	15:54	24-Feb-2024	16:16	22	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
472	24-Feb-2024	PARTS OF INTERCONNECTOR - 3 AND POOTH KHURD VILLAGE BAWANA	307	Other Outage	Unplanned Outage	24-Feb-2024	18:36	24-Feb-2024	20:52	136	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
473	25-Feb-2024	PARTS OF E-1 SEC-5 POOTH KHURD BAWANA	74	Other Outage	Unplanned Outage	25-Feb-2024	09:46	25-Feb-2024	11:23	97	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
474	25-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	1	Other Outage	Unplanned Outage	25-Feb-2024	10:30	25-Feb-2024	11:47	77	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
475	25-Feb-2024	PARTS OF E-1 SEC-5 POOTH KHURD BAWANA	85	Other Outage	Unplanned Outage	25-Feb-2024	10:37	25-Feb-2024	11:23	46	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
476	25-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	18	Other Outage	Unplanned Outage	25-Feb-2024	10:46	25-Feb-2024	11:47	61	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
477	25-Feb-2024	PARTS OF O,N,L BLOCK SEC-3 POOTH KHURD BAWANA	255	Other Outage	Unplanned Outage	25-Feb-2024	11:04	25-Feb-2024	13:20	136	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
478	25-Feb-2024	PART OF BULLA COLONY BAWANA	18	Other Outage	Planned Outage	25-Feb-2024	11:14	25-Feb-2024	15:55	281	0.00023	PLANNED OUTAGE
479	25-Feb-2024	PARTS OF LADPUR VILLAGE BAWANA	1320	Other Outage	Planned Outage	25-Feb-2024	11:27	25-Feb-2024	15:50	263	0.00190	PLANNED OUTAGE
480	25-Feb-2024	PARTS OF O,N,L BLOCK SEC-3 POOTH KHURD BAWANA	23	Other Outage	Unplanned Outage	25-Feb-2024	12:32	25-Feb-2024	13:20	48	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
481	25-Feb-2024	PARTS OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	276	Other Outage	Unplanned Outage	25-Feb-2024	17:24	25-Feb-2024	17:39	15	0.00042	FORCE MAJEURE/EXTERNAL FACTORS
482	26-Feb-2024	PART OF I BLOCK SECTOR-3 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	26-Feb-2024	08:13	26-Feb-2024	08:30	17	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
483	26-Feb-2024	PARTS OF PUNJAB KHOR, JATHKHOR, QUTUBGARDH (ARA COLONY), QUTUBGARDH(BALAJIENCLAVE) BAWANA	224	Other Outage	Planned Outage	26-Feb-2024	10:20	26-Feb-2024	17:20	420	0.00047	PLANNED OUTAGE
484	26-Feb-2024	PART OF PUNJAB KHOR BAWANA	18	Other Outage	Planned Outage	26-Feb-2024	10:23	26-Feb-2024	14:30	247	0.00014	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
485	26-Feb-2024	PART OF F BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	26-Feb-2024	10:55	26-Feb-2024	12:55	120	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
486	26-Feb-2024	PARTS OF N-3 SEC-5 AND N-4,SEC- 5 BAWANA	1971	Other Outage	Planned Outage	26-Feb-2024	10:57	26-Feb-2024	17:58	421	0.00234	PLANNED OUTAGE
487	26-Feb-2024	PART OF F BLK SEC-1 BAWANA	4	Other Outage	Unplanned Outage	26-Feb-2024	11:07	26-Feb-2024	13:17	130	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
488	26-Feb-2024	PART OF LM BLOCK SEC-1 BAWANA	4	160 kVA	Unplanned Outage	26-Feb-2024	11:08	26-Feb-2024	11:43	35	0.00001	EODB COMPLIANCE
489	26-Feb-2024	PART OF NMO BLOCK SEC-5 POOTH KHURD BAWANA	3	315 kVA	Unplanned Outage	26-Feb-2024	11:13	26-Feb-2024	11:57	44	0.00001	EODB COMPLIANCE
490	26-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	2	Other Outage	Unplanned Outage	26-Feb-2024	11:16	26-Feb-2024	14:51	215	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
491	26-Feb-2024	PART OF LM BLOCK SEC-3 DSIDC BAWANA	4	Other Outage	Unplanned Outage	26-Feb-2024	11:30	26-Feb-2024	14:03	153	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
492	26-Feb-2024	PART OF VILL. KANJHAWLA BAWANA	16	Other Outage	Planned Outage	26-Feb-2024	11:46	26-Feb-2024	16:57	311	0.00095	PLANNED OUTAGE
493	26-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	1	160 kVA	Unplanned Outage	26-Feb-2024	12:31	26-Feb-2024	13:28	57	0.00002	EODB COMPLIANCE
494	26-Feb-2024	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	6	160 kVA	Unplanned Outage	26-Feb-2024	12:58	26-Feb-2024	13:35	37	0.00001	EODB COMPLIANCE
495	26-Feb-2024	PART OF F BLK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	26-Feb-2024	14:14	26-Feb-2024	16:27	133	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
496	26-Feb-2024	PART OF NMO BLOCK SEC-5 POOTH KHURD BAWANA	5	160 kVA	Unplanned Outage	26-Feb-2024	14:26	26-Feb-2024	15:07	41	0.00001	EODB COMPLIANCE
497	26-Feb-2024	PART OF F BLK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	26-Feb-2024	14:30	26-Feb-2024	16:32	122	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
498	26-Feb-2024	PART OF E BLK SEC-5 BAWANA	5	315 kVA	Unplanned Outage	26-Feb-2024	14:32	26-Feb-2024	15:02	30	0.00001	EODB COMPLIANCE
499	26-Feb-2024	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL BAWANA	187	Other Outage	Unplanned Outage	26-Feb-2024	15:19	26-Feb-2024	15:59	40	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
500	26-Feb-2024	PART OF INTERCONNECTOR-1 BAWANA	1	100 kVA	Unplanned Outage	26-Feb-2024	15:40	26-Feb-2024	16:40	60	0.00002	EODB COMPLIANCE
501	26-Feb-2024	PART OF ARIHANT SQUARE SHOPING COMPLEX BAWANA	2	Other Outage	Unplanned Outage	26-Feb-2024	15:51	26-Feb-2024	17:05	74	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
502	26-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	26-Feb-2024	16:11	26-Feb-2024	16:42	31	0.00001	EODB COMPLIANCE
503	26-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	211	Other Outage	Unplanned Outage	26-Feb-2024	16:53	26-Feb-2024	17:28	35	0.00115	FORCE MAJEURE/EXTERNAL FACTORS
504	26-Feb-2024	PART OF LM BLOCK SEC-1 DSIDC BAWANA	2	Other Outage	Unplanned Outage	26-Feb-2024	21:53	26-Feb-2024	23:13	80	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
505	26-Feb-2024	PARTS OF LM BLOCK SEC-1 DSIDC BAWANA	262	Other Outage	Unplanned Outage	26-Feb-2024	22:38	26-Feb-2024	23:13	35	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
506	27-Feb-2024	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL BAWANA	242	Other Outage	Unplanned Outage	27-Feb-2024	02:45	27-Feb-2024	03:13	28	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
507	27-Feb-2024	PARTS OF O,N,L BLOCK SEC-3 POOTH KHURD BAWANA	284	Other Outage	Unplanned Outage	27-Feb-2024	08:12	27-Feb-2024	09:40	88	0.00110	FORCE MAJEURE/EXTERNAL FACTORS
508	27-Feb-2024	PARTS OF ESS-1 & 2 BAWANA	1096	Other Outage	Planned Outage	27-Feb-2024	09:59	27-Feb-2024	17:38	459	0.00153	PLANNED OUTAGE
509	27-Feb-2024	PARTS OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	276	Other Outage	Unplanned Outage	27-Feb-2024	10:15	27-Feb-2024	10:43	28	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
510	27-Feb-2024	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA	642	Other Outage	Planned Outage	27-Feb-2024	10:37	27-Feb-2024	11:43	66	0.00011	PLANNED OUTAGE
511	27-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	3	Other Outage	Unplanned Outage	27-Feb-2024	11:15	27-Feb-2024	16:02	287	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
512	27-Feb-2024	PART OF L.C.H.-3164 BLOCK-8 DSIDC BAWANA	20	Other Outage	Unplanned Outage	27-Feb-2024	11:16	27-Feb-2024	16:03	287	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
513	27-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	4	160 kVA	Planned Outage	27-Feb-2024	11:31	27-Feb-2024	13:22	111	0.00003	PLANNED OUTAGE
514	27-Feb-2024	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA	506	Other Outage	Planned Outage	27-Feb-2024	11:43	27-Feb-2024	17:53	370	0.00164	PLANNED OUTAGE
515	27-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	7	63 kVA	Unplanned Outage	27-Feb-2024	11:47	27-Feb-2024	12:53	66	0.00002	EODB COMPLIANCE
516	27-Feb-2024	PART OF POOTH KHURD VILLAGE BAWANA	4	100 kVA	Unplanned Outage	27-Feb-2024	11:53	27-Feb-2024	12:42	49	0.00001	EODB COMPLIANCE
517	27-Feb-2024	PART OF L-BLOCK SEC-5 POOTH KHURD BAWANA	4	400 kVA	Unplanned Outage	27-Feb-2024	12:27	27-Feb-2024	12:59	32	0.00001	EODB COMPLIANCE
518	27-Feb-2024	PART OF K-31 SEC-5 BAWANA	1	63 kVA	Unplanned Outage	27-Feb-2024	13:14	27-Feb-2024	14:20	66	0.00002	EODB COMPLIANCE
519	27-Feb-2024	PART OF K-31 SEC-5 BAWANA	7	315 kVA	Unplanned Outage	27-Feb-2024	14:23	27-Feb-2024	15:02	39	0.00001	EODB COMPLIANCE
520	27-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	6	100 kVA	Unplanned Outage	27-Feb-2024	14:37	27-Feb-2024	15:11	34	0.00001	EODB COMPLIANCE
521	27-Feb-2024	PART OF I BLK SEC-1 BAWANA	4	315 kVA	Planned Outage	27-Feb-2024	14:43	27-Feb-2024	16:32	109	0.00003	PLANNED OUTAGE
522	27-Feb-2024	PART OF DD MALL SECT-5 BAWANA	5	400 kVA	Unplanned Outage	27-Feb-2024	15:22	27-Feb-2024	16:08	46	0.00001	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
523	27-Feb-2024	PARTS OF E-1 SEC-5 POOTH KHURD BAWANA	319	Other Outage	Unplanned Outage	27-Feb-2024	16:16	27-Feb-2024	16:54	38	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
524	27-Feb-2024	PART OF B BLOCK SEC-4 POOTH KHURD BAWANA	9	500 kVA	Unplanned Outage	27-Feb-2024	16:19	27-Feb-2024	16:48	29	0.00001	EODB COMPLIANCE
525	27-Feb-2024	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD BAWANA	136	Other Outage	Planned Outage	27-Feb-2024	17:03	27-Feb-2024	17:53	50	0.00017	PLANNED OUTAGE
526	27-Feb-2024	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	3968	Other Outage	Unplanned Outage	27-Feb-2024	18:55	27-Feb-2024	19:45	50	0.00111	FORCE MAJEURE/EXTERNAL FACTORS
527	28-Feb-2024	PARTS OF JYONTI VILLAGE BAWANA	1752	Other Outage	Planned Outage	28-Feb-2024	05:36	28-Feb-2024	13:06	450	0.00225	PLANNED OUTAGE
528	28-Feb-2024	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	211	Other Outage	Unplanned Outage	28-Feb-2024	06:45	28-Feb-2024	07:39	54	0.00075	FORCE MAJEURE/EXTERNAL FACTORS
529	28-Feb-2024	PARTS OF BULLA COLONY BAWANA	144	Other Outage	Planned Outage	28-Feb-2024	07:00	28-Feb-2024	08:43	103	0.00014	PLANNED OUTAGE
530	28-Feb-2024	PARTS OF B-BLOCK SEC-3 POOTH KHURD BAWANA	354	Other Outage	Unplanned Outage	28-Feb-2024	09:12	28-Feb-2024	10:45	93	0.00065	FORCE MAJEURE/EXTERNAL FACTORS
531	28-Feb-2024	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	335	Other Outage	Unplanned Outage	28-Feb-2024	10:00	28-Feb-2024	10:50	50	0.00250	FORCE MAJEURE/EXTERNAL FACTORS
532	28-Feb-2024	PARTS OF E-BLOCK JJ COLONY BAWANA	2734	Other Outage	Unplanned Outage	28-Feb-2024	10:00	28-Feb-2024	10:17	17	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
533	28-Feb-2024	PARTS OF A,F BLK SEC-2 DSIDC, DJB-TW NO-17 BAWANA	37	Other Outage	Planned Outage	28-Feb-2024	10:35	28-Feb-2024	17:07	392	0.00022	PLANNED OUTAGE
534	28-Feb-2024	PART OF SEC-5 B BLOCK BAWANA	3	315 kVA	Unplanned Outage	28-Feb-2024	10:35	28-Feb-2024	11:05	30	0.00001	EODB COMPLIANCE
535	28-Feb-2024	PARTS OF KANJHAWLA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEVRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	1003	Other Outage	Planned Outage	28-Feb-2024	10:43	28-Feb-2024	13:57	194	0.00140	PLANNED OUTAGE
536	28-Feb-2024	PARTS OF ESS-1 & 2 BAWANA	565	Other Outage	Unplanned Outage	28-Feb-2024	10:49	28-Feb-2024	12:05	76	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
537	28-Feb-2024	PARTS OF ESS-1 & 2 BAWANA	688	Other Outage	Unplanned Outage	28-Feb-2024	10:55	28-Feb-2024	12:05	70	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
538	28-Feb-2024	PART OF HI BLOCK SEC 5 DSIDC BAWANA	4	315 kVA	Unplanned Outage	28-Feb-2024	10:57	28-Feb-2024	12:35	98	0.00003	EODB COMPLIANCE
539	28-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	5	Other Outage	Unplanned Outage	28-Feb-2024	11:32	28-Feb-2024	17:54	382	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
540	28-Feb-2024	PARTS OF A,F,G, H, I BLOCKS OF SEC- 1 DSIDC BAWANA	21	Other Outage	Unplanned Outage	28-Feb-2024	11:40	28-Feb-2024	13:42	122	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
541	28-Feb-2024	PART OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	5	315 kVA	Unplanned Outage	28-Feb-2024	11:48	28-Feb-2024	13:05	77	0.00002	EODB COMPLIANCE
542	28-Feb-2024	PART OF K-1 BLK.SEC-1. BAWANA	5	Other Outage	Unplanned Outage	28-Feb-2024	11:49	28-Feb-2024	18:01	372	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
543	28-Feb-2024	PART OF KRISHNA MARKET BAWANA	18	Other Outage	Unplanned Outage	28-Feb-2024	11:55	28-Feb-2024	14:26	151	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
544	28-Feb-2024	PART OF DD MALL SECT-5 BAWANA	6	400 kVA	Unplanned Outage	28-Feb-2024	12:38	28-Feb-2024	13:10	32	0.00001	EODB COMPLIANCE
545	28-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	28-Feb-2024	13:23	28-Feb-2024	14:24	61	0.00002	EODB COMPLIANCE
546	28-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	4	Other Outage	Unplanned Outage	28-Feb-2024	14:00	28-Feb-2024	16:34	154	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
547	28-Feb-2024	PART OF B-BLOCK SEC-3 POOTH KHURD BAWANA	5	315 kVA	Unplanned Outage	28-Feb-2024	14:26	28-Feb-2024	14:54	28	0.00001	EODB COMPLIANCE
548	28-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	4	400 kVA	Unplanned Outage	28-Feb-2024	14:36	28-Feb-2024	15:50	74	0.00002	EODB COMPLIANCE
549	28-Feb-2024	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	1	Other Outage	Unplanned Outage	28-Feb-2024	15:01	28-Feb-2024	16:48	107	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
550	28-Feb-2024	PART OF LM BLOCK SEC-1 BAWANA	4	160 kVA	Unplanned Outage	28-Feb-2024	15:33	28-Feb-2024	16:12	39	0.00001	EODB COMPLIANCE
551	28-Feb-2024	PART OF I BLK SEC-1 BAWANA	6	Other Outage	Unplanned Outage	28-Feb-2024	16:00	28-Feb-2024	17:46	106	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
552	28-Feb-2024	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	48	Other Outage	Unplanned Outage	28-Feb-2024	16:15	28-Feb-2024	16:52	37	0.00087	FORCE MAJEURE/EXTERNAL FACTORS
553	28-Feb-2024	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	281	Other Outage	Unplanned Outage	28-Feb-2024	17:16	28-Feb-2024	18:00	44	0.00098	FORCE MAJEURE/EXTERNAL FACTORS
554	28-Feb-2024	PART OF F BLOCK SEC-4 DSIDC BAWANA	2	Other Outage	Unplanned Outage	28-Feb-2024	22:41	28-Feb-2024	22:51	10	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
555	29-Feb-2024	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT BAWANA	60	Other Outage	Unplanned Outage	29-Feb-2024	03:12	29-Feb-2024	03:31	19	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
556	29-Feb-2024	PARTS OF F & G BLOCK BAWANA	102	Other Outage	Planned Outage	29-Feb-2024	07:04	29-Feb-2024	08:45	101	0.00028	EODB COMPLIANCE
557	29-Feb-2024	PART OF ESS-2, 3 & 4 BAWANA	1	990 kVA	Planned Outage	29-Feb-2024	07:12	29-Feb-2024	08:50	98	0.00003	PLANNED OUTAGE
558	29-Feb-2024	PARTS OF G-BLOCK SEC-3 POOTH KHURD BAWANA	307	Other Outage	Unplanned Outage	29-Feb-2024	07:47	29-Feb-2024	08:32	45	0.00056	FORCE MAJEURE/EXTERNAL FACTORS
559	29-Feb-2024	PART OF VILL. KANJHAWLA BAWANA	19	Other Outage	Planned Outage	29-Feb-2024	10:19	29-Feb-2024	17:49	450	0.00063	PLANNED OUTAGE
560	29-Feb-2024	PART OF BULLA COLONY BAWANA	18	Other Outage	Planned Outage	29-Feb-2024	10:31	29-Feb-2024	17:27	416	0.00069	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
561	29-Feb-2024	PARTS OF BAWANA STADIUM AND INDS. AREA BAWANA	1376	Other Outage	Planned Outage	29-Feb-2024	10:46	29-Feb-2024	17:52	426	0.00154	PLANNED OUTAGE
562	29-Feb-2024	PARTS OF LADPUR VILLAGE BAWANA	1320	Other Outage	Planned Outage	29-Feb-2024	10:50	29-Feb-2024	17:20	390	0.00282	PLANNED OUTAGE
563	29-Feb-2024	PART OF N BLOCK SEC-2 BAWANA	6	Other Outage	Unplanned Outage	29-Feb-2024	10:55	29-Feb-2024	13:45	170	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
564	29-Feb-2024	PARTS OF KANJHAWLA INDUSTRIAL AREA, LAD PUR, CHOTU RAM POLYTECHNIC, GHEWRA VILLAGE AND PETROL PUMP OF GHEVRA BAWANA	31	Other Outage	Planned Outage	29-Feb-2024	11:10	29-Feb-2024	17:56	406	0.00023	PLANNED OUTAGE
565	29-Feb-2024	PART OF I BLK SEC-5 BAWANA	8	250 kVA	Unplanned Outage	29-Feb-2024	11:12	29-Feb-2024	11:44	32	0.00001	EODB COMPLIANCE
566	29-Feb-2024	PART OF M BLOCK SECTOR-1 POOTH KHURD BAWANA	8	400 kVA	Unplanned Outage	29-Feb-2024	11:16	29-Feb-2024	11:34	18	0.00001	EODB COMPLIANCE
567	29-Feb-2024	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1 BAWANA	68	Other Outage	Planned Outage	29-Feb-2024	11:19	29-Feb-2024	17:59	400	0.00011	PLANNED OUTAGE
568	29-Feb-2024	PART OF D BLOCK SEC-5 BAWANA	7	Other Outage	Unplanned Outage	29-Feb-2024	11:22	29-Feb-2024	12:54	92	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
569	29-Feb-2024	PART OF C BLK SEC-02 BAWANA	5	Other Outage	Unplanned Outage	29-Feb-2024	11:37	29-Feb-2024	12:39	62	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
570	29-Feb-2024	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2 BAWANA	642	Other Outage	Unplanned Outage	29-Feb-2024	11:50	29-Feb-2024	12:25	35	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
571	29-Feb-2024	PART OF J-32 SECTOR-5 POOTH KHURD BAWANA	5	250 kVA	Unplanned Outage	29-Feb-2024	12:11	29-Feb-2024	13:25	74	0.00002	EODB COMPLIANCE
572	29-Feb-2024	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	9	400 kVA	Unplanned Outage	29-Feb-2024	12:21	29-Feb-2024	13:35	74	0.00002	EODB COMPLIANCE
573	29-Feb-2024	PART OF POLICE STATION KHANJHAWLA BAWANA	2	Other Outage	Unplanned Outage	29-Feb-2024	13:48	29-Feb-2024	14:33	45	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
574	29-Feb-2024	PART OF N BLOCK SEC-2 BAWANA	8	Other Outage	Unplanned Outage	29-Feb-2024	13:56	29-Feb-2024	14:51	55	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
575	29-Feb-2024	PART OF N BLOCK SEC-2 BAWANA	6	Other Outage	Unplanned Outage	29-Feb-2024	14:14	29-Feb-2024	16:50	156	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
576	29-Feb-2024	PART OF SEC-5 B BLOCK BAWANA	2	160 kVA	Unplanned Outage	29-Feb-2024	14:33	29-Feb-2024	15:11	38	0.00001	EODB COMPLIANCE
577	29-Feb-2024	PART OF E BLK SEC-02 BAWANA	4	Other Outage	Unplanned Outage	29-Feb-2024	14:39	29-Feb-2024	16:01	82	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
578	29-Feb-2024	PART OF TUBEWELL NO - 1322 BAWANA	3	400 kVA	Unplanned Outage	29-Feb-2024	14:44	29-Feb-2024	16:15	91	0.00003	EODB COMPLIANCE
579	29-Feb-2024	PART OF N BLOCK SEC-2 BAWANA	5	Other Outage	Unplanned Outage	29-Feb-2024	14:56	29-Feb-2024	16:23	87	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
580	29-Feb-2024	PART OF F BLK SEC-1 POOTH KHURD BAWANA	3	160 kVA	Unplanned Outage	29-Feb-2024	14:57	29-Feb-2024	15:30	33	0.00001	EODB COMPLIANCE
581	29-Feb-2024	PART OF H-BLOCK SEC-1 POOTH KHURD BAWANA	10	315 kVA	Unplanned Outage	29-Feb-2024	15:42	29-Feb-2024	16:53	71	0.00002	EODB COMPLIANCE
582	29-Feb-2024	PARTS OF G BLK SEC-1 BAWANA	151	Other Outage	Unplanned Outage	29-Feb-2024	15:53	29-Feb-2024	16:25	32	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
583	29-Feb-2024	PART OF E BLK SEC-1 BAWANA	3	250 kVA	Unplanned Outage	29-Feb-2024	15:54	29-Feb-2024	17:05	71	0.00002	EODB COMPLIANCE
CIVIL LINES												
1	02-Feb-2024	PARTS OF RUB SANGAM PARK GTK ROAD CIVIL LINES	509	990 kVA	Planned Outage	02-Feb-2024	11:06	02-Feb-2024	13:26	140	0.00031	PLANNED OUTAGE
2	02-Feb-2024	PARTS OF SANGAM PARK OLD ,DSIDC SANGAM PARK, MCD SCHOOL R P BAGH. CIVIL LINES	225	400 kVA	Planned Outage	02-Feb-2024	14:19	02-Feb-2024	15:47	88	0.00007	PLANNED OUTAGE
3	04-Feb-2024	PART OF MIG FLAT KALYAN VIHAR CIVIL LINES	6	Other Outage	Unplanned Outage	04-Feb-2024	10:33	04-Feb-2024	10:48	15	0.000004	FORCE MAJEURE/EXTERNAL FACTORS
4	07-Feb-2024	PARTS OF HUDSON LINE,VIJAY NAGAR DOUBLE STOREY,ASHOKA MANUFACTURING,KIRPAL ASHRAM,VIJAY NAGAR 8-9 BLOCK,GURMANDI DUPLEX FLATS CIVIL LINES	245	630 kVA	Planned Outage	07-Feb-2024	13:57	07-Feb-2024	15:49	112	0.00037	PLANNED OUTAGE
5	07-Feb-2024	PART OF MIG FLAT KALYAN VIHAR CIVIL LINES	1	Other Outage	Unplanned Outage	07-Feb-2024	22:00	07-Feb-2024	23:59	119	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
6	08-Feb-2024	PART OF MIG FLAT KALYAN VIHAR CIVIL LINES	1	Other Outage	Unplanned Outage	08-Feb-2024	11:24	08-Feb-2024	17:30	366	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
7	08-Feb-2024	PARTS OF GURMANDI GANDA NALA, R.P. BAGH MOTHER DAIRY, DTC COLONY, KHATIK BASTI CIVIL LINES	302	Other Outage	Planned Outage	08-Feb-2024	11:54	08-Feb-2024	13:43	109	0.00018	PLANNED OUTAGE
8	08-Feb-2024	PART OF RAJ NIWAS MARG CIVIL LINES	1	Other Outage	Unplanned Outage	08-Feb-2024	13:30	08-Feb-2024	14:00	30	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
9	08-Feb-2024	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINES	1166	Other Outage	Unplanned Outage	08-Feb-2024	14:56	08-Feb-2024	15:20	23	0.00019	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
10	08-Feb-2024	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINES	116	Other Outage	Unplanned Outage	08-Feb-2024	14:56	08-Feb-2024	15:30	33	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
11	09-Feb-2024	PARTS OF WAZIRABAD WATER WORKS CIVIL LINES	116	Other Outage	Unplanned Outage	09-Feb-2024	05:50	09-Feb-2024	06:00	10	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
12	09-Feb-2024	PARTS OF ROAD NO- 45, POLIC CHONKI, GUDWARA, CNG PUMP CIVIL LINES	1083	Other Outage	Planned Outage	09-Feb-2024	11:57	09-Feb-2024	15:37	220	0.00073	PLANNED OUTAGE
13	09-Feb-2024	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINES	104	Other Outage	Unplanned Outage	09-Feb-2024	16:25	09-Feb-2024	17:45	80	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
14	10-Feb-2024	PARTS OF VARDHMAN PLAZA PACKAGE-1 & 2, A & C- BLK. NEHRU VIHAR, OLD & NEW TIMARPUR CIVIL LINES	1212	Other Outage	Planned Outage	10-Feb-2024	11:38	10-Feb-2024	14:40	182	0.00061	PLANNED OUTAGE
15	11-Feb-2024	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	47	Other Outage	Planned Outage	11-Feb-2024	10:50	11-Feb-2024	14:23	213	0.00030	PLANNED OUTAGE
16	11-Feb-2024	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	137	Other Outage	Unplanned Outage	11-Feb-2024	11:13	11-Feb-2024	12:30	77	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
17	12-Feb-2024	PARTS OF VARDHMAN PLAZA PACKAGE-1 & 2, A & C- BLK. NEHRU VIHAR, OLD & NEW TIMARPUR CIVIL LINES	897	Other Outage	Planned Outage	12-Feb-2024	11:13	12-Feb-2024	16:27	314	0.00105	PLANNED OUTAGE
18	13-Feb-2024	PARTS OF OLD TIMARPUR, D BLOCK NEW TIMARPUR, SATYAWATI, NEW TIMARPUR PARKING, A BLOCK NEHRU VIHAR, DA FLATS TIMAR PUR. CIVIL LINES	1761	Other Outage	Planned Outage	13-Feb-2024	11:03	13-Feb-2024	14:34	211	0.00070	PLANNED OUTAGE
19	16-Feb-2024	PARTS OF NURUDDIN PARK, BERIWALA BAGH CIVIL LINES	280	Other Outage	Planned Outage	16-Feb-2024	11:01	16-Feb-2024	13:06	125	0.00090	PLANNED OUTAGE
20	16-Feb-2024	PARTS OF DRDO & TIMARPUR CIVIL LINES	2253	Other Outage	Unplanned Outage	16-Feb-2024	12:32	16-Feb-2024	12:47	14	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
21	16-Feb-2024	PART OF DRDO CIVIL LINES	1	Other Outage	Unplanned Outage	16-Feb-2024	12:32	16-Feb-2024	14:20	107	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
22	16-Feb-2024	PARTS OF KHALSA COLLEGE, MALL APP. REVERA APP. ISH. MES APP. CIVIL LINES	296	Other Outage	Unplanned Outage	16-Feb-2024	16:51	16-Feb-2024	17:33	42	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
23	17-Feb-2024	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINES	110	Other Outage	Unplanned Outage	17-Feb-2024	10:33	17-Feb-2024	10:45	12	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
24	17-Feb-2024	PART OF WAZIRABAD WATER WORKS CIVIL LINES	8	Other Outage	Unplanned Outage	17-Feb-2024	10:33	17-Feb-2024	13:52	199	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
25	17-Feb-2024	PARTS OF DVB COLONY, PART OF R P BAGH, PART OF KABIR NAGAR, PART OF OM NAGAR, KISHOR NAGAR. CIVIL LINES	2459	Other Outage	Unplanned Outage	17-Feb-2024	12:34	17-Feb-2024	13:36	62	0.00043	FORCE MAJEURE/EXTERNAL FACTORS
26	20-Feb-2024	PARTS OF KHALSA COLLEGE, MALL APP. REVERA APP. ISH. MES APP. CIVIL LINES	709	Other Outage	Unplanned Outage	20-Feb-2024	00:47	20-Feb-2024	01:05	18	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
27	20-Feb-2024	PARTS OF KAMLA NAGAR, A-BLOCK,F-BLOCK, PART OF CHANDERWAL, PART OF KOLHA PUR ROAD. CIVIL LINES	1168	Other Outage	Unplanned Outage	20-Feb-2024	13:02	20-Feb-2024	13:30	27	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
28	20-Feb-2024	PART OF WAZIRABAD WATER WORKS CIVIL LINES	8	Other Outage	Unplanned Outage	20-Feb-2024	16:08	20-Feb-2024	18:47	159	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
29	21-Feb-2024	PART OF WAZIRABAD WATER WORKS CIVIL LINES	1	Other Outage	Unplanned Outage	21-Feb-2024	07:42	21-Feb-2024	08:00	18	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
30	21-Feb-2024	PARTS OF R P BAGH, JAIN COLONY, PART OF C C COLONY. CIVIL LINES	286	630 kVA	Planned Outage	21-Feb-2024	11:11	21-Feb-2024	12:56	105	0.00076	PLANNED OUTAGE
31	21-Feb-2024	PART OF GOKHLE MARKET CIVIL LINES	17	Other Outage	Planned Outage	21-Feb-2024	12:18	21-Feb-2024	17:02	284	0.00016	PLANNED OUTAGE
32	21-Feb-2024	PARTS OF GURMANDI GANDA NALA, R.P. BAGH MOTHER DAIRY, DTC COLONY, KHATIK BASTI CIVIL LINES	233	Other Outage	Planned Outage	21-Feb-2024	14:36	21-Feb-2024	16:55	139	0.00015	PLANNED OUTAGE
33	22-Feb-2024	PARTS OF SWISS APARTMENT AND NARMADA SWITCHING CIVIL LINES	1591	Other Outage	Planned Outage	22-Feb-2024	11:46	22-Feb-2024	14:08	142	0.00079	PLANNED OUTAGE
34	23-Feb-2024	PARTS OF KALYAN VIHAR, SFS FLATS KALYAN VIHAR, MASHWARI SADAN, PART OF NEW GUPTA COLONY, PART OF OLD GUPTA COLONY, PART OF SINGLE STORY VIJAY NAGAR. POLO ROAD. ISHWAR COLONY &MAA KALYANI KUNJ	228	630 kVA	Planned Outage	23-Feb-2024	10:40	23-Feb-2024	12:34	114	0.00016	PLANNED OUTAGE
35	23-Feb-2024	PART OF MIG FLAT KALYAN VIHAR CIVIL LINES	1	Other Outage	Planned Outage	23-Feb-2024	11:14	23-Feb-2024	13:08	114	0.00003	EODB COMPLIANCE
36	23-Feb-2024	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	671	Other Outage	Unplanned Outage	23-Feb-2024	16:54	23-Feb-2024	16:58	4	0.00002	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
37	24-Feb-2024	PARTS OF HUDSON LINE, PART OF SINGLE STORY VIJAY NAGAR, CIVIL LINES	407	Other Outage	Unplanned Outage	24-Feb-2024	01:46	24-Feb-2024	02:15	29	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
38	24-Feb-2024	PARTS OF POLO GROUND, OLD GUPTA COLONY DISPENSARY CIVIL LINES	308	990 kVA	Planned Outage	24-Feb-2024	10:49	24-Feb-2024	12:49	120	0.00087	PLANNED OUTAGE
39	24-Feb-2024	PARTS OF POLO GROUND, OLD GUPTA COLONY DISPENSARY CIVIL LINES	163	630 kVA	Planned Outage	24-Feb-2024	14:06	24-Feb-2024	15:47	101	0.00011	PLANNED OUTAGE
40	24-Feb-2024	PART OF DU SPORTS COMPLEX CIVIL LINES	13	630 kVA	Planned Outage	24-Feb-2024	14:17	24-Feb-2024	15:41	83	0.00009	PLANNED OUTAGE
41	25-Feb-2024	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	312	Other Outage	Planned Outage	25-Feb-2024	10:36	25-Feb-2024	16:13	337	0.00056	PLANNED OUTAGE
42	26-Feb-2024	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	325	Other Outage	Unplanned Outage	26-Feb-2024	08:29	26-Feb-2024	08:35	6	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
43	26-Feb-2024	PARTS OF ROAD NO- 45, POLIC CHONKI, GUDWARA, CNG PUMP CIVIL LINES	700	1000 kVA	Planned Outage	26-Feb-2024	11:39	26-Feb-2024	13:02	83	0.00074	PLANNED OUTAGE
44	26-Feb-2024	PARTS OF FLAGSTAFF ROAD, 16 RAJPUR ROAD, 21 RAJPUR ROAD,24 RAJPUR ROAD,4 BATTERY LANE, TIRATH RAM HOSPITAL, CIVIL LINES	109	990 kVA	Planned Outage	26-Feb-2024	14:15	26-Feb-2024	16:04	109	0.00009	PLANNED OUTAGE
45	26-Feb-2024	PARTS OF NEHRU VIHAR SEWAGE CIVIL LINES	753	Other Outage	Unplanned Outage	26-Feb-2024	15:37	26-Feb-2024	16:47	70	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
46	26-Feb-2024	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP. CIVIL LINES	73	Other Outage	Unplanned Outage	26-Feb-2024	18:24	26-Feb-2024	18:35	11	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
47	26-Feb-2024	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN CIVIL LINES	67	Other Outage	Unplanned Outage	26-Feb-2024	22:53	26-Feb-2024	23:22	29	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
48	27-Feb-2024	PART OF NEHRU VIHAR SEWAGE CIVIL LINES	1	Other Outage	Planned Outage	27-Feb-2024	08:48	27-Feb-2024	15:26	398	0.00022	PLANNED OUTAGE
49	27-Feb-2024	PARTS OF KALYAN VIHAR, SFS FLATS KALYAN VIHAR, MASHWARI SADAN, PART OF NEW GUPTA COLONY, PART OF OLD GUPTA COLONY, PART OF SINGLE STORY VIJAY NAGAR, POLO ROAD, ISHWAR COLONY &MAA KALYANI KUNJ	422	Other Outage	Planned Outage	27-Feb-2024	10:58	27-Feb-2024	13:29	151	0.00021	PLANNED OUTAGE
50	28-Feb-2024	PARTS OF KAMLA NAGAR, A-BLOCK,F-BLOCK, PART OF CHANDERWAL, PART OF KOLHA PUR ROAD. CIVIL LINES	395	630 kVA	Planned Outage	28-Feb-2024	10:50	28-Feb-2024	12:55	125	0.00017	PLANNED OUTAGE
51	28-Feb-2024	PARTS OF C C COLONY, PART OF GURMANDI,KHATIK BASTI AND JAIN COLONY CIVIL LINES	492	Other Outage	Planned Outage	28-Feb-2024	10:56	28-Feb-2024	14:17	201	0.00028	PLANNED OUTAGE
52	28-Feb-2024	PARTS OF KAMLA NAGAR, A-BLOCK,F-BLOCK, PART OF CHANDERWAL, PART OF KOLHA PUR ROAD. CIVIL LINES	256	990 kVA	Planned Outage	28-Feb-2024	14:19	28-Feb-2024	16:10	111	0.00012	PLANNED OUTAGE
53	29-Feb-2024	PARTS OF PUNJABI BASTI, MAIN BAZAR SUBZI MANDI, SHORA KOTHI, PART OF MALKA GANJ, PART OF ARYA PURA, DELHI FLOOR MILL, ROBIN CINEMA, PART OF MUKEEM PURA CIVIL LINES	479	Other Outage	Unplanned Outage	29-Feb-2024	02:15	29-Feb-2024	02:29	14	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
54	29-Feb-2024	PARTS OF PUNJABI BASTI, MAIN BAZAR SUBZI MANDI, SHORA KOTHI, PART OF MALKA GANJ, PART OF ARYA PURA, DELHI FLOOR MILL, ROBIN CINEMA, PART OF MUKEEM PURA CIVIL LINES	1006	Other Outage	Unplanned Outage	29-Feb-2024	02:15	29-Feb-2024	02:52	37	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
55	29-Feb-2024	PARTS OF PUNJABI BASTI, MAIN BAZAR SUBZI MANDI, SHORA KOTHI, PART OF MALKA GANJ, PART OF ARYA PURA, DELHI FLOOR MILL, ROBIN CINEMA, PART OF MUKEEM PURA CIVIL LINES	1680	Other Outage	Unplanned Outage	29-Feb-2024	02:15	29-Feb-2024	02:52	37	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
56	29-Feb-2024	PARTS OF INDRA MARKET CIVIL LINES	895	Other Outage	Planned Outage	29-Feb-2024	10:45	29-Feb-2024	12:38	113	0.00113	PLANNED OUTAGE
57	29-Feb-2024	PARTS OF DRDO & TIMARPUR CIVIL LINES	977	Other Outage	Planned Outage	29-Feb-2024	11:02	29-Feb-2024	14:40	218	0.00097	PLANNED OUTAGE
58	29-Feb-2024	PARTS OF NEW KIRORI MAL COLLEGE CIVIL LINES	701	990 kVA	Planned Outage	29-Feb-2024	14:19	29-Feb-2024	15:37	78	0.00017	PLANNED OUTAGE
59	29-Feb-2024	PARTS OF NEW COURT CIVIL LINES	478	Other Outage	Unplanned Outage	29-Feb-2024	14:45	29-Feb-2024	15:10	25	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
60	29-Feb-2024	PARTS OF NEW COURT CIVIL LINES	478	Other Outage	Unplanned Outage	29-Feb-2024	15:47	29-Feb-2024	16:00	13	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
KESHAV PURAM												
1	01-Feb-2024	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK) KESHAV PURAM	660	Other Outage	Unplanned Outage	01-Feb-2024	08:25	01-Feb-2024	13:02	277	0.00193	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF RAMPURA VILLAGE , RAM PURA MAIN ROAD, LIG FLATS RAM PURA KESHAV PURAM	52	Other Outage	Unplanned Outage	01-Feb-2024	09:03	01-Feb-2024	10:07	65	0.00027	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
3	01-Feb-2024	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	72	Other Outage	Unplanned Outage	01-Feb-2024	09:37	01-Feb-2024	10:48	71	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF GANDA NALA SHASTRI NGR SHAKTI NAGAR KESHAV PURAM	2258	Other Outage	Unplanned Outage	01-Feb-2024	13:56	01-Feb-2024	14:43	47	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PART OF RAMPURA VILLAGE KESHAV PURAM	8	Other Outage	Unplanned Outage	01-Feb-2024	15:18	01-Feb-2024	16:40	82	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
6	02-Feb-2024	PARTS OF SFS COLONY, PART OF WAZIRPUR VILLAGE, PART OF KC & KD BLOCK ASHOK VIHAR KESHAV PURAM	182	630 kVA	Planned Outage	02-Feb-2024	11:11	02-Feb-2024	15:27	256	0.00014	PLANNED OUTAGE
7	02-Feb-2024	PARTS OF SFS COLONY, PART OF WAZIRPUR VILLAGE, PART OF KC & KD BLOCK ASHOK VIHAR KESHAV PURAM	84	630 kVA	Planned Outage	02-Feb-2024	11:12	02-Feb-2024	15:28	256	0.00014	PLANNED OUTAGE
8	02-Feb-2024	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	13	Other Outage	Unplanned Outage	02-Feb-2024	11:17	02-Feb-2024	12:05	48	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
9	02-Feb-2024	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK) KESHAV PURAM	29	Other Outage	Unplanned Outage	02-Feb-2024	14:36	02-Feb-2024	15:08	32	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
10	02-Feb-2024	PART OF WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	4	Other Outage	Unplanned Outage	02-Feb-2024	14:36	02-Feb-2024	15:41	64	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
11	02-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	3	250 kVA	Unplanned Outage	02-Feb-2024	14:41	02-Feb-2024	15:24	43	0.00001	EODB COMPLIANCE
12	02-Feb-2024	PARTS OF C-5, C-6 & C-7 KESHAV PURAM	374	Other Outage	Unplanned Outage	02-Feb-2024	16:42	02-Feb-2024	17:20	38	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
13	04-Feb-2024	PARTS OF DDA PH-1 & II, DAYA BASTI KESHAV PURAM	915	Other Outage	Unplanned Outage	04-Feb-2024	13:20	04-Feb-2024	14:12	51	0.00086	FORCE MAJEURE/EXTERNAL FACTORS
14	04-Feb-2024	PART OF DAYA BASTI RAILAY STATION KESHAV PURAM	1	Other Outage	Unplanned Outage	04-Feb-2024	13:20	04-Feb-2024	14:30	69	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
15	04-Feb-2024	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	206	Other Outage	Unplanned Outage	04-Feb-2024	13:45	04-Feb-2024	13:48	3	0.000004	FORCE MAJEURE/EXTERNAL FACTORS
16	04-Feb-2024	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	206	Other Outage	Unplanned Outage	04-Feb-2024	14:06	04-Feb-2024	14:09	3	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
17	05-Feb-2024	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	5	400 kVA	Planned Outage	05-Feb-2024	07:50	05-Feb-2024	10:00	130	0.00004	PLANNED OUTAGE
18	05-Feb-2024	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	5	400 kVA	Planned Outage	05-Feb-2024	07:55	05-Feb-2024	10:01	126	0.00007	PLANNED OUTAGE
19	05-Feb-2024	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	7	400 kVA	Planned Outage	05-Feb-2024	08:02	05-Feb-2024	10:04	122	0.00003	PLANNED OUTAGE
20	05-Feb-2024	PARTS OF KANHIYA NAGAR, PART OF GANESH PURA KESHAV PURAM	653	Other Outage	Unplanned Outage	05-Feb-2024	10:27	05-Feb-2024	11:14	47	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
21	05-Feb-2024	PARTS OF SFS FLATS, DA FLATS, KC-KD PH-1, WAZIRPUR VILLAGE KESHAV PURAM	349	Other Outage	Planned Outage	05-Feb-2024	11:25	05-Feb-2024	12:40	75	0.00010	PLANNED OUTAGE
22	05-Feb-2024	PARTS OF MANSOORI, C - 1 TO C - 31 LAWARANCE ROAD INDUSTRIAL AREA KESHAV PURAM	85	Other Outage	Unplanned Outage	05-Feb-2024	15:04	05-Feb-2024	15:10	6	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
23	05-Feb-2024	PARTS OF SHASTRI NAGAR KESHAV PURAM	1256	Other Outage	Unplanned Outage	05-Feb-2024	23:04	06-Feb-2024	00:09	64	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
24	05-Feb-2024	PARTS OF SHASTRI NAGAR KESHAV PURAM	1739	Other Outage	Unplanned Outage	05-Feb-2024	23:04	06-Feb-2024	00:10	65	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
25	05-Feb-2024	PARTS OF B - BLOCK (OUTER), GANDA NALA SHASTRI NAGAR S/S NO-1, STATUE PARK KESHAV PURAM	2728	Other Outage	Unplanned Outage	05-Feb-2024	23:45	06-Feb-2024	00:03	17	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
26	06-Feb-2024	PART OF DIST. OFFICE KESHAV PURAM	1	Other Outage	Unplanned Outage	06-Feb-2024	12:43	06-Feb-2024	15:48	185	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
27	06-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	19	Other Outage	Unplanned Outage	06-Feb-2024	13:25	06-Feb-2024	14:53	88	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
28	06-Feb-2024	PART OF RAM PURA DDA KESHAV PURAM	2	250 kVA	Unplanned Outage	06-Feb-2024	16:22	06-Feb-2024	17:10	48	0.00001	EODB COMPLIANCE
29	07-Feb-2024	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	82	Other Outage	Planned Outage	07-Feb-2024	10:52	07-Feb-2024	13:34	162	0.00023	PLANNED OUTAGE
30	07-Feb-2024	PARTS OF HIMACHAL COLD STORE, JASWANT, HARYANA, C-12, MODERN COLD STORE, C - 9/2, C - 9/3, C - 12, C - 7, C - 6/1 TO C - 6/12 INDUSTRIAL AREA LAWRENCE ROAD KESHAV PURAM	65	Other Outage	Planned Outage	07-Feb-2024	10:53	07-Feb-2024	15:38	285	0.00016	PSD ON INDUSTRIAL WEEKLY OFF
31	07-Feb-2024	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA KESHAV PURAM	121	Other Outage	Planned Outage	07-Feb-2024	11:00	07-Feb-2024	13:35	155	0.00052	PLANNED OUTAGE
32	07-Feb-2024	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	35	Other Outage	Planned Outage	07-Feb-2024	11:05	07-Feb-2024	15:08	243	0.00014	PSD ON INDUSTRIAL WEEKLY OFF
33	07-Feb-2024	PARTS OF B BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	26	Other Outage	Planned Outage	07-Feb-2024	11:07	07-Feb-2024	16:36	329	0.00046	PSD ON INDUSTRIAL WEEKLY OFF
34	07-Feb-2024	PARTS OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	55	Other Outage	Unplanned Outage	07-Feb-2024	12:24	07-Feb-2024	12:54	30	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
35	07-Feb-2024	PARTS OF B/66 & B/65 WAZIR PUR KESHAV PURAM	79	Other Outage	Unplanned Outage	07-Feb-2024	13:17	07-Feb-2024	13:51	34	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
36	07-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	2	Other Outage	Unplanned Outage	07-Feb-2024	13:17	07-Feb-2024	13:51	34	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
37	07-Feb-2024	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	272	Other Outage	Unplanned Outage	07-Feb-2024	13:36	07-Feb-2024	14:05	28	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
38	07-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	7	400 kVA	Unplanned Outage	07-Feb-2024	14:14	07-Feb-2024	15:16	62	0.00002	EODB COMPLIANCE
39	07-Feb-2024	PART OF C - 6/12 INDUSTRIAL AREA LAWRENCE ROAD KESHAV PURAM	7	Other Outage	Unplanned Outage	07-Feb-2024	16:19	07-Feb-2024	17:00	41	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
40	07-Feb-2024	PARTS OF K, L,11, 12 AND SANJAY MARKET WAZIRPUR JJ COLONY KESHAV PURAM	452	Other Outage	Unplanned Outage	07-Feb-2024	16:32	07-Feb-2024	17:01	29	0.00015	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
41	07-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	103	Other Outage	Unplanned Outage	07-Feb-2024	17:05	07-Feb-2024	17:20	15	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
42	08-Feb-2024	PART OF DSIDC SHEDS-21 KESHAV PURAM	16	630 kVA	Planned Outage	08-Feb-2024	07:46	08-Feb-2024	09:53	127	0.00018	PLANNED OUTAGE
43	08-Feb-2024	PART OF C-33 WAZIRPUR KESHAV PURAM	3	400 kVA	Planned Outage	08-Feb-2024	07:54	08-Feb-2024	08:47	53	0.00003	PLANNED OUTAGE
44	08-Feb-2024	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	72	Other Outage	Unplanned Outage	08-Feb-2024	08:48	08-Feb-2024	09:37	49	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
45	08-Feb-2024	PARTS OF A, B, C BLOCK ASHOK VIHAR PH. - 1 KESHAV PURAM	231	Other Outage	Planned Outage	08-Feb-2024	11:49	08-Feb-2024	14:07	138	0.00015	PLANNED OUTAGE
46	08-Feb-2024	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	123	Other Outage	Unplanned Outage	08-Feb-2024	12:30	08-Feb-2024	12:58	28	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
47	08-Feb-2024	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL KESHAV PURAM	2815	Other Outage	Unplanned Outage	08-Feb-2024	13:36	08-Feb-2024	14:05	29	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
48	08-Feb-2024	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL KESHAV PURAM	886	Other Outage	Unplanned Outage	08-Feb-2024	13:36	08-Feb-2024	15:50	134	0.00037	FORCE MAJEURE/EXTERNAL FACTORS
49	08-Feb-2024	PART OF DSIDC CKT.1 KESHAV PURAM	4	Other Outage	Unplanned Outage	08-Feb-2024	15:44	08-Feb-2024	16:06	22	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
50	08-Feb-2024	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	6	250 kVA	Unplanned Outage	08-Feb-2024	16:19	08-Feb-2024	17:17	58	0.00002	EODB COMPLIANCE
51	09-Feb-2024	PARTS OF DSIDC CKT.1 CKT.2, B - 71, B - 40 KESHAV PURAM	76	Other Outage	Planned Outage	09-Feb-2024	07:07	09-Feb-2024	08:54	107	0.00024	EODB COMPLIANCE
52	09-Feb-2024	PARTS OF B - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	70	Other Outage	Planned Outage	09-Feb-2024	07:52	09-Feb-2024	11:03	191	0.00011	EODB COMPLIANCE
53	09-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	429	Other Outage	Unplanned Outage	09-Feb-2024	09:49	09-Feb-2024	10:10	21	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
54	09-Feb-2024	PART OF C-BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	4	250 kVA	Unplanned Outage	09-Feb-2024	11:02	09-Feb-2024	11:31	29	0.00001	EODB COMPLIANCE
55	09-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 kVA	Unplanned Outage	09-Feb-2024	12:45	09-Feb-2024	14:09	84	0.00002	EODB COMPLIANCE
56	09-Feb-2024	PARTS OF M/S SUBHASH ENTER PRISES, AJAY PLASTICS UNIT- 2, SHAHZADA BAGH NO-3, DDA SLUM TENAMANT KESHAV PURAM	326	Other Outage	Unplanned Outage	09-Feb-2024	15:57	09-Feb-2024	16:10	13	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
57	09-Feb-2024	PARTS OF M/S SUBHASH ENTER PRISES, AJAY PLASTICS UNIT- 2, SHAHZADA BAGH NO-3, DDA SLUM TENAMANT KESHAV PURAM	1016	Other Outage	Unplanned Outage	09-Feb-2024	15:57	09-Feb-2024	16:20	23	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
58	09-Feb-2024	PARTS OF COMMUNITY CENTRE, PART OF STRIPEX RAMPURA KESHAV PURAM	71	Other Outage	Unplanned Outage	09-Feb-2024	16:01	09-Feb-2024	16:43	42	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
59	10-Feb-2024	PART OF C-BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	8	400 kVA	Unplanned Outage	10-Feb-2024	13:19	10-Feb-2024	14:41	82	0.00002	EODB COMPLIANCE
60	10-Feb-2024	PART OF G-40 LAWARNCE ROAD INDUSTRIAL AREA KESHAV PURAM	10	Other Outage	Unplanned Outage	10-Feb-2024	15:20	10-Feb-2024	19:03	222	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
61	10-Feb-2024	PARTS OF G - 5, G - 29 TO G - 40 LAWARNCE ROAD INDUSTRIAL AREA, G - 41 TO G - 59, B - 38, 39, B - 34, B - 35, B - 36 KESHAV PURAM	30	Other Outage	Unplanned Outage	10-Feb-2024	15:20	10-Feb-2024	19:04	223	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
62	10-Feb-2024	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	36	Other Outage	Unplanned Outage	10-Feb-2024	22:57	11-Feb-2024	00:06	69	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
63	11-Feb-2024	PART OF VIKRAM FLOOR MILL KESHAV PURAM	1	Other Outage	Planned Outage	11-Feb-2024	11:52	11-Feb-2024	16:37	285	0.00008	EODB COMPLIANCE
64	11-Feb-2024	PARTS OF DSIDC SHEDS AND PARTLY C - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	81	Other Outage	Unplanned Outage	11-Feb-2024	14:30	11-Feb-2024	15:00	29	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
65	11-Feb-2024	PARTS OF DSIDC SHEDS AND PARTLY C - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	116	Other Outage	Unplanned Outage	11-Feb-2024	14:30	11-Feb-2024	16:52	141	0.00075	FORCE MAJEURE/EXTERNAL FACTORS
66	11-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA AND PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	176	Other Outage	Unplanned Outage	11-Feb-2024	20:42	11-Feb-2024	22:04	82	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
67	12-Feb-2024	PARTS OF B - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	40	315 kVA	Planned Outage	12-Feb-2024	07:48	12-Feb-2024	09:38	110	0.00018	PLANNED OUTAGE
68	12-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	4	400 kVA	Planned Outage	12-Feb-2024	07:51	12-Feb-2024	09:29	98	0.00008	PLANNED OUTAGE
69	12-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	15	315 kVA	Planned Outage	12-Feb-2024	07:53	12-Feb-2024	09:28	95	0.00013	PLANNED OUTAGE
70	13-Feb-2024	PARTS OF PUNJAB KESRI, HINDU, C-6, C-5 KESHAV PURAM	27	Other Outage	Unplanned Outage	13-Feb-2024	17:12	13-Feb-2024	17:30	17	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
71	13-Feb-2024	PARTS OF PUNJAB KESRI, HINDU, C-6, C-5 KESHAV PURAM	24	Other Outage	Unplanned Outage	13-Feb-2024	17:12	13-Feb-2024	17:56	43	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
72	13-Feb-2024	PARTS OF PUNJAB KESRI, HINDU, C-6, C-5 KESHAV PURAM	396	Other Outage	Unplanned Outage	13-Feb-2024	17:12	13-Feb-2024	18:11	58	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
73	13-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	2	Other Outage	Unplanned Outage	13-Feb-2024	18:03	13-Feb-2024	18:17	14	0.000004	FORCE MAJEURE/EXTERNAL FACTORS
74	13-Feb-2024	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	126	Other Outage	Unplanned Outage	13-Feb-2024	22:20	13-Feb-2024	22:48	28	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
75	13-Feb-2024	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	7	Other Outage	Unplanned Outage	13-Feb-2024	22:20	14-Feb-2024	00:21	121	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
76	14-Feb-2024	PARTS OF B BLOCK WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	102	Other Outage	Planned Outage	14-Feb-2024	10:58	14-Feb-2024	15:14	256	0.00085	PSD ON INDUSTRIAL WEEKLY OFF
77	14-Feb-2024	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	293	Other Outage	Planned Outage	14-Feb-2024	11:35	14-Feb-2024	17:17	342	0.00285	PSD ON INDUSTRIAL WEEKLY OFF

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
78	14-Feb-2024	PARTS OF JA BLK MURGA MKT AND PART OF J-BLOCK ASHOK VIHAR PH-1 KESHAV PURAM	1314	Other Outage	Unplanned Outage	14-Feb-2024	16:10	14-Feb-2024	16:55	45	0.00025	FORCE MAJEURE/EXTERNAL FACTORS
79	14-Feb-2024	PART OF G-40 LAWARNCE ROAD INDUSTRIAL AREA KESHAV PURAM	4	400 kVA	Unplanned Outage	14-Feb-2024	16:13	14-Feb-2024	17:10	57	0.00002	EODB COMPLIANCE
80	15-Feb-2024	PARTS OF NIMRI COLONY, WEAVERS COLONY A-BLOCK AND B-BLOCK ASHOK VIHAR PH-4 KESHAV PURAM	219	630 kVA	Planned Outage	15-Feb-2024	10:52	15-Feb-2024	12:59	127	0.00092	PLANNED OUTAGE
81	15-Feb-2024	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	6	500 kVA	Unplanned Outage	15-Feb-2024	11:12	15-Feb-2024	14:55	223	0.00006	EODB COMPLIANCE
82	15-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	97	Other Outage	Unplanned Outage	15-Feb-2024	14:15	15-Feb-2024	17:21	186	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
83	15-Feb-2024	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL KESHAV PURAM	887	Other Outage	Unplanned Outage	15-Feb-2024	14:43	15-Feb-2024	15:14	31	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
84	15-Feb-2024	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	6	500 kVA	Unplanned Outage	15-Feb-2024	15:07	15-Feb-2024	16:32	85	0.00002	EODB COMPLIANCE
85	16-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	3	315 kVA	Planned Outage	16-Feb-2024	07:48	16-Feb-2024	10:20	152	0.00004	PLANNED OUTAGE
86	16-Feb-2024	PARTS OF B/66 & B/65 WAZIR PUR KESHAV PURAM	78	Other Outage	Planned Outage	16-Feb-2024	08:41	16-Feb-2024	10:00	79	0.00004	PLANNED OUTAGE
87	16-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	64	Other Outage	Unplanned Outage	16-Feb-2024	15:39	16-Feb-2024	17:00	81	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
88	16-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	46	Other Outage	Unplanned Outage	16-Feb-2024	15:46	16-Feb-2024	16:56	70	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
89	17-Feb-2024	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	6	100 kVA	Unplanned Outage	17-Feb-2024	11:57	17-Feb-2024	12:09	12	0.000003	EODB COMPLIANCE
90	17-Feb-2024	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	2	400 kVA	Unplanned Outage	17-Feb-2024	13:34	17-Feb-2024	14:36	62	0.00002	EODB COMPLIANCE
91	17-Feb-2024	PART OF RAM PURA DDA KESHAV PURAM	2	250 kVA	Unplanned Outage	17-Feb-2024	14:55	17-Feb-2024	15:44	49	0.00001	EODB COMPLIANCE
92	18-Feb-2024	PARTS OF POCKET - A ASHOK VIHAR PH-2, INVITATION MARKET, POCKET A, B, C ASHOK VIHAR PH -3, ARYA BHATT ENCLEV, SAWAN PARK,SUNDER LAL JAIN	233	Other Outage	Unplanned Outage	18-Feb-2024	00:30	18-Feb-2024	00:56	26	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
93	19-Feb-2024	PART OF C-BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	4	315 kVA	Planned Outage	19-Feb-2024	08:09	19-Feb-2024	09:22	73	0.00004	PLANNED OUTAGE
94	19-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	173	315 kVA	Planned Outage	19-Feb-2024	08:13	19-Feb-2024	09:27	74	0.00010	PLANNED OUTAGE
95	19-Feb-2024	PARTS OF CET PLANT, C-1, C-2, C-3,ASHOK VIHAR PH - 2, PRESIDUM SCHOOL KESHAV PURAM	72	400 kVA	Planned Outage	19-Feb-2024	11:46	19-Feb-2024	13:26	100	0.00006	PLANNED OUTAGE
96	19-Feb-2024	PARTS OF CET PLANT, C-1, C-2, C-3,ASHOK VIHAR PH - 2, PRESIDUM SCHOOL KESHAV PURAM	268	1000 kVA	Planned Outage	19-Feb-2024	11:52	19-Feb-2024	13:23	91	0.00008	PLANNED OUTAGE
97	20-Feb-2024	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	293	Other Outage	Unplanned Outage	20-Feb-2024	01:22	20-Feb-2024	03:48	146	0.00061	FORCE MAJEURE/EXTERNAL FACTORS
98	20-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	24	Other Outage	Unplanned Outage	20-Feb-2024	04:53	20-Feb-2024	05:10	16	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
99	20-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	79	Other Outage	Unplanned Outage	20-Feb-2024	04:53	20-Feb-2024	07:07	133	0.00037	FORCE MAJEURE/EXTERNAL FACTORS
100	20-Feb-2024	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4 KESHAV PURAM	273	Other Outage	Unplanned Outage	20-Feb-2024	07:42	20-Feb-2024	08:20	38	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
101	20-Feb-2024	PART OF RAM PURACOMMUNITY CENTRE KESHAV PURAM	1	Other Outage	Unplanned Outage	20-Feb-2024	12:25	20-Feb-2024	13:01	36	0.00001	EODB COMPLIANCE
102	20-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	11	400 kVA	Unplanned Outage	20-Feb-2024	14:44	20-Feb-2024	15:14	30	0.00001	EODB COMPLIANCE
103	20-Feb-2024	PART OF C-31 LAWARANCE ROAD INDUSTRIAL. AREA KESHAV PURAM	4	250 kVA	Unplanned Outage	20-Feb-2024	16:22	20-Feb-2024	16:58	36	0.00001	EODB COMPLIANCE
104	20-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	97	Other Outage	Unplanned Outage	20-Feb-2024	16:46	20-Feb-2024	17:47	62	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
105	20-Feb-2024	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA KESHAV PURAM	33	Other Outage	Unplanned Outage	20-Feb-2024	20:39	20-Feb-2024	21:10	31	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
106	21-Feb-2024	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2 KESHAV PURAM	54	Other Outage	Planned Outage	21-Feb-2024	10:28	21-Feb-2024	13:04	156	0.00009	PLANNED OUTAGE
107	21-Feb-2024	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	30	Other Outage	Planned Outage	21-Feb-2024	10:29	21-Feb-2024	14:05	216	0.00012	PSD ON INDUSTRIAL WEEKLY OFF
108	21-Feb-2024	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	10	Other Outage	Planned Outage	21-Feb-2024	10:35	21-Feb-2024	14:05	210	0.00012	PSD ON INDUSTRIAL WEEKLY OFF
109	21-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	97	Other Outage	Planned Outage	21-Feb-2024	10:42	21-Feb-2024	15:10	268	0.00015	PSD ON INDUSTRIAL WEEKLY OFF
110	21-Feb-2024	PARTS OF G - 5, G - 29 TO G - 40 LAWARNCE ROAD INDUSTRIAL AREA, G - 41 TO G - 59, B - 38, 39, B - 34, B - 35, B - 36 KESHAV PURAM	62	Other Outage	Planned Outage	21-Feb-2024	14:13	21-Feb-2024	17:17	184	0.00056	PSD ON INDUSTRIAL WEEKLY OFF
111	21-Feb-2024	PARTS OF G - 5, G - 29 TO G - 40 LAWARNCE ROAD INDUSTRIAL AREA, G - 41 TO G - 59, B - 38, 39, B - 34, B - 35, B - 36 KESHAV PURAM	69	Other Outage	Planned Outage	21-Feb-2024	14:18	21-Feb-2024	17:17	179	0.00085	PSD ON INDUSTRIAL WEEKLY OFF
112	21-Feb-2024	PART OF L-BLOCK JJ COLONY KESHAV PURAM	5	Other Outage	Unplanned Outage	21-Feb-2024	16:12	21-Feb-2024	17:12	60	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
113	22-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	429	Other Outage	Unplanned Outage	22-Feb-2024	08:40	22-Feb-2024	08:57	17	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
114	22-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	7	400 kVA	Unplanned Outage	22-Feb-2024	10:41	22-Feb-2024	11:27	46	0.00001	EODB COMPLIANCE
115	22-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	283	Other Outage	Unplanned Outage	22-Feb-2024	10:49	22-Feb-2024	11:29	40	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
116	22-Feb-2024	PARTS OF D, E, H & J BLOCK ASHOK VIHAR PH - 1 KESHAV PURAM	238	630 kVA	Planned Outage	22-Feb-2024	11:02	22-Feb-2024	12:59	117	0.00085	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
117	22-Feb-2024	PART OF L-BLOCK JJ COLONY KESHAV PURAM	5	160 kVA	Unplanned Outage	22-Feb-2024	11:21	22-Feb-2024	11:50	29	0.00001	EODB COMPLIANCE
118	22-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	8	400 kVA	Unplanned Outage	22-Feb-2024	12:00	22-Feb-2024	12:32	32	0.00001	EODB COMPLIANCE
119	22-Feb-2024	PART OF C-31 LAWARANCE ROAD INDUSTRIAL AREA KESHAV PURAM	3	400 kVA	Unplanned Outage	22-Feb-2024	12:40	22-Feb-2024	13:21	41	0.00001	EODB COMPLIANCE
120	22-Feb-2024	PARTS OF A BLOCK GULABI BAGH AND PETROL PUMP KESHAV PURAM	263	Other Outage	Unplanned Outage	22-Feb-2024	13:21	22-Feb-2024	13:36	15	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
121	22-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	6	400 kVA	Unplanned Outage	22-Feb-2024	13:30	22-Feb-2024	14:00	30	0.00001	EODB COMPLIANCE
122	22-Feb-2024	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	7	400 kVA	Unplanned Outage	22-Feb-2024	15:01	22-Feb-2024	16:03	62	0.00002	EODB COMPLIANCE
123	22-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	1	Other Outage	Unplanned Outage	22-Feb-2024	15:30	22-Feb-2024	16:05	35	0.00001	EODB COMPLIANCE
124	23-Feb-2024	PARTS OF I A-BLOCK, PART OF H & J BLOCK ASHOK VIHAR PH - 1, POLICE COLONY & SPORTS COMPLEX, TRANSFORMER WORK SHOP J BLOCK KESHAV	354	Other Outage	Unplanned Outage	23-Feb-2024	10:09	23-Feb-2024	10:28	19	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
125	23-Feb-2024	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	377	630 kVA	Planned Outage	23-Feb-2024	10:22	23-Feb-2024	12:16	114	0.00041	PLANNED OUTAGE
126	23-Feb-2024	PARTS OF JA BLK MURGA MKT AND PART OF J-BLOCK ASHOK VIHAR PH-1 KESHAV PURAM	769	Other Outage	Unplanned Outage	23-Feb-2024	12:30	23-Feb-2024	12:41	11	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
127	23-Feb-2024	PART OF WAZIR PUR INDUSTRIAL AREA KESHAV PURAM	11	Other Outage	Unplanned Outage	23-Feb-2024	14:29	23-Feb-2024	15:05	36	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
128	23-Feb-2024	PART OF L-BLOCK JJ COLONY KESHAV PURAM	11	400 kVA	Unplanned Outage	23-Feb-2024	15:36	23-Feb-2024	16:17	41	0.00001	EODB COMPLIANCE
129	23-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA AND PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	216	Other Outage	Unplanned Outage	23-Feb-2024	17:51	23-Feb-2024	18:31	40	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
130	24-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	36	Other Outage	Unplanned Outage	24-Feb-2024	07:17	24-Feb-2024	08:31	74	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
131	24-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	61	Other Outage	Unplanned Outage	24-Feb-2024	07:17	24-Feb-2024	09:15	118	0.00033	FORCE MAJEURE/EXTERNAL FACTORS
132	24-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	1272	Other Outage	Unplanned Outage	24-Feb-2024	08:38	24-Feb-2024	09:15	37	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
133	24-Feb-2024	PARTS OF A, B, C & D BLOCK ASHOK VIHAR-1 KESHAV PURAM	1251	Other Outage	Unplanned Outage	24-Feb-2024	09:51	24-Feb-2024	10:10	19	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
134	24-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	1531	Other Outage	Unplanned Outage	24-Feb-2024	10:20	24-Feb-2024	11:15	55	0.00046	FORCE MAJEURE/EXTERNAL FACTORS
135	24-Feb-2024	PARTS OF K, L,J1, J2 AND SANJAY MARKET WAZIRPUR JJ COLONY KESHAV PURAM	452	Other Outage	Planned Outage	24-Feb-2024	11:41	24-Feb-2024	15:40	239	0.00053	PLANNED OUTAGE
136	25-Feb-2024	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	429	Other Outage	Unplanned Outage	25-Feb-2024	12:10	25-Feb-2024	12:50	41	0.00034	FORCE MAJEURE/EXTERNAL FACTORS
137	26-Feb-2024	PART OF G-40 LAWARANCE ROAD INDUSTRIAL AREA KESHAV PURAM	7	Other Outage	Unplanned Outage	26-Feb-2024	09:59	26-Feb-2024	10:19	20	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
138	26-Feb-2024	PART OF DSIDC SHEDS-21 KESHAV PURAM	7	Other Outage	Unplanned Outage	26-Feb-2024	11:49	26-Feb-2024	12:11	22	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
139	26-Feb-2024	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	15	Other Outage	Unplanned Outage	26-Feb-2024	12:07	26-Feb-2024	12:38	31	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
140	26-Feb-2024	PART OF A BLOCK GROUP INDUSTRIAL AREA KESHAV PURAM	4	100 kVA	Unplanned Outage	26-Feb-2024	14:55	26-Feb-2024	15:17	22	0.00001	EODB COMPLIANCE
141	26-Feb-2024	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA KESHAV PURAM	5	Other Outage	Unplanned Outage	26-Feb-2024	15:32	26-Feb-2024	16:09	37	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
142	26-Feb-2024	PARTS OF I A-BLOCK, PART OF H & J BLOCK ASHOK VIHAR PH - 1, POLICE COLONY & SPORTS COMPLEX, TRANSFORMER WORK SHOP J BLOCK KESHAV PURAM	395	Other Outage	Unplanned Outage	26-Feb-2024	23:02	26-Feb-2024	23:15	13	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
143	27-Feb-2024	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA. KESHAV PURAM	30	Other Outage	Unplanned Outage	27-Feb-2024	11:31	27-Feb-2024	12:26	55	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
144	27-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	133	Other Outage	Unplanned Outage	27-Feb-2024	16:44	27-Feb-2024	17:16	32	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
145	27-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	1530	Other Outage	Unplanned Outage	27-Feb-2024	16:44	27-Feb-2024	17:19	35	0.00035	FORCE MAJEURE/EXTERNAL FACTORS
146	27-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	1530	Other Outage	Unplanned Outage	27-Feb-2024	18:36	27-Feb-2024	20:13	97	0.00094	FORCE MAJEURE/EXTERNAL FACTORS
147	28-Feb-2024	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	3	Other Outage	Unplanned Outage	28-Feb-2024	02:24	28-Feb-2024	02:42	18	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
148	28-Feb-2024	PART OF RAM PURACOMMUNITY CENTRE KESHAV PURAM	20	Other Outage	Planned Outage	28-Feb-2024	10:34	28-Feb-2024	16:05	331	0.00009	EODB COMPLIANCE
149	28-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	79	Other Outage	Planned Outage	28-Feb-2024	11:10	28-Feb-2024	13:50	160	0.00009	PSD ON INDUSTRIAL WEEKLY OFF
150	28-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	36	Other Outage	Planned Outage	28-Feb-2024	11:18	28-Feb-2024	15:49	271	0.00083	PSD ON INDUSTRIAL WEEKLY OFF
151	28-Feb-2024	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR KESHAV PURAM	130	Other Outage	Planned Outage	28-Feb-2024	11:26	28-Feb-2024	13:40	133	0.00015	PSD ON INDUSTRIAL WEEKLY OFF
152	28-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	1470	Other Outage	Unplanned Outage	28-Feb-2024	11:28	28-Feb-2024	12:50	82	0.00046	FORCE MAJEURE/EXTERNAL FACTORS
153	28-Feb-2024	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTIAL AREA KESHAV PURAM	60	Other Outage	Unplanned Outage	28-Feb-2024	11:28	28-Feb-2024	17:42	374	0.00104	FORCE MAJEURE/EXTERNAL FACTORS
154	28-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	24	Other Outage	Unplanned Outage	28-Feb-2024	13:50	28-Feb-2024	13:57	7	0.00004	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
155	28-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	79	Other Outage	Unplanned Outage	28-Feb-2024	13:50	28-Feb-2024	16:06	136	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
156	28-Feb-2024	PART OF RAM PURACOMMUNITY CENTRE KESHAV PURAM	9	Other Outage	Unplanned Outage	28-Feb-2024	16:11	28-Feb-2024	21:03	292	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
157	28-Feb-2024	PART OF RAM PURA DDA KESHAV PURAM	3	Other Outage	Unplanned Outage	28-Feb-2024	18:10	28-Feb-2024	19:04	54	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
158	28-Feb-2024	PARTS OF HALDI KESRI, RAM PURA DDA KESHAV PURAM	21	Other Outage	Unplanned Outage	28-Feb-2024	18:31	28-Feb-2024	19:04	33	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
159	29-Feb-2024	PARTS OF MANSOORI, C - 1 TO C - 31 LAWARANCE ROAD INDUSTRIAL AREA KESHAV PURAM	85	Other Outage	Unplanned Outage	29-Feb-2024	02:49	29-Feb-2024	03:10	20	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
160	29-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	5	400 kVA	Unplanned Outage	29-Feb-2024	12:53	29-Feb-2024	13:33	40	0.00001	EODB COMPLIANCE
161	29-Feb-2024	PART OF B/66 WAZIR PUR KESHAV PURAM	3	250 kVA	Unplanned Outage	29-Feb-2024	12:57	29-Feb-2024	13:31	34	0.00001	EODB COMPLIANCE
162	29-Feb-2024	PART OF C-31 LAWARANCE ROAD INDUSTRIAL AREA KESHAV PURAM	3	Other Outage	Unplanned Outage	29-Feb-2024	13:33	29-Feb-2024	14:52	79	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
KIRARI												
1	01-Feb-2024	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	3376	Other Outage	Unplanned Outage	01-Feb-2024	02:23	01-Feb-2024	03:29	65	0.00060	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PART OF KIRARI KIRARI	9	Other Outage	Unplanned Outage	01-Feb-2024	12:00	01-Feb-2024	16:40	280	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PART OF MAIN ROAD KARALA KIRARI	3	Other Outage	Unplanned Outage	01-Feb-2024	12:15	01-Feb-2024	13:30	75	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PART OF MAIN ROAD KARALA KIRARI	7	Other Outage	Unplanned Outage	01-Feb-2024	12:28	01-Feb-2024	13:30	62	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PART OF KIRARI KIRARI	2	100 kVA	Unplanned Outage	01-Feb-2024	13:05	01-Feb-2024	14:09	64	0.00002	EODB COMPLIANCE
6	01-Feb-2024	PARTS OF KIRARI KIRARI	893	Other Outage	Unplanned Outage	01-Feb-2024	13:20	01-Feb-2024	13:40	20	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF KIRARI KIRARI	2411	Other Outage	Unplanned Outage	01-Feb-2024	13:20	01-Feb-2024	13:35	16	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
8	01-Feb-2024	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	57	Other Outage	Unplanned Outage	01-Feb-2024	13:35	01-Feb-2024	14:48	73	0.00051	FORCE MAJEURE/EXTERNAL FACTORS
9	02-Feb-2024	PARTS OF RELIANCE TOWER AGRA NAGAR KIRARI	6511	Other Outage	Unplanned Outage	02-Feb-2024	08:38	02-Feb-2024	09:50	72	0.00129	FORCE MAJEURE/EXTERNAL FACTORS
10	02-Feb-2024	PARTS OF RELIANCE TOWER AGRA NAGAR KIRARI	1648	Other Outage	Unplanned Outage	02-Feb-2024	08:38	02-Feb-2024	10:03	85	0.00040	FORCE MAJEURE/EXTERNAL FACTORS
11	02-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	449	Other Outage	Planned Outage	02-Feb-2024	11:02	02-Feb-2024	16:31	329	0.00238	PLANNED OUTAGE
12	02-Feb-2024	PART OF KIRARI KIRARI	1	Other Outage	Unplanned Outage	02-Feb-2024	14:37	02-Feb-2024	14:48	11	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
13	03-Feb-2024	PARTS OF RANI KHERA KARAL KIRARI	2609	Other Outage	Unplanned Outage	03-Feb-2024	04:37	03-Feb-2024	05:05	28	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
14	03-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	449	Other Outage	Planned Outage	03-Feb-2024	09:39	03-Feb-2024	14:50	311	0.00225	PLANNED OUTAGE
15	03-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	1136	Other Outage	Planned Outage	03-Feb-2024	10:15	03-Feb-2024	12:04	108	0.00036	PLANNED OUTAGE
16	03-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL. KIRARI	250	Other Outage	Planned Outage	03-Feb-2024	10:35	03-Feb-2024	11:27	52	0.00023	PLANNED OUTAGE
17	03-Feb-2024	PARTS OF RAMA VIHAR AND SUKHBIR NAGAR MAIN ROAD. KIRARI	1676	Other Outage	Planned Outage	03-Feb-2024	11:36	03-Feb-2024	17:49	373	0.00373	PLANNED OUTAGE
18	03-Feb-2024	PARTS OF HINDU MUSLIM AMAN VIHAR, RAMESH ENCLAVE, TATA TOWER, BITTOO WALA, KAILASH VIHAR NO-1, RAJ BIR AMAN VIAHR KIRARI	817	Other Outage	Planned Outage	03-Feb-2024	11:56	03-Feb-2024	13:15	79	0.00057	PLANNED OUTAGE
19	03-Feb-2024	PARTS OF HINDU MUSLIM AMAN VIHAR, RAMESH ENCLAVE, TATA TOWER, BITTOO WALA, KAILASH VIHAR NO-1, RAJ BIR AMAN VIAHR KIRARI	56	Other Outage	Planned Outage	03-Feb-2024	12:16	03-Feb-2024	13:13	57	0.00005	PLANNED OUTAGE
20	03-Feb-2024	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	2348	Other Outage	Unplanned Outage	03-Feb-2024	13:50	03-Feb-2024	14:43	53	0.00068	FORCE MAJEURE/EXTERNAL FACTORS
21	03-Feb-2024	PARTS OF SOM BAZAR KIRARI	3334	Other Outage	Unplanned Outage	03-Feb-2024	18:10	03-Feb-2024	19:35	85	0.00142	FORCE MAJEURE/EXTERNAL FACTORS
22	05-Feb-2024	PARTS OF RAMESH ENCLAVE AND SHIV CHOWK KIRARI	3137	Other Outage	Unplanned Outage	05-Feb-2024	18:18	05-Feb-2024	18:40	22	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
23	05-Feb-2024	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	328	Other Outage	Unplanned Outage	05-Feb-2024	19:11	05-Feb-2024	20:02	51	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
24	05-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL. KIRARI	2145	Other Outage	Unplanned Outage	05-Feb-2024	22:26	05-Feb-2024	22:41	14	0.00009	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
25	05-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL. KIRARI	5546	Other Outage	Unplanned Outage	05-Feb-2024	22:26	05-Feb-2024	23:13	46	0.00071	FORCE MAJEURE/EXTERNAL FACTORS
26	06-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	56	Other Outage	Planned Outage	06-Feb-2024	10:49	06-Feb-2024	17:58	429	0.00024	PLANNED OUTAGE
27	06-Feb-2024	PARTS OF KARALA VILLAGE KIRARI	1029	Other Outage	Unplanned Outage	06-Feb-2024	11:55	06-Feb-2024	16:13	258	0.00072	FORCE MAJEURE/EXTERNAL FACTORS
28	06-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	2145	Other Outage	Unplanned Outage	06-Feb-2024	14:15	06-Feb-2024	14:49	34	0.00048	FORCE MAJEURE/EXTERNAL FACTORS
29	06-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	2779	Other Outage	Unplanned Outage	06-Feb-2024	14:15	06-Feb-2024	14:50	34	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
30	06-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	633	Other Outage	Unplanned Outage	06-Feb-2024	14:15	06-Feb-2024	15:40	84	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
31	06-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL. KIRARI	166	Other Outage	Unplanned Outage	06-Feb-2024	20:12	06-Feb-2024	23:29	197	0.00137	FORCE MAJEURE/EXTERNAL FACTORS
32	07-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 KIRARI	352	Other Outage	Unplanned Outage	07-Feb-2024	00:56	07-Feb-2024	01:57	61	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
33	07-Feb-2024	PARTS OF KIRARI BARAT GHAR KIRARI	785	Other Outage	Planned Outage	07-Feb-2024	11:13	07-Feb-2024	17:37	384	0.00160	PLANNED OUTAGE
34	07-Feb-2024	PARTS OF KIRARI BARAT GHAR KIRARI	61	Other Outage	Planned Outage	07-Feb-2024	11:36	07-Feb-2024	17:31	355	0.00118	PLANNED OUTAGE
35	07-Feb-2024	PART OF NITHARI VILLAGE KIRARI	1	Other Outage	Unplanned Outage	07-Feb-2024	22:37	07-Feb-2024	22:58	21	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
36	08-Feb-2024	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	2344	Other Outage	Planned Outage	08-Feb-2024	11:23	08-Feb-2024	17:45	381	0.00424	PLANNED OUTAGE
37	08-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	533	Other Outage	Planned Outage	08-Feb-2024	11:37	08-Feb-2024	13:47	130	0.00043	PLANNED OUTAGE
38	08-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL. KIRARI	250	Other Outage	Planned Outage	08-Feb-2024	12:01	08-Feb-2024	13:09	68	0.00028	PLANNED OUTAGE
39	08-Feb-2024	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	781	Other Outage	Planned Outage	08-Feb-2024	12:07	08-Feb-2024	16:44	277	0.00062	PLANNED OUTAGE
40	08-Feb-2024	PART OF POCKET C-1 ESS-8 (DP) SECT-37 KIRARI	2	Other Outage	Planned Outage	08-Feb-2024	12:40	08-Feb-2024	13:10	30	0.00001	PLANNED OUTAGE
41	10-Feb-2024	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK KIRARI	1431	Other Outage	Planned Outage	10-Feb-2024	11:24	10-Feb-2024	17:35	371	0.00371	PLANNED OUTAGE
42	10-Feb-2024	PARTS OF ROOPALI ENCLAVE KIRARI	1254	Other Outage	Unplanned Outage	10-Feb-2024	13:11	10-Feb-2024	13:36	25	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
43	11-Feb-2024	PART OF POCKET C-1 ESS-8 (DP) SECT-37 KIRARI	2	Other Outage	Planned Outage	11-Feb-2024	11:47	11-Feb-2024	15:47	240	0.00007	PLANNED OUTAGE
44	11-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	159	Other Outage	Unplanned Outage	11-Feb-2024	16:04	11-Feb-2024	16:45	41	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
45	13-Feb-2024	PART OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	8	Other Outage	Unplanned Outage	13-Feb-2024	00:33	13-Feb-2024	00:57	24	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
46	13-Feb-2024	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	781	Other Outage	Planned Outage	13-Feb-2024	10:48	13-Feb-2024	17:27	399	0.00288	PLANNED OUTAGE
47	13-Feb-2024	PARTS OF RANI KHERA KARAL KIRARI	2272	Other Outage	Planned Outage	13-Feb-2024	11:56	13-Feb-2024	15:20	203	0.00204	PLANNED OUTAGE
48	13-Feb-2024	PARTS OF SOM BAZAR KIRARI	771	Other Outage	Planned Outage	13-Feb-2024	12:31	13-Feb-2024	14:36	125	0.00028	PLANNED OUTAGE
49	13-Feb-2024	PARTS OF PRATAP VIHAR AND SHIV CHOWK KIRARI MANGOLPURI KIRARI	2082	Other Outage	Unplanned Outage	13-Feb-2024	17:28	13-Feb-2024	17:48	21	0.00025	INTERRUPTION DUE TO FAULT
50	13-Feb-2024	PARTS OF PRATAP VIHAR AND SHIV CHOWK KIRARI MANGOLPURI KIRARI	3388	Other Outage	Unplanned Outage	13-Feb-2024	17:28	13-Feb-2024	18:40	72	0.00110	INTERRUPTION DUE TO FAULT
51	14-Feb-2024	PART OF MAIN ROAD KARALA KIRARI	20	Other Outage	Planned Outage	14-Feb-2024	12:14	14-Feb-2024	16:57	282	0.00039	PLANNED OUTAGE
52	14-Feb-2024	PART OF NITHARI VILLAGE KIRARI	20	Other Outage	Unplanned Outage	14-Feb-2024	12:16	14-Feb-2024	12:39	23	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
53	15-Feb-2024	PART OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	2	Other Outage	Unplanned Outage	15-Feb-2024	23:14	16-Feb-2024	00:53	99	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
54	16-Feb-2024	PARTS OF KARALA VILLAGE KIRARI	614	Other Outage	Planned Outage	16-Feb-2024	12:00	16-Feb-2024	17:30	330	0.00238	PLANNED OUTAGE
55	16-Feb-2024	PARTS OF ROOPALI ENCLAVE KIRARI	1139	Other Outage	Unplanned Outage	16-Feb-2024	13:31	16-Feb-2024	16:18	167	0.00056	FORCE MAJEURE/EXTERNAL FACTORS
56	17-Feb-2024	PARTS OF RAMESH WALA NO. 3 KIRARI	960	Other Outage	Planned Outage	17-Feb-2024	11:03	17-Feb-2024	17:09	366	0.00081	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
57	17-Feb-2024	PART OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	6	Other Outage	Planned Outage	17-Feb-2024	11:50	17-Feb-2024	16:57	307	0.00009	PLANNED OUTAGE
58	17-Feb-2024	PARTS OF RANI KHERA KARAL KIRARI	146	Other Outage	Planned Outage	17-Feb-2024	13:18	17-Feb-2024	14:25	67	0.00020	PLANNED OUTAGE
59	18-Feb-2024	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	65	Other Outage	Unplanned Outage	18-Feb-2024	15:20	18-Feb-2024	17:00	100	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
60	19-Feb-2024	PART OF KIRARI KIRARI	4	Other Outage	Unplanned Outage	19-Feb-2024	00:51	19-Feb-2024	01:10	19	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
61	19-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	28	Other Outage	Planned Outage	19-Feb-2024	10:55	19-Feb-2024	17:15	380	0.00021	PLANNED OUTAGE
62	19-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	179	Other Outage	Planned Outage	19-Feb-2024	11:21	19-Feb-2024	17:15	354	0.00020	PLANNED OUTAGE
63	19-Feb-2024	PARTS OF KAMAL KANT JHA TO VIDYA PATI NAGAR KIRARI	1359	Other Outage	Planned Outage	19-Feb-2024	11:57	19-Feb-2024	16:51	294	0.00098	PLANNED OUTAGE
64	19-Feb-2024	PARTS OF PASHU AUSHADHALAYA KIRARI	3971	Other Outage	Unplanned Outage	19-Feb-2024	14:12	19-Feb-2024	15:02	50	0.00057	FORCE MAJEURE/EXTERNAL FACTORS
65	19-Feb-2024	PARTS OF PASHU AUSHADHALAYA KIRARI	1524	Other Outage	Unplanned Outage	19-Feb-2024	14:12	19-Feb-2024	15:03	50	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
66	19-Feb-2024	PART OF PASHU AUSHADHALAYA KIRARI	10	Other Outage	Unplanned Outage	19-Feb-2024	14:12	19-Feb-2024	15:06	53	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
67	19-Feb-2024	PARTS OF PASHU AUSHADHALAYA KIRARI	819	Other Outage	Unplanned Outage	19-Feb-2024	14:12	19-Feb-2024	15:07	54	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
68	19-Feb-2024	PARTS OF AMAN VIHAR AND SHIV CHOWK KIRARI	43	Other Outage	Unplanned Outage	19-Feb-2024	18:00	19-Feb-2024	21:03	183	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
69	19-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	88	Other Outage	Unplanned Outage	19-Feb-2024	22:45	20-Feb-2024	00:16	91	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
70	20-Feb-2024	PARTS OF VILL-RANI KHERA,VILL- RASOOL PUR, VILL- MUBARAK PUR, BAGYA VIHAR, MEER VIHAR,YOGI RAJ PURAM & PART OF AGAR NAGER KIRARI	2397	Other Outage	Unplanned Outage	20-Feb-2024	03:25	20-Feb-2024	03:47	21	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
71	20-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	1400	Other Outage	Planned Outage	20-Feb-2024	10:42	20-Feb-2024	17:48	426	0.00178	PLANNED OUTAGE
72	20-Feb-2024	PARTS OF NITHARI VILLAGE KIRARI	1034	Other Outage	Unplanned Outage	20-Feb-2024	14:39	20-Feb-2024	15:20	40	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
73	21-Feb-2024	PARTS OF PREM NAGAR-1 KIRARI	28	Other Outage	Planned Outage	21-Feb-2024	09:24	21-Feb-2024	14:23	299	0.00017	PLANNED OUTAGE
74	21-Feb-2024	PARTS OF VIDYA PATI NAGAR AREA KIRARI	1338	Other Outage	Planned Outage	21-Feb-2024	12:24	21-Feb-2024	16:21	237	0.00086	PLANNED OUTAGE
75	21-Feb-2024	PARTS OF VILL-RANI KHERA,VILL- RASOOL PUR, VILL- MUBARAK PUR, BAGYA VIHAR, MEER VIHAR,YOGI RAJ PURAM & PART OF AGAR NAGER KIRARI	873	Other Outage	Unplanned Outage	21-Feb-2024	12:39	21-Feb-2024	14:05	86	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
76	21-Feb-2024	PART OF VILL. KANJHAWLA KIRARI	19	Other Outage	Unplanned Outage	21-Feb-2024	20:53	22-Feb-2024	01:16	263	0.00044	FORCE MAJEURE/EXTERNAL FACTORS
77	22-Feb-2024	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	423	Other Outage	Planned Outage	22-Feb-2024	08:48	22-Feb-2024	15:52	423	0.00153	PLANNED OUTAGE
78	22-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, U-BLOCK, DJB KIRARI, DHURVA ENCL. KIRARI	1065	Other Outage	Planned Outage	22-Feb-2024	11:34	22-Feb-2024	17:21	347	0.00145	PLANNED OUTAGE
79	22-Feb-2024	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	775	Other Outage	Planned Outage	22-Feb-2024	12:38	22-Feb-2024	17:50	312	0.00225	PLANNED OUTAGE
80	23-Feb-2024	PART OF AMAN VIHAR KIRARI	2	Other Outage	Planned Outage	23-Feb-2024	11:25	23-Feb-2024	17:15	350	0.00010	PLANNED OUTAGE
81	23-Feb-2024	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DJB KIRARI, HARI ENCLAVE-2 KIRARI	4562	Other Outage	Unplanned Outage	23-Feb-2024	13:16	23-Feb-2024	14:05	48	0.00074	FORCE MAJEURE/EXTERNAL FACTORS
82	24-Feb-2024	PARTS OF JAIN NAGAR & SUKHBIR NAGAR KIRARI	1531	Other Outage	Planned Outage	24-Feb-2024	11:12	24-Feb-2024	17:44	392	0.00109	PLANNED OUTAGE
83	24-Feb-2024	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DJB KIRARI, HARI ENCLAVE-2 KIRARI	153	Other Outage	Planned Outage	24-Feb-2024	11:19	24-Feb-2024	15:31	252	0.00161	PLANNED OUTAGE
84	25-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 KIRARI	955	Other Outage	Unplanned Outage	25-Feb-2024	17:35	25-Feb-2024	17:42	7	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
85	25-Feb-2024	PART OF KARALA VILLAGE KIRARI	16	Other Outage	Unplanned Outage	25-Feb-2024	17:35	25-Feb-2024	20:16	161	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
86	26-Feb-2024	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	1724	Other Outage	Unplanned Outage	26-Feb-2024	13:11	26-Feb-2024	13:52	41	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
87	26-Feb-2024	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	736	Other Outage	Unplanned Outage	26-Feb-2024	13:11	26-Feb-2024	15:50	159	0.00071	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
88	26-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 KIRARI	377	Other Outage	Unplanned Outage	26-Feb-2024	14:11	26-Feb-2024	14:35	24	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
89	26-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 KIRARI	456	Other Outage	Unplanned Outage	26-Feb-2024	14:36	26-Feb-2024	15:56	80	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
90	26-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 KIRARI	382	Other Outage	Unplanned Outage	26-Feb-2024	15:56	26-Feb-2024	16:35	39	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
91	27-Feb-2024	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE KIRARI	736	Other Outage	Unplanned Outage	27-Feb-2024	17:01	27-Feb-2024	18:04	63	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
92	27-Feb-2024	PARTS OF SOM BAZAR KIRARI	3335	Other Outage	Unplanned Outage	27-Feb-2024	18:32	27-Feb-2024	19:05	33	0.00034	FORCE MAJEURE/EXTERNAL FACTORS
93	28-Feb-2024	PART OF MAIN ROAD KARALA KIRARI	20	Other Outage	Planned Outage	28-Feb-2024	12:02	28-Feb-2024	16:58	295	0.00025	PLANNED OUTAGE
94	28-Feb-2024	PARTS OF POCKET C-2 ESS-2 (DP) SEC-37 KIRARI	344	Other Outage	Unplanned Outage	28-Feb-2024	15:51	28-Feb-2024	20:39	288	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
95	29-Feb-2024	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR KIRARI	320	Other Outage	Planned Outage	29-Feb-2024	11:26	29-Feb-2024	17:30	364	0.00051	PLANNED OUTAGE
MANGOLPURI												
1	01-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER. MANGOLPURI	1369	Other Outage	Unplanned Outage	01-Feb-2024	00:08	01-Feb-2024	01:14	66	0.00055	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 , MANDIR WALI GALI MANGOLPURI	562	Other Outage	Unplanned Outage	01-Feb-2024	05:39	01-Feb-2024	07:05	86	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 , MANDIR WALI GALI MANGOLPURI	330	Other Outage	Unplanned Outage	01-Feb-2024	05:39	01-Feb-2024	08:09	150	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	1370	Other Outage	Unplanned Outage	01-Feb-2024	05:47	01-Feb-2024	06:55	67	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	224	Other Outage	Unplanned Outage	01-Feb-2024	05:47	01-Feb-2024	08:59	191	0.00053	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI MANGOLPURI	1548	Other Outage	Unplanned Outage	01-Feb-2024	06:16	01-Feb-2024	07:00	44	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI MANGOLPURI	210	Other Outage	Unplanned Outage	01-Feb-2024	06:16	01-Feb-2024	07:25	69	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
8	01-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	3944	Other Outage	Unplanned Outage	01-Feb-2024	08:09	01-Feb-2024	08:31	22	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
9	01-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	1370	Other Outage	Unplanned Outage	01-Feb-2024	08:23	01-Feb-2024	08:59	36	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
10	01-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	57	Other Outage	Unplanned Outage	01-Feb-2024	08:57	01-Feb-2024	16:27	450	0.00063	FORCE MAJEURE/EXTERNAL FACTORS
11	01-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JIC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER. MANGOLPURI	592	Other Outage	Unplanned Outage	01-Feb-2024	09:16	01-Feb-2024	10:08	52	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
12	01-Feb-2024	PART OF PKT-16 SEC-20 MANGOLPURI	6	Other Outage	Unplanned Outage	01-Feb-2024	10:48	01-Feb-2024	12:07	79	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
13	01-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	312	Other Outage	Unplanned Outage	01-Feb-2024	11:51	01-Feb-2024	16:27	276	0.00077	FORCE MAJEURE/EXTERNAL FACTORS
14	01-Feb-2024	PARTS OF MUSKAN HOSPITAL MANGOLPURI	756	Other Outage	Unplanned Outage	01-Feb-2024	16:16	01-Feb-2024	16:43	28	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
15	01-Feb-2024	PART OF MUSKAN HOSPITAL MANGOLPURI	4	Other Outage	Unplanned Outage	01-Feb-2024	16:50	01-Feb-2024	17:10	20	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
16	01-Feb-2024	PARTS OF PKT-09 SEC-21 MANGOLPURI	975	Other Outage	Unplanned Outage	01-Feb-2024	23:06	01-Feb-2024	23:22	16	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
17	01-Feb-2024	PARTS OF PKT-09 SEC-21 MANGOLPURI	124	Other Outage	Unplanned Outage	01-Feb-2024	23:06	01-Feb-2024	23:29	23	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
18	02-Feb-2024	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1, MANGOLPURI	773	Other Outage	Unplanned Outage	02-Feb-2024	09:26	02-Feb-2024	09:57	31	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
19	02-Feb-2024	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR. MANGOLPURI	545	630 kVA	Planned Outage	02-Feb-2024	11:42	02-Feb-2024	13:08	86	0.00062	PLANNED OUTAGE
20	02-Feb-2024	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI MANGOLPURI	85	Other Outage	Planned Outage	02-Feb-2024	11:48	02-Feb-2024	17:09	321	0.00098	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
21	02-Feb-2024	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 MANGOLPURI	111	400 kVA	Planned Outage	02-Feb-2024	14:29	02-Feb-2024	16:11	102	0.00006	PLANNED OUTAGE
22	02-Feb-2024	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI MANGOLPURI	346	630 kVA	Planned Outage	02-Feb-2024	14:41	02-Feb-2024	16:12	91	0.00013	PLANNED OUTAGE
23	02-Feb-2024	PARTS OF A-4 SEC-20 MANGOLPURI	55	Other Outage	Unplanned Outage	02-Feb-2024	15:13	02-Feb-2024	15:36	23	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
24	02-Feb-2024	PART OF BUDH VIHAR PH-2 SHYAM COLONY MANGOLPURI	5	Other Outage	Unplanned Outage	02-Feb-2024	22:24	02-Feb-2024	22:34	10	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
25	03-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	314	Other Outage	Planned Outage	03-Feb-2024	11:01	03-Feb-2024	17:55	414	0.00184	PLANNED OUTAGE
26	03-Feb-2024	PARTS OF BEGUM PUR VILLAGE, BEGUM PUR POLICE STN SEC 22 RHN, PKT-5-6 SEC-22 MANGOLPURI	417	Other Outage	Planned Outage	03-Feb-2024	11:06	03-Feb-2024	17:52	406	0.00169	PLANNED OUTAGE
27	03-Feb-2024	PART OF T- BLK SULTAN PURI MANGOLPURI	4	Other Outage	Unplanned Outage	03-Feb-2024	11:45	03-Feb-2024	12:45	60	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
28	03-Feb-2024	PARTS OF PKT-09 SEC-21 MANGOLPURI	124	Other Outage	Planned Outage	03-Feb-2024	12:26	03-Feb-2024	16:05	219	0.00012	PLANNED OUTAGE
29	03-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	30	Other Outage	Unplanned Outage	03-Feb-2024	13:25	03-Feb-2024	13:54	29	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
30	03-Feb-2024	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 MANGOLPURI	1923	Other Outage	Unplanned Outage	03-Feb-2024	13:25	03-Feb-2024	13:35	10	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
31	03-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	1506	Other Outage	Unplanned Outage	03-Feb-2024	14:49	03-Feb-2024	16:02	73	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
32	04-Feb-2024	PARTS OF POOTHKALAN NO.7, 12 , D-4 SEC-20 MANGOLPURI	52	Other Outage	Unplanned Outage	04-Feb-2024	04:36	04-Feb-2024	04:57	21	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
33	04-Feb-2024	PARTS OF POOTHKALAN NO.7, 12 , D-4 SEC-20 MANGOLPURI	3397	Other Outage	Unplanned Outage	04-Feb-2024	04:36	04-Feb-2024	05:17	41	0.00068	FORCE MAJEURE/EXTERNAL FACTORS
34	04-Feb-2024	PARTS OF POOTHKALAN NO.7, 12 , D-4 SEC-20 MANGOLPURI	1134	Other Outage	Unplanned Outage	04-Feb-2024	04:36	04-Feb-2024	05:43	67	0.00047	FORCE MAJEURE/EXTERNAL FACTORS
35	04-Feb-2024	PARTS OF SULTAN PUR MAZRA VILL. , U- BLK & T- BLK M. PURI MANGOLPURI	174	Other Outage	Unplanned Outage	04-Feb-2024	06:00	04-Feb-2024	06:25	25	0.00017	INTERRUPTION DUE TO FAULT
36	04-Feb-2024	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI MANGOLPURI	215	Other Outage	Unplanned Outage	04-Feb-2024	09:34	04-Feb-2024	10:21	47	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
37	04-Feb-2024	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI MANGOLPURI	46	Other Outage	Unplanned Outage	04-Feb-2024	09:34	04-Feb-2024	11:39	125	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
38	04-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	314	Other Outage	Unplanned Outage	04-Feb-2024	11:21	04-Feb-2024	11:55	34	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
39	04-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	34	Other Outage	Unplanned Outage	04-Feb-2024	20:31	04-Feb-2024	21:30	59	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
40	04-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	36	Other Outage	Unplanned Outage	04-Feb-2024	20:33	04-Feb-2024	21:30	57	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
41	04-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	631	Other Outage	Unplanned Outage	04-Feb-2024	20:43	04-Feb-2024	21:30	47	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
42	05-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JJC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER. MANGOLPURI	893	Other Outage	Planned Outage	05-Feb-2024	10:32	05-Feb-2024	16:05	333	0.00111	PLANNED OUTAGE
43	05-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Planned Outage	05-Feb-2024	11:31	05-Feb-2024	18:32	421	0.00012	FORCE MAJEURE DUE TO SABOTAGE
44	05-Feb-2024	PARTS OF MUSKAN HOSPITAL MANGOLPURI	756	Other Outage	Unplanned Outage	05-Feb-2024	11:39	05-Feb-2024	11:55	15	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
45	05-Feb-2024	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	671	Other Outage	Planned Outage	05-Feb-2024	12:39	05-Feb-2024	15:31	172	0.00172	PLANNED OUTAGE
46	05-Feb-2024	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	130	Other Outage	Planned Outage	05-Feb-2024	14:32	05-Feb-2024	15:13	41	0.00014	PLANNED OUTAGE
47	06-Feb-2024	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE. MANGOLPURI	406	630 kVA	Planned Outage	06-Feb-2024	11:02	06-Feb-2024	12:55	113	0.00060	PLANNED OUTAGE
48	06-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Planned Outage	06-Feb-2024	11:55	06-Feb-2024	17:03	308	0.00017	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
49	06-Feb-2024	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	1932	Other Outage	Planned Outage	06-Feb-2024	12:29	06-Feb-2024	16:35	246	0.00137	PLANNED OUTAGE
50	06-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	322	Other Outage	Planned Outage	06-Feb-2024	12:38	06-Feb-2024	17:29	291	0.00186	PLANNED OUTAGE
51	06-Feb-2024	PARTS OF G. D. GOENKA, PKT-17 SEC-22 , PKT-12 SEC-22, RAJEEV NAGAR PH.2 NO.1 & 2 MANGOLPURI	1479	Other Outage	Planned Outage	06-Feb-2024	12:45	06-Feb-2024	16:40	235	0.00098	PLANNED OUTAGE
52	06-Feb-2024	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	639	Other Outage	Unplanned Outage	06-Feb-2024	21:14	06-Feb-2024	21:45	31	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
53	07-Feb-2024	PARTS OF MAMGOL PURI PATTHAR MARKET AND FURNITURE MKT MANGOLPURI	98	Other Outage	Unplanned Outage	07-Feb-2024	10:26	07-Feb-2024	11:37	71	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
54	07-Feb-2024	PARTS OF T-1 & T-4 MPIA MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	1116	Other Outage	Planned Outage	07-Feb-2024	11:00	07-Feb-2024	12:51	111	0.00046	PLANNED OUTAGE
55	07-Feb-2024	PARTS OF BEGUMPUR BUS STAND MANGOLPURI	1214	Other Outage	Planned Outage	07-Feb-2024	11:26	07-Feb-2024	17:25	359	0.00120	PLANNED OUTAGE
56	07-Feb-2024	PARTS OF SULTANPURI P3 BLOCK MANGOLPURI	561	Other Outage	Planned Outage	07-Feb-2024	11:38	07-Feb-2024	12:15	37	0.00006	PLANNED OUTAGE
57	07-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	234	630 kVA	Planned Outage	07-Feb-2024	11:59	07-Feb-2024	15:49	230	0.00077	PLANNED OUTAGE
58	07-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	439	Other Outage	Unplanned Outage	07-Feb-2024	12:26	07-Feb-2024	15:34	188	0.00052	FORCE MAJEURE/EXTERNAL FACTORS
59	07-Feb-2024	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI MANGOLPURI	600	Other Outage	Planned Outage	07-Feb-2024	14:25	07-Feb-2024	16:25	120	0.00020	PLANNED OUTAGE
60	07-Feb-2024	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI MANGOLPURI	937	Other Outage	Planned Outage	07-Feb-2024	14:28	07-Feb-2024	16:28	120	0.00033	PLANNED OUTAGE
61	07-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	68	Other Outage	Unplanned Outage	07-Feb-2024	15:12	07-Feb-2024	16:04	52	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
62	08-Feb-2024	PARTS OF RMU OUTDOOR ,JAL BOARD PUMP HOUSE. MANGOLPURI	683	1000 kVA	Planned Outage	08-Feb-2024	11:29	08-Feb-2024	12:27	58	0.00011	PLANNED OUTAGE
63	08-Feb-2024	PARTS OF KRISHAN VIHAR NO-1, BUDH VIHAR PH-1, SATSANG BHAWAN MANGOLPURI	372	630 kVA	Planned Outage	08-Feb-2024	11:44	08-Feb-2024	16:42	298	0.00099	PLANNED OUTAGE
64	08-Feb-2024	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	671	Other Outage	Unplanned Outage	08-Feb-2024	12:47	08-Feb-2024	13:08	20	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
65	08-Feb-2024	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	1932	Other Outage	Unplanned Outage	08-Feb-2024	12:47	08-Feb-2024	13:16	28	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
66	08-Feb-2024	PARTS OF KRISHAN VIHAR NO-1, BUDH VIHAR PH-1, SATSANG BHAWAN MANGOLPURI	979	Other Outage	Planned Outage	08-Feb-2024	14:51	08-Feb-2024	16:56	125	0.00090	PLANNED OUTAGE
67	08-Feb-2024	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 MANGOLPURI	2127	Other Outage	Unplanned Outage	08-Feb-2024	14:55	08-Feb-2024	15:20	25	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
68	08-Feb-2024	PARTS OF H BLOCK MOTHER DAIRY SULTAN PURI MANGOLPURI	1425	Other Outage	Unplanned Outage	08-Feb-2024	15:46	08-Feb-2024	16:05	19	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
69	09-Feb-2024	PARTS OF POOTHKALAN NO.7, 12 , D-4 SEC-20 MANGOLPURI	600	Other Outage	Unplanned Outage	09-Feb-2024	10:17	09-Feb-2024	10:56	39	0.00007	INTERRUPTION DUE TO FAULT
70	09-Feb-2024	PARTS OF PKT-11 SEC-22 MANGOLPURI	684	Other Outage	Planned Outage	09-Feb-2024	11:31	09-Feb-2024	16:50	319	0.00230	PLANNED OUTAGE
71	09-Feb-2024	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL. MANGOLPURI	196	Other Outage	Planned Outage	09-Feb-2024	11:35	09-Feb-2024	16:03	267	0.00022	PLANNED OUTAGE
72	09-Feb-2024	PARTS OF H BLOCK MOTHER DAIRY SULTAN PURI MANGOLPURI	509	630 kVA	Planned Outage	09-Feb-2024	11:40	09-Feb-2024	12:59	79	0.00042	PLANNED OUTAGE
73	09-Feb-2024	PARTS OF BEGUMPUR BUS STAND MANGOLPURI	2216	Other Outage	Planned Outage	09-Feb-2024	13:44	09-Feb-2024	15:40	116	0.00116	PLANNED OUTAGE
74	09-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	883	Other Outage	Planned Outage	09-Feb-2024	14:13	09-Feb-2024	15:35	82	0.00059	PLANNED OUTAGE
75	09-Feb-2024	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR MANGOLPURI	216	Other Outage	Unplanned Outage	09-Feb-2024	16:20	09-Feb-2024	16:30	10	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
76	09-Feb-2024	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR MANGOLPURI	2772	Other Outage	Unplanned Outage	09-Feb-2024	16:20	09-Feb-2024	16:50	30	0.00025	FORCE MAJEURE/EXTERNAL FACTORS
77	09-Feb-2024	PARTS OF T- BLK . M. PURI PARTIALLY,B-1,2,3,4,5,A-1,2,3,4,5 BLKS.S. PURI MANGOLPURI	4734	Other Outage	Unplanned Outage	09-Feb-2024	17:26	09-Feb-2024	17:50	23	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
78	10-Feb-2024	PART OF PKT-09 SEC-21 MANGOLPURI	1	Other Outage	Planned Outage	10-Feb-2024	08:25	10-Feb-2024	15:05	400	0.00011	EODB COMPLIANCE
79	10-Feb-2024	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	405	Other Outage	Planned Outage	10-Feb-2024	11:08	10-Feb-2024	12:03	55	0.00018	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
80	10-Feb-2024	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	1282	Other Outage	Planned Outage	10-Feb-2024	11:54	10-Feb-2024	15:40	226	0.00075	PLANNED OUTAGE
81	10-Feb-2024	PART OF POLICE QUARTER NEAR RG-23 MANGOLPURI	1	Other Outage	Planned Outage	10-Feb-2024	12:30	10-Feb-2024	16:40	250	0.00007	PLANNED OUTAGE
82	10-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JJC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER. MANGOLPURI	253	400 kVA	Planned Outage	10-Feb-2024	14:06	10-Feb-2024	14:47	41	0.00006	PLANNED OUTAGE
83	10-Feb-2024	PARTS OF MUSKAN HOSPITAL MANGOLPURI	736	Other Outage	Unplanned Outage	10-Feb-2024	16:48	10-Feb-2024	17:18	30	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
84	11-Feb-2024	PARTS OF MAMGOL PURI PATTHAR MARKET AND FURNITURE MKT MANGOLPURI	98	Other Outage	Planned Outage	11-Feb-2024	10:51	11-Feb-2024	17:40	409	0.00034	PSD ON INDUSTRIAL WEEKLY OFF
85	11-Feb-2024	PART OF T-5 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	16	Other Outage	Planned Outage	11-Feb-2024	11:31	11-Feb-2024	15:45	254	0.00007	PSD ON INDUSTRIAL WEEKLY OFF
86	11-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	1468	Other Outage	Unplanned Outage	11-Feb-2024	18:42	11-Feb-2024	19:14	31	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
87	12-Feb-2024	PARTS OF PKT-11 SEC-22 MANGOLPURI	541	Other Outage	Unplanned Outage	12-Feb-2024	09:06	12-Feb-2024	09:51	44	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
88	12-Feb-2024	PART OF T-4 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	1	Other Outage	Unplanned Outage	12-Feb-2024	10:05	12-Feb-2024	10:33	28	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
89	12-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	806	Other Outage	Planned Outage	12-Feb-2024	11:20	12-Feb-2024	13:12	112	0.00081	PLANNED OUTAGE
90	12-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	465	Other Outage	Planned Outage	12-Feb-2024	11:38	12-Feb-2024	17:53	375	0.00156	PLANNED OUTAGE
91	12-Feb-2024	PARTS OF BEGUM PUR VILLAGE, BEGUM PUR POLICE STN SEC 22 RHN, PKT-5-6 SEC-22 MANGOLPURI	389	Other Outage	Planned Outage	12-Feb-2024	12:44	12-Feb-2024	16:21	217	0.00157	PLANNED OUTAGE
92	12-Feb-2024	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	1935	Other Outage	Planned Outage	12-Feb-2024	13:30	12-Feb-2024	16:47	197	0.00109	PLANNED OUTAGE
93	12-Feb-2024	PARTS OF SULTANPURI P3 BLOCK MANGOLPURI	730	Other Outage	Planned Outage	12-Feb-2024	14:18	12-Feb-2024	15:24	66	0.00022	PLANNED OUTAGE
94	12-Feb-2024	PART OF NO -22 MANGOLPURI MANGOLPURI	6	Other Outage	Unplanned Outage	12-Feb-2024	15:22	12-Feb-2024	15:44	22	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
95	13-Feb-2024	PARTS OF T- BLK . M. PURI PARTIALLY,B-1,2,3,4,5,A-1,2,3,4,5 BLKS.S. PURI MANGOLPURI	517	Other Outage	Planned Outage	13-Feb-2024	10:50	13-Feb-2024	12:23	93	0.00013	PLANNED OUTAGE
96	13-Feb-2024	PARTS OF POLICE QUARTER NEAR RG-23, PETROL PUMP SEC-23, V. POOTH KALAN, TATA TELE SERVICES, MANGERAM PARK, GARG GOYAL TRADING COMPANY MANGOLPURI	950	Other Outage	Planned Outage	13-Feb-2024	11:10	13-Feb-2024	14:29	199	0.00055	PLANNED OUTAGE
97	13-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Planned Outage	13-Feb-2024	11:19	13-Feb-2024	17:14	355	0.00020	PLANNED OUTAGE
98	13-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JJC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER. MANGOLPURI	893	Other Outage	Planned Outage	13-Feb-2024	11:28	13-Feb-2024	15:00	212	0.00047	PLANNED OUTAGE
99	13-Feb-2024	PARTS OF WORK CENTRE AND SULTANPURI MANGOLPURI	1353	Other Outage	Planned Outage	13-Feb-2024	11:33	13-Feb-2024	13:53	140	0.00054	PLANNED OUTAGE
100	13-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	174	315 kVA	Planned Outage	13-Feb-2024	14:18	13-Feb-2024	15:49	91	0.00013	PLANNED OUTAGE
101	14-Feb-2024	PARTS OF P1-BLK SULTANPURI MANGOLPURI	3605	Other Outage	Unplanned Outage	14-Feb-2024	07:37	14-Feb-2024	08:34	56	0.00070	INTERRUPTION DUE TO FAULT
102	14-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Planned Outage	14-Feb-2024	11:43	14-Feb-2024	17:15	332	0.00018	PLANNED OUTAGE
103	14-Feb-2024	PARTS OF PKT-09 SEC-21 MANGOLPURI	125	Other Outage	Planned Outage	14-Feb-2024	11:50	14-Feb-2024	17:34	344	0.00191	PLANNED OUTAGE
104	14-Feb-2024	PARTS OF P1-BLK SULTANPURI MANGOLPURI	1716	Other Outage	Planned Outage	14-Feb-2024	12:19	14-Feb-2024	12:56	37	0.00015	PLANNED OUTAGE
105	15-Feb-2024	PARTS OF POOTHKALAN NO.7, 12 , D-4 SEC-20 MANGOLPURI	1136	Other Outage	Unplanned Outage	15-Feb-2024	09:28	15-Feb-2024	09:56	28	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
106	15-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JJC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI ,HGI LABOUR CLY, W-48,49 JJ CLUSTER. MANGOLPURI	606	Other Outage	Planned Outage	15-Feb-2024	11:02	15-Feb-2024	13:01	119	0.00076	PLANNED OUTAGE
107	15-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Planned Outage	15-Feb-2024	11:24	15-Feb-2024	17:18	354	0.00049	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
108	15-Feb-2024	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR. MANGOLPURI	1023	Other Outage	Planned Outage	15-Feb-2024	11:36	15-Feb-2024	16:45	309	0.00309	PLANNED OUTAGE
109	15-Feb-2024	PART OF POLICE QUARTER NEAR RG-23 MANGOLPURI	1	Other Outage	Planned Outage	15-Feb-2024	12:56	15-Feb-2024	15:44	168	0.00005	PLANNED OUTAGE
110	15-Feb-2024	PART OF BEGUM PUR VILLAGE MANGOLPURI	1	Other Outage	Unplanned Outage	15-Feb-2024	14:08	15-Feb-2024	15:17	69	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
111	15-Feb-2024	PART OF RATAN VIHAR MANGOLPURI	2	Other Outage	Unplanned Outage	15-Feb-2024	16:04	15-Feb-2024	16:34	30	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
112	16-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	143	Other Outage	Planned Outage	16-Feb-2024	11:28	16-Feb-2024	16:41	313	0.00113	PLANNED OUTAGE
113	17-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	1301	Other Outage	Planned Outage	17-Feb-2024	11:33	17-Feb-2024	18:39	426	0.00178	FORCE MAJEURE DUE TO SABOTAGE
114	17-Feb-2024	PART OF PKT-09 SEC-21 MANGOLPURI	1	Other Outage	Planned Outage	17-Feb-2024	12:40	17-Feb-2024	15:26	166	0.00005	PLANNED OUTAGE
115	17-Feb-2024	PART OF T-4 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	5	Other Outage	Unplanned Outage	17-Feb-2024	17:45	17-Feb-2024	19:17	91	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
116	17-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	130	Other Outage	Unplanned Outage	17-Feb-2024	22:01	17-Feb-2024	22:57	56	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
117	17-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	1951	Other Outage	Unplanned Outage	17-Feb-2024	22:01	18-Feb-2024	00:52	170	0.00189	FORCE MAJEURE/EXTERNAL FACTORS
118	18-Feb-2024	PARTS OF T-1 & T-4 MPJA MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	24	Other Outage	Planned Outage	18-Feb-2024	08:48	18-Feb-2024	17:21	513	0.00029	PSD ON INDUSTRIAL WEEKLY OFF
119	18-Feb-2024	PARTS OF T-2 & T-4 MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	49	Other Outage	Planned Outage	18-Feb-2024	10:14	18-Feb-2024	16:57	403	0.00056	PSD ON INDUSTRIAL WEEKLY OFF
120	18-Feb-2024	PARTS OF T-1, T-2 & T-5 MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	96	Other Outage	Planned Outage	18-Feb-2024	10:51	18-Feb-2024	13:24	153	0.00043	PSD ON INDUSTRIAL WEEKLY OFF
121	18-Feb-2024	PART OF BEGUM PUR VILLAGE MANGOLPURI	1	Other Outage	Planned Outage	18-Feb-2024	11:37	18-Feb-2024	14:35	178	0.00005	PLANNED OUTAGE
122	18-Feb-2024	PARTS OF POOTHKALAN MARKET MANGOLPURI	1663	Other Outage	Unplanned Outage	18-Feb-2024	12:07	18-Feb-2024	12:30	23	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
123	19-Feb-2024	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR. MANGOLPURI	207	Other Outage	Unplanned Outage	19-Feb-2024	05:45	19-Feb-2024	06:42	57	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
124	19-Feb-2024	PARTS OF G. D. GOENKA, PKT-17 SEC-22 , PKT-12 SEC-22, RAJEEV NAGAR PH.2 NO.1 & 2 MANGOLPURI	216	Other Outage	Unplanned Outage	19-Feb-2024	10:01	19-Feb-2024	10:30	29	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
125	19-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	253	Other Outage	Planned Outage	19-Feb-2024	10:58	19-Feb-2024	18:34	456	0.00063	FORCE MAJEURE DUE TO SABOTAGE
126	19-Feb-2024	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI MANGOLPURI	620	Other Outage	Planned Outage	19-Feb-2024	11:29	19-Feb-2024	14:17	168	0.00033	PLANNED OUTAGE
127	19-Feb-2024	PARTS OF BEGUM PUR VILLAGE, BEGUM PUR POLICE STN SEC 22 RHN, PKT-5-6 SEC-22 MANGOLPURI	487	Other Outage	Planned Outage	19-Feb-2024	11:40	19-Feb-2024	16:41	301	0.00217	PLANNED OUTAGE
128	19-Feb-2024	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI MANGOLPURI	338	Other Outage	Planned Outage	19-Feb-2024	12:16	19-Feb-2024	17:30	314	0.00035	PLANNED OUTAGE
129	19-Feb-2024	PARTS OF T- BLK - M. PURI PARTIALLY,B-1,2,3,4,5,A-1,2,3,4,5 BLKS.S. PURI MANGOLPURI	3967	Other Outage	Unplanned Outage	19-Feb-2024	13:08	19-Feb-2024	13:58	50	0.00042	FORCE MAJEURE/EXTERNAL FACTORS
130	19-Feb-2024	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE. MANGOLPURI	2655	Other Outage	Unplanned Outage	19-Feb-2024	14:47	19-Feb-2024	15:47	60	0.00050	FORCE MAJEURE/EXTERNAL FACTORS
131	19-Feb-2024	PARTS OF G. D. GOENKA, PKT-17 SEC-22 , PKT-12 SEC-22, RAJEEV NAGAR PH.2 NO.1 & 2 MANGOLPURI	5117	Other Outage	Unplanned Outage	19-Feb-2024	16:06	19-Feb-2024	16:49	43	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
132	19-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	1131	Other Outage	Unplanned Outage	19-Feb-2024	16:46	19-Feb-2024	17:13	27	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
133	20-Feb-2024	PARTS OF T-2 & T-4 MANGOL PURI INDUSTRIAL AREA PH. - 1 MANGOLPURI	49	Other Outage	Unplanned Outage	20-Feb-2024	00:11	20-Feb-2024	00:39	28	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
134	20-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	836	Other Outage	Unplanned Outage	20-Feb-2024	00:17	20-Feb-2024	01:12	54	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
135	20-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	632	Other Outage	Unplanned Outage	20-Feb-2024	00:17	20-Feb-2024	02:44	146	0.00102	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
136	20-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	716	Other Outage	Unplanned Outage	20-Feb-2024	01:39	20-Feb-2024	02:30	51	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
137	20-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	58	Other Outage	Unplanned Outage	20-Feb-2024	08:33	20-Feb-2024	09:40	67	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
138	20-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	574	Other Outage	Unplanned Outage	20-Feb-2024	08:35	20-Feb-2024	09:40	65	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
139	20-Feb-2024	PARTS OF H BLOCK MOTHER DAIRY SULTAN PURI MANGOLPURI	30	Other Outage	Unplanned Outage	20-Feb-2024	08:42	20-Feb-2024	08:56	14	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
140	20-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JIC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JIC, B-3 BLK JIC. MANGOLPURI	832	Other Outage	Planned Outage	20-Feb-2024	11:05	20-Feb-2024	13:25	140	0.00101	PLANNED OUTAGE
141	20-Feb-2024	PARTS OF POOTHKALAN MANGOLPURI	753	Other Outage	Planned Outage	20-Feb-2024	11:29	20-Feb-2024	14:21	172	0.00038	PLANNED OUTAGE
142	20-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	143	Other Outage	Planned Outage	20-Feb-2024	12:19	20-Feb-2024	12:53	34	0.00014	PLANNED OUTAGE
143	20-Feb-2024	PARTS OF POCKET 7, 8 & PARTIALLY 9 OF SECTOR 24. MANGOLPURI	592	630 kVA	Planned Outage	20-Feb-2024	14:31	20-Feb-2024	16:15	104	0.00043	PLANNED OUTAGE
144	20-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	2286	Other Outage	Unplanned Outage	20-Feb-2024	19:47	20-Feb-2024	20:10	23	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
145	20-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	1594	Other Outage	Unplanned Outage	20-Feb-2024	19:47	20-Feb-2024	21:00	73	0.00040	FORCE MAJEURE/EXTERNAL FACTORS
146	20-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	1914	Other Outage	Unplanned Outage	20-Feb-2024	19:47	20-Feb-2024	21:40	113	0.00063	FORCE MAJEURE/EXTERNAL FACTORS
147	21-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	979	Other Outage	Planned Outage	21-Feb-2024	10:55	21-Feb-2024	11:33	38	0.00027	PLANNED OUTAGE
148	21-Feb-2024	PARTS OF BEGUMPUR BUS STAND MANGOLPURI	1214	Other Outage	Planned Outage	21-Feb-2024	10:59	21-Feb-2024	17:40	401	0.00167	PLANNED OUTAGE
149	23-Feb-2024	PART OF T-5 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	2	100 kVA	Unplanned Outage	23-Feb-2024	11:09	23-Feb-2024	13:12	123	0.00003	EODB COMPLIANCE
150	23-Feb-2024	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR. MANGOLPURI	1023	Other Outage	Planned Outage	23-Feb-2024	12:11	23-Feb-2024	14:44	153	0.00111	PLANNED OUTAGE
151	23-Feb-2024	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK. MANGOLPURI	3387	Other Outage	Unplanned Outage	23-Feb-2024	12:14	23-Feb-2024	12:37	23	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
152	23-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	129	Other Outage	Planned Outage	23-Feb-2024	12:34	23-Feb-2024	14:56	142	0.00047	PLANNED OUTAGE
153	23-Feb-2024	PART OF NO -22 MANGOLPURI MANGOLPURI	2	315 kVA	Unplanned Outage	23-Feb-2024	14:43	23-Feb-2024	15:53	70	0.00002	EODB COMPLIANCE
154	24-Feb-2024	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21 MANGOLPURI	1937	Other Outage	Unplanned Outage	24-Feb-2024	08:06	24-Feb-2024	08:28	22	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
155	24-Feb-2024	PARTS OF FRIENDS ENCLAVE WEST, 80 SQ. YARD, HARIJAN BASTI, INDRA JHEEL PREM NAGAR, INDUSTRIAL BELT IN Z-518 AND PREM NAGAR - 1, PART OF PREM NAGAR - 2 STATION BLOCK, KHOOB RAM PARK , HARSUKH BLOCK AND PART OF KIRARI VILLAGE, RATAN VIHAR. MANGOLPURI	742	Other Outage	Planned Outage	24-Feb-2024	10:08	24-Feb-2024	13:31	203	0.00203	PLANNED OUTAGE
156	24-Feb-2024	PARTS OF POOTHKALAN MARKET MANGOLPURI	1663	Other Outage	Unplanned Outage	24-Feb-2024	10:55	24-Feb-2024	11:20	25	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
157	24-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	440	Other Outage	Planned Outage	24-Feb-2024	11:07	24-Feb-2024	16:18	311	0.00069	PLANNED OUTAGE
158	24-Feb-2024	PARTS OF BEGUM PUR VILLAGE, BEGUM PUR POLICE STN SEC 22 RHN, PKT-5-6 SEC-22 MANGOLPURI	393	Other Outage	Planned Outage	24-Feb-2024	11:50	24-Feb-2024	16:37	287	0.00175	PLANNED OUTAGE
159	25-Feb-2024	PARTS OF C BLOCK, DDA SLUM , G BLOCK H BLOCK, Y BLOCK MANGOLPURI	3085	Other Outage	Unplanned Outage	25-Feb-2024	10:49	25-Feb-2024	10:55	5	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
160	25-Feb-2024	PARTS OF T-4 MANGOL PURI INDUSTRIAL AREA PH.-1 MANGOLPURI	28	Other Outage	Planned Outage	25-Feb-2024	11:52	25-Feb-2024	15:34	222	0.00031	PSD ON INDUSTRIAL WEEKLY OFF
161	25-Feb-2024	PART OF A-4 SEC-20 MANGOLPURI	15	Other Outage	Unplanned Outage	25-Feb-2024	23:58	26-Feb-2024	07:00	422	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
162	26-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	779	Other Outage	Unplanned Outage	26-Feb-2024	03:44	26-Feb-2024	04:15	31	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
163	26-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	526	Other Outage	Unplanned Outage	26-Feb-2024	03:44	26-Feb-2024	04:22	38	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
164	26-Feb-2024	PARTS OF SANJAY GANDHI HOSPITAL MANGOLPURI	39	Other Outage	Planned Outage	26-Feb-2024	11:15	26-Feb-2024	14:53	218	0.00012	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
165	26-Feb-2024	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR MANGOLPURI	1174	Other Outage	Planned Outage	26-Feb-2024	11:30	26-Feb-2024	17:17	347	0.00183	PLANNED OUTAGE
166	26-Feb-2024	PARTS OF P1-BLK SULTANPURI MANGOLPURI	2427	Other Outage	Unplanned Outage	26-Feb-2024	12:36	26-Feb-2024	13:14	38	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
167	26-Feb-2024	PARTS OF P1-BLK SULTANPURI MANGOLPURI	1182	Other Outage	Unplanned Outage	26-Feb-2024	12:36	26-Feb-2024	15:02	145	0.00044	FORCE MAJEURE/EXTERNAL FACTORS
168	27-Feb-2024	PARTS OF SULTANPURI P3 BLOCK MANGOLPURI	2878	Other Outage	Unplanned Outage	27-Feb-2024	08:21	27-Feb-2024	08:42	21	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
169	27-Feb-2024	PARTS OF SULTANPURI P3 BLOCK MANGOLPURI	422	Other Outage	Unplanned Outage	27-Feb-2024	08:21	27-Feb-2024	09:28	67	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
170	27-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	788	Other Outage	Unplanned Outage	27-Feb-2024	09:04	27-Feb-2024	09:35	31	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
171	27-Feb-2024	PARTS OF SULTANPURI P4 BLOCK MANGOLPURI	807	Other Outage	Unplanned Outage	27-Feb-2024	09:04	27-Feb-2024	10:20	75	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
172	27-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	2925	Other Outage	Unplanned Outage	27-Feb-2024	09:20	27-Feb-2024	09:59	39	0.00033	FORCE MAJEURE/EXTERNAL FACTORS
173	27-Feb-2024	PARTS OF PKT-16 SEC-20 MANGOLPURI	1241	Other Outage	Unplanned Outage	27-Feb-2024	09:20	27-Feb-2024	11:34	134	0.00045	FORCE MAJEURE/EXTERNAL FACTORS
174	27-Feb-2024	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC. MANGOLPURI	364	Other Outage	Planned Outage	27-Feb-2024	11:19	27-Feb-2024	17:52	393	0.00055	PLANNED OUTAGE
175	27-Feb-2024	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE. MANGOLPURI	208	Other Outage	Planned Outage	27-Feb-2024	11:29	27-Feb-2024	17:29	360	0.00030	PLANNED OUTAGE
176	27-Feb-2024	PARTS OF SULTANPURI P3 BLOCK MANGOLPURI	69	Other Outage	Unplanned Outage	27-Feb-2024	12:15	27-Feb-2024	14:00	105	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
177	27-Feb-2024	PARTS OF G. D. GOENKA, PKT-17 SEC-22 , PKT-12 SEC-22, RAJEEV NAGAR PH.2 NO.1 & 2 MANGOLPURI	478	Other Outage	Planned Outage	27-Feb-2024	14:28	27-Feb-2024	17:32	184	0.00026	PLANNED OUTAGE
178	28-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	726	Other Outage	Unplanned Outage	28-Feb-2024	10:24	28-Feb-2024	11:26	62	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
179	28-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	175	Other Outage	Planned Outage	28-Feb-2024	11:18	28-Feb-2024	17:08	350	0.00224	PLANNED OUTAGE
180	28-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Unplanned Outage	28-Feb-2024	12:29	28-Feb-2024	13:52	83	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
181	28-Feb-2024	PARTS OF CETPLANT , HARIZEN BASTI , RAJ PARK , BERIWALA BAGH JJC, EAST FRIENDS ENCLAVE S. PURI , ABHIMANYU COMPLEX. F-1,3,6,7 BLKS. S. PURI MCD QUARTER (JAHANGIR PURI) H1 CLUSTER MANGOLPURI	130	Other Outage	Planned Outage	28-Feb-2024	13:18	28-Feb-2024	15:26	128	0.00014	PLANNED OUTAGE
182	28-Feb-2024	PART OF T-4 MANGOL PURI INDUSTRIAL AREA PH-1 MANGOLPURI	2	25 kVA	Unplanned Outage	28-Feb-2024	14:18	28-Feb-2024	14:41	23	0.00001	EODB COMPLIANCE
183	28-Feb-2024	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN MANGOLPURI	836	Other Outage	Unplanned Outage	28-Feb-2024	20:51	28-Feb-2024	21:26	35	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
184	29-Feb-2024	PARTS OF EAST FRIENDS ENCLAVE MANGOLPURI	1411	Other Outage	Planned Outage	29-Feb-2024	10:52	29-Feb-2024	19:38	526	0.00380	FORCE MAJEURE DUE TO SABOTAGE
185	29-Feb-2024	PART OF HARSHDEV PARK MANGOLPURI	2	Other Outage	Planned Outage	29-Feb-2024	11:59	29-Feb-2024	19:12	433	0.00012	FORCE MAJEURE DUE TO SABOTAGE
MODEL TOWN												
1	01-Feb-2024	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	211	Other Outage	Unplanned Outage	01-Feb-2024	00:57	01-Feb-2024	02:10	73	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	114	Other Outage	Unplanned Outage	01-Feb-2024	01:20	01-Feb-2024	02:10	50	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	2256	Other Outage	Unplanned Outage	01-Feb-2024	02:32	01-Feb-2024	02:55	23	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PART OF C-BLK OLD ZONAL OFFICE MODEL TOWN	2	Other Outage	Unplanned Outage	01-Feb-2024	02:32	01-Feb-2024	03:11	40	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF MUKHERJEE NAGAR DASH MESH PARK , MUKHERJEE NGAR NO-3 MODEL TOWN	1269	Other Outage	Unplanned Outage	01-Feb-2024	03:00	01-Feb-2024	03:40	40	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PARTS OF POLICE COLONY, PART OF E, F, K & M BLOCK MODEL TOWN, RESEB NAGARI MODEL TOWN	1198	Other Outage	Unplanned Outage	01-Feb-2024	05:38	01-Feb-2024	07:15	97	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF ARYABHATT.POLYTECHNIC, PART OF B - BLOCK INDUSTRIAL AREA GTK MODEL TOWN	68	Other Outage	Unplanned Outage	01-Feb-2024	06:43	01-Feb-2024	07:19	36	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
8	01-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	138	Other Outage	Unplanned Outage	01-Feb-2024	07:33	01-Feb-2024	08:43	70	0.00020	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
9	01-Feb-2024	PART OF K BLOCK JAHANGIR PURI MODEL TOWN	16	Other Outage	Unplanned Outage	01-Feb-2024	09:00	01-Feb-2024	11:40	160	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
10	01-Feb-2024	PART OF A BLOCK DDA SLUM FLATS MODEL TOWN	1	Other Outage	Unplanned Outage	01-Feb-2024	09:02	01-Feb-2024	17:11	489	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
11	01-Feb-2024	PART OF RADIO COLONY NO-6 MODEL TOWN	15	Other Outage	Planned Outage	01-Feb-2024	11:07	01-Feb-2024	15:17	250	0.00021	PLANNED OUTAGE
12	01-Feb-2024	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	198	Other Outage	Unplanned Outage	01-Feb-2024	11:16	01-Feb-2024	11:40	24	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
13	01-Feb-2024	PARTS OF DILKUSH BAGH INDUSTRIAL AREA, PART OF A AREAL AREA GTK MODEL TOWN	1523	Other Outage	Unplanned Outage	01-Feb-2024	11:52	01-Feb-2024	13:12	80	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
14	01-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	52	Other Outage	Unplanned Outage	01-Feb-2024	18:32	01-Feb-2024	20:20	108	0.00045	FORCE MAJEURE/EXTERNAL FACTORS
15	02-Feb-2024	PARTS OF C-BLK (OLD ZONAL OFFICE) MODEL TOWN	110	Other Outage	Unplanned Outage	02-Feb-2024	09:41	02-Feb-2024	10:15	34	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
16	02-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	181	Other Outage	Planned Outage	02-Feb-2024	10:33	02-Feb-2024	15:02	269	0.00015	PLANNED OUTAGE
17	02-Feb-2024	PARTS OF OUTRAM LINES. HAKIKAT NAGAR. MALL ROAD MAIN ROAD MODEL TOWN	452	990 kVA	Planned Outage	02-Feb-2024	11:00	02-Feb-2024	13:10	130	0.00094	PLANNED OUTAGE
18	02-Feb-2024	PARTS OF B, D, H & F BLOCK MODEL TOWN AND PART OF K & Z BLOCK MODEL TOWN	279	Other Outage	Planned Outage	02-Feb-2024	11:06	02-Feb-2024	14:36	210	0.00023	PLANNED OUTAGE
19	02-Feb-2024	PARTS OF OUTRAM LINES. HAKIKAT NAGAR. MALL ROAD MAIN ROAD MODEL TOWN	159	630 kVA	Planned Outage	02-Feb-2024	14:19	02-Feb-2024	15:44	85	0.00038	PLANNED OUTAGE
20	02-Feb-2024	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	254	Other Outage	Planned Outage	02-Feb-2024	15:00	02-Feb-2024	15:31	31	0.00014	PLANNED OUTAGE
21	02-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	434	630 kVA	Planned Outage	02-Feb-2024	15:49	02-Feb-2024	16:14	25	0.00011	PLANNED OUTAGE
22	02-Feb-2024	PARTS OF J-BLOCK JHODWALA MODEL TOWN	1385	Other Outage	Unplanned Outage	02-Feb-2024	20:40	02-Feb-2024	21:10	31	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
23	02-Feb-2024	PARTS OF J-BLOCK JHODWALA MODEL TOWN	1032	Other Outage	Unplanned Outage	02-Feb-2024	20:40	02-Feb-2024	21:15	35	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
24	03-Feb-2024	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	355	Other Outage	Planned Outage	03-Feb-2024	10:12	03-Feb-2024	12:57	165	0.00023	PLANNED OUTAGE
25	03-Feb-2024	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTK MODEL TOWN	25	Other Outage	Unplanned Outage	03-Feb-2024	10:23	03-Feb-2024	11:26	63	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
26	03-Feb-2024	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTK MODEL TOWN	69	Other Outage	Unplanned Outage	03-Feb-2024	10:25	03-Feb-2024	11:26	61	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
27	03-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	310	Other Outage	Planned Outage	03-Feb-2024	10:26	03-Feb-2024	14:46	260	0.00108	PLANNED OUTAGE
28	03-Feb-2024	PARTS OF AAKASH CINEMA, NANIWALA BAGH COMMERCIAL COMPLEX (AZAD PUR), PART OF MCD COLONY, SHASTRI MARKET., DISTT. OFFICE MODEL TOWN	429	630 kVA	Planned Outage	03-Feb-2024	11:20	03-Feb-2024	12:27	67	0.00011	PLANNED OUTAGE
29	03-Feb-2024	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	114	630 kVA	Planned Outage	03-Feb-2024	11:41	03-Feb-2024	12:36	55	0.00023	PLANNED OUTAGE
30	03-Feb-2024	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	286	990 kVA	Planned Outage	03-Feb-2024	12:12	03-Feb-2024	13:57	104	0.00029	PLANNED OUTAGE
31	03-Feb-2024	PARTS OF B, C, E, H, G BLOCKS & PART OF A BLOCK MODEL TOWN, D.A. FLATS MODEL TOWN	106	630 kVA	Planned Outage	03-Feb-2024	15:12	03-Feb-2024	15:54	42	0.00030	PLANNED OUTAGE
32	03-Feb-2024	PARTS OF MAHINDRA PARK & SANJAY NAGAR MODEL TOWN	88	Other Outage	Unplanned Outage	03-Feb-2024	18:04	03-Feb-2024	19:13	69	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
33	04-Feb-2024	PART OF MCD QUARTER JAHANGIR PURI MODEL TOWN	4	Other Outage	Planned Outage	04-Feb-2024	14:42	04-Feb-2024	17:34	172	0.00005	PLANNED OUTAGE
34	05-Feb-2024	PART OF AIR STAFF QUARTER MODEL TOWN	1	Other Outage	Planned Outage	05-Feb-2024	08:18	05-Feb-2024	10:37	139	0.00004	PLANNED OUTAGE
35	05-Feb-2024	PART OF MCD COLONY. R BLOCK MODEL TOWN	1	Other Outage	Unplanned Outage	05-Feb-2024	10:19	05-Feb-2024	10:43	23	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
36	05-Feb-2024	PARTS OF MCD COLONY. R & C BLOCK (MODEL TOWN), DJB QUARTERS. MODEL TOWN	1331	Other Outage	Unplanned Outage	05-Feb-2024	10:19	05-Feb-2024	10:47	27	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
37	05-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	226	Other Outage	Planned Outage	05-Feb-2024	10:24	05-Feb-2024	14:41	257	0.00036	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
38	05-Feb-2024	PARTS OF F-GANDHI VIHAR -1,2,3,4, CNG GOPAL PUR,A-GANDHI VIHAR,C-GANDHI VIHAR,D-GANDHI VIHAR,E-GANDHI VIHAR,NIRANKARI SAROVER,ITI DHEERPUR,HOLYCROSS,FAIMLY COURT,YOGRAJ,JJC MODEL TOWN	353	630 kVA	Planned Outage	05-Feb-2024	10:53	05-Feb-2024	12:26	93	0.00067	PLANNED OUTAGE
39	05-Feb-2024	PARTS OF F-GANDHI VIHAR -1,2,3,4, CNG GOPAL PUR,A-GANDHI VIHAR,C-GANDHI VIHAR,D-GANDHI VIHAR,E-GANDHI VIHAR,NIRANKARI SAROVER,ITI DHEERPUR,HOLYCROSS,FAIMLY COURT,YOGRAJ,JJC MODEL TOWN	138	630 kVA	Planned Outage	05-Feb-2024	10:57	05-Feb-2024	12:39	102	0.00034	PLANNED OUTAGE
40	05-Feb-2024	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	642	Other Outage	Planned Outage	05-Feb-2024	11:23	05-Feb-2024	15:00	217	0.00072	PLANNED OUTAGE
41	05-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	358	Other Outage	Planned Outage	05-Feb-2024	11:31	05-Feb-2024	14:43	192	0.00064	PLANNED OUTAGE
42	05-Feb-2024	PARTS OF INDRA VIHAR, HAKIKAT NGAR, PART OF OUTRAM LINES, DTC DEPOT, PART OF MALL ROAD. PG WOMEN HOSTEL MODEL TOWN	159	Other Outage	Planned Outage	05-Feb-2024	11:37	05-Feb-2024	13:39	122	0.00010	PLANNED OUTAGE
43	05-Feb-2024	PARTS OF F-GANDHI VIHAR -1,2,3,4, CNG GOPAL PUR,A-GANDHI VIHAR,C-GANDHI VIHAR,D-GANDHI VIHAR,E-GANDHI VIHAR,NIRANKARI SAROVER,ITI DHEERPUR,HOLYCROSS,FAIMLY COURT,YOGRAJ,JJC MODEL TOWN	234	630 kVA	Planned Outage	05-Feb-2024	14:03	05-Feb-2024	15:35	92	0.00031	PLANNED OUTAGE
44	05-Feb-2024	PARTS OF F-GANDHI VIHAR -1,2,3,4, CNG GOPAL PUR,A-GANDHI VIHAR,C-GANDHI VIHAR,D-GANDHI VIHAR,E-GANDHI VIHAR,NIRANKARI SAROVER,ITI DHEERPUR,HOLYCROSS,FAIMLY COURT,YOGRAJ,JJC MODEL TOWN	226	630 kVA	Planned Outage	05-Feb-2024	14:05	05-Feb-2024	15:36	91	0.00030	PLANNED OUTAGE
45	05-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	316	630 kVA	Planned Outage	05-Feb-2024	14:39	05-Feb-2024	16:33	114	0.00082	PLANNED OUTAGE
46	05-Feb-2024	PARTS OF MULTI LEVEL CAR PARKING , F BLOK MDT MODEL TOWN	143	Other Outage	Unplanned Outage	05-Feb-2024	22:52	05-Feb-2024	23:25	33	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
47	05-Feb-2024	PARTS OF MULTI LEVEL CAR PARKING , F BLOK MDT MODEL TOWN	197	Other Outage	Unplanned Outage	05-Feb-2024	22:52	05-Feb-2024	23:32	40	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
48	05-Feb-2024	PARTS OF MULTI LEVEL CAR PARKING , F BLOK MDT MODEL TOWN	1062	Other Outage	Unplanned Outage	05-Feb-2024	22:52	05-Feb-2024	23:35	43	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
49	05-Feb-2024	PARTS OF MULTI LEVEL CAR PARKING , F BLOK MDT MODEL TOWN	163	Other Outage	Unplanned Outage	05-Feb-2024	22:52	05-Feb-2024	23:40	48	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
50	06-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	314	Other Outage	Planned Outage	06-Feb-2024	10:20	06-Feb-2024	14:59	279	0.00031	PLANNED OUTAGE
51	06-Feb-2024	PARTS OF SUBZI MANDI AND D-BLK MODEL TOWN	473	990 kVA	Planned Outage	06-Feb-2024	11:11	06-Feb-2024	13:30	139	0.00031	PLANNED OUTAGE
52	06-Feb-2024	PART OF MCD QUARTER JAHANGIR PURI MODEL TOWN	19	100 kVA	Planned Outage	06-Feb-2024	11:17	06-Feb-2024	13:35	138	0.00008	PLANNED OUTAGE
53	06-Feb-2024	PARTS OF MUKHERJEE NAGAR -3 MODEL TOWN	698	Other Outage	Planned Outage	06-Feb-2024	11:56	06-Feb-2024	14:41	165	0.00032	PLANNED OUTAGE
54	06-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	405	Other Outage	Planned Outage	06-Feb-2024	12:42	06-Feb-2024	14:10	88	0.00039	PLANNED OUTAGE
55	06-Feb-2024	PART OF A - BLOCK INDUSTRIAL AREA MODEL TOWN	3	250 kVA	Unplanned Outage	06-Feb-2024	13:01	06-Feb-2024	13:25	24	0.00001	EODB COMPLIANCE
56	07-Feb-2024	PARTS OF KEWAL PARK, MCD JHEEL COLONY , R BLOCK MOTHER DAIRY , QUEEN MERY & SRIJAN SCHOOL MODEL TOWN	269	630 kVA	Planned Outage	07-Feb-2024	10:46	07-Feb-2024	12:27	101	0.00034	PLANNED OUTAGE
57	07-Feb-2024	PART OF MKT JAHANGIR PURI MODEL TOWN	4	160 kVA	Planned Outage	07-Feb-2024	11:36	07-Feb-2024	12:54	78	0.00002	PLANNED OUTAGE
58	07-Feb-2024	PART OF K BLOCK JAHANGIR PURI MODEL TOWN	20	Other Outage	Unplanned Outage	07-Feb-2024	11:48	07-Feb-2024	12:15	27	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
59	07-Feb-2024	PARTS OF KEWAL PARK, MCD JHEEL COLONY , R BLOCK MOTHER DAIRY , QUEEN MERY & SRIJAN SCHOOL MODEL TOWN	275	990 kVA	Planned Outage	07-Feb-2024	12:30	07-Feb-2024	14:00	90	0.00010	PLANNED OUTAGE
60	08-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	200	Other Outage	Planned Outage	08-Feb-2024	10:31	08-Feb-2024	14:55	264	0.00044	PLANNED OUTAGE
61	08-Feb-2024	PARTS OF NANIWALA BAGH , RAMESHWAR NAGAR MODEL TOWN	389	630 kVA	Planned Outage	08-Feb-2024	10:52	08-Feb-2024	12:22	90	0.00020	PLANNED OUTAGE
62	08-Feb-2024	PARTS OF GALI NO-3 MAJLIS PARK ADARSH NAGAR MODEL TOWN	524	990 kVA	Planned Outage	08-Feb-2024	11:00	08-Feb-2024	12:55	115	0.00026	PLANNED OUTAGE
63	08-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	275	Other Outage	Planned Outage	08-Feb-2024	11:19	08-Feb-2024	13:15	116	0.00039	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
64	08-Feb-2024	PARTS OF NANIWALA BAGH , RAMESHWAR NAGAR MODEL TOWN	197	630 kVA	Planned Outage	08-Feb-2024	12:28	08-Feb-2024	13:35	67	0.00030	PLANNED OUTAGE
65	08-Feb-2024	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	21	Other Outage	Unplanned Outage	08-Feb-2024	13:10	08-Feb-2024	13:51	41	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
66	08-Feb-2024	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	2363	Other Outage	Planned Outage	08-Feb-2024	14:37	08-Feb-2024	16:09	92	0.00059	PLANNED OUTAGE
67	08-Feb-2024	PARTS OF B, D, H & F BLOCK MODEL TOWN AND PART OF K & Z BLOCK MODEL TOWN	169	990 kVA	Planned Outage	08-Feb-2024	14:59	08-Feb-2024	15:37	38	0.00005	PLANNED OUTAGE
68	08-Feb-2024	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTK MODEL TOWN	1277	Other Outage	Unplanned Outage	08-Feb-2024	15:35	08-Feb-2024	16:20	45	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
69	08-Feb-2024	PARTS OF MAHINDRA PARK & SANJAY NAGAR MODEL TOWN	146	Other Outage	Unplanned Outage	08-Feb-2024	19:11	08-Feb-2024	19:47	36	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
70	09-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	304	Other Outage	Unplanned Outage	09-Feb-2024	04:40	09-Feb-2024	05:12	31	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
71	09-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	2949	Other Outage	Unplanned Outage	09-Feb-2024	04:40	09-Feb-2024	05:31	50	0.00049	FORCE MAJEURE/EXTERNAL FACTORS
72	09-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	283	Other Outage	Planned Outage	09-Feb-2024	10:19	09-Feb-2024	15:05	286	0.00207	PLANNED OUTAGE
73	09-Feb-2024	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	355	Other Outage	Planned Outage	09-Feb-2024	10:32	09-Feb-2024	15:25	293	0.00041	PLANNED OUTAGE
74	09-Feb-2024	PARTS OF INDRA VIKAS COLONY MODEL TOWN	469	630 kVA	Planned Outage	09-Feb-2024	10:55	09-Feb-2024	12:03	68	0.00008	PLANNED OUTAGE
75	09-Feb-2024	PARTS OF MAJLIS PARK GALI NO 13 MODEL TOWN	980	Other Outage	Planned Outage	09-Feb-2024	11:19	09-Feb-2024	15:37	258	0.00057	PLANNED OUTAGE
76	09-Feb-2024	PARTS OF J-BLOCK JHODWALA MODEL TOWN	1039	Other Outage	Planned Outage	09-Feb-2024	11:28	09-Feb-2024	15:05	217	0.00072	PLANNED OUTAGE
77	09-Feb-2024	PARTS OF T. B HOSPITAL. I.D.HOSPITAL, MUKHERJEE NAGAR (WEST)PART OF OUTRAM LINE,PART OF MALL ROAD, TAGOR PARK EXTN. PART OF DHAKA VILLAGE, 250 BEDDED HOSPITAL, AIR HOSTEL & PART OF NIRANKARI COLONY MODEL TOWN	668	1000 kVA	Planned Outage	09-Feb-2024	11:57	09-Feb-2024	13:42	105	0.00023	PLANNED OUTAGE
78	09-Feb-2024	PART OF A - BLOCK INDUSTRIAL AREA MODEL TOWN	5	400 kVA	Unplanned Outage	09-Feb-2024	14:10	09-Feb-2024	14:45	35	0.00001	EODB COMPLIANCE
79	09-Feb-2024	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	864	Other Outage	Planned Outage	09-Feb-2024	14:30	09-Feb-2024	16:35	125	0.00090	PLANNED OUTAGE
80	09-Feb-2024	PART OF SANJAY NAGAR MODEL TOWN	17	Other Outage	Unplanned Outage	09-Feb-2024	15:54	09-Feb-2024	16:35	41	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
81	09-Feb-2024	PART OF RADIO COLONY NO-6 MODEL TOWN	15	Other Outage	Unplanned Outage	09-Feb-2024	22:23	09-Feb-2024	23:09	46	0.00006	INTERRUPTION DUE TO FAULT
82	10-Feb-2024	PARTS OF MAJLIS PARK GALI NO 13 MODEL TOWN	1902	Other Outage	Unplanned Outage	10-Feb-2024	07:24	10-Feb-2024	07:45	21	0.00017	INTERRUPTION DUE TO FAULT
83	10-Feb-2024	PART OF EE-BLOCK NALEWALA MODEL TOWN	19	Other Outage	Unplanned Outage	10-Feb-2024	08:14	10-Feb-2024	09:21	67	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
84	10-Feb-2024	PART OF 336 SFS FLAT NO-2 MODEL TOWN	1	Other Outage	Planned Outage	10-Feb-2024	08:38	10-Feb-2024	10:30	112	0.00006	PLANNED OUTAGE
85	10-Feb-2024	PARTS OF MCD COLONY. R & C BLOCK (MODEL TOWN), DJB QUARTERS. MODEL TOWN	466	1000 kVA	Planned Outage	10-Feb-2024	11:30	10-Feb-2024	13:30	120	0.00087	PLANNED OUTAGE
86	10-Feb-2024	PARTS OF MAHINDRA PARK & SANJAY NAGAR MODEL TOWN	418	990 kVA	Planned Outage	10-Feb-2024	11:30	10-Feb-2024	13:46	136	0.00019	PLANNED OUTAGE
87	10-Feb-2024	PART OF SANJAY NAGAR MODEL TOWN	7	160 kVA	Planned Outage	10-Feb-2024	14:35	10-Feb-2024	15:51	76	0.00002	PLANNED OUTAGE
88	10-Feb-2024	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	27	Other Outage	Unplanned Outage	10-Feb-2024	18:57	10-Feb-2024	19:25	28	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
89	10-Feb-2024	PARTS OF INDRA VIKAS COLONY MODEL TOWN	3003	Other Outage	Unplanned Outage	10-Feb-2024	22:52	10-Feb-2024	23:13	21	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
90	11-Feb-2024	PARTS OF MAHINDRA PARK & SANJAY NAGAR MODEL TOWN	54	Other Outage	Unplanned Outage	11-Feb-2024	06:19	11-Feb-2024	07:16	57	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
91	11-Feb-2024	PARTS OF A-BLK JINDAL WALA MODEL TOWN	150	Other Outage	Unplanned Outage	11-Feb-2024	11:52	11-Feb-2024	12:54	62	0.00014	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
92	11-Feb-2024	PART OF C-BLK (OLD ZONAL OFFICE) MODEL TOWN	18	Other Outage	Unplanned Outage	11-Feb-2024	16:08	11-Feb-2024	16:55	47	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
93	11-Feb-2024	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	1084	Other Outage	Unplanned Outage	11-Feb-2024	22:40	12-Feb-2024	00:37	117	0.00049	FORCE MAJEURE/EXTERNAL FACTORS
94	12-Feb-2024	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	671	Other Outage	Planned Outage	12-Feb-2024	10:24	12-Feb-2024	14:49	265	0.00191	PLANNED OUTAGE
95	12-Feb-2024	PARTS OF A-BLK JINDAL WALA MODEL TOWN	203	Other Outage	Planned Outage	12-Feb-2024	10:46	12-Feb-2024	15:51	305	0.00042	PLANNED OUTAGE
96	12-Feb-2024	PARTS OF BUDH MANDIR AZADPUR, TRANSPORT CENTRE, BHAROLLA VILLAGE, DARGAH WALA, ADARSH NAGAR POLICE STATION MODEL TOWN	1014	Other Outage	Planned Outage	12-Feb-2024	11:14	12-Feb-2024	13:19	125	0.00125	PLANNED OUTAGE
97	12-Feb-2024	PARTS OF A-BLK JINDAL WALA MODEL TOWN	55	315 kVA	Planned Outage	12-Feb-2024	14:13	12-Feb-2024	16:00	107	0.00015	PLANNED OUTAGE
98	13-Feb-2024	PART OF POLICE COLONY MODEL TOWN	1	Other Outage	Planned Outage	13-Feb-2024	08:56	13-Feb-2024	09:38	42	0.00001	PLANNED OUTAGE
99	13-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	376	Other Outage	Planned Outage	13-Feb-2024	10:15	13-Feb-2024	14:45	270	0.00060	PLANNED OUTAGE
100	13-Feb-2024	PARTS OF MULTI LEVEL CAR PARKING , F BLOK MDT MODEL TOWN	143	Other Outage	Planned Outage	13-Feb-2024	11:18	13-Feb-2024	13:32	134	0.00007	PLANNED OUTAGE
101	13-Feb-2024	PARTS OF J-BLOCK JHODWALA MODEL TOWN	244	Other Outage	Planned Outage	13-Feb-2024	14:26	13-Feb-2024	16:17	111	0.00012	PLANNED OUTAGE
102	13-Feb-2024	PARTS OF KEWAL PARK, MCD JHEEL COLONY , R BLOCK MOTHER DAIRY , QUEEN MERY & SRIJAN SCHOOL MODEL TOWN	275	Other Outage	Unplanned Outage	13-Feb-2024	16:03	13-Feb-2024	16:18	15	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
103	14-Feb-2024	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	257	Other Outage	Unplanned Outage	14-Feb-2024	09:00	14-Feb-2024	09:17	17	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
104	14-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	314	Other Outage	Planned Outage	14-Feb-2024	10:18	14-Feb-2024	14:06	228	0.00044	PLANNED OUTAGE
105	14-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	310	Other Outage	Planned Outage	14-Feb-2024	10:22	14-Feb-2024	14:06	224	0.00044	PLANNED OUTAGE
106	14-Feb-2024	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL) MODEL TOWN	27	Other Outage	Planned Outage	14-Feb-2024	10:53	14-Feb-2024	15:38	285	0.00087	PSD ON INDUSTRIAL WEEKLY OFF
107	14-Feb-2024	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	208	Other Outage	Planned Outage	14-Feb-2024	14:44	14-Feb-2024	15:35	51	0.00037	PLANNED OUTAGE
108	15-Feb-2024	PART OF DJB WWTP MAILIS PARK MODEL TOWN	1	Other Outage	Unplanned Outage	15-Feb-2024	00:51	15-Feb-2024	01:50	59	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
109	15-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	172	Other Outage	Planned Outage	15-Feb-2024	10:26	15-Feb-2024	14:42	256	0.00185	PLANNED OUTAGE
110	15-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	243	Other Outage	Planned Outage	15-Feb-2024	10:31	15-Feb-2024	14:44	253	0.00183	PLANNED OUTAGE
111	15-Feb-2024	PARTS OF SBI COLONY,GUJARAWALA TOWN PART 2 MODEL TOWN	701	990 kVA	Planned Outage	15-Feb-2024	10:49	15-Feb-2024	16:32	343	0.00076	PLANNED OUTAGE
112	15-Feb-2024	PART OF MCD QUARTER JAHANGIR PURI MODEL TOWN	1	Other Outage	Planned Outage	15-Feb-2024	11:26	15-Feb-2024	13:17	111	0.00006	PLANNED OUTAGE
113	15-Feb-2024	PARTS OF SABZI MANDI, SARAI EXTENSION, SARAI PEEPAL THALLA,APMC OFFICE(HT CONSUMER) MODEL TOWN	590	630 kVA	Planned Outage	15-Feb-2024	11:32	15-Feb-2024	16:07	275	0.00046	PLANNED OUTAGE
114	15-Feb-2024	PARTS OF C-BLK (OLD ZONAL OFFICE) MODEL TOWN	252	Other Outage	Unplanned Outage	15-Feb-2024	20:58	15-Feb-2024	22:34	96	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
115	16-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	193	Other Outage	Planned Outage	16-Feb-2024	10:27	16-Feb-2024	14:23	236	0.00151	PLANNED OUTAGE
116	16-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	71	Other Outage	Planned Outage	16-Feb-2024	10:35	16-Feb-2024	14:20	225	0.00069	PLANNED OUTAGE
117	16-Feb-2024	PARTS OF A - BLOCK. GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK. MODEL TOWN	115	630 kVA	Planned Outage	16-Feb-2024	10:41	16-Feb-2024	12:55	134	0.00097	PLANNED OUTAGE
118	16-Feb-2024	PARTS OF A - BLOCK. GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK. MODEL TOWN	297	990 kVA	Planned Outage	16-Feb-2024	10:42	16-Feb-2024	12:55	133	0.00133	PLANNED OUTAGE
119	16-Feb-2024	PARTS OF NEW TAGOR PAR,DHEERPUR KIOSK,NEW BHAI PERMA PERMA NAND,207 TAGOR PARK,BP COLONY MODEL TOWN	2042	Other Outage	Unplanned Outage	16-Feb-2024	13:27	16-Feb-2024	13:53	26	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
120	16-Feb-2024	PARTS OF DERAWALA A BLOCK, BIJLEE APPARTMENTS MODEL TOWN	373	990 kVA	Planned Outage	16-Feb-2024	14:17	16-Feb-2024	15:49	92	0.00013	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
121	16-Feb-2024	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	92	Other Outage	Planned Outage	16-Feb-2024	14:29	16-Feb-2024	15:42	73	0.00022	PLANNED OUTAGE
122	16-Feb-2024	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	550	Other Outage	Planned Outage	16-Feb-2024	14:32	16-Feb-2024	16:18	106	0.00068	PLANNED OUTAGE
123	16-Feb-2024	PARTS OF THEKE WALA AZADPUR MODEL TOWN	670	Other Outage	Unplanned Outage	16-Feb-2024	19:38	16-Feb-2024	20:25	47	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
124	16-Feb-2024	PARTS OF THEKE WALA AZADPUR MODEL TOWN	2034	Other Outage	Unplanned Outage	16-Feb-2024	19:38	16-Feb-2024	21:12	94	0.00109	FORCE MAJEURE/EXTERNAL FACTORS
125	17-Feb-2024	PARTS OF ORBIT PLAZA , PART OF B BLOCK GUJARAWALAN MODEL TOWN	126	Other Outage	Planned Outage	17-Feb-2024	10:31	17-Feb-2024	13:09	158	0.00110	PLANNED OUTAGE
126	17-Feb-2024	PARTS OF INTERCONNECTOR 1 & 2 TO JAHANGIRPURI MKT MODEL TOWN	26	Other Outage	Unplanned Outage	17-Feb-2024	12:16	17-Feb-2024	14:12	116	0.00032	INTERRUPTION DUE TO FAULT
127	17-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	2344	Other Outage	Unplanned Outage	17-Feb-2024	12:17	17-Feb-2024	12:42	25	0.00031	INTERRUPTION DUE TO FAULT
128	17-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	3803	Other Outage	Unplanned Outage	17-Feb-2024	12:17	17-Feb-2024	13:31	74	0.00113	INTERRUPTION DUE TO FAULT
129	17-Feb-2024	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) MODEL TOWN	2948	Other Outage	Unplanned Outage	17-Feb-2024	12:17	17-Feb-2024	14:10	113	0.00157	INTERRUPTION DUE TO FAULT
130	17-Feb-2024	PARTS OF B-BLK DERAWALA NGR, LSC DERAWALA NAGAR, PENTAMED HOSPITAL MODEL TOWN	207	630 kVA	Planned Outage	17-Feb-2024	14:19	17-Feb-2024	15:57	98	0.00011	PLANNED OUTAGE
131	17-Feb-2024	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	207	Other Outage	Unplanned Outage	17-Feb-2024	18:44	17-Feb-2024	20:49	126	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
132	18-Feb-2024	PART OF DURGA CHARITABLE MODEL TOWN	1	315 kVA	Planned Outage	18-Feb-2024	10:59	18-Feb-2024	12:25	86	0.00002	PLANNED OUTAGE
133	18-Feb-2024	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	322	Other Outage	Unplanned Outage	18-Feb-2024	23:05	18-Feb-2024	23:50	45	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
134	19-Feb-2024	PARTS OF D BLOCK (HOUSE NO 1-1000) & E BLOCK (1000-2000) JAHNGIRPURI MODEL TOWN	201	Other Outage	Planned Outage	19-Feb-2024	10:40	19-Feb-2024	15:04	264	0.00029	PLANNED OUTAGE
135	19-Feb-2024	PARTS OF D BLOCK (HOUSE NO 1-1000) & E BLOCK (1000-2000) JAHNGIRPURI MODEL TOWN	101	Other Outage	Planned Outage	19-Feb-2024	10:44	19-Feb-2024	14:58	254	0.00028	PLANNED OUTAGE
136	19-Feb-2024	PARTS OF INDRA VIKAS COLONY MODEL TOWN	416	630 kVA	Planned Outage	19-Feb-2024	10:54	19-Feb-2024	13:08	134	0.00019	PLANNED OUTAGE
137	19-Feb-2024	PARTS OF SBI COLONY,GUJARAWALA TOWN PART 2 MODEL TOWN	210	630 kVA	Planned Outage	19-Feb-2024	11:07	19-Feb-2024	13:03	116	0.00074	PLANNED OUTAGE
138	19-Feb-2024	PARTS OF SBI COLONY,GUJARAWALA TOWN PART 2 MODEL TOWN	141	630 kVA	Planned Outage	19-Feb-2024	11:11	19-Feb-2024	13:06	115	0.00073	PLANNED OUTAGE
139	19-Feb-2024	PARTS OF A-BLK JINDAL WALA MODEL TOWN	203	Other Outage	Planned Outage	19-Feb-2024	11:43	19-Feb-2024	16:16	273	0.00174	PLANNED OUTAGE
140	19-Feb-2024	PARTS OF DHEERPUR VILLAGE, PART OF NIRANKARI COLONY, SWARG ASHRAM, PART OF WEST PARMANAD COLONY, PART OF WEST MUKHERJEE NAGAR, AIR TRAINING CENTER. ROSARY SCHOOL , PRADHAN MARKET. ROSARY SCHOOLROAD. & 30 QTRS MODEL TOWN	270	630 kVA	Planned Outage	19-Feb-2024	14:17	19-Feb-2024	15:34	77	0.00011	PLANNED OUTAGE
141	19-Feb-2024	PARTS OF DILKUSH BAGH INDUSTRIAL AREA, PART OF A AREAL AREA GTK MODEL TOWN	69	Other Outage	Unplanned Outage	19-Feb-2024	14:57	19-Feb-2024	16:20	82	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
142	19-Feb-2024	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	37	Other Outage	Unplanned Outage	19-Feb-2024	15:09	19-Feb-2024	15:45	36	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
143	20-Feb-2024	PARTS OF J-BLOCK JHODWALA MODEL TOWN	185	Other Outage	Unplanned Outage	20-Feb-2024	00:47	20-Feb-2024	03:30	163	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
144	20-Feb-2024	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTK MODEL TOWN	518	Other Outage	Unplanned Outage	20-Feb-2024	01:45	20-Feb-2024	03:35	110	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
145	20-Feb-2024	PARTS OF J-BLOCK JHODWALA MODEL TOWN	854	Other Outage	Unplanned Outage	20-Feb-2024	02:40	20-Feb-2024	03:30	50	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
146	20-Feb-2024	PARTS OF C-BLK (OLD ZONAL OFFICE) MODEL TOWN	245	Other Outage	Planned Outage	20-Feb-2024	10:36	20-Feb-2024	12:34	118	0.00049	PLANNED OUTAGE
147	20-Feb-2024	PARTS OF D BLOCK (HOUSE NO 1-1000) & E BLOCK (1000-2000) JAHNGIRPURI MODEL TOWN	1197	Other Outage	Planned Outage	20-Feb-2024	10:36	20-Feb-2024	14:04	208	0.00133	PLANNED OUTAGE
148	20-Feb-2024	PARTS OF MUKHERJEE NAGAR -3 MODEL TOWN	851	Other Outage	Planned Outage	20-Feb-2024	10:53	20-Feb-2024	13:11	138	0.00058	PLANNED OUTAGE
149	20-Feb-2024	PARTS OF A - BLOCK. GUJARAWALA, B - BLOCK GUJARAWALA, LSC GUJARAWALA B - BLOCK. MODEL TOWN	254	630 kVA	Planned Outage	20-Feb-2024	10:55	20-Feb-2024	13:35	160	0.00067	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
150	20-Feb-2024	PARTS OF A - BLOCK. GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK. MODEL TOWN	209	630 kVA	Planned Outage	20-Feb-2024	10:58	20-Feb-2024	13:33	155	0.00052	PLANNED OUTAGE
151	20-Feb-2024	PARTS OF MUKHERJEE NAGAR -3 MODEL TOWN	226	990 kVA	Planned Outage	20-Feb-2024	11:27	20-Feb-2024	13:14	107	0.00036	PLANNED OUTAGE
152	20-Feb-2024	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	291	Other Outage	Planned Outage	20-Feb-2024	13:41	20-Feb-2024	15:15	94	0.00060	PLANNED OUTAGE
153	20-Feb-2024	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	942	Other Outage	Planned Outage	20-Feb-2024	14:48	20-Feb-2024	16:40	112	0.00081	PLANNED OUTAGE
154	20-Feb-2024	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	2296	Other Outage	Unplanned Outage	20-Feb-2024	22:34	20-Feb-2024	22:45	11	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
155	20-Feb-2024	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	230	Other Outage	Unplanned Outage	20-Feb-2024	23:00	20-Feb-2024	23:10	10	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
156	20-Feb-2024	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	230	Other Outage	Unplanned Outage	20-Feb-2024	23:12	21-Feb-2024	00:03	51	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
157	21-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	195	Other Outage	Planned Outage	21-Feb-2024	10:21	21-Feb-2024	14:53	272	0.00174	PLANNED OUTAGE
158	21-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	148	Other Outage	Planned Outage	21-Feb-2024	10:25	21-Feb-2024	14:56	271	0.00173	PLANNED OUTAGE
159	21-Feb-2024	PARTS OF ARYABHATT.POLYTECHNIC, PART OF B - BLOCK INDUSTRIAL AREA GTK MODEL TOWN	522	Other Outage	Planned Outage	21-Feb-2024	10:34	21-Feb-2024	13:05	151	0.00025	PLANNED OUTAGE
160	21-Feb-2024	PARTS OF NEW TAGOR PAR,DHEERPUR KIOSK,NEW BHAI PERMA PERMA NAND,207 TAGOR PARK,BP COLONY MODEL TOWN	39	Other Outage	Planned Outage	21-Feb-2024	10:48	21-Feb-2024	13:18	150	0.00008	PLANNED OUTAGE
161	21-Feb-2024	PARTS OF MUKHERJEE NAGAR COM COMPLEX & PART OF MUKHERJEE NAGAR , BATRA CINEMA & SHAH ALAM BANDH PUMP HOUSE MODEL TOWN	230	Other Outage	Unplanned Outage	21-Feb-2024	11:47	21-Feb-2024	14:13	146	0.00243	FORCE MAJEURE/EXTERNAL FACTORS
162	21-Feb-2024	PART OF MCD QUARTER JAHANGIR PURI MODEL TOWN	9	Other Outage	Planned Outage	21-Feb-2024	12:00	21-Feb-2024	13:13	73	0.00004	PLANNED OUTAGE
163	21-Feb-2024	PARTS OF B BLK SHAKTI NAGAR MODEL TOWN	54	990 kVA	Planned Outage	21-Feb-2024	14:08	21-Feb-2024	16:03	115	0.00006	PSD ON INDUSTRIAL WEEKLY OFF
164	21-Feb-2024	PART OF JAHANGIRPURI MKT MODEL TOWN	13	Other Outage	Unplanned Outage	21-Feb-2024	15:27	21-Feb-2024	16:05	38	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
165	22-Feb-2024	PARTS OF FCI GODOWN, PART OF B - BLOCK INDUSTRIAL AREA, SANGAM PARK, PART OF R. P. BAGH MODEL TOWN	42	Other Outage	Planned Outage	22-Feb-2024	07:55	22-Feb-2024	09:29	94	0.00005	PLANNED OUTAGE
166	22-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	179	Other Outage	Planned Outage	22-Feb-2024	10:37	22-Feb-2024	15:03	266	0.00015	PLANNED OUTAGE
167	22-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	117	Other Outage	Planned Outage	22-Feb-2024	10:49	22-Feb-2024	14:54	245	0.00177	PLANNED OUTAGE
168	22-Feb-2024	PARTS OF PUMP HOUSE (HT CONSUMER),PART OF KEWAL PARK , MAILISH PARK GALI NO 11 ,12, 13, RAJAN BABU ROAD, MODEL TOWN	138	Other Outage	Planned Outage	22-Feb-2024	11:08	22-Feb-2024	13:30	142	0.00008	PLANNED OUTAGE
169	22-Feb-2024	PART OF A BLOCK GTK MODEL TOWN	9	250 kVA	Unplanned Outage	22-Feb-2024	11:32	22-Feb-2024	12:23	51	0.00001	EODB COMPLIANCE
170	22-Feb-2024	PARTS OF A-BLK JINDAL WALA MODEL TOWN	184	Other Outage	Planned Outage	22-Feb-2024	14:30	22-Feb-2024	16:18	108	0.00048	PLANNED OUTAGE
171	22-Feb-2024	PARTS OF INDRA NAGAR, ADARSH NAGAR EXTN.,PART OF MAILISH PARK, MOOL CHAND COLONY AND NANDA ROAD MODEL TOWN	217	400 kVA	Planned Outage	22-Feb-2024	14:32	22-Feb-2024	15:47	75	0.00033	PLANNED OUTAGE
172	22-Feb-2024	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	217	Other Outage	Unplanned Outage	22-Feb-2024	22:48	22-Feb-2024	23:18	30	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
173	23-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	228	Other Outage	Planned Outage	23-Feb-2024	10:26	23-Feb-2024	15:08	282	0.00180	PLANNED OUTAGE
174	23-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	212	Other Outage	Planned Outage	23-Feb-2024	10:28	23-Feb-2024	15:15	287	0.00120	PLANNED OUTAGE
175	23-Feb-2024	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	346	Other Outage	Planned Outage	23-Feb-2024	10:34	23-Feb-2024	16:38	364	0.00051	PLANNED OUTAGE
176	23-Feb-2024	PARTS OF F-GANDHI VIHAR -1,2,3,4, CNG GOPAL PURA,GANDHI VIHAR,C-GANDHI VIHAR,D-GANDHI VIHAR,E-GANDHI VIHAR,NIRANKARI SAROVER,ITI DHEERPUR,HOLYCROSS,FAIMLY COURT,YOGRAJ,JJC MODEL TOWN	572	630 kVA	Planned Outage	23-Feb-2024	11:08	23-Feb-2024	13:10	122	0.00122	PLANNED OUTAGE
177	23-Feb-2024	PARTS OF THEKE WALA AZADPUR MODEL TOWN	560	630 kVA	Planned Outage	23-Feb-2024	11:13	23-Feb-2024	13:14	121	0.00087	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
178	23-Feb-2024	PARTS OF THEKE WALA AZADPUR MODEL TOWN	398	630 kVA	Planned Outage	23-Feb-2024	11:17	23-Feb-2024	13:16	119	0.00096	PLANNED OUTAGE
179	23-Feb-2024	PARTS OF CORONATION PILLAR, SMAGAM STHAL & Radio Colony Staff Qtrs MODEL TOWN	77	160 kVA	Planned Outage	23-Feb-2024	11:20	23-Feb-2024	15:13	233	0.00019	PLANNED OUTAGE
180	23-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	2273	Other Outage	Planned Outage	23-Feb-2024	11:26	23-Feb-2024	13:48	142	0.00051	PLANNED OUTAGE
181	23-Feb-2024	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI MODEL TOWN	207	Other Outage	Planned Outage	23-Feb-2024	14:32	23-Feb-2024	16:11	99	0.00028	PLANNED OUTAGE
182	24-Feb-2024	PART OF NANIWALA BAGH MODEL TOWN	1	Other Outage	Planned Outage	24-Feb-2024	08:27	24-Feb-2024	09:59	92	0.00003	PLANNED OUTAGE
183	24-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	1548	Other Outage	Planned Outage	24-Feb-2024	10:34	24-Feb-2024	15:06	272	0.00272	PLANNED OUTAGE
184	24-Feb-2024	PARTS OF C-BLK (OLD ZONAL OFFICE) MODEL TOWN	203	Other Outage	Planned Outage	24-Feb-2024	14:15	24-Feb-2024	15:57	102	0.00011	PLANNED OUTAGE
185	25-Feb-2024	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	83	Other Outage	Unplanned Outage	25-Feb-2024	08:00	25-Feb-2024	10:55	175	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
186	25-Feb-2024	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	263	Other Outage	Unplanned Outage	25-Feb-2024	08:00	25-Feb-2024	13:30	330	0.00073	FORCE MAJEURE/EXTERNAL FACTORS
187	25-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	398	Other Outage	Unplanned Outage	25-Feb-2024	11:10	25-Feb-2024	11:30	20	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
188	25-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	2501	Other Outage	Unplanned Outage	25-Feb-2024	11:10	25-Feb-2024	11:49	39	0.00048	FORCE MAJEURE/EXTERNAL FACTORS
189	25-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	2278	Other Outage	Unplanned Outage	25-Feb-2024	11:10	25-Feb-2024	12:10	60	0.00072	FORCE MAJEURE/EXTERNAL FACTORS
190	25-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	3829	Other Outage	Unplanned Outage	25-Feb-2024	11:10	25-Feb-2024	12:25	75	0.00131	FORCE MAJEURE/EXTERNAL FACTORS
191	25-Feb-2024	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2 MODEL TOWN	83	Other Outage	Unplanned Outage	25-Feb-2024	12:58	25-Feb-2024	13:30	32	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
192	26-Feb-2024	PARTS OF D - BLOCK SHALIMAR PARK, C, D, K & F, BLOCK MODEL TOWN	1073	Other Outage	Unplanned Outage	26-Feb-2024	04:16	26-Feb-2024	04:36	19	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
193	26-Feb-2024	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTK MODEL TOWN	518	Other Outage	Unplanned Outage	26-Feb-2024	06:47	26-Feb-2024	07:10	23	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
194	26-Feb-2024	PART OF VILLAGE SARAI PIPAL THALA MODEL TOWN	1	Other Outage	Planned Outage	26-Feb-2024	07:34	26-Feb-2024	09:07	93	0.00003	PLANNED OUTAGE
195	26-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	89	Other Outage	Planned Outage	26-Feb-2024	10:28	26-Feb-2024	15:10	282	0.00016	PLANNED OUTAGE
196	26-Feb-2024	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI MODEL TOWN	172	Other Outage	Planned Outage	26-Feb-2024	10:31	26-Feb-2024	15:10	279	0.00039	PLANNED OUTAGE
197	26-Feb-2024	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	2128	Other Outage	Planned Outage	26-Feb-2024	10:56	26-Feb-2024	13:00	124	0.00124	PLANNED OUTAGE
198	26-Feb-2024	PARTS OF TO CORONATION PILLAR -1,CORONATION PILLAR -2,SAMAGAM GROUND MODEL TOWN	143	Other Outage	Planned Outage	26-Feb-2024	11:04	26-Feb-2024	13:45	161	0.00072	PLANNED OUTAGE
199	26-Feb-2024	PARTS OF ADARSH NAGAR,C-BLOCK MAJILSH PARK,RAJAN BABU ROAD , PART OF ADARSH NAGAR EXTN , MODEL TOWN	215	400 kVA	Planned Outage	26-Feb-2024	11:39	26-Feb-2024	12:45	66	0.00048	PLANNED OUTAGE
200	26-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	21	Other Outage	Unplanned Outage	26-Feb-2024	15:39	26-Feb-2024	16:23	44	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
201	26-Feb-2024	PARTS OF BUDH MANDIR AZADPUR, TRANSPORT CENTRE, BHAROLLA VILLAGE, DARGAH WALA, ADARSH NAGAR POLICE STATION MODEL TOWN	319	Other Outage	Unplanned Outage	26-Feb-2024	17:22	26-Feb-2024	18:08	46	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
202	26-Feb-2024	PARTS OF BUDH MANDIR AZADPUR, TRANSPORT CENTRE, BHAROLLA VILLAGE, DARGAH WALA, ADARSH NAGAR POLICE STATION MODEL TOWN	1014	Other Outage	Unplanned Outage	26-Feb-2024	17:22	26-Feb-2024	18:10	48	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
203	26-Feb-2024	PARTS OF BUDH MANDIR AZADPUR, TRANSPORT CENTRE, BHAROLLA VILLAGE, DARGAH WALA, ADARSH NAGAR POLICE STATION MODEL TOWN	180	Other Outage	Unplanned Outage	26-Feb-2024	17:22	26-Feb-2024	18:20	58	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
204	27-Feb-2024	PART OF RADIO COLONY NO-6 MODEL TOWN	1	Other Outage	Planned Outage	27-Feb-2024	07:54	27-Feb-2024	09:07	73	0.00004	PLANNED OUTAGE
205	27-Feb-2024	PARTS OF HAKIKAT NGR KIOSK,HAKIKAT NGR PI/M,NU LIFE MODEL TOWN	290	630 kVA	Planned Outage	27-Feb-2024	10:52	27-Feb-2024	13:44	172	0.00124	PLANNED OUTAGE
206	27-Feb-2024	PARTS OF PUMP HOUSE (HT CONSUMER),PART OF KEWAL PARK , MAJILSH PARK GALI NO 11 ,12, 13, RAJAN BABU ROAD, MODEL TOWN	139	Other Outage	Planned Outage	27-Feb-2024	11:01	27-Feb-2024	12:35	94	0.00042	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
207	27-Feb-2024	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	633	990 kVA	Planned Outage	27-Feb-2024	11:11	27-Feb-2024	12:57	106	0.00021	PLANNED OUTAGE
208	27-Feb-2024	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS) MODEL TOWN	712	Other Outage	Planned Outage	27-Feb-2024	11:35	27-Feb-2024	13:00	85	0.00019	PLANNED OUTAGE
209	27-Feb-2024	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	360	1000 kVA	Planned Outage	27-Feb-2024	14:13	27-Feb-2024	15:30	77	0.00011	PLANNED OUTAGE
210	27-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	64	Other Outage	Planned Outage	27-Feb-2024	14:20	27-Feb-2024	16:14	114	0.00006	PLANNED OUTAGE
211	27-Feb-2024	PARTS OF SBI COLONY,GUJARAWALA TOWN PART 2 MODEL TOWN	701	Other Outage	Unplanned Outage	27-Feb-2024	14:28	27-Feb-2024	14:55	27	0.00011	INTERRUPTION DUE TO FAULT
212	27-Feb-2024	PARTS OF C-BLK (OLD ZONAL OFFICE) MODEL TOWN	257	Other Outage	Unplanned Outage	27-Feb-2024	19:19	27-Feb-2024	20:00	42	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
213	28-Feb-2024	PARTS OF A-BLK GUJARAWALA TOWN, DILKUSH BAGH, A-63/1 GTK MODEL TOWN	518	Other Outage	Unplanned Outage	28-Feb-2024	08:19	28-Feb-2024	09:00	41	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
214	28-Feb-2024	PARTS OF CORONATION PILLAR, SMAGAM STHAL & Radio Colony Staff Qtrs MODEL TOWN	99	315 kVA	Planned Outage	28-Feb-2024	10:39	28-Feb-2024	12:02	83	0.00023	PLANNED OUTAGE
215	28-Feb-2024	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	1085	Other Outage	Planned Outage	28-Feb-2024	11:10	28-Feb-2024	14:40	210	0.00070	PLANNED OUTAGE
216	28-Feb-2024	PARTS OF NANIWALA BAGH , RAMESHWAR NAGAR MODEL TOWN	78	630 kVA	Planned Outage	28-Feb-2024	11:19	28-Feb-2024	12:35	76	0.00004	PLANNED OUTAGE
217	28-Feb-2024	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER MODEL TOWN	925	Other Outage	Planned Outage	28-Feb-2024	11:28	28-Feb-2024	15:37	249	0.00249	PLANNED OUTAGE
218	28-Feb-2024	PARTS OF 376 S. F. S. FLATS -2,AGGARWAL PLAZA,N-BLOCK,MUKHERJEE NGR-2,MUKHERJEE NGR PUMP HOUSE,MUKHERJEE NGR GAS GODOWN GOPAL PUR,POLICE BOOTH GOPAL MODEL TOWN	99	630 kVA	Planned Outage	28-Feb-2024	14:06	28-Feb-2024	15:39	93	0.00034	PLANNED OUTAGE
219	28-Feb-2024	PARTS OF NANIWALA BAGH , RAMESHWAR NAGAR MODEL TOWN	155	630 kVA	Planned Outage	28-Feb-2024	14:27	28-Feb-2024	15:39	72	0.00004	PLANNED OUTAGE
220	28-Feb-2024	PARTS OF A-BLK JINDAL WALA MODEL TOWN	111	Other Outage	Unplanned Outage	28-Feb-2024	16:22	28-Feb-2024	16:44	22	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
221	29-Feb-2024	PART OF VILLAGE SARAI PIPAL THALA MODEL TOWN	1	Other Outage	Planned Outage	29-Feb-2024	07:30	29-Feb-2024	08:45	75	0.00010	PLANNED OUTAGE
222	29-Feb-2024	PARTS OF BHAI PARMANAD COLONY, PART OF DHAKA VILLAGE, PART OF MUKHERJEE NAGAR & VPCI Colony MODEL TOWN	583	990 kVA	Planned Outage	29-Feb-2024	10:46	29-Feb-2024	12:50	124	0.00090	PLANNED OUTAGE
223	29-Feb-2024	PARTS OF EE-BLOCK NALEWALA MODEL TOWN	398	Other Outage	Planned Outage	29-Feb-2024	11:18	29-Feb-2024	14:30	192	0.00027	PLANNED OUTAGE
224	29-Feb-2024	PARTS OF BHAI PARMANAD COLONY, PART OF DHAKA VILLAGE, PART OF MUKHERJEE NAGAR & VPCI Colony MODEL TOWN	569	990 kVA	Planned Outage	29-Feb-2024	14:22	29-Feb-2024	15:25	63	0.00012	PLANNED OUTAGE
225	29-Feb-2024	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK MODEL TOWN	149	Other Outage	Planned Outage	29-Feb-2024	14:46	29-Feb-2024	16:18	92	0.00056	PLANNED OUTAGE
MOTI NAGAR												
1	01-Feb-2024	PARTS OF J,L ,K, BLOCK KIRTI NAGAR INDUSTRIAL AREA. MOTI NAGAR	1296	Other Outage	Unplanned Outage	01-Feb-2024	03:08	01-Feb-2024	03:50	42	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	95	Other Outage	Unplanned Outage	01-Feb-2024	12:11	01-Feb-2024	15:01	169	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF 6-BLK MOTHER DAIRY, 6/5A,OLD RANJIT NAGAR, SHIV CHOWK, GALI NO-10 (OLD) MOTI NAGAR	580	Other Outage	Unplanned Outage	01-Feb-2024	16:23	01-Feb-2024	17:42	79	0.00033	FORCE MAJEURE/EXTERNAL FACTORS
4	02-Feb-2024	PARTS OF ESI HOSPITAL, BASAI DARAPUR MOTI NAGAR	1027	Other Outage	Unplanned Outage	02-Feb-2024	09:47	02-Feb-2024	11:55	128	0.00053	FORCE MAJEURE/EXTERNAL FACTORS
5	02-Feb-2024	PARTS OF RICHIE RICH, C-BLK MANSAROVAR GARDEN, 1-BLK WHS MOTI NAGAR	220	630 kVA	Planned Outage	02-Feb-2024	10:50	02-Feb-2024	14:03	193	0.00021	PLANNED OUTAGE
6	02-Feb-2024	PARTS OF RICHIE RICH, C-BLK MANSAROVAR GARDEN, 1-BLK WHS MOTI NAGAR	220	630 kVA	Planned Outage	02-Feb-2024	10:53	02-Feb-2024	14:05	192	0.00021	PLANNED OUTAGE
7	02-Feb-2024	PART OF B-BLOCK NARAINA INDUSTRIAL AREA PH-II MOTI NAGAR	1	Other Outage	Planned Outage	02-Feb-2024	14:26	02-Feb-2024	16:14	108	0.00003	PLANNED OUTAGE
8	02-Feb-2024	PARTS OF B-BLOCK SUDARSHAN PARK MOTI NAGAR	413	Other Outage	Planned Outage	02-Feb-2024	15:15	02-Feb-2024	15:52	37	0.00016	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
9	03-Feb-2024	PARTS OF KRISHI KUNJ NO.-4, KHATEWALA, KRISHI KUNJ NO-3 MOTI NAGAR	195	Other Outage	Planned Outage	03-Feb-2024	11:26	03-Feb-2024	13:45	139	0.00058	PLANNED OUTAGE
10	03-Feb-2024	PARTS OF B, C, E, H BLOCK NARAINA VIHAR & PART OF NARAINA VILLAGE MOTI NAGAR	284	Other Outage	Unplanned Outage	03-Feb-2024	23:54	04-Feb-2024	01:32	98	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
11	04-Feb-2024	PART OF NARAINA VILLAGE MOTI NAGAR	6	Other Outage	Unplanned Outage	04-Feb-2024	00:45	04-Feb-2024	01:31	46	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
12	05-Feb-2024	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH - 1 MOTI NAGAR	99	Other Outage	Planned Outage	05-Feb-2024	10:53	05-Feb-2024	15:42	289	0.00040	PLANNED OUTAGE
13	05-Feb-2024	PART OF B BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	1	Other Outage	Planned Outage	05-Feb-2024	10:57	05-Feb-2024	13:59	182	0.00005	PSD ON INDUSTRIAL WEEKLY OFF
14	05-Feb-2024	PART OF 41 RAMA ROAD MOTI NAGAR	1	Other Outage	Planned Outage	05-Feb-2024	11:10	05-Feb-2024	12:38	88	0.00002	PLANNED OUTAGE
15	05-Feb-2024	PART OF 63 RAMA HVDS ROAD BISLERI MOTI NAGAR	1	Other Outage	Planned Outage	05-Feb-2024	11:13	05-Feb-2024	15:34	261	0.00007	PSD ON INDUSTRIAL WEEKLY OFF
16	05-Feb-2024	PARTS OF C-BLK JJ COLONY INDER PURI MOTINAGAR MOTI NAGAR	4292	Other Outage	Unplanned Outage	05-Feb-2024	19:46	05-Feb-2024	20:10	23	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
17	06-Feb-2024	PART OF ANANT RAJ MOTI NAGAR	1	Other Outage	Planned Outage	06-Feb-2024	11:05	06-Feb-2024	12:43	98	0.00003	PLANNED OUTAGE
18	06-Feb-2024	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH - 1 MOTI NAGAR	176	Other Outage	Planned Outage	06-Feb-2024	15:04	06-Feb-2024	15:59	55	0.00003	PLANNED OUTAGE
19	07-Feb-2024	PARTS OF BALI NAGAR MOTI NAGAR	623	Other Outage	Planned Outage	07-Feb-2024	10:43	07-Feb-2024	14:05	202	0.00045	PLANNED OUTAGE
20	07-Feb-2024	PARTS OF 54 TO 59 RAMA ROAD, SAW PIPE MOTI NAGAR	758	Other Outage	Unplanned Outage	07-Feb-2024	12:38	07-Feb-2024	13:10	32	0.00133	FORCE MAJEURE/EXTERNAL FACTORS
21	07-Feb-2024	PARTS OF E BLOCK, INDOOR, 10 BLOCK, BC BLOCK MOTI NAGAR	678	Other Outage	Unplanned Outage	07-Feb-2024	12:52	07-Feb-2024	13:51	59	0.00049	FORCE MAJEURE/EXTERNAL FACTORS
22	07-Feb-2024	PART OF E BLOCK MOTI NAGAR	1	Other Outage	Unplanned Outage	07-Feb-2024	12:52	07-Feb-2024	14:21	89	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
23	07-Feb-2024	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK MOTI NAGAR	1915	Other Outage	Unplanned Outage	07-Feb-2024	14:14	07-Feb-2024	14:56	42	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
24	07-Feb-2024	PARTS OF TYAGI MARKET, BASAI DARA PUR, E BLOCK SUDERSHAN PARK, RAMGARH, RATAN PARK, ACPAL MOTI NAGAR	1656	Other Outage	Unplanned Outage	07-Feb-2024	16:54	07-Feb-2024	17:21	27	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
25	08-Feb-2024	PARTS OF DHOBI GHAT, MANDIR WALI GALI MOTI NAGAR	3677	Other Outage	Unplanned Outage	08-Feb-2024	03:32	08-Feb-2024	04:05	33	0.00066	FORCE MAJEURE/EXTERNAL FACTORS
26	08-Feb-2024	PARTS OF 3 BLK GURUDWARA & PART OF RAMESH NAGAR MOTI NAGAR	496	Other Outage	Planned Outage	08-Feb-2024	10:42	08-Feb-2024	14:53	251	0.00105	PLANNED OUTAGE
27	08-Feb-2024	PARTS OF A BLK NARAINA IND AREA PH-1 MOTI NAGAR	278	Other Outage	Unplanned Outage	08-Feb-2024	12:15	08-Feb-2024	12:54	40	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
28	08-Feb-2024	PARTS OF 5/31 ,5/35 JJ CLUSTER,WZ, 3,4 BLOCK KIRTINAGAR INDUSTRIAL AREA. MOTI NAGAR	259	Other Outage	Unplanned Outage	08-Feb-2024	12:56	08-Feb-2024	13:35	40	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
29	08-Feb-2024	PARTS OF F, E & B BLOCK DDA FLAT RANJIT NAGAR, MUNSHI RAM BAGH RANJIT NAGAR, SATYAM CINEMA RANJIT NAGAR, MAIN PATEL ROAD, SHADI KHAM PUR VILLAGE,PART OF COMMUNITY CENTER RANJEET NAGAR,DTC COLONY MOTI NAGAR	208	630 kVA	Planned Outage	08-Feb-2024	14:48	08-Feb-2024	15:56	68	0.00011	PLANNED OUTAGE
30	08-Feb-2024	PARTS OF VSNL, NASC RESIDENTIAL, DUSGHERA & TODAPUR VILLAGE, HARBHAJAN ENCLAVE MOTI NAGAR	4551	Other Outage	Unplanned Outage	08-Feb-2024	14:52	08-Feb-2024	15:25	33	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
31	08-Feb-2024	PART OF NASC RESIDENTIAL MOTI NAGAR	6	Other Outage	Unplanned Outage	08-Feb-2024	14:52	08-Feb-2024	15:51	59	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
32	08-Feb-2024	PARTS OF E BLK JJ COLONY, PART OF INDER PURI MOTI NAGAR	758	Other Outage	Unplanned Outage	08-Feb-2024	17:52	08-Feb-2024	18:14	22	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
33	09-Feb-2024	PARTS OF KRISHI KUNJ NO.-1, KRISHI KUNJ NO.-2 MOTI NAGAR	2957	Other Outage	Unplanned Outage	09-Feb-2024	02:22	09-Feb-2024	03:00	38	0.00063	FORCE MAJEURE/EXTERNAL FACTORS
34	09-Feb-2024	PARTS OF F BLOCK M S GARDEN, E BLOCK M S GARDEN FA - 357 M S GARDEN & SHARDA PURI MOTI NAGAR	449	Other Outage	Planned Outage	09-Feb-2024	10:22	09-Feb-2024	14:02	220	0.00031	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
35	09-Feb-2024	PARTS OF F BLOCK M S GARDEN, F BLOCK SHOPPING CENTRE, FA BLOCK M S GARDEN & DG CABLE HT CONSUMER MOTI NAGAR	291	Other Outage	Planned Outage	09-Feb-2024	14:44	09-Feb-2024	16:52	128	0.00014	PLANNED OUTAGE
36	09-Feb-2024	PART OF C-BLOCK NARAINA INDUSTRIAL AREA PH-1 MOTI NAGAR	7	Other Outage	Unplanned Outage	09-Feb-2024	15:14	11-Feb-2024	17:38	3024	0.00084	FORCE MAJEURE/EXTERNAL FACTORS
37	10-Feb-2024	PARTS OF B-BLOCK SUDARSHAN PARK MOTI NAGAR	743	Other Outage	Planned Outage	10-Feb-2024	10:54	10-Feb-2024	15:46	292	0.00065	PLANNED OUTAGE
38	11-Feb-2024	PARTS OF H, G, I, KIRTI NAGAR MOTI NAGAR	377	Other Outage	Unplanned Outage	11-Feb-2024	07:59	11-Feb-2024	08:18	19	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
39	11-Feb-2024	PARTS OF H, G, I, KIRTI NAGAR MOTI NAGAR	652	Other Outage	Unplanned Outage	11-Feb-2024	07:59	11-Feb-2024	08:24	24	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
40	12-Feb-2024	PART OF ANANT RAJ MOTI NAGAR	1	Other Outage	Unplanned Outage	12-Feb-2024	09:14	12-Feb-2024	10:10	56	0.00002	INTERRUPTION DUE TO FAULT
41	12-Feb-2024	PARTS OF ANANT RAJ RAMA ROAD MOTI NAGAR	205	Other Outage	Unplanned Outage	12-Feb-2024	09:14	12-Feb-2024	10:12	57	0.00013	INTERRUPTION DUE TO FAULT
42	12-Feb-2024	PARTS OF METALLIC IMPRESSIONS, A-58 ASITIC ELECTRICALS, A-46, APEX SHOES MOTI NAGAR	71	Other Outage	Planned Outage	12-Feb-2024	10:21	12-Feb-2024	15:32	311	0.00017	PLANNED OUTAGE
43	12-Feb-2024	PARTS OF L & T MANJEET, 27, 28, 29, 71/1 TO 71/5 NAJAF GARH ROAD MOTI NAGAR	298	Other Outage	Planned Outage	12-Feb-2024	11:12	12-Feb-2024	17:10	358	0.00050	PLANNED OUTAGE
44	12-Feb-2024	PART OF 59 RAMA ROAD MOTI NAGAR	11	400 kVA	Unplanned Outage	12-Feb-2024	11:56	12-Feb-2024	12:14	18	0.00001	EODB COMPLIANCE
45	12-Feb-2024	PARTS OF 36 TO 70, 71/7 RAMA ROAD MOTI NAGAR	100	Other Outage	Planned Outage	12-Feb-2024	14:16	12-Feb-2024	16:24	128	0.00092	PSD ON INDUSTRIAL WEEKLY OFF
46	12-Feb-2024	PART OF E-24 NARAINA VIHAR MOTI NAGAR	9	315 kVA	Unplanned Outage	12-Feb-2024	14:59	12-Feb-2024	17:16	137	0.00004	EODB COMPLIANCE
47	13-Feb-2024	PARTS OF 24, 17, BLOCK MEDICAL SUPRITENDENT MOTI NAGAR	299	400 kVA	Planned Outage	13-Feb-2024	10:49	13-Feb-2024	13:21	152	0.00017	PLANNED OUTAGE
48	13-Feb-2024	PARTS OF 24, 17, BLOCK MEDICAL SUPRITENDENT MOTI NAGAR	204	400 kVA	Planned Outage	13-Feb-2024	10:53	13-Feb-2024	13:23	150	0.00013	PLANNED OUTAGE
49	13-Feb-2024	PARTS OF DHOBI GHAT, MANDIR WALI GALI MOTI NAGAR	524	630 kVA	Planned Outage	13-Feb-2024	14:41	13-Feb-2024	15:43	62	0.00010	PLANNED OUTAGE
50	14-Feb-2024	PARTS OF F BLOCK M S GARDEN, E BLOCK M S GARDEN FA - 357 M S GARDEN & SHARDA PURI MOTI NAGAR	332	990 kVA	Planned Outage	14-Feb-2024	10:33	14-Feb-2024	17:20	407	0.00136	PLANNED OUTAGE
51	14-Feb-2024	PARTS OF RICHIE RICH, C-BLK MANSAROVAR GARDEN, 1-BLK WHS MOTI NAGAR	183	Other Outage	Planned Outage	14-Feb-2024	10:57	14-Feb-2024	14:10	193	0.00113	PLANNED OUTAGE
52	15-Feb-2024	PART OF RAMA ROAD MOTINAGAR MOTI NAGAR	1	Other Outage	Planned Outage	15-Feb-2024	10:55	15-Feb-2024	13:59	184	0.00010	PLANNED OUTAGE
53	15-Feb-2024	PART OF PUSA RESIDENTIAL COMPLEX MOTI NAGAR	1	Other Outage	Planned Outage	15-Feb-2024	11:42	15-Feb-2024	14:03	141	0.00012	PLANNED OUTAGE
54	16-Feb-2024	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTI NAGAR	934	Other Outage	Unplanned Outage	16-Feb-2024	07:27	16-Feb-2024	09:17	110	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
55	16-Feb-2024	PART OF IARI PUSA MOTI NAGAR	1	Other Outage	Planned Outage	16-Feb-2024	11:16	16-Feb-2024	14:30	194	0.00005	PLANNED OUTAGE
56	16-Feb-2024	PARTS OF E BLOCK, INDOOR, 10 BLOCK, BC BLOCK MOTI NAGAR	678	Other Outage	Unplanned Outage	16-Feb-2024	18:21	16-Feb-2024	18:41	19	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
57	16-Feb-2024	PART OF E BLOCK MOTI NAGAR	1	Other Outage	Unplanned Outage	16-Feb-2024	18:21	16-Feb-2024	18:51	29	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
58	16-Feb-2024	PARTS OF KRISHI KUNJ NO.-4, KHATEWALA, KRISHI KUNJ NO-3 MOTI NAGAR	195	Other Outage	Unplanned Outage	16-Feb-2024	19:29	16-Feb-2024	20:51	82	0.00057	FORCE MAJEURE/EXTERNAL FACTORS
59	18-Feb-2024	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	97	Other Outage	Unplanned Outage	18-Feb-2024	12:49	18-Feb-2024	13:15	26	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
60	18-Feb-2024	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	105	Other Outage	Unplanned Outage	18-Feb-2024	12:49	18-Feb-2024	15:09	139	0.00019	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
61	19-Feb-2024	PARTS OF VSNL, NASC RESIDENTIAL, DUSGHERA & TODAPUR VILLAGE, HARBHAJAN ENCLAVE MOTI NAGAR	1774	Other Outage	Unplanned Outage	19-Feb-2024	09:10	19-Feb-2024	09:29	18	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
62	19-Feb-2024	PART OF NASC RESIDENTIAL MOTI NAGAR	6	Other Outage	Unplanned Outage	19-Feb-2024	09:10	19-Feb-2024	10:03	53	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
63	19-Feb-2024	PARTS OF DLF NO 3 KIRTI NAGAR MOTI NAGAR	174	Other Outage	Planned Outage	19-Feb-2024	10:19	19-Feb-2024	16:22	363	0.00030	PSD ON INDUSTRIAL WEEKLY OFF
64	19-Feb-2024	PARTS OF METALLIC IMPRESSIONS, A-58 ASITIC ELECTRICALS, A-46, APEX SHOES MOTI NAGAR	71	Other Outage	Planned Outage	19-Feb-2024	10:39	19-Feb-2024	17:42	423	0.00024	PLANNED OUTAGE
65	19-Feb-2024	PART OF KIRTI NAGAR INDUS.AREA MOTI NAGAR	6	990 kVA	Planned Outage	19-Feb-2024	11:49	19-Feb-2024	13:54	125	0.00003	PSD ON INDUSTRIAL WEEKLY OFF
66	19-Feb-2024	PARTS OF COLD HOLD, SHOOPING CENTER, KIRTI NAGAR INDUS.AREA. MOTI NAGAR	279	Other Outage	Planned Outage	19-Feb-2024	14:10	19-Feb-2024	15:35	85	0.00054	PSD ON INDUSTRIAL WEEKLY OFF
67	19-Feb-2024	PARTS OF B, C, E, H BLOCK NARAINA VIHAR & PART OF NARAINA VILLAGE MOTI NAGAR	291	Other Outage	Unplanned Outage	19-Feb-2024	15:22	19-Feb-2024	16:26	64	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
68	20-Feb-2024	PARTS OF E & G BLOCK KIRTI NAGAR, F BLOCK EXTN. MOTI NAGAR	225	630 kVA	Planned Outage	20-Feb-2024	10:33	20-Feb-2024	13:06	153	0.00111	PLANNED OUTAGE
69	20-Feb-2024	PARTS OF E-24 NARAINA VIHAR, KRISHI KUNJ, Y - BLOCK LOHA MANDI, I - BLK NARAINA VIHAR MOTI NAGAR	275	990 kVA	Planned Outage	20-Feb-2024	11:09	20-Feb-2024	14:38	209	0.00087	PLANNED OUTAGE
70	20-Feb-2024	PARTS OF RANJIT NAGAR,COMMUNITY CENTER MOTI NAGAR	238	Other Outage	Planned Outage	20-Feb-2024	12:25	20-Feb-2024	15:25	180	0.00060	PLANNED OUTAGE
71	20-Feb-2024	PARTS OF 2 BLOCK WHS, 2/23 BLOCK, B - 2 WHS, B-1 BLOCK & CHUNA BHATTI MOTI NAGAR	40	Other Outage	Planned Outage	20-Feb-2024	14:27	20-Feb-2024	17:00	153	0.00043	PLANNED OUTAGE
72	21-Feb-2024	PARTS OF RICHIE RICH, C-BLK MANSAROVAR GARDEN, 1-BLK WHS MOTI NAGAR	549	Other Outage	Planned Outage	21-Feb-2024	10:52	21-Feb-2024	14:15	203	0.00147	PLANNED OUTAGE
73	21-Feb-2024	PART OF 1/5 NAJAF GARH ROAD MOTI NAGAR	6	100 kVA	Unplanned Outage	21-Feb-2024	12:04	21-Feb-2024	12:39	35	0.00001	EODB COMPLIANCE
74	21-Feb-2024	PARTS OF IARI PUSA (PARTLY), PART OF PUSA RESIDENTIAL COMPLEX,PHYTATRON, NRL MOTI NAGAR	227	Other Outage	Planned Outage	21-Feb-2024	14:45	21-Feb-2024	16:00	75	0.00055	PLANNED OUTAGE
75	21-Feb-2024	PART OF 71/7 RAMA ROAD MOTI NAGAR	13	400 kVA	Unplanned Outage	21-Feb-2024	14:52	21-Feb-2024	15:39	47	0.00001	EODB COMPLIANCE
76	21-Feb-2024	PARTS OF A BLK NARAINA IND AREA PH-1 MOTI NAGAR	278	Other Outage	Unplanned Outage	21-Feb-2024	15:40	21-Feb-2024	16:35	55	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
77	21-Feb-2024	PARTS OF IARI PUSA (PARTLY), PART OF PUSA RESIDENTIAL COMPLEX,PHYTATRON, NRL MOTI NAGAR	229	Other Outage	Unplanned Outage	21-Feb-2024	16:16	21-Feb-2024	17:10	53	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
78	21-Feb-2024	PARTS OF F BLOCK BALI NAGAR, WZ AREA BASAI DARA PUR MOTI NAGAR	608	Other Outage	Unplanned Outage	21-Feb-2024	17:27	21-Feb-2024	18:02	35	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
79	22-Feb-2024	PART OF POLICE COLONY TODAPUR MOTI NAGAR	3	Other Outage	Unplanned Outage	22-Feb-2024	10:36	22-Feb-2024	17:59	444	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
80	22-Feb-2024	PART OF 71/7 RAMA ROAD MOTI NAGAR	11	315 kVA	Unplanned Outage	22-Feb-2024	11:43	22-Feb-2024	14:00	137	0.00004	EODB COMPLIANCE
81	22-Feb-2024	PART OF 59 RAMA ROAD MOTI NAGAR	11	400 kVA	Unplanned Outage	22-Feb-2024	15:05	22-Feb-2024	15:35	30	0.00001	EODB COMPLIANCE
82	22-Feb-2024	PART OF 59 RAMA ROAD MOTI NAGAR	9	400 kVA	Unplanned Outage	22-Feb-2024	15:39	22-Feb-2024	16:52	73	0.00002	EODB COMPLIANCE
83	23-Feb-2024	PARTS OF B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	49	Other Outage	Planned Outage	23-Feb-2024	07:19	23-Feb-2024	11:33	254	0.00078	PLANNED OUTAGE
84	23-Feb-2024	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTI NAGAR	934	Other Outage	Planned Outage	23-Feb-2024	10:29	23-Feb-2024	13:49	200	0.00200	PLANNED OUTAGE
85	23-Feb-2024	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTI NAGAR	308	1000 kVA	Planned Outage	23-Feb-2024	10:33	23-Feb-2024	13:51	198	0.00143	PLANNED OUTAGE
86	23-Feb-2024	PART OF 63 RAMA HVDS ROAD BISLERI MOTI NAGAR	10	250 kVA	Unplanned Outage	23-Feb-2024	11:14	23-Feb-2024	12:32	78	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
87	24-Feb-2024	PARTS OF F BLOCK BALI NAGAR, WZ AREA BASAI DARA PUR MOTI NAGAR	608	Other Outage	Planned Outage	24-Feb-2024	10:43	24-Feb-2024	16:27	344	0.00067	PLANNED OUTAGE
88	24-Feb-2024	PARTS OF ESI HOSPITAL, BASAI DARAPUR MOTI NAGAR	1027	Other Outage	Unplanned Outage	24-Feb-2024	12:56	24-Feb-2024	13:15	18	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
89	24-Feb-2024	PART OF KIRTI NAGAR INDUS.AREA MOTI NAGAR	10	100 kVA	Unplanned Outage	24-Feb-2024	13:26	24-Feb-2024	14:37	71	0.00002	EODB COMPLIANCE
90	26-Feb-2024	PARTS OF METALLIC IMPRESSIONS, A-58 ASITIC ELECTRICALS, A-46, APEX SHOES MOTI NAGAR	71	Other Outage	Planned Outage	26-Feb-2024	10:46	26-Feb-2024	16:16	330	0.00037	PLANNED OUTAGE
91	26-Feb-2024	PART OF 59 RAMA ROAD MOTI NAGAR	11	400 kVA	Unplanned Outage	26-Feb-2024	11:00	26-Feb-2024	13:03	123	0.00003	EODB COMPLIANCE
92	26-Feb-2024	PART OF 59 RAMA ROAD MOTI NAGAR	9	400 kVA	Unplanned Outage	26-Feb-2024	11:04	26-Feb-2024	12:52	108	0.00003	EODB COMPLIANCE
93	26-Feb-2024	PARTS OF 35 TO 41 RAMA ROAD MOTI NAGAR	29	Other Outage	Planned Outage	26-Feb-2024	11:15	26-Feb-2024	16:26	311	0.00052	PLANNED OUTAGE
94	26-Feb-2024	PART OF BLK- B NARAINA IND AREA PH 2 MOTI NAGAR	2	Other Outage	Unplanned Outage	26-Feb-2024	13:38	26-Feb-2024	14:22	44	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
95	26-Feb-2024	PARTS OF BLK- B NARAINA IND AREA PH 2 LANDMARK NR.BANTEX COMPANY MOTI NAGAR	105	Other Outage	Unplanned Outage	26-Feb-2024	13:38	26-Feb-2024	16:28	170	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
96	27-Feb-2024	PARTS OF A & B BLOCK NARAINA INDUSTRIAL AREA PH - II , PANDAV NAGAR MOTI NAGAR	278	Other Outage	Unplanned Outage	27-Feb-2024	06:50	27-Feb-2024	07:20	30	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
97	27-Feb-2024	PARTS OF J,L ,K, BLOCK KIRTI NAGAR INDUSTRIAL AREA. MOTI NAGAR	110	Other Outage	Unplanned Outage	27-Feb-2024	10:22	27-Feb-2024	12:28	126	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
98	27-Feb-2024	PARTS OF B-BLOCK SUDARSHAN PARK MOTI NAGAR	413	Other Outage	Planned Outage	27-Feb-2024	10:57	27-Feb-2024	12:48	111	0.00015	PLANNED OUTAGE
99	27-Feb-2024	PARTS OF E BLOCK, INDOOR, 10 BLOCK, BC BLOCK MOTI NAGAR	679	Other Outage	Unplanned Outage	27-Feb-2024	11:15	27-Feb-2024	11:27	12	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
100	27-Feb-2024	PARTS OF 24, 17, BLOCK MEDICAL SUPRITENDENT MOTI NAGAR	820	Other Outage	Planned Outage	27-Feb-2024	11:21	27-Feb-2024	12:26	65	0.00018	PLANNED OUTAGE
101	27-Feb-2024	PART OF 1/5 NAJAF GARH ROAD MOTI NAGAR	9	400 kVA	Unplanned Outage	27-Feb-2024	14:57	27-Feb-2024	17:04	127	0.00004	EODB COMPLIANCE
102	28-Feb-2024	PARTS OF WHS NO. 1, B-1 BLOCK WHS, A BLOCK WHS, A-1, A-2 WHS & JAWAR CAMP JJ CLUSTER MOTI NAGAR	823	Other Outage	Planned Outage	28-Feb-2024	11:02	28-Feb-2024	14:00	178	0.00129	PLANNED OUTAGE
103	28-Feb-2024	PARTS OF SOUTH PATEL NAGAR (7, 8, 9 BLOCKS), COMMERCIAL MARKET SOUTH PATEL NAGAR, PARTS OF RANJIT NAGAR (GALI NO 3, 4, 5, 6, 7, 8, 9,21), KAB NO. - 2, PUSA,MAAN, OLD PUSA GATE,VIVEK , HANUMAAN CHOWK. MOTI NAGAR	155	Other Outage	Planned Outage	28-Feb-2024	11:37	28-Feb-2024	13:30	113	0.00013	PLANNED OUTAGE
104	28-Feb-2024	PART OF 71/7 RAMA ROAD MOTI NAGAR	13	400 kVA	Unplanned Outage	28-Feb-2024	14:58	28-Feb-2024	15:55	57	0.00002	EODB COMPLIANCE
105	28-Feb-2024	PART OF 71/7 RAMA ROAD MOTI NAGAR	6	250 kVA	Unplanned Outage	28-Feb-2024	15:48	28-Feb-2024	16:36	48	0.00001	EODB COMPLIANCE
106	29-Feb-2024	PARTS OF B,C,D,E,F,G,H BLOCK NARAINA VIHAR MOTI NAGAR	527	Other Outage	Unplanned Outage	29-Feb-2024	06:33	29-Feb-2024	07:05	32	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
107	29-Feb-2024	PARTS OF B,C,D,E,F,G,H BLOCK NARAINA VIHAR MOTI NAGAR	107	Other Outage	Unplanned Outage	29-Feb-2024	06:33	29-Feb-2024	07:20	46	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
108	29-Feb-2024	PARTS OF RAMESH NAGAR , 2A - BLOCK, CHAHCA NEHRU PARK, E BLOCK RAMESH NAGAR, 7 BLOCK RAMESH NAGAR, 18 BLOCK RAMESH NAGAR. MOTI NAGAR	2667	Other Outage	Unplanned Outage	29-Feb-2024	07:34	29-Feb-2024	07:54	20	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
109	29-Feb-2024	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1 MOTI NAGAR	146	Other Outage	Unplanned Outage	29-Feb-2024	09:21	29-Feb-2024	09:52	31	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
110	29-Feb-2024	PARTS OF B,C,D,E,F,G,H BLOCK NARAINA VIHAR MOTI NAGAR	625	990 kVA	Planned Outage	29-Feb-2024	10:52	29-Feb-2024	14:40	228	0.00025	PLANNED OUTAGE
111	29-Feb-2024	PART OF KIRTI NAGAR INDUS.AREA MOTI NAGAR	10	315 kVA	Unplanned Outage	29-Feb-2024	11:23	29-Feb-2024	11:40	17	0.000005	EODB COMPLIANCE
112	29-Feb-2024	PART OF 1/5 NAJAF GARH ROAD MOTI NAGAR	9	400 kVA	Unplanned Outage	29-Feb-2024	12:45	29-Feb-2024	13:22	37	0.00001	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
113	29-Feb-2024	PART OF PID,NPL MOTI NAGAR	1	Other Outage	Planned Outage	29-Feb-2024	13:02	29-Feb-2024	17:52	289	0.00008	PLANNED OUTAGE
114	29-Feb-2024	PART OF 1/5 NAJAF GARH ROAD MOTI NAGAR	6	100 kVA	Unplanned Outage	29-Feb-2024	13:28	29-Feb-2024	14:49	81	0.00002	EODB COMPLIANCE
115	29-Feb-2024	PART OF 1/5 NAJAF GARH ROAD MOTI NAGAR	17	400 kVA	Unplanned Outage	29-Feb-2024	14:52	29-Feb-2024	15:23	31	0.00001	EODB COMPLIANCE
116	29-Feb-2024	PARTS OF 36 TO 70, 71/7 RAMA ROAD MOTI NAGAR	100	Other Outage	Unplanned Outage	29-Feb-2024	17:27	29-Feb-2024	18:02	35	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
NARELA												
1	01-Feb-2024	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	51	Other Outage	Unplanned Outage	01-Feb-2024	01:59	01-Feb-2024	10:07	488	0.00068	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	1370	Other Outage	Unplanned Outage	01-Feb-2024	01:59	01-Feb-2024	12:01	602	0.00334	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	3111	Other Outage	Unplanned Outage	01-Feb-2024	04:56	01-Feb-2024	06:20	84	0.00145	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF GHOGHA VILLAGE NARELA	1385	Other Outage	Unplanned Outage	01-Feb-2024	06:36	01-Feb-2024	06:53	17	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF GHOGHA VILLAGE NARELA	2160	Other Outage	Unplanned Outage	01-Feb-2024	06:36	01-Feb-2024	07:38	62	0.00052	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PARTS OF GHOGHA VILLAGE NARELA	952	Other Outage	Unplanned Outage	01-Feb-2024	06:36	01-Feb-2024	12:44	368	0.00102	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF DSIDC BORGARH INDS. AREA NARELA	2502	Other Outage	Unplanned Outage	01-Feb-2024	07:07	01-Feb-2024	07:21	14	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
8	01-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	228	Other Outage	Unplanned Outage	01-Feb-2024	07:32	01-Feb-2024	09:00	88	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
9	01-Feb-2024	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY NARELA	1117	Other Outage	Unplanned Outage	01-Feb-2024	08:05	01-Feb-2024	08:45	40	0.00025	FORCE MAJEURE/EXTERNAL FACTORS
10	01-Feb-2024	PARTS OF DSISC NARELA	661	Other Outage	Unplanned Outage	01-Feb-2024	08:13	01-Feb-2024	08:25	12	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
11	01-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	36	Other Outage	Unplanned Outage	01-Feb-2024	08:55	01-Feb-2024	10:39	105	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
12	01-Feb-2024	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL NARELA	53	Other Outage	Unplanned Outage	01-Feb-2024	09:20	01-Feb-2024	11:28	129	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
13	01-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	1870	Other Outage	Unplanned Outage	01-Feb-2024	09:23	01-Feb-2024	09:44	21	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
14	01-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	56	Other Outage	Unplanned Outage	01-Feb-2024	10:16	01-Feb-2024	11:49	93	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
15	01-Feb-2024	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	2018	Other Outage	Unplanned Outage	01-Feb-2024	10:35	01-Feb-2024	11:35	60	0.00133	FORCE MAJEURE/EXTERNAL FACTORS
16	01-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	161	Other Outage	Unplanned Outage	01-Feb-2024	11:04	01-Feb-2024	11:56	52	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
17	01-Feb-2024	PART OF BAKOLI NARELA	4	250 kVA	Unplanned Outage	01-Feb-2024	11:07	01-Feb-2024	11:56	49	0.00001	EODB COMPLIANCE
18	01-Feb-2024	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	540	Other Outage	Unplanned Outage	01-Feb-2024	11:55	01-Feb-2024	15:16	201	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
19	01-Feb-2024	PARTS OF A5 POLICE COLONY, A5 PKT 6 FLATS NARELA	2910	Other Outage	Unplanned Outage	01-Feb-2024	11:56	01-Feb-2024	12:44	48	0.00040	FORCE MAJEURE/EXTERNAL FACTORS
20	01-Feb-2024	PART OF DSIDC FACTORY NO:E-664 NARELA	5	250 kVA	Unplanned Outage	01-Feb-2024	12:21	01-Feb-2024	14:07	106	0.00003	EODB COMPLIANCE
21	01-Feb-2024	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	67	Other Outage	Unplanned Outage	01-Feb-2024	12:32	01-Feb-2024	17:25	293	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
22	01-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	29	Other Outage	Unplanned Outage	01-Feb-2024	12:40	01-Feb-2024	16:33	233	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
23	01-Feb-2024	PART OF DSIDC NARELA	10	Other Outage	Unplanned Outage	01-Feb-2024	12:56	01-Feb-2024	14:39	103	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
24	01-Feb-2024	PARTS OF DSISC NARELA	512	Other Outage	Unplanned Outage	01-Feb-2024	13:10	01-Feb-2024	14:50	100	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
25	01-Feb-2024	PART OF DSIDC NARELA	8	Other Outage	Unplanned Outage	01-Feb-2024	13:13	01-Feb-2024	14:44	91	0.00005	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
26	01-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	3	160 kVA	Unplanned Outage	01-Feb-2024	13:22	01-Feb-2024	14:32	70	0.00002	EODB COMPLIANCE
27	01-Feb-2024	PARTS OF F-1712 DSIDC NARELA	35	Other Outage	Unplanned Outage	01-Feb-2024	14:06	01-Feb-2024	15:06	60	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
28	01-Feb-2024	PART OF NO-58 H-BLOCK NARELA	6	400 kVA	Unplanned Outage	01-Feb-2024	14:58	01-Feb-2024	15:30	32	0.00001	EODB COMPLIANCE
29	01-Feb-2024	PARTS OF SINGHOLA STAND NARELA	138	Other Outage	Unplanned Outage	01-Feb-2024	15:03	01-Feb-2024	15:18	15	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
30	01-Feb-2024	PART OF A BLOCK NARELA	1	Other Outage	Unplanned Outage	01-Feb-2024	15:10	01-Feb-2024	16:20	70	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
31	01-Feb-2024	PARTS OF A-10 GAS GODOWN NARELA	265	Other Outage	Unplanned Outage	01-Feb-2024	15:58	01-Feb-2024	16:34	36	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
32	01-Feb-2024	PART OF F-1884 DSIDC NARELA	4	400 kVA	Unplanned Outage	01-Feb-2024	16:00	01-Feb-2024	17:04	64	0.00002	EODB COMPLIANCE
33	01-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	28	Other Outage	Unplanned Outage	01-Feb-2024	16:01	01-Feb-2024	16:52	51	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
34	01-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	126	Other Outage	Unplanned Outage	01-Feb-2024	16:15	01-Feb-2024	16:52	36	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
35	01-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	72	Other Outage	Unplanned Outage	01-Feb-2024	17:06	01-Feb-2024	17:55	49	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
36	01-Feb-2024	PART OF SHRADHANAND COLLEGE ALIPUR NARELA	1	Other Outage	Unplanned Outage	01-Feb-2024	17:06	01-Feb-2024	18:07	62	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
37	01-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	154	Other Outage	Unplanned Outage	01-Feb-2024	17:06	01-Feb-2024	18:30	84	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
38	02-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	2190	Other Outage	Unplanned Outage	02-Feb-2024	01:42	02-Feb-2024	03:15	93	0.00054	FORCE MAJEURE/EXTERNAL FACTORS
39	02-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	659	Other Outage	Unplanned Outage	02-Feb-2024	08:01	02-Feb-2024	08:50	49	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
40	02-Feb-2024	PART OF D-1543 DSIDC NARELA	3	Other Outage	Unplanned Outage	02-Feb-2024	09:50	02-Feb-2024	10:26	36	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
41	02-Feb-2024	PARTS OF AMAN VIHAR, SHAMSHAN GHAT NANGLI POONA, MURGI FARM KADIPUR, GURUDWARA GT ROAD NANGLI, MOHAN VILAS, DALMILL NANGLI POONA NARELA	920	Other Outage	Planned Outage	02-Feb-2024	10:40	02-Feb-2024	16:09	329	0.00055	PLANNED OUTAGE
42	02-Feb-2024	PARTS OF SECTOR-B4 ALL POCKETS DDA NARELA, BLOCK-A DSIDC NARELA INDUSTRIAL AREA. NARELA	511	Other Outage	Planned Outage	02-Feb-2024	10:49	02-Feb-2024	15:47	298	0.00132	PLANNED OUTAGE
43	02-Feb-2024	PART OF A BLOCK NARELA	1	Other Outage	Planned Outage	02-Feb-2024	11:10	02-Feb-2024	16:49	339	0.00009	PLANNED OUTAGE
44	02-Feb-2024	PART OF E BLOCK DSIDC NARELA	2	250 kVA	Unplanned Outage	02-Feb-2024	11:13	02-Feb-2024	11:57	44	0.00001	EODB COMPLIANCE
45	02-Feb-2024	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	145	Other Outage	Planned Outage	02-Feb-2024	11:21	02-Feb-2024	16:40	319	0.00018	PLANNED OUTAGE
46	02-Feb-2024	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA , NARELA	82	Other Outage	Planned Outage	02-Feb-2024	11:21	02-Feb-2024	17:58	397	0.00132	PLANNED OUTAGE
47	02-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	1826	Other Outage	Unplanned Outage	02-Feb-2024	12:35	02-Feb-2024	13:25	50	0.00069	FORCE MAJEURE/EXTERNAL FACTORS
48	02-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	225	Other Outage	Unplanned Outage	02-Feb-2024	13:19	02-Feb-2024	18:12	293	0.00065	FORCE MAJEURE/EXTERNAL FACTORS
49	02-Feb-2024	PART OF F BLOCK DSIDC NARELA	2	160 kVA	Unplanned Outage	02-Feb-2024	13:26	02-Feb-2024	14:25	59	0.00002	EODB COMPLIANCE
50	02-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	1826	Other Outage	Unplanned Outage	02-Feb-2024	13:47	02-Feb-2024	14:06	19	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
51	02-Feb-2024	PART OF HIRANKI NARELA	3	63 kVA	Unplanned Outage	02-Feb-2024	14:08	02-Feb-2024	15:00	52	0.00001	EODB COMPLIANCE
52	02-Feb-2024	PART OF G BLOCK NARELA	2	Other Outage	Unplanned Outage	02-Feb-2024	18:29	02-Feb-2024	19:22	53	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
53	02-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	56	Other Outage	Unplanned Outage	02-Feb-2024	18:51	02-Feb-2024	20:00	68	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
54	02-Feb-2024	PARTS OF DSIDC B-2562 NARELA	62	Other Outage	Unplanned Outage	02-Feb-2024	20:00	02-Feb-2024	20:59	59	0.00007	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
55	03-Feb-2024	PARTS OF PARSHURAM CHOWK NARELA	26	Other Outage	Planned Outage	03-Feb-2024	08:32	03-Feb-2024	14:24	352	0.00049	PSD ON INDUSTRIAL WEEKLY OFF
56	03-Feb-2024	PARTS OF GHOGHA VILLAGE NARELA	1385	Other Outage	Unplanned Outage	03-Feb-2024	08:58	03-Feb-2024	09:19	21	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
57	03-Feb-2024	PARTS OF I BLOCK,DSIDC NARELA	96	Other Outage	Planned Outage	03-Feb-2024	10:19	03-Feb-2024	17:43	444	0.00049	PSD ON INDUSTRIAL WEEKLY OFF
58	03-Feb-2024	PARTS OF DSIIDC FACTORY NO-J-2293 TO J-3116 AND J-2824 TO J-2846 AND J-3128 TO J-3141 NARELA	21	Other Outage	Planned Outage	03-Feb-2024	10:32	03-Feb-2024	16:44	372	0.00052	PSD ON INDUSTRIAL WEEKLY OFF
59	03-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	161	Other Outage	Planned Outage	03-Feb-2024	10:35	03-Feb-2024	17:58	442	0.00160	PSD ON INDUSTRIAL WEEKLY OFF
60	03-Feb-2024	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	2001	Other Outage	Planned Outage	03-Feb-2024	10:48	03-Feb-2024	14:00	192	0.00064	PLANNED OUTAGE
61	03-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	101	Other Outage	Planned Outage	03-Feb-2024	10:55	03-Feb-2024	17:41	406	0.00135	PSD ON INDUSTRIAL WEEKLY OFF
62	03-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	51	Other Outage	Planned Outage	03-Feb-2024	10:57	03-Feb-2024	17:44	407	0.00124	PSD ON INDUSTRIAL WEEKLY OFF
63	03-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	139	400 kVA	Planned Outage	03-Feb-2024	11:31	03-Feb-2024	13:35	124	0.00041	PLANNED OUTAGE
64	03-Feb-2024	PARTS OF F-1712 DSIDC NARELA	43	Other Outage	Planned Outage	03-Feb-2024	11:38	03-Feb-2024	12:18	40	0.00006	PSD ON INDUSTRIAL WEEKLY OFF
65	03-Feb-2024	PART OF F BLOCK DSIDC NARELA	3	315 kVA	Unplanned Outage	03-Feb-2024	12:02	03-Feb-2024	13:35	93	0.00003	EODB COMPLIANCE
66	03-Feb-2024	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	1297	Other Outage	Planned Outage	03-Feb-2024	12:11	03-Feb-2024	14:53	162	0.00117	PLANNED OUTAGE
67	03-Feb-2024	PARTS OF B4 POCKET-6 AND 13 PUNJABI COLONY, NIIT CHOWK B-4 POLICE COLONY NARELA	49	Other Outage	Planned Outage	03-Feb-2024	12:39	03-Feb-2024	14:20	101	0.00031	PSD ON INDUSTRIAL WEEKLY OFF
68	03-Feb-2024	PART OF POCKET - 8 JJ. COLONY NARELA	1	Other Outage	Unplanned Outage	03-Feb-2024	12:56	03-Feb-2024	15:42	166	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
69	03-Feb-2024	PARTS OF NO-10 C BLOCK DSIDC NARELA	36	Other Outage	Planned Outage	03-Feb-2024	13:03	03-Feb-2024	17:58	295	0.00016	PSD ON INDUSTRIAL WEEKLY OFF
70	03-Feb-2024	PART OF SEC-L DSIDC BHORGARH NARELA	3	160 kVA	Unplanned Outage	03-Feb-2024	14:13	03-Feb-2024	14:55	42	0.00001	EODB COMPLIANCE
71	03-Feb-2024	PARTS OF ALL INDIA RADIO KHAM PUR NARELA	359	630 kVA	Planned Outage	03-Feb-2024	14:25	03-Feb-2024	16:41	136	0.00045	PLANNED OUTAGE
72	03-Feb-2024	PART OF C BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	03-Feb-2024	15:20	03-Feb-2024	15:58	38	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
73	04-Feb-2024	PARTS OF F-2010 DSIDC NARELA	40	Other Outage	Unplanned Outage	04-Feb-2024	03:41	04-Feb-2024	09:27	346	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
74	04-Feb-2024	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	1784	Other Outage	Unplanned Outage	04-Feb-2024	04:01	04-Feb-2024	04:35	33	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
75	04-Feb-2024	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	192	Other Outage	Unplanned Outage	04-Feb-2024	04:01	04-Feb-2024	04:50	48	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
76	04-Feb-2024	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	620	Other Outage	Unplanned Outage	04-Feb-2024	04:01	04-Feb-2024	06:04	122	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
77	04-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	2333	Other Outage	Unplanned Outage	04-Feb-2024	06:57	04-Feb-2024	07:41	44	0.00061	FORCE MAJEURE/EXTERNAL FACTORS
78	04-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	752	Other Outage	Unplanned Outage	04-Feb-2024	06:57	04-Feb-2024	08:14	77	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
79	04-Feb-2024	PART OF SUNGER PUR VILLAGE NARELA	3	Other Outage	Unplanned Outage	04-Feb-2024	06:57	04-Feb-2024	13:48	411	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
80	04-Feb-2024	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	3431	Other Outage	Unplanned Outage	04-Feb-2024	08:09	04-Feb-2024	09:35	86	0.00072	FORCE MAJEURE/EXTERNAL FACTORS
81	04-Feb-2024	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL NARELA	53	Other Outage	Unplanned Outage	04-Feb-2024	08:37	04-Feb-2024	09:22	45	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
82	04-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	4	Other Outage	Unplanned Outage	04-Feb-2024	10:16	04-Feb-2024	14:17	241	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
83	04-Feb-2024	PARTS OF SINGHOLA STAND NARELA	137	Other Outage	Unplanned Outage	04-Feb-2024	10:30	04-Feb-2024	11:51	81	0.00034	FORCE MAJEURE/EXTERNAL FACTORS
84	04-Feb-2024	PART OF SINGHOLA STAND NARELA	1	Other Outage	Unplanned Outage	04-Feb-2024	10:30	04-Feb-2024	16:28	358	0.00010	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
85	04-Feb-2024	PARTS OF ALL BLOCK OF DSIDC INDUSTRIAL AREA NARELA	29	Other Outage	Unplanned Outage	04-Feb-2024	11:33	04-Feb-2024	14:17	164	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
86	04-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	507	Other Outage	Unplanned Outage	04-Feb-2024	13:08	04-Feb-2024	13:46	38	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
87	04-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	752	Other Outage	Unplanned Outage	04-Feb-2024	13:08	04-Feb-2024	13:46	38	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
88	04-Feb-2024	PARTS OF SINGHOLA STAND NARELA	137	Other Outage	Unplanned Outage	04-Feb-2024	15:54	04-Feb-2024	16:28	34	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
89	04-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	202	Other Outage	Unplanned Outage	04-Feb-2024	19:20	04-Feb-2024	19:50	31	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
90	04-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	1668	Other Outage	Unplanned Outage	04-Feb-2024	19:20	04-Feb-2024	19:55	35	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
91	05-Feb-2024	PARTS OF G BLOCK DSIDC NARELA	56	Other Outage	Planned Outage	05-Feb-2024	08:05	05-Feb-2024	10:40	155	0.00052	PLANNED OUTAGE
92	05-Feb-2024	PART OF E BLOCK NARELA	19	Other Outage	Unplanned Outage	05-Feb-2024	10:25	05-Feb-2024	11:29	64	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
93	05-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	547	Other Outage	Planned Outage	05-Feb-2024	10:44	05-Feb-2024	16:08	324	0.00144	PLANNED OUTAGE
94	05-Feb-2024	PARTS OF C BLOCK, DSIDC NARELA	79	Other Outage	Unplanned Outage	05-Feb-2024	10:55	05-Feb-2024	11:19	23	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
95	05-Feb-2024	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION NARELA	26	Other Outage	Planned Outage	05-Feb-2024	11:03	05-Feb-2024	16:26	322	0.00045	PLANNED OUTAGE
96	05-Feb-2024	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	324	400 kVA	Planned Outage	05-Feb-2024	11:46	05-Feb-2024	13:31	105	0.00020	PLANNED OUTAGE
97	05-Feb-2024	PARTS OF B4 POCKET-6 AND 13 PUNJABI COLONY, NIIT CHOWK B-4 POLICE COLONY NARELA	775	Other Outage	Planned Outage	05-Feb-2024	12:09	05-Feb-2024	13:29	80	0.00058	PLANNED OUTAGE
98	05-Feb-2024	PART OF E BLOCK DSIDC NARELA	7	400 kVA	Unplanned Outage	05-Feb-2024	12:32	05-Feb-2024	13:22	50	0.00001	EODB COMPLIANCE
99	05-Feb-2024	PARTS OF SINGHOLA STAND NARELA	58	Other Outage	Planned Outage	05-Feb-2024	12:46	05-Feb-2024	17:50	304	0.00127	PLANNED OUTAGE
100	05-Feb-2024	PART OF NO-58 H-BLOCK NARELA	6	Other Outage	Unplanned Outage	05-Feb-2024	13:14	05-Feb-2024	13:40	26	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
101	05-Feb-2024	PART OF I BLOCK NARELA	4	400 kVA	Unplanned Outage	05-Feb-2024	13:31	05-Feb-2024	14:31	60	0.00002	EODB COMPLIANCE
102	05-Feb-2024	PARTS OF A BLOCK DSIDC NARELA	368	400 kVA	Planned Outage	05-Feb-2024	13:54	05-Feb-2024	15:15	81	0.00009	PLANNED OUTAGE
103	05-Feb-2024	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	5	Other Outage	Unplanned Outage	05-Feb-2024	16:04	05-Feb-2024	17:26	82	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
104	05-Feb-2024	PART OF AGRICULTURE LAND OF PALLA NARELA	1	25 kVA	Unplanned Outage	05-Feb-2024	16:07	05-Feb-2024	16:33	26	0.00001	EODB COMPLIANCE
105	05-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	343	Other Outage	Unplanned Outage	05-Feb-2024	16:18	05-Feb-2024	18:33	134	0.00056	FORCE MAJEURE/EXTERNAL FACTORS
106	05-Feb-2024	PARTS OF DCM ALIPUR NARELA	80	Other Outage	Unplanned Outage	05-Feb-2024	16:30	05-Feb-2024	16:45	15	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
107	05-Feb-2024	PARTS OF DCM ALIPUR NARELA	965	Other Outage	Unplanned Outage	05-Feb-2024	16:30	05-Feb-2024	17:24	54	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
108	06-Feb-2024	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL NARELA	53	Other Outage	Unplanned Outage	06-Feb-2024	05:50	06-Feb-2024	07:24	94	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
109	06-Feb-2024	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	5	Other Outage	Unplanned Outage	06-Feb-2024	07:20	06-Feb-2024	12:35	315	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
110	06-Feb-2024	PARTS OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	28	Other Outage	Unplanned Outage	06-Feb-2024	08:15	06-Feb-2024	12:34	259	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
111	06-Feb-2024	PART OF SANNOOTH NARELA	2	63 kVA	Unplanned Outage	06-Feb-2024	10:53	06-Feb-2024	12:04	71	0.00002	EODB COMPLIANCE
112	06-Feb-2024	PART OF NO.-1 A BLOCK DSIDC NARELA	1	Other Outage	Unplanned Outage	06-Feb-2024	11:26	06-Feb-2024	12:05	39	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
113	06-Feb-2024	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	388	Other Outage	Planned Outage	06-Feb-2024	11:38	06-Feb-2024	16:31	293	0.00212	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
114	06-Feb-2024	PART OF NO-58 H-BLOCK NARELA	6	400 kVA	Unplanned Outage	06-Feb-2024	11:38	06-Feb-2024	12:12	34	0.00001	EODB COMPLIANCE
115	06-Feb-2024	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY NARELA	1117	Other Outage	Unplanned Outage	06-Feb-2024	12:41	06-Feb-2024	13:07	26	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
116	06-Feb-2024	PART OF F-1884 DSIDC NARELA	4	250 kVA	Unplanned Outage	06-Feb-2024	12:57	06-Feb-2024	13:23	26	0.00001	EODB COMPLIANCE
117	06-Feb-2024	PARTS OF SECTOR - A5, POCKET - 8 J. J. COLONY (NARELA), A5 POCKET - 13 DDA FLATS MAMUR PUR COLONY, SEWA ASHRAM, DDA MKT. A-5 NARELA	886	Other Outage	Unplanned Outage	06-Feb-2024	13:04	06-Feb-2024	13:12	8	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
118	06-Feb-2024	PART OF B BLOCK DSIDC NARELA	4	250 kVA	Unplanned Outage	06-Feb-2024	15:11	06-Feb-2024	16:19	68	0.00002	EODB COMPLIANCE
119	06-Feb-2024	PART OF NANGLI KIOSK NARELA	14	100 kVA	Unplanned Outage	06-Feb-2024	15:21	06-Feb-2024	15:52	31	0.00001	EODB COMPLIANCE
120	06-Feb-2024	PARTS OF J-3057 DSIDC NARELA	110	Other Outage	Unplanned Outage	06-Feb-2024	16:24	06-Feb-2024	17:01	37	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
121	06-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	80	Other Outage	Unplanned Outage	06-Feb-2024	17:38	06-Feb-2024	18:28	50	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
122	07-Feb-2024	PARTS OF DSIDC B-2562 NARELA	62	Other Outage	Unplanned Outage	07-Feb-2024	07:48	07-Feb-2024	10:11	143	0.00079	FORCE MAJEURE/EXTERNAL FACTORS
123	07-Feb-2024	PARTS OF G BLOCK DSIDC NARELA	35	Other Outage	Planned Outage	07-Feb-2024	08:04	07-Feb-2024	10:25	141	0.00004	PLANNED OUTAGE
124	07-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	36	Other Outage	Unplanned Outage	07-Feb-2024	08:13	07-Feb-2024	08:35	22	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
125	07-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	53	Other Outage	Unplanned Outage	07-Feb-2024	08:13	07-Feb-2024	09:56	103	0.00072	FORCE MAJEURE/EXTERNAL FACTORS
126	07-Feb-2024	PART OF SANNOOTH NARELA	2	63 kVA	Unplanned Outage	07-Feb-2024	10:52	07-Feb-2024	11:34	42	0.00001	EODB COMPLIANCE
127	07-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	57	Other Outage	Unplanned Outage	07-Feb-2024	11:26	07-Feb-2024	13:13	107	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
128	07-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	315	Other Outage	Planned Outage	07-Feb-2024	11:28	07-Feb-2024	16:16	288	0.00096	PLANNED OUTAGE
129	07-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	228	Other Outage	Planned Outage	07-Feb-2024	11:30	07-Feb-2024	16:22	292	0.00024	PLANNED OUTAGE
130	07-Feb-2024	PARTS OF DCM ALIPUR NARELA	1314	Other Outage	Planned Outage	07-Feb-2024	11:31	07-Feb-2024	16:33	302	0.00210	PLANNED OUTAGE
131	07-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	547	Other Outage	Planned Outage	07-Feb-2024	11:54	07-Feb-2024	16:53	299	0.00100	PLANNED OUTAGE
132	07-Feb-2024	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	58	160 kVA	Planned Outage	07-Feb-2024	13:05	07-Feb-2024	14:02	57	0.00003	PLANNED OUTAGE
133	07-Feb-2024	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	108	Other Outage	Unplanned Outage	07-Feb-2024	13:39	07-Feb-2024	15:20	101	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
134	07-Feb-2024	PARTS OF I BLOCK, DSIDC & SHAHPUR VILLAGE RESIDENTAIL NARELA	93	Other Outage	Unplanned Outage	07-Feb-2024	13:43	07-Feb-2024	14:11	27	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
135	07-Feb-2024	PARTS OF NO-35 F-BLOCK DSIDC NARELA	77	Other Outage	Unplanned Outage	07-Feb-2024	13:54	07-Feb-2024	16:05	130	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
136	07-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	29	Other Outage	Unplanned Outage	07-Feb-2024	14:04	07-Feb-2024	14:50	45	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
137	07-Feb-2024	PART OF F BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	07-Feb-2024	14:48	07-Feb-2024	15:13	25	0.00001	EODB COMPLIANCE
138	07-Feb-2024	PART OF SEC-L DSIDC BHORGARH NARELA	4	Other Outage	Unplanned Outage	07-Feb-2024	16:37	07-Feb-2024	17:29	52	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
139	07-Feb-2024	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	2159	Other Outage	Unplanned Outage	07-Feb-2024	20:55	07-Feb-2024	21:50	55	0.00092	FORCE MAJEURE/EXTERNAL FACTORS
140	08-Feb-2024	PARTS OF F-1712 DSIDC NARELA	35	Other Outage	Planned Outage	08-Feb-2024	07:43	08-Feb-2024	10:20	157	0.00022	PLANNED OUTAGE
141	08-Feb-2024	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	1969	Other Outage	Planned Outage	08-Feb-2024	11:08	08-Feb-2024	17:47	399	0.00133	PLANNED OUTAGE
142	08-Feb-2024	PART OF BAKOLI NARELA	16	400 kVA	Planned Outage	08-Feb-2024	11:12	08-Feb-2024	12:59	107	0.00024	PLANNED OUTAGE
143	08-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	59	Other Outage	Planned Outage	08-Feb-2024	11:13	08-Feb-2024	16:55	342	0.00114	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
144	08-Feb-2024	PART OF ALTERNATE PLOTS SECTOR A-9 NARELA	9	Other Outage	Planned Outage	08-Feb-2024	11:35	08-Feb-2024	17:11	336	0.00019	PLANNED OUTAGE
145	08-Feb-2024	PART OF G BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	08-Feb-2024	11:38	08-Feb-2024	12:06	28	0.00001	EODB COMPLIANCE
146	08-Feb-2024	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD NARELA	349	400 kVA	Planned Outage	08-Feb-2024	11:54	08-Feb-2024	14:08	134	0.00097	PLANNED OUTAGE
147	08-Feb-2024	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	1	Other Outage	Planned Outage	08-Feb-2024	12:09	08-Feb-2024	17:05	296	0.00008	PLANNED OUTAGE
148	08-Feb-2024	PART OF BRAHAM PRAKASH SUNGER PUR NARELA	2	Other Outage	Unplanned Outage	08-Feb-2024	12:20	08-Feb-2024	15:56	216	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
149	08-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	77	Other Outage	Unplanned Outage	08-Feb-2024	12:26	08-Feb-2024	13:09	43	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
150	08-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	204	Other Outage	Unplanned Outage	08-Feb-2024	12:29	08-Feb-2024	13:00	31	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
151	08-Feb-2024	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	57	315 kVA	Planned Outage	08-Feb-2024	12:59	08-Feb-2024	16:05	186	0.00010	PLANNED OUTAGE
152	08-Feb-2024	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY NARELA	102	315 kVA	Planned Outage	08-Feb-2024	13:22	08-Feb-2024	15:46	144	0.00048	PLANNED OUTAGE
153	08-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	96	Other Outage	Unplanned Outage	08-Feb-2024	14:06	08-Feb-2024	15:42	96	0.00080	FORCE MAJEURE/EXTERNAL FACTORS
154	08-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	73	Other Outage	Unplanned Outage	08-Feb-2024	14:06	08-Feb-2024	18:22	256	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
155	08-Feb-2024	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD NARELA	205	400 kVA	Planned Outage	08-Feb-2024	14:10	08-Feb-2024	16:21	131	0.00044	PLANNED OUTAGE
156	08-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	1802	Other Outage	Unplanned Outage	08-Feb-2024	14:23	08-Feb-2024	15:00	37	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
157	08-Feb-2024	PART OF BRAHAM PRAKASH SUNGER PUR NARELA	3	100 kVA	Unplanned Outage	08-Feb-2024	15:13	08-Feb-2024	15:43	30	0.00001	EODB COMPLIANCE
158	08-Feb-2024	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	3085	Other Outage	Unplanned Outage	08-Feb-2024	16:16	08-Feb-2024	16:28	12	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
159	08-Feb-2024	PARTS OF G BLOCK DSIDC NARELA	41	Other Outage	Unplanned Outage	08-Feb-2024	18:52	08-Feb-2024	19:35	43	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
160	08-Feb-2024	PART OF A BLOCK NARELA	3	Other Outage	Unplanned Outage	08-Feb-2024	19:59	08-Feb-2024	21:34	94	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
161	09-Feb-2024	PARTS OF D BLOCK DSIDC NARELA	64	Other Outage	Unplanned Outage	09-Feb-2024	10:18	09-Feb-2024	11:25	67	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
162	09-Feb-2024	PARTS OF SECTOR-B4 ALL POCKETS DDA NARELA, BLOCK-A DSIDC NARELA INDUSTRIAL AREA. NARELA	821	Other Outage	Planned Outage	09-Feb-2024	10:38	09-Feb-2024	17:13	395	0.00252	PLANNED OUTAGE
163	09-Feb-2024	PART OF SUNGER PUR VILLAGE NARELA	3	Other Outage	Planned Outage	09-Feb-2024	10:42	09-Feb-2024	18:25	463	0.00013	FORCE MAJEURE DUE TO SABOTAGE
164	09-Feb-2024	PART OF DSIIDC FACTORY NO:E-664 NARELA	2	315 kVA	Unplanned Outage	09-Feb-2024	10:53	09-Feb-2024	11:45	52	0.00001	EODB COMPLIANCE
165	09-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	175	Other Outage	Planned Outage	09-Feb-2024	10:55	09-Feb-2024	16:52	357	0.00030	PLANNED OUTAGE
166	09-Feb-2024	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	1705	Other Outage	Planned Outage	09-Feb-2024	11:14	09-Feb-2024	18:18	424	0.00295	FORCE MAJEURE DUE TO SABOTAGE
167	09-Feb-2024	PART OF C BLK NARELA	5	100 kVA	Unplanned Outage	09-Feb-2024	11:14	09-Feb-2024	13:05	111	0.00003	EODB COMPLIANCE
168	09-Feb-2024	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY NARELA	2581	Other Outage	Planned Outage	09-Feb-2024	11:58	09-Feb-2024	16:57	299	0.00216	PLANNED OUTAGE
169	09-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	3	315 kVA	Unplanned Outage	09-Feb-2024	12:07	09-Feb-2024	13:08	61	0.00002	EODB COMPLIANCE
170	09-Feb-2024	PART OF E BLOCK NARELA	4	400 kVA	Unplanned Outage	09-Feb-2024	12:32	09-Feb-2024	13:19	47	0.00001	EODB COMPLIANCE
171	09-Feb-2024	PART OF DSIDC NARELA	14	Other Outage	Unplanned Outage	09-Feb-2024	12:59	09-Feb-2024	13:45	46	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
172	09-Feb-2024	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY NARELA	4276	Other Outage	Unplanned Outage	09-Feb-2024	12:59	09-Feb-2024	14:12	73	0.00061	FORCE MAJEURE/EXTERNAL FACTORS
173	09-Feb-2024	PART OF HIRANKI NARELA	3	63 kVA	Planned Outage	09-Feb-2024	14:09	09-Feb-2024	15:43	94	0.00005	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
174	09-Feb-2024	PART OF C BLOCK DSIDC NARELA	1	250 kVA	Unplanned Outage	09-Feb-2024	14:35	09-Feb-2024	15:22	47	0.00001	EODB COMPLIANCE
175	09-Feb-2024	PART OF D BLOCK NARELA	5	Other Outage	Unplanned Outage	09-Feb-2024	15:20	09-Feb-2024	18:47	207	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
176	09-Feb-2024	PARTS OF DSIDC B-2562 NARELA	46	Other Outage	Unplanned Outage	09-Feb-2024	15:41	09-Feb-2024	16:09	28	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
177	09-Feb-2024	PART OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA NARELA	3	315 kVA	Unplanned Outage	09-Feb-2024	16:33	09-Feb-2024	17:15	42	0.00001	EODB COMPLIANCE
178	09-Feb-2024	PARTS OF D BLOCK DSIDC NARELA	59	Other Outage	Unplanned Outage	09-Feb-2024	16:53	09-Feb-2024	18:47	114	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
179	10-Feb-2024	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI SHAHPUR NARELA	96	Other Outage	Planned Outage	10-Feb-2024	08:06	10-Feb-2024	17:45	579	0.00177	PSD ON INDUSTRIAL WEEKLY OFF
180	10-Feb-2024	PARTS OF J-3057 DSIDC NARELA	63	Other Outage	Planned Outage	10-Feb-2024	09:07	10-Feb-2024	17:03	476	0.00026	PSD ON INDUSTRIAL WEEKLY OFF
181	10-Feb-2024	PARTS OF DSIIDC FACTORY NO:E-664 TO E-679 NARELA	27	Other Outage	Planned Outage	10-Feb-2024	10:02	10-Feb-2024	17:29	447	0.00012	PSD ON INDUSTRIAL WEEKLY OFF
182	10-Feb-2024	PARTS OF J-3368 DSIDC NARELA	108	Other Outage	Planned Outage	10-Feb-2024	10:05	10-Feb-2024	17:51	466	0.00207	PSD ON INDUSTRIAL WEEKLY OFF
183	10-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	161	Other Outage	Planned Outage	10-Feb-2024	10:08	10-Feb-2024	17:58	470	0.00300	PSD ON INDUSTRIAL WEEKLY OFF
184	10-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	101	Other Outage	Planned Outage	10-Feb-2024	10:11	10-Feb-2024	17:40	449	0.00200	PSD ON INDUSTRIAL WEEKLY OFF
185	10-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	51	Other Outage	Planned Outage	10-Feb-2024	10:13	10-Feb-2024	17:40	447	0.00149	PSD ON INDUSTRIAL WEEKLY OFF
186	10-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	70	Other Outage	Planned Outage	10-Feb-2024	10:16	10-Feb-2024	17:55	459	0.00026	PLANNED OUTAGE
187	10-Feb-2024	PARTS OF NANGLI KIOSK ALIPUR NARELA	330	Other Outage	Planned Outage	10-Feb-2024	10:36	10-Feb-2024	15:15	279	0.00202	PLANNED OUTAGE
188	10-Feb-2024	PART OF E-695 DSIDC NARELA	4	400 kVA	Unplanned Outage	10-Feb-2024	10:40	10-Feb-2024	11:16	36	0.00001	EODB COMPLIANCE
189	10-Feb-2024	PARTS OF J-3368 DSIDC NARELA	27	Other Outage	Planned Outage	10-Feb-2024	10:41	10-Feb-2024	13:41	180	0.00025	PSD ON INDUSTRIAL WEEKLY OFF
190	10-Feb-2024	PARTS OF D-1543 DSIDC NARELA	42	Other Outage	Planned Outage	10-Feb-2024	10:45	10-Feb-2024	16:03	318	0.00018	PSD ON INDUSTRIAL WEEKLY OFF
191	10-Feb-2024	PART OF HARIZAN BASTI NARELA	5	400 kVA	Unplanned Outage	10-Feb-2024	10:46	10-Feb-2024	12:12	86	0.00002	EODB COMPLIANCE
192	10-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	276	Other Outage	Planned Outage	10-Feb-2024	11:02	10-Feb-2024	17:15	373	0.00269	PLANNED OUTAGE
193	10-Feb-2024	PART OF H BLOCK NARELA	6	400 kVA	Unplanned Outage	10-Feb-2024	11:04	10-Feb-2024	13:25	141	0.00004	EODB COMPLIANCE
194	10-Feb-2024	PART OF NO-58 H-BLOCK NARELA	2	250 kVA	Unplanned Outage	10-Feb-2024	11:10	10-Feb-2024	11:41	31	0.00001	EODB COMPLIANCE
195	10-Feb-2024	PARTS OF A-10 GAS GODOWN NARELA	430	630 kVA	Planned Outage	10-Feb-2024	11:49	10-Feb-2024	14:11	142	0.00047	PLANNED OUTAGE
196	10-Feb-2024	PART OF E BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	10-Feb-2024	11:49	10-Feb-2024	12:29	40	0.00001	EODB COMPLIANCE
197	10-Feb-2024	PARTS OF A BLOCK DSIDC NARELA	42	Other Outage	Planned Outage	10-Feb-2024	11:56	10-Feb-2024	12:43	47	0.00013	PSD ON INDUSTRIAL WEEKLY OFF
198	10-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	3	250 kVA	Unplanned Outage	10-Feb-2024	12:08	10-Feb-2024	12:49	41	0.00001	EODB COMPLIANCE
199	10-Feb-2024	PARTS OF DSIDC FACTORY NO: F-1829 TO F-1863 AND A-1 TO A-34 NARELA	26	Other Outage	Planned Outage	10-Feb-2024	12:16	10-Feb-2024	14:33	137	0.00038	PSD ON INDUSTRIAL WEEKLY OFF
200	10-Feb-2024	PARTS OF F-1884 DSIDC NARELA	55	Other Outage	Planned Outage	10-Feb-2024	12:19	10-Feb-2024	14:18	119	0.00036	PSD ON INDUSTRIAL WEEKLY OFF
201	10-Feb-2024	PART OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA NARELA	4	400 kVA	Unplanned Outage	10-Feb-2024	12:44	10-Feb-2024	14:13	89	0.00002	EODB COMPLIANCE
202	10-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	4	400 kVA	Unplanned Outage	10-Feb-2024	12:51	10-Feb-2024	14:12	81	0.00002	EODB COMPLIANCE
203	10-Feb-2024	PART OF E BLOCK DSIDC NARELA	1	315 kVA	Unplanned Outage	10-Feb-2024	13:05	10-Feb-2024	14:11	66	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
204	10-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	4	315 kVA	Unplanned Outage	10-Feb-2024	14:43	10-Feb-2024	15:36	53	0.00001	EODB COMPLIANCE
205	10-Feb-2024	PART OF C BLOCK DSIDC NARELA	5	400 kVA	Unplanned Outage	10-Feb-2024	14:50	10-Feb-2024	15:42	52	0.00001	EODB COMPLIANCE
206	10-Feb-2024	PART OF H BLOCK NARELA	1	250 kVA	Unplanned Outage	10-Feb-2024	14:55	10-Feb-2024	16:15	80	0.00002	EODB COMPLIANCE
207	10-Feb-2024	PART OF H BLOCK NARELA	3	315 kVA	Unplanned Outage	10-Feb-2024	14:59	10-Feb-2024	16:19	80	0.00002	EODB COMPLIANCE
208	10-Feb-2024	PART OF B BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	10-Feb-2024	15:11	10-Feb-2024	16:49	98	0.00003	EODB COMPLIANCE
209	10-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	2	250 kVA	Unplanned Outage	10-Feb-2024	15:37	10-Feb-2024	16:23	46	0.00001	EODB COMPLIANCE
210	10-Feb-2024	PART OF B BLOCK DSIDC NARELA	2	250 kVA	Unplanned Outage	10-Feb-2024	16:10	10-Feb-2024	16:38	28	0.00001	EODB COMPLIANCE
211	11-Feb-2024	PART OF ALL INDIA RADIO KHAM PUR NARELA	14	Other Outage	Unplanned Outage	11-Feb-2024	04:21	11-Feb-2024	04:54	33	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
212	11-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	171	Other Outage	Unplanned Outage	11-Feb-2024	07:59	11-Feb-2024	09:00	61	0.00042	FORCE MAJEURE/EXTERNAL FACTORS
213	11-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	53	Other Outage	Unplanned Outage	11-Feb-2024	08:03	11-Feb-2024	08:14	11	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
214	11-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	36	Other Outage	Unplanned Outage	11-Feb-2024	08:03	11-Feb-2024	08:20	17	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
215	11-Feb-2024	PARTS OF F BLOCK DSIDC NARELA	27	Other Outage	Unplanned Outage	11-Feb-2024	09:36	11-Feb-2024	10:30	54	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
216	11-Feb-2024	PARTS OF F BLOCK DSIDC NARELA	32	Other Outage	Unplanned Outage	11-Feb-2024	09:36	11-Feb-2024	10:35	59	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
217	11-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	659	Other Outage	Unplanned Outage	11-Feb-2024	12:10	11-Feb-2024	13:10	60	0.00050	FORCE MAJEURE/EXTERNAL FACTORS
218	11-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	70	Other Outage	Unplanned Outage	11-Feb-2024	12:10	11-Feb-2024	13:15	65	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
219	11-Feb-2024	PART OF SHRADHANAND COLLEGE ALIPUR NARELA	20	Other Outage	Unplanned Outage	11-Feb-2024	12:19	12-Feb-2024	11:29	1390	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
220	11-Feb-2024	PART OF SHRADHANAND COLLEGE ALIPUR NARELA	20	Other Outage	Unplanned Outage	11-Feb-2024	12:19	11-Feb-2024	13:15	56	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
221	11-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	21	Other Outage	Unplanned Outage	11-Feb-2024	12:19	11-Feb-2024	13:15	56	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
222	11-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	154	Other Outage	Unplanned Outage	11-Feb-2024	12:19	11-Feb-2024	14:15	116	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
223	11-Feb-2024	PART OF SHRADHANAND COLLEGE ALIPUR NARELA	11	Other Outage	Unplanned Outage	11-Feb-2024	12:19	13-Feb-2024	12:03	2864	0.00159	FORCE MAJEURE/EXTERNAL FACTORS
224	11-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	228	Other Outage	Unplanned Outage	11-Feb-2024	13:48	11-Feb-2024	14:12	24	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
225	11-Feb-2024	PARTS OF NO-35 F-BLOCK DSIDC NARELA	73	Other Outage	Unplanned Outage	11-Feb-2024	18:16	11-Feb-2024	19:54	97	0.00054	FORCE MAJEURE/EXTERNAL FACTORS
226	11-Feb-2024	PART OF NO-35 F-BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	11-Feb-2024	18:16	11-Feb-2024	23:02	285	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
227	11-Feb-2024	PARTS OF NO-35 F-BLOCK DSIDC NARELA	73	Other Outage	Unplanned Outage	11-Feb-2024	21:45	11-Feb-2024	23:02	77	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
228	12-Feb-2024	PART OF A BLOCK NARELA	5	Other Outage	Unplanned Outage	12-Feb-2024	00:19	12-Feb-2024	00:58	39	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
229	12-Feb-2024	PART OF NO - 7 B-BLOCK NARELA	5	400 kVA	Unplanned Outage	12-Feb-2024	10:43	12-Feb-2024	12:27	104	0.00003	EODB COMPLIANCE
230	12-Feb-2024	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	1370	Other Outage	Planned Outage	12-Feb-2024	10:44	12-Feb-2024	15:56	312	0.00130	PLANNED OUTAGE
231	12-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	171	Other Outage	Planned Outage	12-Feb-2024	11:04	12-Feb-2024	17:58	414	0.00138	PLANNED OUTAGE
232	12-Feb-2024	PART OF NO-58 H-BLOCK NARELA	3	315 kVA	Unplanned Outage	12-Feb-2024	11:06	12-Feb-2024	12:16	70	0.00002	EODB COMPLIANCE
233	12-Feb-2024	PART OF E BLOCK DSIDC NARELA	2	250 kVA	Unplanned Outage	12-Feb-2024	11:13	12-Feb-2024	12:02	49	0.00001	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
234	12-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	310	Other Outage	Planned Outage	12-Feb-2024	11:19	12-Feb-2024	16:30	311	0.00104	PLANNED OUTAGE
235	12-Feb-2024	PART OF DSIIDC FACTORY NO: F-1829 NARELA	5	250 kVA	Unplanned Outage	12-Feb-2024	11:27	12-Feb-2024	12:45	78	0.00002	EODB COMPLIANCE
236	12-Feb-2024	PART OF I BLOCK DSIDC NARELA	4	400 kVA	Unplanned Outage	12-Feb-2024	11:31	12-Feb-2024	13:10	99	0.00003	EODB COMPLIANCE
237	12-Feb-2024	PARTS OF SECTOR - A5, POCKET - 8 J. J. COLONY (NARELA), A5 POCKET - 13 DDA FLATS MAMUR PUR COLONY, SEWA ASHRAM, DDA MKT. A-5 NARELA	23	Other Outage	Planned Outage	12-Feb-2024	11:40	12-Feb-2024	17:02	322	0.00072	PLANNED OUTAGE
238	12-Feb-2024	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3153	Other Outage	Planned Outage	12-Feb-2024	11:47	12-Feb-2024	17:41	354	0.00148	PLANNED OUTAGE
239	12-Feb-2024	PARTS OF SINGHOLA STAND NARELA	690	Other Outage	Planned Outage	12-Feb-2024	12:03	12-Feb-2024	16:27	264	0.00051	PLANNED OUTAGE
240	12-Feb-2024	PART OF NO-58 H-BLOCK NARELA	4	400 kVA	Unplanned Outage	12-Feb-2024	12:19	12-Feb-2024	13:14	55	0.00002	EODB COMPLIANCE
241	12-Feb-2024	PART OF E BLOCK DSIDC NARELA	5	400 kVA	Unplanned Outage	12-Feb-2024	12:23	12-Feb-2024	13:23	60	0.00002	EODB COMPLIANCE
242	12-Feb-2024	PART OF F BLOCK DSIDC NARELA	2	160 kVA	Unplanned Outage	12-Feb-2024	12:30	12-Feb-2024	13:27	57	0.00002	EODB COMPLIANCE
243	12-Feb-2024	PARTS OF G BLOCK DSIDC NARELA	48	Other Outage	Unplanned Outage	12-Feb-2024	13:07	12-Feb-2024	13:49	42	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
244	12-Feb-2024	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	3	315 kVA	Unplanned Outage	12-Feb-2024	13:25	12-Feb-2024	14:06	41	0.00001	EODB COMPLIANCE
245	12-Feb-2024	PART OF NO-58 H-BLOCK NARELA	3	250 kVA	Unplanned Outage	12-Feb-2024	14:16	12-Feb-2024	14:53	37	0.00001	EODB COMPLIANCE
246	12-Feb-2024	PART OF I BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	12-Feb-2024	14:19	12-Feb-2024	14:54	35	0.00001	EODB COMPLIANCE
247	12-Feb-2024	PART OF A BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	12-Feb-2024	14:45	12-Feb-2024	15:08	23	0.00001	EODB COMPLIANCE
248	12-Feb-2024	PART OF F BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	12-Feb-2024	14:48	12-Feb-2024	15:40	52	0.00001	EODB COMPLIANCE
249	12-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	426	Other Outage	Unplanned Outage	12-Feb-2024	15:29	12-Feb-2024	18:03	154	0.00086	FORCE MAJEURE/EXTERNAL FACTORS
250	12-Feb-2024	PART OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA NARELA	1	315 kVA	Unplanned Outage	12-Feb-2024	15:34	12-Feb-2024	16:45	71	0.00002	EODB COMPLIANCE
251	12-Feb-2024	PART OF A BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	12-Feb-2024	15:46	12-Feb-2024	16:42	56	0.00002	EODB COMPLIANCE
252	12-Feb-2024	PARTS OF A BLOCK, DSIDC NARELA	60	Other Outage	Unplanned Outage	12-Feb-2024	16:06	12-Feb-2024	16:41	35	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
253	12-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	204	Other Outage	Unplanned Outage	12-Feb-2024	16:37	12-Feb-2024	17:25	48	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
254	12-Feb-2024	PART OF J-3057 DSIDC NARELA	2	Other Outage	Unplanned Outage	12-Feb-2024	18:52	12-Feb-2024	19:35	43	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
255	12-Feb-2024	PARTS OF POCKET-1 NARELA	1085	Other Outage	Unplanned Outage	12-Feb-2024	22:58	12-Feb-2024	23:06	8	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
256	12-Feb-2024	PARTS OF POCKET-1 NARELA	390	Other Outage	Unplanned Outage	12-Feb-2024	22:58	13-Feb-2024	00:59	120	0.00040	FORCE MAJEURE/EXTERNAL FACTORS
257	13-Feb-2024	PARTS OF POCKET-1 NARELA	50	Other Outage	Unplanned Outage	13-Feb-2024	00:24	13-Feb-2024	00:59	35	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
258	13-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	41	Other Outage	Unplanned Outage	13-Feb-2024	00:28	13-Feb-2024	01:28	60	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
259	13-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	41	Other Outage	Unplanned Outage	13-Feb-2024	01:33	13-Feb-2024	01:58	24	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
260	13-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	44	Other Outage	Planned Outage	13-Feb-2024	07:43	13-Feb-2024	10:39	176	0.00049	PLANNED OUTAGE
261	13-Feb-2024	PARTS OF GHOGHA VILLAGE NARELA	1282	Other Outage	Unplanned Outage	13-Feb-2024	10:15	13-Feb-2024	10:55	40	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
262	13-Feb-2024	PARTS OF GHOGHA VILLAGE NARELA	103	Other Outage	Unplanned Outage	13-Feb-2024	10:15	13-Feb-2024	12:15	120	0.00033	FORCE MAJEURE/EXTERNAL FACTORS
263	13-Feb-2024	PARTS OF J-3057 DSIDC NARELA	39	Other Outage	Unplanned Outage	13-Feb-2024	10:54	13-Feb-2024	11:38	44	0.00024	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
264	13-Feb-2024	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	600	Other Outage	Planned Outage	13-Feb-2024	11:05	13-Feb-2024	17:56	411	0.00411	PLANNED OUTAGE
265	13-Feb-2024	PART OF D BLOCK DSIDC NARELA	4	250 kVA	Unplanned Outage	13-Feb-2024	11:05	13-Feb-2024	11:53	48	0.00001	EODB COMPLIANCE
266	13-Feb-2024	PART OF NO-35 F-BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	13-Feb-2024	11:13	13-Feb-2024	12:35	82	0.00002	EODB COMPLIANCE
267	13-Feb-2024	PARTS OF DSIDC BORGARH INDS. AREA NARELA	196	Other Outage	Planned Outage	13-Feb-2024	11:50	13-Feb-2024	17:49	359	0.00259	PLANNED OUTAGE
268	13-Feb-2024	PART OF D BLOCK NARELA	1	250 kVA	Unplanned Outage	13-Feb-2024	12:20	13-Feb-2024	15:47	207	0.00006	EODB COMPLIANCE
269	13-Feb-2024	PART OF D BLOCK DSIDC NARELA	2	315 kVA	Unplanned Outage	13-Feb-2024	12:24	13-Feb-2024	13:05	41	0.00001	EODB COMPLIANCE
270	13-Feb-2024	PART OF STAND WALA KUSHAK HIRANKI NARELA	15	Other Outage	Unplanned Outage	13-Feb-2024	12:40	13-Feb-2024	17:25	285	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
271	13-Feb-2024	PART OF DSIIDC FACTORY NO:D-1501 NARELA	3	Other Outage	Unplanned Outage	13-Feb-2024	12:46	13-Feb-2024	14:44	118	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
272	13-Feb-2024	PARTS OF SEC-B AND SEC-C DSIDC BHORGARH NARELA	109	Other Outage	Planned Outage	13-Feb-2024	14:27	13-Feb-2024	16:34	127	0.00007	PLANNED OUTAGE
273	13-Feb-2024	PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL NARELA	4	400 kVA	Unplanned Outage	13-Feb-2024	15:38	13-Feb-2024	16:14	36	0.00001	EODB COMPLIANCE
274	13-Feb-2024	PART OF D BLOCK DSIDC NARELA	7	400 kVA	Unplanned Outage	13-Feb-2024	15:51	13-Feb-2024	16:17	26	0.00001	EODB COMPLIANCE
275	13-Feb-2024	PARTS OF ALL INDIA RADIO KHAM PUR NARELA	1249	Other Outage	Unplanned Outage	13-Feb-2024	15:57	13-Feb-2024	18:13	136	0.00076	FORCE MAJEURE/EXTERNAL FACTORS
276	13-Feb-2024	PART OF F BLOCK NARELA	4	Other Outage	Unplanned Outage	13-Feb-2024	17:13	13-Feb-2024	17:40	27	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
277	13-Feb-2024	PART OF DSIIDC FACTORY NO: F-1829 NARELA	2	Other Outage	Unplanned Outage	13-Feb-2024	18:14	13-Feb-2024	18:39	25	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
278	14-Feb-2024	PART OF B BLOCK DSIDC NARELA	3	Other Outage	Unplanned Outage	14-Feb-2024	08:37	14-Feb-2024	08:58	21	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
279	14-Feb-2024	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3153	Other Outage	Planned Outage	14-Feb-2024	10:08	14-Feb-2024	17:59	471	0.00458	PLANNED OUTAGE
280	14-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	3108	Other Outage	Planned Outage	14-Feb-2024	10:14	14-Feb-2024	17:59	465	0.00814	PLANNED OUTAGE
281	14-Feb-2024	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR. NARELA	716	Other Outage	Planned Outage	14-Feb-2024	10:26	14-Feb-2024	16:31	365	0.00091	PLANNED OUTAGE
282	14-Feb-2024	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	189	Other Outage	Planned Outage	14-Feb-2024	10:30	14-Feb-2024	17:25	415	0.00092	PLANNED OUTAGE
283	14-Feb-2024	PART OF E BLOCK NARELA	4	400 kVA	Unplanned Outage	14-Feb-2024	10:42	14-Feb-2024	11:47	65	0.00002	EODB COMPLIANCE
284	14-Feb-2024	PART OF BAKOLI NARELA	2	Other Outage	Planned Outage	14-Feb-2024	10:44	14-Feb-2024	12:43	119	0.00007	PLANNED OUTAGE
285	14-Feb-2024	PART OF A BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	14-Feb-2024	10:48	14-Feb-2024	11:11	23	0.00001	EODB COMPLIANCE
286	14-Feb-2024	PARTS OF SHASTRI PARK PHOOL BAGH NARELA	51	160 kVA	Planned Outage	14-Feb-2024	11:15	14-Feb-2024	16:14	299	0.00025	PLANNED OUTAGE
287	14-Feb-2024	PART OF NANGLI KIOSK NARELA	11	Other Outage	Planned Outage	14-Feb-2024	11:20	14-Feb-2024	17:35	375	0.00063	PLANNED OUTAGE
288	14-Feb-2024	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	88	Other Outage	Planned Outage	14-Feb-2024	11:28	14-Feb-2024	17:45	377	0.00157	PLANNED OUTAGE
289	14-Feb-2024	PART OF A BLOCK DSIDC NARELA	5	400 kVA	Unplanned Outage	14-Feb-2024	11:57	14-Feb-2024	12:29	32	0.00001	EODB COMPLIANCE
290	14-Feb-2024	PART OF E BLOCK DSIDC NARELA	3	400 kVA	Unplanned Outage	14-Feb-2024	12:25	14-Feb-2024	13:13	48	0.00001	EODB COMPLIANCE
291	14-Feb-2024	PART OF BAKOLI NARELA	4	160 kVA	Planned Outage	14-Feb-2024	12:48	14-Feb-2024	17:10	262	0.00015	PLANNED OUTAGE
292	14-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	2	315 kVA	Unplanned Outage	14-Feb-2024	13:01	14-Feb-2024	13:26	25	0.00001	EODB COMPLIANCE
293	14-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	2	160 kVA	Unplanned Outage	14-Feb-2024	13:27	14-Feb-2024	14:43	76	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
294	14-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	1920	Other Outage	Unplanned Outage	14-Feb-2024	14:06	14-Feb-2024	14:50	44	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
295	14-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	1286	Other Outage	Unplanned Outage	14-Feb-2024	14:06	14-Feb-2024	15:41	96	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
296	14-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	575	Other Outage	Unplanned Outage	14-Feb-2024	14:06	14-Feb-2024	16:07	121	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
297	14-Feb-2024	PART OF E-695 DSIDC NARELA	2	250 kVA	Unplanned Outage	14-Feb-2024	14:20	14-Feb-2024	15:19	59	0.00002	EODB COMPLIANCE
298	14-Feb-2024	PART OF ESS-12 DSIDC NARELA	14	630 kVA	Planned Outage	14-Feb-2024	14:22	14-Feb-2024	15:24	62	0.00003	PLANNED OUTAGE
299	14-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	5	315 kVA	Unplanned Outage	14-Feb-2024	14:46	14-Feb-2024	15:27	41	0.00001	EODB COMPLIANCE
300	14-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	3	250 kVA	Unplanned Outage	14-Feb-2024	15:29	14-Feb-2024	16:10	41	0.00001	EODB COMPLIANCE
301	14-Feb-2024	PART OF A BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	14-Feb-2024	15:56	14-Feb-2024	16:43	47	0.00001	EODB COMPLIANCE
302	14-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	310	Other Outage	Unplanned Outage	14-Feb-2024	17:27	14-Feb-2024	18:36	70	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
303	14-Feb-2024	PARTS OF NANGLI KIOSK ALIPUR NARELA	331	Other Outage	Unplanned Outage	14-Feb-2024	20:33	14-Feb-2024	21:10	37	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
304	14-Feb-2024	PART OF H BLOCK NARELA	3	Other Outage	Unplanned Outage	14-Feb-2024	22:22	14-Feb-2024	23:48	86	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
305	15-Feb-2024	PARTS OF DSIIDC FACTORY NO: F-1829 TO F-1863 AND A-1 TO A-34 NARELA	65	Other Outage	Planned Outage	15-Feb-2024	07:49	15-Feb-2024	10:58	189	0.00058	PLANNED OUTAGE
306	15-Feb-2024	PARTS OF A BLOCK, DSIDC NARELA	64	Other Outage	Unplanned Outage	15-Feb-2024	08:12	15-Feb-2024	09:01	49	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
307	15-Feb-2024	PART OF J-3057 DSIDC NARELA	3	Other Outage	Unplanned Outage	15-Feb-2024	10:26	15-Feb-2024	11:29	63	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
308	15-Feb-2024	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA , NARELA	553	Other Outage	Planned Outage	15-Feb-2024	10:28	15-Feb-2024	17:05	397	0.00287	PLANNED OUTAGE
309	15-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	256	Other Outage	Planned Outage	15-Feb-2024	10:33	15-Feb-2024	17:03	390	0.00282	PLANNED OUTAGE
310	15-Feb-2024	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	1784	Other Outage	Planned Outage	15-Feb-2024	10:39	15-Feb-2024	17:30	411	0.00411	PLANNED OUTAGE
311	15-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	1826	Other Outage	Planned Outage	15-Feb-2024	10:55	15-Feb-2024	12:56	121	0.00044	PLANNED OUTAGE
312	15-Feb-2024	PART OF DSIIDC FACTORY NO:D-1501 NARELA	3	250 kVA	Unplanned Outage	15-Feb-2024	11:17	15-Feb-2024	11:49	32	0.00001	EODB COMPLIANCE
313	15-Feb-2024	PARTS OF I BLOCK,DSIDC NARELA	65	Other Outage	Unplanned Outage	15-Feb-2024	11:26	15-Feb-2024	11:50	24	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
314	15-Feb-2024	PART OF C BLOCK DSIDC NARELA	4	400 kVA	Unplanned Outage	15-Feb-2024	12:27	15-Feb-2024	13:19	52	0.00001	EODB COMPLIANCE
315	15-Feb-2024	PART OF A BLOCK NARELA	3	Other Outage	Unplanned Outage	15-Feb-2024	12:32	15-Feb-2024	13:46	74	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
316	15-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	955	Other Outage	Planned Outage	15-Feb-2024	13:01	15-Feb-2024	15:43	162	0.00041	PLANNED OUTAGE
317	15-Feb-2024	PART OF DSIDC B-2562 NARELA	4	315 kVA	Unplanned Outage	15-Feb-2024	13:24	15-Feb-2024	14:55	91	0.00003	EODB COMPLIANCE
318	15-Feb-2024	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	499	630 kVA	Planned Outage	15-Feb-2024	14:47	15-Feb-2024	16:50	123	0.00017	PLANNED OUTAGE
319	15-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	42	Other Outage	Unplanned Outage	15-Feb-2024	15:04	15-Feb-2024	18:00	176	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
320	15-Feb-2024	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	1565	Other Outage	Unplanned Outage	15-Feb-2024	15:08	15-Feb-2024	15:59	51	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
321	15-Feb-2024	PARTS OF B BLOCK DSIDC NARELA	29	Other Outage	Unplanned Outage	15-Feb-2024	15:19	15-Feb-2024	18:01	162	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
322	15-Feb-2024	PART OF DSIIDC FACTORY NO:D-1501 NARELA	2	315 kVA	Unplanned Outage	15-Feb-2024	15:26	15-Feb-2024	16:06	40	0.00001	EODB COMPLIANCE
323	15-Feb-2024	PARTS OF ALL BLOCK OF DSIDC INDUSTRIAL AREA NARELA	110	Other Outage	Unplanned Outage	15-Feb-2024	21:50	15-Feb-2024	22:06	16	0.00022	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
324	16-Feb-2024	PART OF ALTERNATE PLOTS SECTOR A-9 NARELA	8	Other Outage	Planned Outage	16-Feb-2024	10:24	16-Feb-2024	17:18	414	0.00035	PLANNED OUTAGE
325	16-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	150	Other Outage	Planned Outage	16-Feb-2024	10:24	16-Feb-2024	17:54	450	0.00325	PLANNED OUTAGE
326	16-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	1262	Other Outage	Planned Outage	16-Feb-2024	10:49	16-Feb-2024	17:56	427	0.00427	PLANNED OUTAGE
327	16-Feb-2024	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	123	Other Outage	Planned Outage	16-Feb-2024	11:02	16-Feb-2024	17:44	402	0.00045	PLANNED OUTAGE
328	16-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	1861	Other Outage	Planned Outage	16-Feb-2024	11:33	16-Feb-2024	17:02	328	0.00182	PLANNED OUTAGE
329	16-Feb-2024	PART OF DSIIDC FACTORY NO-J-2293 NARELA	3	315 kVA	Unplanned Outage	16-Feb-2024	11:49	16-Feb-2024	12:33	44	0.00001	EODB COMPLIANCE
330	16-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	249	Other Outage	Unplanned Outage	16-Feb-2024	12:14	16-Feb-2024	14:06	112	0.00078	FORCE MAJEURE/EXTERNAL FACTORS
331	16-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	3	315 kVA	Unplanned Outage	16-Feb-2024	12:36	16-Feb-2024	13:24	48	0.00001	EODB COMPLIANCE
332	16-Feb-2024	PART OF D BLOCK NARELA	3	400 kVA	Unplanned Outage	16-Feb-2024	13:21	16-Feb-2024	14:54	93	0.00003	EODB COMPLIANCE
333	16-Feb-2024	PART OF J-3057 DSIDC NARELA	7	315 kVA	Unplanned Outage	16-Feb-2024	13:27	16-Feb-2024	14:17	50	0.00001	EODB COMPLIANCE
334	16-Feb-2024	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	2552	Other Outage	Unplanned Outage	16-Feb-2024	13:29	16-Feb-2024	14:00	30	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
335	16-Feb-2024	PART OF SANNOTH NARELA	7	Other Outage	Unplanned Outage	16-Feb-2024	13:29	16-Feb-2024	14:45	75	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
336	16-Feb-2024	PART OF J-3057 DSIDC NARELA	2	Other Outage	Unplanned Outage	16-Feb-2024	14:01	16-Feb-2024	14:27	26	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
337	16-Feb-2024	PART OF J-3057 DSIDC NARELA	4	160 kVA	Unplanned Outage	16-Feb-2024	14:51	16-Feb-2024	15:29	38	0.00001	EODB COMPLIANCE
338	16-Feb-2024	PART OF BRAHAM PRAKASH SUNGER PUR NARELA	2	Other Outage	Unplanned Outage	16-Feb-2024	15:15	16-Feb-2024	15:46	31	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
339	16-Feb-2024	PART OF DSIIDC FACTORY NO-J-2293 NARELA	2	250 kVA	Unplanned Outage	16-Feb-2024	15:31	16-Feb-2024	16:16	45	0.00001	EODB COMPLIANCE
340	16-Feb-2024	PART OF B BLOCK DSIDC NARELA	5	Other Outage	Unplanned Outage	16-Feb-2024	15:41	16-Feb-2024	16:39	58	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
341	16-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	4	315 kVA	Unplanned Outage	16-Feb-2024	15:51	16-Feb-2024	16:55	64	0.00002	EODB COMPLIANCE
342	16-Feb-2024	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	2096	Other Outage	Unplanned Outage	16-Feb-2024	19:12	16-Feb-2024	19:51	39	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
343	16-Feb-2024	PART OF E BLOCK NARELA	10	Other Outage	Unplanned Outage	16-Feb-2024	19:40	16-Feb-2024	20:08	28	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
344	16-Feb-2024	PART OF POCKET - H NARELA	14	Other Outage	Unplanned Outage	16-Feb-2024	20:41	16-Feb-2024	21:12	31	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
345	17-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	70	Other Outage	Unplanned Outage	17-Feb-2024	08:25	17-Feb-2024	09:17	52	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
346	17-Feb-2024	PARTS OF I BLOCK,DSIDC NARELA	100	Other Outage	Planned Outage	17-Feb-2024	08:28	17-Feb-2024	17:01	513	0.00371	PSD ON INDUSTRIAL WEEKLY OFF
347	17-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	161	Other Outage	Unplanned Outage	17-Feb-2024	09:31	17-Feb-2024	10:04	33	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
348	17-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	39	Other Outage	Planned Outage	17-Feb-2024	09:51	17-Feb-2024	14:50	299	0.00025	PSD ON INDUSTRIAL WEEKLY OFF
349	17-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	56	Other Outage	Planned Outage	17-Feb-2024	10:14	17-Feb-2024	17:14	420	0.00058	PSD ON INDUSTRIAL WEEKLY OFF
350	17-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	161	Other Outage	Planned Outage	17-Feb-2024	10:21	17-Feb-2024	17:54	453	0.00327	PSD ON INDUSTRIAL WEEKLY OFF
351	17-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	101	Other Outage	Planned Outage	17-Feb-2024	10:21	17-Feb-2024	17:38	437	0.00194	PSD ON INDUSTRIAL WEEKLY OFF
352	17-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	51	Other Outage	Planned Outage	17-Feb-2024	10:24	17-Feb-2024	17:40	436	0.00145	PSD ON INDUSTRIAL WEEKLY OFF
353	17-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	70	Other Outage	Planned Outage	17-Feb-2024	10:39	17-Feb-2024	17:49	430	0.00143	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
354	17-Feb-2024	PARTS OF J-3057 DSIDC NARELA	110	Other Outage	Planned Outage	17-Feb-2024	10:39	17-Feb-2024	16:54	375	0.00167	PSD ON INDUSTRIAL WEEKLY OFF
355	17-Feb-2024	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	578	Other Outage	Planned Outage	17-Feb-2024	10:43	17-Feb-2024	14:47	244	0.00034	PLANNED OUTAGE
356	17-Feb-2024	PART OF F BLOCK DSIDC NARELA	4	315 kVA	Unplanned Outage	17-Feb-2024	10:43	17-Feb-2024	14:03	200	0.00006	EODB COMPLIANCE
357	17-Feb-2024	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR NARELA	316	630 kVA	Planned Outage	17-Feb-2024	11:00	17-Feb-2024	15:08	248	0.00041	PLANNED OUTAGE
358	17-Feb-2024	PART OF E BLOCK DSIDC NARELA	4	250 kVA	Unplanned Outage	17-Feb-2024	11:19	17-Feb-2024	12:03	44	0.00001	EODB COMPLIANCE
359	17-Feb-2024	PARTS OF DSIDC BHORGARH VILLAGE NARELA	108	Other Outage	Planned Outage	17-Feb-2024	11:20	17-Feb-2024	17:47	387	0.00172	PSD ON INDUSTRIAL WEEKLY OFF
360	17-Feb-2024	PARTS OF SHASTRI PARK PHOOL BAGH NARELA	375	Other Outage	Planned Outage	17-Feb-2024	11:32	17-Feb-2024	12:34	62	0.00045	EODB COMPLIANCE
361	17-Feb-2024	PART OF H BLOCK NARELA	3	160 kVA	Unplanned Outage	17-Feb-2024	11:32	17-Feb-2024	13:06	94	0.00003	EODB COMPLIANCE
362	17-Feb-2024	PARTS OF PARSHURAM CHOWK NARELA	26	Other Outage	Planned Outage	17-Feb-2024	11:34	17-Feb-2024	17:45	371	0.00113	PSD ON INDUSTRIAL WEEKLY OFF
363	17-Feb-2024	PARTS OF NEW SHIV MANDIR TIKRI NARELA	905	Other Outage	Planned Outage	17-Feb-2024	11:49	17-Feb-2024	15:01	192	0.00139	PLANNED OUTAGE
364	17-Feb-2024	PARTS OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA. NARELA	61	Other Outage	Planned Outage	17-Feb-2024	12:11	17-Feb-2024	14:31	140	0.00062	PSD ON INDUSTRIAL WEEKLY OFF
365	17-Feb-2024	PART OF E BLOCK DSIDC NARELA	4	400 kVA	Unplanned Outage	17-Feb-2024	12:30	17-Feb-2024	14:24	114	0.00003	EODB COMPLIANCE
366	17-Feb-2024	PART OF NO-58 H-BLOCK NARELA	4	400 kVA	Unplanned Outage	17-Feb-2024	14:11	17-Feb-2024	15:24	73	0.00002	EODB COMPLIANCE
367	17-Feb-2024	PART OF C BLOCK NARELA	3	400 kVA	Unplanned Outage	17-Feb-2024	15:14	17-Feb-2024	16:20	66	0.00002	EODB COMPLIANCE
368	17-Feb-2024	PART OF NO-58 H-BLOCK NARELA	5	400 kVA	Unplanned Outage	17-Feb-2024	15:41	17-Feb-2024	16:18	37	0.00001	EODB COMPLIANCE
369	17-Feb-2024	PARTS OF F BLOCK DSIDC NARELA	38	Other Outage	Unplanned Outage	17-Feb-2024	18:58	17-Feb-2024	19:26	28	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
370	18-Feb-2024	PART OF D BLOCK DSIDC NARELA	5	Other Outage	Unplanned Outage	18-Feb-2024	10:54	18-Feb-2024	12:47	113	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
371	18-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	80	Other Outage	Unplanned Outage	18-Feb-2024	11:31	18-Feb-2024	11:54	23	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
372	18-Feb-2024	PARTS OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA. NARELA	61	Other Outage	Unplanned Outage	18-Feb-2024	11:49	18-Feb-2024	12:38	49	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
373	18-Feb-2024	PARTS OF DSIIDC FACTORY NO:D-1501 TO D-1522 AND D-1645 TO D-1651 NARELA	51	Other Outage	Unplanned Outage	18-Feb-2024	12:49	18-Feb-2024	13:14	24	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
374	18-Feb-2024	PART OF DSIIDC FACTORY NO:D-1501 NARELA	3	Other Outage	Unplanned Outage	18-Feb-2024	12:49	18-Feb-2024	13:14	24	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
375	18-Feb-2024	PART OF DSIIDC FACTORY NO: F-1829 NARELA	3	Other Outage	Unplanned Outage	18-Feb-2024	17:58	18-Feb-2024	19:04	66	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
376	19-Feb-2024	PART OF DSIDC B-2562 NARELA	4	Other Outage	Unplanned Outage	19-Feb-2024	08:44	19-Feb-2024	09:08	24	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
377	19-Feb-2024	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY NARELA	333	Other Outage	Unplanned Outage	19-Feb-2024	09:04	19-Feb-2024	10:28	84	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
378	19-Feb-2024	PARTS OF SINGHOLA STAND NARELA	138	Other Outage	Planned Outage	19-Feb-2024	10:17	19-Feb-2024	17:56	459	0.00026	PLANNED OUTAGE
379	19-Feb-2024	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	3153	Other Outage	Planned Outage	19-Feb-2024	10:30	19-Feb-2024	18:00	450	0.00400	PLANNED OUTAGE
380	19-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	171	Other Outage	Planned Outage	19-Feb-2024	10:31	19-Feb-2024	17:55	444	0.00025	PLANNED OUTAGE
381	19-Feb-2024	PART OF D BLOCK DSIDC NARELA	1	400 kVA	Unplanned Outage	19-Feb-2024	11:04	19-Feb-2024	11:52	48	0.00001	EODB COMPLIANCE
382	19-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	41	Other Outage	Planned Outage	19-Feb-2024	11:33	19-Feb-2024	12:04	31	0.00002	EODB COMPLIANCE
383	19-Feb-2024	PARTS OF H BLOCK DSIDC NARELA	44	Other Outage	Unplanned Outage	19-Feb-2024	11:37	19-Feb-2024	13:52	135	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
384	19-Feb-2024	PART OF H BLOCK NARELA	2	Other Outage	Unplanned Outage	19-Feb-2024	11:37	19-Feb-2024	15:01	204	0.00006	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
385	19-Feb-2024	PARTS OF POCKET-1 NARELA	440	Other Outage	Planned Outage	19-Feb-2024	11:56	19-Feb-2024	16:58	302	0.00134	PLANNED OUTAGE
386	19-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	152	Other Outage	Unplanned Outage	19-Feb-2024	12:05	19-Feb-2024	12:46	41	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
387	19-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	1861	Other Outage	Unplanned Outage	19-Feb-2024	12:22	19-Feb-2024	13:32	71	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
388	19-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	70	Other Outage	Unplanned Outage	19-Feb-2024	12:29	19-Feb-2024	12:55	26	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
389	19-Feb-2024	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI SHAHPUR NARELA	79	Other Outage	Unplanned Outage	19-Feb-2024	12:37	19-Feb-2024	13:13	36	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
390	19-Feb-2024	PART OF NO - 7 B-BLOCK NARELA	7	400 kVA	Unplanned Outage	19-Feb-2024	12:40	19-Feb-2024	15:16	156	0.00004	EODB COMPLIANCE
391	19-Feb-2024	PARTS OF J-3057 DSIDC NARELA	110	Other Outage	Unplanned Outage	19-Feb-2024	14:04	19-Feb-2024	14:30	26	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
392	19-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	209	Other Outage	Unplanned Outage	19-Feb-2024	14:22	19-Feb-2024	15:02	40	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
393	19-Feb-2024	PART OF SANNOTH NARELA	2	Other Outage	Unplanned Outage	19-Feb-2024	14:44	19-Feb-2024	20:51	367	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
394	19-Feb-2024	PARTS OF F BLOCK DSIDC NARELA	51	Other Outage	Unplanned Outage	19-Feb-2024	15:32	19-Feb-2024	16:53	81	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
395	19-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	631	Other Outage	Unplanned Outage	19-Feb-2024	15:38	19-Feb-2024	21:01	323	0.00162	FORCE MAJEURE/EXTERNAL FACTORS
396	19-Feb-2024	PART OF E BLOCK NARELA	8	Other Outage	Unplanned Outage	19-Feb-2024	16:15	19-Feb-2024	17:04	49	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
397	20-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	1128	Other Outage	Unplanned Outage	20-Feb-2024	00:33	20-Feb-2024	01:05	32	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
398	20-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	152	Other Outage	Unplanned Outage	20-Feb-2024	01:39	20-Feb-2024	02:30	51	0.00058	FORCE MAJEURE/EXTERNAL FACTORS
399	20-Feb-2024	PARTS OF A BLOCK DSIDC NARELA	117	Other Outage	Unplanned Outage	20-Feb-2024	01:48	20-Feb-2024	02:19	31	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
400	20-Feb-2024	PARTS OF F BLOCK DSIDC NARELA	32	Other Outage	Planned Outage	20-Feb-2024	07:47	20-Feb-2024	10:32	165	0.00014	PLANNED OUTAGE
401	20-Feb-2024	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI NARELA	204	Other Outage	Unplanned Outage	20-Feb-2024	08:50	20-Feb-2024	09:51	60	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
402	20-Feb-2024	PARTS OF AIR NANGLI NARELA	545	Other Outage	Planned Outage	20-Feb-2024	10:29	20-Feb-2024	16:32	362	0.00262	PLANNED OUTAGE
403	20-Feb-2024	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY NARELA	215	Other Outage	Planned Outage	20-Feb-2024	10:30	20-Feb-2024	17:45	435	0.00060	PLANNED OUTAGE
404	20-Feb-2024	PART OF G BLOCK NARELA	4	315 kVA	Unplanned Outage	20-Feb-2024	10:45	20-Feb-2024	11:34	49	0.00001	EODB COMPLIANCE
405	20-Feb-2024	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA NARELA	1565	Other Outage	Planned Outage	20-Feb-2024	10:46	20-Feb-2024	17:44	418	0.00267	PLANNED OUTAGE
406	20-Feb-2024	PART OF DSIIDC FACTORY NO-J-2293 NARELA	3	Other Outage	Unplanned Outage	20-Feb-2024	11:13	20-Feb-2024	11:46	33	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
407	20-Feb-2024	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	229	315 kVA	Planned Outage	20-Feb-2024	11:17	20-Feb-2024	13:50	153	0.00111	PLANNED OUTAGE
408	20-Feb-2024	PART OF J-3368 DSIDC NARELA	2	160 kVA	Unplanned Outage	20-Feb-2024	11:44	20-Feb-2024	12:31	47	0.00001	EODB COMPLIANCE
409	20-Feb-2024	PARTS OF DCM ALIPUR NARELA	2036	Other Outage	Unplanned Outage	20-Feb-2024	12:26	20-Feb-2024	12:55	29	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
410	20-Feb-2024	PART OF C BLK NARELA	7	Other Outage	Unplanned Outage	20-Feb-2024	12:29	20-Feb-2024	13:36	67	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
411	20-Feb-2024	PART OF C BLK NARELA	17	Other Outage	Unplanned Outage	20-Feb-2024	12:41	20-Feb-2024	13:36	55	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
412	20-Feb-2024	PART OF H BLOCK NARELA	5	Other Outage	Unplanned Outage	20-Feb-2024	12:51	20-Feb-2024	14:19	88	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
413	20-Feb-2024	PARTS OF DSIDC B-2562 NARELA	52	Other Outage	Unplanned Outage	20-Feb-2024	13:10	20-Feb-2024	13:52	43	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
414	20-Feb-2024	PART OF J-3368 DSIDC NARELA	6	400 kVA	Unplanned Outage	20-Feb-2024	13:23	20-Feb-2024	14:17	54	0.00002	EODB COMPLIANCE
415	20-Feb-2024	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	57	315 kVA	Planned Outage	20-Feb-2024	13:41	20-Feb-2024	14:39	58	0.00003	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
416	20-Feb-2024	PART OF D-1543 DSIDC NARELA	3	250 kVA	Unplanned Outage	20-Feb-2024	14:38	20-Feb-2024	15:17	39	0.00001	EODB COMPLIANCE
417	20-Feb-2024	PART OF J-3368 DSIDC NARELA	9	315 kVA	Unplanned Outage	20-Feb-2024	14:53	20-Feb-2024	16:30	97	0.00003	EODB COMPLIANCE
418	20-Feb-2024	PART OF NO-35 F-BLOCK DSIDC NARELA	6	400 kVA	Unplanned Outage	20-Feb-2024	15:09	20-Feb-2024	15:42	33	0.00001	EODB COMPLIANCE
419	20-Feb-2024	PART OF I BLOCK NARELA	3	315 kVA	Unplanned Outage	20-Feb-2024	15:59	20-Feb-2024	16:27	28	0.00001	EODB COMPLIANCE
420	20-Feb-2024	PARTS OF J-3057 DSIDC NARELA	63	Other Outage	Unplanned Outage	20-Feb-2024	16:03	20-Feb-2024	17:22	79	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
421	20-Feb-2024	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY NARELA	39	Other Outage	Unplanned Outage	20-Feb-2024	16:20	20-Feb-2024	17:04	44	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
422	20-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	228	Other Outage	Unplanned Outage	20-Feb-2024	17:06	20-Feb-2024	17:35	29	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
423	21-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	50	Other Outage	Unplanned Outage	21-Feb-2024	09:38	21-Feb-2024	13:04	206	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
424	21-Feb-2024	PARTS OF A BLOCK DSIDC , CNG PUMP NEAR SRHC HOSPITAL NARELA	1693	Other Outage	Planned Outage	21-Feb-2024	11:12	21-Feb-2024	16:49	337	0.00431	PLANNED OUTAGE
425	21-Feb-2024	PART OF C BLK NARELA	2	160 kVA	Unplanned Outage	21-Feb-2024	11:19	21-Feb-2024	11:55	36	0.00001	EODB COMPLIANCE
426	21-Feb-2024	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD NARELA	2133	Other Outage	Planned Outage	21-Feb-2024	11:22	21-Feb-2024	17:51	389	0.00389	PLANNED OUTAGE
427	21-Feb-2024	PART OF NANGLI KIOSK NARELA	11	Other Outage	Planned Outage	21-Feb-2024	11:30	21-Feb-2024	16:57	327	0.00018	PLANNED OUTAGE
428	21-Feb-2024	PARTS OF C-611 DSIDC NARELA	44	Other Outage	Unplanned Outage	21-Feb-2024	11:33	21-Feb-2024	12:18	45	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
429	21-Feb-2024	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY NARELA	306	Other Outage	Planned Outage	21-Feb-2024	11:47	21-Feb-2024	17:23	336	0.00215	PLANNED OUTAGE
430	21-Feb-2024	PART OF NO-58 H-BLOCK NARELA	6	400 kVA	Unplanned Outage	21-Feb-2024	11:48	21-Feb-2024	12:27	39	0.00001	EODB COMPLIANCE
431	21-Feb-2024	PART OF JHANGOLA VILLAGE NARELA	5	Other Outage	Planned Outage	21-Feb-2024	11:55	21-Feb-2024	17:13	317	0.00018	PLANNED OUTAGE
432	21-Feb-2024	PART OF C BLK NARELA	2	100 kVA	Unplanned Outage	21-Feb-2024	12:09	21-Feb-2024	13:11	62	0.00002	EODB COMPLIANCE
433	21-Feb-2024	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI SHAHPUR NARELA	79	Other Outage	Unplanned Outage	21-Feb-2024	12:41	21-Feb-2024	12:57	16	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
434	21-Feb-2024	PART OF C BLK NARELA	2	63 kVA	Unplanned Outage	21-Feb-2024	13:14	21-Feb-2024	14:28	74	0.00002	EODB COMPLIANCE
435	21-Feb-2024	PART OF SANNOTH NARELA	5	Other Outage	Unplanned Outage	21-Feb-2024	13:18	21-Feb-2024	14:32	74	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
436	21-Feb-2024	PART OF PARSHURAM CHOWK NARELA	4	400 kVA	Unplanned Outage	21-Feb-2024	14:33	21-Feb-2024	15:11	38	0.00001	EODB COMPLIANCE
437	21-Feb-2024	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I AND OM VIHAR COLONY LAMPUR NARELA	1784	Other Outage	Unplanned Outage	21-Feb-2024	14:40	21-Feb-2024	15:42	62	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
438	21-Feb-2024	PART OF BAKOLI NARELA	1	Other Outage	Unplanned Outage	21-Feb-2024	14:42	21-Feb-2024	17:03	141	0.00004	EODB COMPLIANCE
439	21-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	302	Other Outage	Unplanned Outage	21-Feb-2024	15:07	21-Feb-2024	15:57	50	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
440	21-Feb-2024	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA , NARELA	57	Other Outage	Unplanned Outage	21-Feb-2024	15:09	21-Feb-2024	16:40	91	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
441	21-Feb-2024	PART OF DSIDC-1 INDS.AREA NARELA	2	500 kVA	Unplanned Outage	21-Feb-2024	15:14	21-Feb-2024	16:29	75	0.00002	EODB COMPLIANCE
442	21-Feb-2024	PART OF C BLK NARELA	4	63 kVA	Unplanned Outage	21-Feb-2024	15:47	21-Feb-2024	16:26	39	0.00001	EODB COMPLIANCE
443	21-Feb-2024	PART OF AGRICULTURE LAND OF PALLA NARELA	18	Other Outage	Unplanned Outage	21-Feb-2024	16:23	21-Feb-2024	17:17	54	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
444	21-Feb-2024	PARTS OF DSIDC BORGARH INDS. AREA NARELA	1187	Other Outage	Unplanned Outage	21-Feb-2024	16:42	21-Feb-2024	17:57	74	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
445	22-Feb-2024	PARTS OF SINGHOLA STAND NARELA	138	Other Outage	Unplanned Outage	22-Feb-2024	01:23	22-Feb-2024	02:05	41	0.00006	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
446	22-Feb-2024	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI SHAHPUR NARELA	35	Other Outage	Unplanned Outage	22-Feb-2024	07:37	22-Feb-2024	08:55	78	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
447	22-Feb-2024	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL NARELA	53	Other Outage	Planned Outage	22-Feb-2024	08:02	22-Feb-2024	10:20	138	0.00019	PLANNED OUTAGE
448	22-Feb-2024	PART OF SINGHOLA STAND NARELA	17	Other Outage	Unplanned Outage	22-Feb-2024	09:22	22-Feb-2024	10:31	69	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
449	22-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	61	Other Outage	Unplanned Outage	22-Feb-2024	10:10	22-Feb-2024	10:28	18	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
450	22-Feb-2024	PART OF DSIDC B-2562 NARELA	6	Other Outage	Unplanned Outage	22-Feb-2024	11:03	22-Feb-2024	11:38	35	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
451	22-Feb-2024	PART OF D BLOCK NARELA	4	400 KVA	Unplanned Outage	22-Feb-2024	11:13	22-Feb-2024	12:26	73	0.00002	EODB COMPLIANCE
452	22-Feb-2024	PART OF BHAKTAWARPUR NARELA	5	630 kVA	Planned Outage	22-Feb-2024	11:21	22-Feb-2024	12:32	71	0.00004	PLANNED OUTAGE
453	22-Feb-2024	PART OF AGRICULTURE LAND OF PALLA NARELA	6	63 kVA	Planned Outage	22-Feb-2024	11:22	22-Feb-2024	16:03	281	0.00016	PLANNED OUTAGE
454	22-Feb-2024	PARTS OF DCM ALIPUR NARELA	1228	Other Outage	Planned Outage	22-Feb-2024	11:27	22-Feb-2024	16:18	291	0.00121	PLANNED OUTAGE
455	22-Feb-2024	PART OF G BLOCK DSIDC NARELA	6	400 kVA	Unplanned Outage	22-Feb-2024	11:53	22-Feb-2024	12:45	52	0.00001	EODB COMPLIANCE
456	22-Feb-2024	PART OF BHAKTAWARPUR NARELA	9	630 kVA	Planned Outage	22-Feb-2024	11:54	22-Feb-2024	13:30	96	0.00003	PLANNED OUTAGE
457	22-Feb-2024	PARTS OF AIR NANGLI NARELA	2652	Other Outage	Unplanned Outage	22-Feb-2024	12:42	22-Feb-2024	13:31	49	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
458	22-Feb-2024	PART OF BHAKTAWARPUR NARELA	4	630 kVA	Planned Outage	22-Feb-2024	13:15	22-Feb-2024	15:15	120	0.00007	PLANNED OUTAGE
459	22-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	66	Other Outage	Unplanned Outage	22-Feb-2024	13:22	22-Feb-2024	14:28	66	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
460	22-Feb-2024	PARTS OF F-1884 DSIDC NARELA	59	Other Outage	Unplanned Outage	22-Feb-2024	13:30	22-Feb-2024	13:47	17	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
461	22-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	239	630 kVA	Planned Outage	22-Feb-2024	13:37	22-Feb-2024	15:10	93	0.00010	PLANNED OUTAGE
462	22-Feb-2024	PART OF TRIVENI COLONY NARELA	1	Other Outage	Unplanned Outage	22-Feb-2024	13:45	22-Feb-2024	14:50	65	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
463	22-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	121	Other Outage	Unplanned Outage	22-Feb-2024	13:45	22-Feb-2024	14:07	21	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
464	22-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	40	Other Outage	Unplanned Outage	22-Feb-2024	13:45	22-Feb-2024	14:31	45	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
465	22-Feb-2024	PART OF B BLOCK DSIDC NARELA	3	Other Outage	Unplanned Outage	22-Feb-2024	14:13	22-Feb-2024	15:14	61	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
466	22-Feb-2024	PART OF H BLOCK NARELA	1	160 kVA	Unplanned Outage	22-Feb-2024	14:51	22-Feb-2024	15:17	26	0.00001	EODB COMPLIANCE
467	22-Feb-2024	PART OF A BLOCK DSIDC NARELA	3	400 kVA	Unplanned Outage	22-Feb-2024	15:59	22-Feb-2024	16:34	35	0.00001	EODB COMPLIANCE
468	22-Feb-2024	PART OF RAJEEV COLONY NARELA	5	Other Outage	Unplanned Outage	22-Feb-2024	18:43	22-Feb-2024	19:09	26	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
469	22-Feb-2024	PART OF NANGLI KIOSK NARELA	1	Other Outage	Unplanned Outage	22-Feb-2024	20:17	22-Feb-2024	20:57	40	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
470	23-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	67	Other Outage	Unplanned Outage	23-Feb-2024	07:53	23-Feb-2024	15:52	480	0.00053	FORCE MAJEURE/EXTERNAL FACTORS
471	23-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	69	Other Outage	Unplanned Outage	23-Feb-2024	09:21	23-Feb-2024	10:10	49	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
472	23-Feb-2024	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR. NARELA	2992	Other Outage	Unplanned Outage	23-Feb-2024	10:31	23-Feb-2024	11:00	29	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
473	23-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	343	Other Outage	Planned Outage	23-Feb-2024	10:52	23-Feb-2024	15:40	288	0.00120	PLANNED OUTAGE
474	23-Feb-2024	PART OF HARIZAN BASTI NARELA	4	Other Outage	Planned Outage	23-Feb-2024	11:34	23-Feb-2024	16:49	315	0.00009	PLANNED OUTAGE
475	23-Feb-2024	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK NARELA	26	Other Outage	Unplanned Outage	23-Feb-2024	11:36	23-Feb-2024	12:20	44	0.00001	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
476	23-Feb-2024	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE NARELA	607	Other Outage	Planned Outage	23-Feb-2024	11:56	23-Feb-2024	16:38	282	0.00118	PLANNED OUTAGE
477	23-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	44	Other Outage	Unplanned Outage	23-Feb-2024	13:56	23-Feb-2024	14:40	43	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
478	23-Feb-2024	PARTS OF A-10 GAS GODOWN NARELA	25	Other Outage	Unplanned Outage	23-Feb-2024	15:15	23-Feb-2024	19:03	227	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
479	23-Feb-2024	PARTS OF A-10 GAS GODOWN NARELA	836	Other Outage	Unplanned Outage	23-Feb-2024	15:15	23-Feb-2024	19:03	228	0.00070	FORCE MAJEURE/EXTERNAL FACTORS
480	23-Feb-2024	PART OF NAFE SINGH NO-2 NARELA	7	Other Outage	Unplanned Outage	23-Feb-2024	16:06	23-Feb-2024	16:17	11	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
481	23-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	44	Other Outage	Unplanned Outage	23-Feb-2024	16:50	23-Feb-2024	17:15	25	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
482	23-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	222	Other Outage	Unplanned Outage	23-Feb-2024	17:10	23-Feb-2024	17:27	17	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
483	23-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	51	Other Outage	Unplanned Outage	23-Feb-2024	17:10	23-Feb-2024	17:37	27	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
484	23-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	51	Other Outage	Unplanned Outage	23-Feb-2024	17:39	23-Feb-2024	18:00	21	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
485	23-Feb-2024	PART OF G BLOCK NARELA	2	Other Outage	Unplanned Outage	23-Feb-2024	18:15	23-Feb-2024	18:51	36	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
486	23-Feb-2024	PARTS OF I BLOCK, DSIDC & SHAHPUR VILLAGE RESIDENTAIL NARELA	97	Other Outage	Unplanned Outage	23-Feb-2024	19:24	23-Feb-2024	19:49	25	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
487	24-Feb-2024	PART OF DSIIDC FACTORY NO:D-1501 NARELA	5	Other Outage	Unplanned Outage	24-Feb-2024	08:20	24-Feb-2024	08:57	37	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
488	24-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	146	Other Outage	Unplanned Outage	24-Feb-2024	08:28	24-Feb-2024	09:10	43	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
489	24-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	50	Other Outage	Unplanned Outage	24-Feb-2024	08:28	24-Feb-2024	18:13	585	0.00081	FORCE MAJEURE/EXTERNAL FACTORS
490	24-Feb-2024	PARTS OF SWAROOP VIHAR NO. 2 NARELA	1826	Other Outage	Unplanned Outage	24-Feb-2024	08:37	24-Feb-2024	09:10	33	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
491	24-Feb-2024	PARTS OF E BLOCK DSIDC NARELA	174	Other Outage	Planned Outage	24-Feb-2024	09:09	24-Feb-2024	17:32	503	0.00363	PSD ON INDUSTRIAL WEEKLY OFF
492	24-Feb-2024	PARTS OF A BLOCK DSIDC NARELA	117	Other Outage	Planned Outage	24-Feb-2024	10:04	24-Feb-2024	17:57	473	0.00053	PSD ON INDUSTRIAL WEEKLY OFF
493	24-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	256	Other Outage	Planned Outage	24-Feb-2024	10:45	24-Feb-2024	17:02	377	0.00272	PLANNED OUTAGE
494	24-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	80	Other Outage	Planned Outage	24-Feb-2024	10:48	24-Feb-2024	16:56	368	0.00020	PSD ON INDUSTRIAL WEEKLY OFF
495	24-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	568	Other Outage	Planned Outage	24-Feb-2024	10:59	24-Feb-2024	15:54	295	0.00041	PLANNED OUTAGE
496	24-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	66	Other Outage	Planned Outage	24-Feb-2024	11:05	24-Feb-2024	17:56	411	0.00126	PLANNED OUTAGE
497	24-Feb-2024	PART OF F-1712 DSIDC NARELA	4	400 kVA	Unplanned Outage	24-Feb-2024	11:05	24-Feb-2024	12:11	66	0.00002	EODB COMPLIANCE
498	24-Feb-2024	PARTS OF DSIDC L BLOCK BHORGARH NARELA	31	Other Outage	Planned Outage	24-Feb-2024	11:09	24-Feb-2024	17:57	408	0.00113	PLANNED OUTAGE
499	24-Feb-2024	PARTS OF KADIPUR VILLAGE, PREM NAGAR NARELA	89	Other Outage	Planned Outage	24-Feb-2024	11:14	24-Feb-2024	14:49	215	0.00012	PLANNED OUTAGE
500	24-Feb-2024	PARTS OF D-1543 DSIDC NARELA	42	Other Outage	Planned Outage	24-Feb-2024	11:19	24-Feb-2024	17:44	385	0.00032	PSD ON INDUSTRIAL WEEKLY OFF
501	24-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	101	Other Outage	Planned Outage	24-Feb-2024	11:26	24-Feb-2024	17:50	384	0.00245	PSD ON INDUSTRIAL WEEKLY OFF
502	24-Feb-2024	PARTS OF C BLK DSIDC BHORGARH NARELA	51	Other Outage	Planned Outage	24-Feb-2024	11:30	24-Feb-2024	17:52	382	0.00117	PSD ON INDUSTRIAL WEEKLY OFF
503	24-Feb-2024	PARTS OF J-3368 DSIDC NARELA	108	Other Outage	Planned Outage	24-Feb-2024	11:34	24-Feb-2024	14:12	158	0.00018	PSD ON INDUSTRIAL WEEKLY OFF
504	24-Feb-2024	PART OF H BLOCK NARELA	3	315 kVA	Unplanned Outage	24-Feb-2024	11:43	24-Feb-2024	14:10	147	0.00004	EODB COMPLIANCE
505	24-Feb-2024	PARTS OF DSIIDC FACTORY NO:D-1501 TO D-1522 AND D-1645 TO D-1651 NARELA	51	Other Outage	Planned Outage	24-Feb-2024	11:47	24-Feb-2024	15:31	224	0.00012	PSD ON INDUSTRIAL WEEKLY OFF

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
506	24-Feb-2024	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA , NARELA	575	Other Outage	Planned Outage	24-Feb-2024	11:56	24-Feb-2024	17:06	310	0.00224	PLANNED OUTAGE
507	24-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	44	Other Outage	Planned Outage	24-Feb-2024	12:06	24-Feb-2024	17:49	343	0.00095	PSD ON INDUSTRIAL WEEKLY OFF
508	24-Feb-2024	PART OF F BLOCK NARELA	4	315 kVA	Unplanned Outage	24-Feb-2024	12:54	24-Feb-2024	13:56	62	0.00002	EODB COMPLIANCE
509	24-Feb-2024	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	5468	Other Outage	Unplanned Outage	24-Feb-2024	14:41	24-Feb-2024	14:58	17	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
510	24-Feb-2024	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER NARELA	3667	Other Outage	Unplanned Outage	24-Feb-2024	14:41	24-Feb-2024	16:20	99	0.00110	FORCE MAJEURE/EXTERNAL FACTORS
511	24-Feb-2024	PART OF BHORGARH VILLAGE NARELA	3	250 kVA	Unplanned Outage	24-Feb-2024	15:08	24-Feb-2024	15:46	38	0.00001	EODB COMPLIANCE
512	24-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	53	Other Outage	Unplanned Outage	24-Feb-2024	15:20	24-Feb-2024	15:42	21	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
513	24-Feb-2024	PART OF F BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	24-Feb-2024	15:36	24-Feb-2024	16:48	72	0.00002	EODB COMPLIANCE
514	24-Feb-2024	PARTS OF C BLOCK DSIDC NARELA	36	Other Outage	Unplanned Outage	24-Feb-2024	15:44	24-Feb-2024	18:44	179	0.00100	FORCE MAJEURE/EXTERNAL FACTORS
515	24-Feb-2024	PART OF NO-10 C BLOCK DSIDC NARELA	3	250 kVA	Unplanned Outage	24-Feb-2024	16:09	24-Feb-2024	17:04	55	0.00002	EODB COMPLIANCE
516	24-Feb-2024	PARTS OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL DSIDC NARELA	73	Other Outage	Unplanned Outage	24-Feb-2024	16:15	24-Feb-2024	16:43	28	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
517	24-Feb-2024	PART OF BAKOLI NARELA	1	Other Outage	Unplanned Outage	24-Feb-2024	16:30	24-Feb-2024	18:47	137	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
518	24-Feb-2024	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY NARELA	40	Other Outage	Unplanned Outage	24-Feb-2024	16:59	24-Feb-2024	18:46	107	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
519	24-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	315	Other Outage	Unplanned Outage	24-Feb-2024	17:03	24-Feb-2024	17:50	46	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
520	24-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1097	Other Outage	Unplanned Outage	24-Feb-2024	20:37	24-Feb-2024	21:54	76	0.00042	FORCE MAJEURE/EXTERNAL FACTORS
521	24-Feb-2024	PART OF BAKOLI NARELA	4	Other Outage	Unplanned Outage	24-Feb-2024	20:37	24-Feb-2024	22:05	88	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
522	24-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	594	Other Outage	Unplanned Outage	24-Feb-2024	20:37	24-Feb-2024	22:35	117	0.00033	FORCE MAJEURE/EXTERNAL FACTORS
523	25-Feb-2024	PARTS OF DISTRICT OFFICE NARELA	466	Other Outage	Unplanned Outage	25-Feb-2024	10:12	25-Feb-2024	10:41	29	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
524	25-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	121	Other Outage	Unplanned Outage	25-Feb-2024	11:11	25-Feb-2024	11:35	24	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
525	25-Feb-2024	PART OF POCKET - H NARELA	11	Other Outage	Unplanned Outage	25-Feb-2024	13:36	25-Feb-2024	15:48	132	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
526	25-Feb-2024	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	2006	Other Outage	Unplanned Outage	25-Feb-2024	13:39	25-Feb-2024	14:00	21	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
527	25-Feb-2024	PARTS OF SHASTRI PARK PHOOL BAGH NARELA	4806	Other Outage	Unplanned Outage	25-Feb-2024	16:53	25-Feb-2024	17:34	41	0.00057	FORCE MAJEURE/EXTERNAL FACTORS
528	25-Feb-2024	PART OF F-1712 DSIDC NARELA	2	Other Outage	Unplanned Outage	25-Feb-2024	19:29	25-Feb-2024	19:58	29	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
529	26-Feb-2024	PART OF NAFE SINGH NO-2 NARELA	2	Other Outage	Unplanned Outage	26-Feb-2024	08:05	26-Feb-2024	09:30	84	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
530	26-Feb-2024	PART OF D BLOCK NARELA	5	Other Outage	Unplanned Outage	26-Feb-2024	08:48	26-Feb-2024	08:59	11	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
531	26-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	2733	Other Outage	Planned Outage	26-Feb-2024	10:37	26-Feb-2024	17:36	419	0.00419	PLANNED OUTAGE
532	26-Feb-2024	PARTS OF GAUTAM COLONY AND SANJAY COLONY NARELA	2678	Other Outage	Planned Outage	26-Feb-2024	10:38	26-Feb-2024	17:27	409	0.00341	PLANNED OUTAGE
533	26-Feb-2024	PART OF TRIVENI COLONY NARELA	17	Other Outage	Planned Outage	26-Feb-2024	10:41	26-Feb-2024	16:29	348	0.00019	PLANNED OUTAGE
534	26-Feb-2024	PART OF E BLOCK DSIDC NARELA	5	250 kVA	Unplanned Outage	26-Feb-2024	10:44	26-Feb-2024	11:19	35	0.00001	EODB COMPLIANCE
535	26-Feb-2024	PARTS OF ALL INDIA RADIO KHAM PUR NARELA	160	400 kVA	Planned Outage	26-Feb-2024	10:47	26-Feb-2024	11:42	55	0.00024	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
536	26-Feb-2024	PART OF J-3057 DSIDC NARELA	3	160 kVA	Unplanned Outage	26-Feb-2024	10:56	26-Feb-2024	12:00	64	0.00002	EODB COMPLIANCE
537	26-Feb-2024	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI NARELA	64	Other Outage	Planned Outage	26-Feb-2024	11:20	26-Feb-2024	16:50	330	0.00028	PLANNED OUTAGE
538	26-Feb-2024	PART OF C BLOCK DSIDC NARELA	3	315 kVA	Unplanned Outage	26-Feb-2024	11:21	26-Feb-2024	12:22	61	0.00002	EODB COMPLIANCE
539	26-Feb-2024	PARTS OF ALL INDIA RADIO KHAM PUR NARELA	133	400 kVA	Planned Outage	26-Feb-2024	12:01	26-Feb-2024	13:20	79	0.00004	PLANNED OUTAGE
540	26-Feb-2024	PART OF D-1543 DSIDC NARELA	3	315 kVA	Unplanned Outage	26-Feb-2024	12:04	26-Feb-2024	13:20	76	0.00002	EODB COMPLIANCE
541	26-Feb-2024	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA NARELA	79	Other Outage	Planned Outage	26-Feb-2024	12:24	26-Feb-2024	16:12	228	0.00013	PLANNED OUTAGE
542	26-Feb-2024	PART OF E BLOCK NARELA	7	Other Outage	Unplanned Outage	26-Feb-2024	12:34	26-Feb-2024	13:16	42	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
543	26-Feb-2024	PART OF NANGLI KIOSK NARELA	1	Other Outage	Unplanned Outage	26-Feb-2024	12:39	26-Feb-2024	13:25	46	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
544	26-Feb-2024	PART OF BAKOLI NARELA	1	Other Outage	Unplanned Outage	26-Feb-2024	14:03	26-Feb-2024	14:56	53	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
545	26-Feb-2024	PART OF F BLOCK NARELA	4	315 kVA	Unplanned Outage	26-Feb-2024	14:11	26-Feb-2024	15:09	58	0.00002	EODB COMPLIANCE
546	26-Feb-2024	PART OF J-3368 DSIDC NARELA	5	400 kVA	Unplanned Outage	26-Feb-2024	14:15	26-Feb-2024	14:42	27	0.00001	EODB COMPLIANCE
547	26-Feb-2024	PART OF NO-58 H-BLOCK NARELA	3	250 kVA	Unplanned Outage	26-Feb-2024	14:18	26-Feb-2024	14:50	32	0.00001	EODB COMPLIANCE
548	26-Feb-2024	PARTS OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL DSIDC NARELA	28	Other Outage	Unplanned Outage	26-Feb-2024	14:23	26-Feb-2024	14:56	33	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
549	26-Feb-2024	PART OF F BLOCK NARELA	1	315 kVA	Unplanned Outage	26-Feb-2024	15:11	26-Feb-2024	16:01	50	0.00001	EODB COMPLIANCE
550	26-Feb-2024	PART OF NO-58 H-BLOCK NARELA	1	160 kVA	Unplanned Outage	26-Feb-2024	15:19	26-Feb-2024	16:04	45	0.00001	EODB COMPLIANCE
551	26-Feb-2024	PART OF DSIDC-1 INDS.AREA NARELA	4	315 kVA	Unplanned Outage	26-Feb-2024	16:30	26-Feb-2024	17:15	45	0.00001	EODB COMPLIANCE
552	26-Feb-2024	PARTS OF NANGLI KIOSK ALIPUR NARELA	1099	Other Outage	Unplanned Outage	26-Feb-2024	22:37	26-Feb-2024	22:59	22	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
553	27-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	1695	Other Outage	Unplanned Outage	27-Feb-2024	04:10	27-Feb-2024	04:48	38	0.00032	FORCE MAJEURE/EXTERNAL FACTORS
554	27-Feb-2024	PARTS OF E BLOCK DSIDC NARELA	33	Other Outage	Planned Outage	27-Feb-2024	07:48	27-Feb-2024	10:18	150	0.00008	PLANNED OUTAGE
555	27-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	75	Other Outage	Unplanned Outage	27-Feb-2024	08:20	27-Feb-2024	09:10	50	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
556	27-Feb-2024	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY NARELA	50	Other Outage	Planned Outage	27-Feb-2024	10:31	27-Feb-2024	17:47	436	0.00145	PLANNED OUTAGE
557	27-Feb-2024	PARTS OF DISTRICT OFFICE NARELA	1137	Other Outage	Unplanned Outage	27-Feb-2024	10:38	27-Feb-2024	11:52	74	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
558	27-Feb-2024	PART OF NO-58 H-BLOCK NARELA	4	400 kVA	Unplanned Outage	27-Feb-2024	10:53	27-Feb-2024	11:37	44	0.00001	EODB COMPLIANCE
559	27-Feb-2024	PARTS OF AMAN VIHAR, SHAMSHAN GHAT NANGLI POONA, MURGI FARM KADIPUR, GURUDWARA GT ROAD NANGLI, MOHAN VILAS, DALMILL NANGLI POONA NARELA	1840	Other Outage	Planned Outage	27-Feb-2024	11:05	27-Feb-2024	19:00	475	0.00264	FORCE MAJEURE DUE TO SABOTAGE
560	27-Feb-2024	PARTS OF KURENI VILLAGE, MANDI EXTN, PANIABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT. NARELA	402	630 kVA	Planned Outage	27-Feb-2024	11:16	27-Feb-2024	13:38	142	0.00020	PLANNED OUTAGE
561	27-Feb-2024	PART OF H BLOCK NARELA	3	315 kVA	Unplanned Outage	27-Feb-2024	11:18	27-Feb-2024	12:15	57	0.00002	EODB COMPLIANCE
562	27-Feb-2024	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI SHAHPUR NARELA	41	Other Outage	Unplanned Outage	27-Feb-2024	11:26	27-Feb-2024	13:30	124	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
563	27-Feb-2024	PART OF E BLOCK NARELA	4	315 kVA	Unplanned Outage	27-Feb-2024	11:28	27-Feb-2024	12:36	68	0.00002	EODB COMPLIANCE
564	27-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	202	Other Outage	Planned Outage	27-Feb-2024	11:41	27-Feb-2024	17:38	357	0.00119	PLANNED OUTAGE
565	27-Feb-2024	PART OF J-3057 DSIDC NARELA	2	160 kVA	Unplanned Outage	27-Feb-2024	12:21	27-Feb-2024	13:03	42	0.00001	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
566	27-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	3	250 kVA	Unplanned Outage	27-Feb-2024	12:48	27-Feb-2024	13:27	39	0.00001	EODB COMPLIANCE
567	27-Feb-2024	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	315 kVA	Unplanned Outage	27-Feb-2024	13:18	27-Feb-2024	15:34	136	0.00004	EODB COMPLIANCE
568	27-Feb-2024	PART OF I BLOCK NARELA	3	250 kVA	Unplanned Outage	27-Feb-2024	13:29	27-Feb-2024	14:41	72	0.00002	EODB COMPLIANCE
569	27-Feb-2024	PARTS OF PKT-1C ESS-3 NARELA	518	Other Outage	Unplanned Outage	27-Feb-2024	14:19	27-Feb-2024	15:21	62	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
570	27-Feb-2024	PART OF NO-58 H-BLOCK NARELA	3	250 kVA	Unplanned Outage	27-Feb-2024	14:26	27-Feb-2024	15:16	50	0.00001	EODB COMPLIANCE
571	27-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	2	250 kVA	Unplanned Outage	27-Feb-2024	14:31	27-Feb-2024	15:18	47	0.00001	EODB COMPLIANCE
572	27-Feb-2024	PARTS OF A BLOCK DSIDC NARELA	165	630 kVA	Planned Outage	27-Feb-2024	14:38	27-Feb-2024	16:25	107	0.00012	PLANNED OUTAGE
573	27-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	6	250 kVA	Unplanned Outage	27-Feb-2024	15:43	27-Feb-2024	16:23	40	0.00001	EODB COMPLIANCE
574	27-Feb-2024	PART OF DSIDC-1 INDS.AREA NARELA	4	315 kVA	Unplanned Outage	27-Feb-2024	15:57	27-Feb-2024	16:38	41	0.00001	EODB COMPLIANCE
575	27-Feb-2024	PART OF DSIIDC FACTORY NO:J-2293 NARELA	2	160 kVA	Unplanned Outage	27-Feb-2024	16:03	27-Feb-2024	16:31	28	0.00001	EODB COMPLIANCE
576	27-Feb-2024	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE NARELA	407	Other Outage	Unplanned Outage	27-Feb-2024	16:05	27-Feb-2024	17:05	60	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
577	27-Feb-2024	PART OF J-3057 DSIDC NARELA	6	Other Outage	Unplanned Outage	27-Feb-2024	18:16	27-Feb-2024	18:47	31	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
578	27-Feb-2024	PARTS OF NANGLI KIOSK ALIPUR NARELA	124	Other Outage	Unplanned Outage	27-Feb-2024	18:49	27-Feb-2024	19:22	33	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
579	27-Feb-2024	PART OF NANGLI KIOSK NARELA	5	Other Outage	Unplanned Outage	27-Feb-2024	18:49	27-Feb-2024	19:22	33	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
580	27-Feb-2024	PARTS OF F-2010 DSIDC NARELA	40	Other Outage	Unplanned Outage	27-Feb-2024	19:24	27-Feb-2024	22:27	183	0.00051	FORCE MAJEURE/EXTERNAL FACTORS
581	28-Feb-2024	PARTS OF ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	228	Other Outage	Planned Outage	28-Feb-2024	10:18	28-Feb-2024	15:18	300	0.00058	PLANNED OUTAGE
582	28-Feb-2024	PART OF DSIIDC FACTORY NO:D-1501 NARELA	4	315 kVA	Unplanned Outage	28-Feb-2024	10:28	28-Feb-2024	10:44	16	0.000005	EODB COMPLIANCE
583	28-Feb-2024	PART OF NANGLI KIOSK NARELA	20	Other Outage	Planned Outage	28-Feb-2024	10:56	28-Feb-2024	16:50	354	0.00020	PLANNED OUTAGE
584	28-Feb-2024	PART OF D BLOCK NARELA	3	400 kVA	Unplanned Outage	28-Feb-2024	11:02	28-Feb-2024	12:14	72	0.00002	EODB COMPLIANCE
585	28-Feb-2024	PART OF H BLOCK NARELA	6	250 kVA	Unplanned Outage	28-Feb-2024	11:09	28-Feb-2024	12:07	58	0.00002	EODB COMPLIANCE
586	28-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	4	250 kVA	Unplanned Outage	28-Feb-2024	11:18	28-Feb-2024	11:41	23	0.00001	EODB COMPLIANCE
587	28-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	59	Other Outage	Planned Outage	28-Feb-2024	11:27	28-Feb-2024	17:42	375	0.00125	PLANNED OUTAGE
588	28-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	136	Other Outage	Planned Outage	28-Feb-2024	11:32	28-Feb-2024	16:17	285	0.00032	PLANNED OUTAGE
589	28-Feb-2024	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	1693	Other Outage	Planned Outage	28-Feb-2024	12:10	28-Feb-2024	17:33	323	0.00270	PLANNED OUTAGE
590	28-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	2	250 kVA	Unplanned Outage	28-Feb-2024	12:10	28-Feb-2024	13:01	51	0.00001	EODB COMPLIANCE
591	28-Feb-2024	PART OF C BLOCK DSIDC NARELA	3	315 kVA	Unplanned Outage	28-Feb-2024	12:27	28-Feb-2024	13:18	51	0.00001	EODB COMPLIANCE
592	28-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	513	Other Outage	Planned Outage	28-Feb-2024	13:00	28-Feb-2024	16:59	239	0.00040	PLANNED OUTAGE
593	28-Feb-2024	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY NARELA	97	Other Outage	Unplanned Outage	28-Feb-2024	13:02	28-Feb-2024	14:03	61	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
594	28-Feb-2024	PART OF J-3057 DSIDC NARELA	4	400 kVA	Unplanned Outage	28-Feb-2024	13:13	28-Feb-2024	14:05	52	0.00001	EODB COMPLIANCE
595	28-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	5	250 kVA	Unplanned Outage	28-Feb-2024	13:28	28-Feb-2024	14:32	64	0.00002	EODB COMPLIANCE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
596	28-Feb-2024	PART OF H BLOCK NARELA	3	250 kVA	Unplanned Outage	28-Feb-2024	14:29	28-Feb-2024	15:40	71	0.00002	EODB COMPLIANCE
597	28-Feb-2024	PARTS OF PKT-1C ESS-3 NARELA	352	630 kVA	Planned Outage	28-Feb-2024	14:40	28-Feb-2024	15:58	78	0.00011	PLANNED OUTAGE
598	28-Feb-2024	PART OF B BLOCK DSIDC NARELA	3	400 kVA	Unplanned Outage	28-Feb-2024	15:12	28-Feb-2024	15:26	14	0.000004	EODB COMPLIANCE
599	28-Feb-2024	PART OF H BLOCK NARELA	3	315 kVA	Unplanned Outage	28-Feb-2024	15:58	28-Feb-2024	16:33	35	0.00001	EODB COMPLIANCE
600	28-Feb-2024	PART OF E BLOCK DSIDC NARELA	2	Other Outage	Unplanned Outage	28-Feb-2024	16:05	28-Feb-2024	18:32	147	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
601	28-Feb-2024	PART OF NO - 7 B-BLOCK NARELA	2	250 kVA	Unplanned Outage	28-Feb-2024	16:05	28-Feb-2024	16:49	44	0.00001	EODB COMPLIANCE
602	28-Feb-2024	PART OF NO-10 C BLOCK DSIDC NARELA	1	Other Outage	Unplanned Outage	28-Feb-2024	19:20	28-Feb-2024	19:42	22	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
603	28-Feb-2024	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY NARELA	1117	Other Outage	Unplanned Outage	28-Feb-2024	19:51	28-Feb-2024	20:20	28	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
604	28-Feb-2024	PART OF DSIDC NARELA	10	Other Outage	Unplanned Outage	28-Feb-2024	19:51	28-Feb-2024	21:56	125	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
605	29-Feb-2024	PARTS OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	33	Other Outage	Planned Outage	29-Feb-2024	07:43	29-Feb-2024	09:59	136	0.00011	PLANNED OUTAGE
606	29-Feb-2024	PARTS OF E BLOCK DSIDC NARELA	54	Other Outage	Unplanned Outage	29-Feb-2024	08:07	29-Feb-2024	08:30	23	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
607	29-Feb-2024	PARTS OF E BLOCK DSIDC NARELA	33	Other Outage	Unplanned Outage	29-Feb-2024	08:07	29-Feb-2024	08:30	23	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
608	29-Feb-2024	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI NARELA	171	Other Outage	Unplanned Outage	29-Feb-2024	09:29	29-Feb-2024	14:59	330	0.00073	FORCE MAJEURE/EXTERNAL FACTORS
609	29-Feb-2024	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL. NARELA	273	400 kVA	Planned Outage	29-Feb-2024	10:26	29-Feb-2024	12:08	102	0.00074	PLANNED OUTAGE
610	29-Feb-2024	PART OF H BLOCK NARELA	4	400 kVA	Unplanned Outage	29-Feb-2024	10:30	29-Feb-2024	11:28	58	0.00002	EODB COMPLIANCE
611	29-Feb-2024	PART OF NO-10 C BLOCK DSIDC NARELA	2	400 kVA	Unplanned Outage	29-Feb-2024	10:47	29-Feb-2024	12:41	114	0.00003	EODB COMPLIANCE
612	29-Feb-2024	PARTS OF DISTRICT OFFICE NARELA	4857	Other Outage	Unplanned Outage	29-Feb-2024	11:16	29-Feb-2024	11:45	28	0.00040	FORCE MAJEURE/EXTERNAL FACTORS
613	29-Feb-2024	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2 NARELA	261	400 kVA	Planned Outage	29-Feb-2024	11:22	29-Feb-2024	13:43	141	0.00102	PLANNED OUTAGE
614	29-Feb-2024	PART OF H BLOCK NARELA	5	315 kVA	Unplanned Outage	29-Feb-2024	11:30	29-Feb-2024	13:03	93	0.00003	EODB COMPLIANCE
615	29-Feb-2024	PART OF DSIDC-1 INDS.AREA NARELA	3	400 kVA	Unplanned Outage	29-Feb-2024	11:36	29-Feb-2024	12:15	39	0.00001	EODB COMPLIANCE
616	29-Feb-2024	PART OF ZONAL OFFICE OM VIHAR COLONY NARELA	4	Other Outage	Unplanned Outage	29-Feb-2024	12:03	29-Feb-2024	17:42	339	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
617	29-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	35	630 kVA	Planned Outage	29-Feb-2024	12:42	29-Feb-2024	14:07	85	0.00005	PLANNED OUTAGE
618	29-Feb-2024	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	78	160 kVA	Planned Outage	29-Feb-2024	12:48	29-Feb-2024	14:08	80	0.00004	PLANNED OUTAGE
619	29-Feb-2024	PART OF NO-35 F-BLOCK DSIDC NARELA	5	400 kVA	Unplanned Outage	29-Feb-2024	13:07	29-Feb-2024	14:00	53	0.00001	EODB COMPLIANCE
620	29-Feb-2024	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	582	Other Outage	Planned Outage	29-Feb-2024	13:13	29-Feb-2024	16:02	169	0.00028	PLANNED OUTAGE
621	29-Feb-2024	PARTS OF C BLK POOTH KHURD NARELA	191	Other Outage	Unplanned Outage	29-Feb-2024	13:51	29-Feb-2024	14:21	30	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
622	29-Feb-2024	PART OF J-3368 DSIDC NARELA	3	315 kVA	Unplanned Outage	29-Feb-2024	14:16	29-Feb-2024	15:02	46	0.00001	EODB COMPLIANCE
623	29-Feb-2024	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL NARELA	300	400 kVA	Planned Outage	29-Feb-2024	14:19	29-Feb-2024	15:48	89	0.00064	PLANNED OUTAGE
624	29-Feb-2024	PART OF H-1331 DSIDC INDUSTRIAL AREA NARELA	4	400 kVA	Unplanned Outage	29-Feb-2024	14:20	29-Feb-2024	15:06	46	0.00001	EODB COMPLIANCE
625	29-Feb-2024	PARTS OF C BLOCK 1272 DSIDC NARELA	52	Other Outage	Unplanned Outage	29-Feb-2024	14:41	29-Feb-2024	15:45	64	0.00004	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
626	29-Feb-2024	PART OF NO-35 F-BLOCK DSIDC NARELA	6	400 kVA	Unplanned Outage	29-Feb-2024	15:19	29-Feb-2024	15:44	25	0.00001	EODB COMPLIANCE
627	29-Feb-2024	PART OF NO-58 H-BLOCK NARELA	4	400 kVA	Unplanned Outage	29-Feb-2024	15:37	29-Feb-2024	16:56	79	0.00002	EODB COMPLIANCE
628	29-Feb-2024	PART OF NAFE SINGH NO-2 NARELA	4	Other Outage	Unplanned Outage	29-Feb-2024	15:57	29-Feb-2024	16:30	33	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
629	29-Feb-2024	PART OF NO.-1 A BLOCK DSIDC NARELA	4	Other Outage	Unplanned Outage	29-Feb-2024	21:54	29-Feb-2024	22:45	51	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
PITAM PURA												
1	01-Feb-2024	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	1842	Other Outage	Unplanned Outage	01-Feb-2024	03:44	01-Feb-2024	04:57	73	0.00037	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF C, D G,H,J BLOCK PSS JJ COLONY PITAM PURA	1251	Other Outage	Unplanned Outage	01-Feb-2024	06:05	01-Feb-2024	07:24	80	0.00044	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF DEEPALI VARDHMAN MALL, TARUN ENCLAVE, DEEPALI PITAM PURA	237	Other Outage	Unplanned Outage	01-Feb-2024	08:46	01-Feb-2024	10:11	85	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	44	Other Outage	Unplanned Outage	01-Feb-2024	11:31	01-Feb-2024	12:38	67	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL,KP PLINTH, PART OF MD,DPCP BLOCK PITAM PURA	181	Other Outage	Unplanned Outage	01-Feb-2024	16:57	01-Feb-2024	18:09	72	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	110	Other Outage	Unplanned Outage	01-Feb-2024	17:11	01-Feb-2024	18:13	62	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL,KP PLINTH, PART OF MD,DPCP BLOCK PITAM PURA	846	Other Outage	Unplanned Outage	01-Feb-2024	18:38	01-Feb-2024	18:54	16	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
8	04-Feb-2024	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	656	Other Outage	Unplanned Outage	04-Feb-2024	13:36	04-Feb-2024	14:09	33	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
9	04-Feb-2024	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	1331	Other Outage	Unplanned Outage	04-Feb-2024	13:36	04-Feb-2024	14:17	41	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
10	05-Feb-2024	PARTS OF RAJA ENCLAVE, ASHIYANA APPARTMENT, MANDAKNI APPARTMENT, EMINABAD MARKET, EMINABAD APPARTMENT, RAJASTHALI APPARTMENT, PART OF PITAMPURA VILLAGE PITAM PURA	447	990 kVA	Planned Outage	05-Feb-2024	10:39	05-Feb-2024	12:33	114	0.00082	PLANNED OUTAGE
11	05-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	3	160 kVA	Unplanned Outage	05-Feb-2024	10:56	05-Feb-2024	11:18	22	0.00001	EODB COMPLIANCE
12	05-Feb-2024	PARTS OF GD, JD, FD, HD BLOCK PITAM PURA	1166	Other Outage	Unplanned Outage	05-Feb-2024	13:20	05-Feb-2024	14:00	41	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
13	05-Feb-2024	PARTS OF GD, JD, FD, HD BLOCK PITAM PURA	153	Other Outage	Unplanned Outage	05-Feb-2024	13:20	05-Feb-2024	15:50	150	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
14	05-Feb-2024	PARTS OF M BLOCK SHAKURPUR, MOTHER DAIRY, ROAD NO - 43 PITAM PURA	500	630 kVA	Planned Outage	05-Feb-2024	14:26	05-Feb-2024	15:58	92	0.00066	PLANNED OUTAGE
15	06-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	4	160 kVA	Planned Outage	06-Feb-2024	07:12	06-Feb-2024	08:54	102	0.00006	PLANNED OUTAGE
16	06-Feb-2024	PARTS OF KALASH ENCLAVE,,112 MIG FLATS, MILANIUM PUBLIC SCHOOL, MAHARAJA AGARSEN BHAWAN, LOREN HIGH SCHOOL, PART OF IDPL, PART OF VILLAGE PITAM PURA & JANTA FLATS PITAM PURA	117	Other Outage	Planned Outage	06-Feb-2024	10:56	06-Feb-2024	15:44	288	0.00040	PLANNED OUTAGE
17	06-Feb-2024	PARTS OF KALASH ENCLAVE,,112 MIG FLATS, MILANIUM PUBLIC SCHOOL, MAHARAJA AGARSEN BHAWAN, LOREN HIGH SCHOOL, PART OF IDPL, PART OF VILLAGE PITAM PURA & JANTA FLATS PITAM PURA	117	Other Outage	Unplanned Outage	06-Feb-2024	19:07	06-Feb-2024	19:36	29	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
18	07-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	3	100 kVA	Planned Outage	07-Feb-2024	07:10	07-Feb-2024	08:56	106	0.00015	PSD ON INDUSTRIAL WEEKLY OFF
19	07-Feb-2024	PART OF GP BLK PITAM PURA	14	Other Outage	Planned Outage	07-Feb-2024	10:30	07-Feb-2024	14:09	219	0.00012	PLANNED OUTAGE
20	07-Feb-2024	PARTS OF A BLOCK (MANGOL PURI), B BLOCK MANGOL PURI (PARTLY),BC BLOCK MANGOL PURI PH - 2 PITAM PURA	68	Other Outage	Planned Outage	07-Feb-2024	11:05	07-Feb-2024	16:18	313	0.00017	PSD ON INDUSTRIAL WEEKLY OFF

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
21	07-Feb-2024	PART OF GP BLK PITAM PURA	1	315 kVA	Planned Outage	07-Feb-2024	14:25	07-Feb-2024	15:59	94	0.00005	PLANNED OUTAGE
22	08-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	8	100 kVA	Planned Outage	08-Feb-2024	07:15	08-Feb-2024	08:58	103	0.00003	PLANNED OUTAGE
23	08-Feb-2024	PARTS OF MULTANI MOHALLA, PART OF RANI BAGH, PART OF COMMERCIAL COMPLEX, PART OF MAHENDRA PARK PITAM PURA	574	990 kVA	Planned Outage	08-Feb-2024	10:35	08-Feb-2024	13:02	147	0.00106	PLANNED OUTAGE
24	08-Feb-2024	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR PITAM PURA	178	630 kVA	Planned Outage	08-Feb-2024	10:36	08-Feb-2024	12:29	113	0.00038	PLANNED OUTAGE
25	08-Feb-2024	PART OF E-126 PITAM PURA	4	25 kVA	Unplanned Outage	08-Feb-2024	11:25	08-Feb-2024	11:57	32	0.00001	EODB COMPLIANCE
26	08-Feb-2024	PARTS OF E-1, 2, 3,4, C-1, 2, 3, C-4, 5, 6, C-7 NETAJI SUBHAS PALACE PITAM PURA	228	Other Outage	Planned Outage	08-Feb-2024	12:00	08-Feb-2024	13:51	110	0.00012	PLANNED OUTAGE
27	08-Feb-2024	PARTS OF MAHENDRA PARK AND RAMLILA GROUND PITAM PURA	763	990 kVA	Planned Outage	08-Feb-2024	13:58	08-Feb-2024	16:07	129	0.00093	PLANNED OUTAGE
28	08-Feb-2024	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR PITAM PURA	128	315 kVA	Planned Outage	08-Feb-2024	14:05	08-Feb-2024	16:16	131	0.00047	PLANNED OUTAGE
29	08-Feb-2024	PARTS OF KOHAT ENCLAVE AND VASUDHA KUNJ PITAM PURA	340	Other Outage	Planned Outage	08-Feb-2024	14:10	08-Feb-2024	15:57	107	0.00039	PLANNED OUTAGE
30	09-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	9	100 kVA	Planned Outage	09-Feb-2024	06:53	09-Feb-2024	08:37	104	0.00003	PLANNED OUTAGE
31	09-Feb-2024	PARTS OF KOHAT ENCLAVE AND VASUDHA KUNJ PITAM PURA	1094	Other Outage	Unplanned Outage	09-Feb-2024	07:47	09-Feb-2024	08:05	19	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
32	09-Feb-2024	PARTS OF KOHAT ENCLAVE AND VASUDHA KUNJ PITAM PURA	92	Other Outage	Unplanned Outage	09-Feb-2024	10:40	09-Feb-2024	15:46	306	0.00085	FORCE MAJEURE/EXTERNAL FACTORS
33	09-Feb-2024	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	417	Other Outage	Planned Outage	09-Feb-2024	12:30	09-Feb-2024	14:22	111	0.00071	PLANNED OUTAGE
34	11-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	9	160 kVA	Planned Outage	11-Feb-2024	07:04	11-Feb-2024	09:01	117	0.00003	PLANNED OUTAGE
35	12-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	18	250 kVA	Planned Outage	12-Feb-2024	06:59	12-Feb-2024	08:25	86	0.00024	PLANNED OUTAGE
36	12-Feb-2024	PARTS OF JHULA LAL NO-1, A BLOCK LOK VIHAR PITAM PURA	277	990 kVA	Planned Outage	12-Feb-2024	10:51	12-Feb-2024	13:09	138	0.00058	PLANNED OUTAGE
37	12-Feb-2024	PARTS OF JHULA LAL NO-1, A BLOCK LOK VIHAR PITAM PURA	123	630 kVA	Planned Outage	12-Feb-2024	14:07	12-Feb-2024	15:46	99	0.00014	PLANNED OUTAGE
38	13-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	2	160 kVA	Planned Outage	13-Feb-2024	07:19	13-Feb-2024	08:56	97	0.00013	PLANNED OUTAGE
39	13-Feb-2024	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	420	Other Outage	Planned Outage	13-Feb-2024	10:42	13-Feb-2024	14:46	244	0.00034	PLANNED OUTAGE
40	13-Feb-2024	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL,KP PLINTH, PART OF MD,DPCP BLOCK PITAM PURA	154	630 kVA	Planned Outage	13-Feb-2024	10:54	13-Feb-2024	13:39	165	0.00023	PLANNED OUTAGE
41	13-Feb-2024	PARTS OF DUDIYAL APPTT.,MADHUBAN CHOCK DDA PUMP HOUSE.,MADHUBAN APPTT.DAKSHANI DELHI APPTT. RAMA MKT., CHUPAL VILLAGE PITAMPURA..AND PART OF B BLOCK SARASWATI VIHAR. PITAM PURA	60	Other Outage	Unplanned Outage	13-Feb-2024	11:57	13-Feb-2024	12:40	43	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
42	13-Feb-2024	PARTS OF JHULA LAL NO-1, A BLOCK LOK VIHAR PITAM PURA	86	630 kVA	Planned Outage	13-Feb-2024	14:09	13-Feb-2024	16:33	144	0.00008	PLANNED OUTAGE
43	13-Feb-2024	PARTS OF GD, JD, FD, HD BLOCK PITAM PURA	1319	Other Outage	Unplanned Outage	13-Feb-2024	15:31	13-Feb-2024	15:45	14	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
44	14-Feb-2024	PARTS OF A-BLOCK MANGOLPURI INDUSTRIAL AREA AND PARTS OF BC-BLOCK MANGOLPURI INDUSTRIAL AREA. PITAM PURA	24	Other Outage	Planned Outage	14-Feb-2024	10:34	14-Feb-2024	16:25	351	0.00117	PSD ON INDUSTRIAL WEEKLY OFF

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
45	14-Feb-2024	PARTS OF AP-1 BLOCK PITAM PURA	146	630 kVA	Planned Outage	14-Feb-2024	10:49	14-Feb-2024	12:15	86	0.00012	PLANNED OUTAGE
46	14-Feb-2024	PARTS OF SIRI NAGAR KHATTE WALA, M BLOCK SHAKURPUR, SAMRAT ENCLAVE, A - BLOCK J.J. COLONY, RAJDHANI ENCLAVE, SIRI NAGAR GURUDWARA PITAM PURA	133	400 kVA	Planned Outage	14-Feb-2024	14:07	14-Feb-2024	15:57	110	0.00037	PLANNED OUTAGE
47	15-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	4	160 kVA	Planned Outage	15-Feb-2024	06:41	15-Feb-2024	07:46	65	0.00002	PLANNED OUTAGE
48	15-Feb-2024	PART OF NO-8 MIA PH-2 PITAM PURA	6	Other Outage	Unplanned Outage	15-Feb-2024	08:35	15-Feb-2024	09:23	48	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
49	16-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	8	160 kVA	Planned Outage	16-Feb-2024	07:15	16-Feb-2024	09:06	111	0.00003	PLANNED OUTAGE
50	16-Feb-2024	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR. PITAM PURA	142	630 kVA	Planned Outage	16-Feb-2024	10:29	16-Feb-2024	11:32	63	0.00040	PLANNED OUTAGE
51	16-Feb-2024	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR. PITAM PURA	208	630 kVA	Planned Outage	16-Feb-2024	11:34	16-Feb-2024	12:12	38	0.00027	PLANNED OUTAGE
52	16-Feb-2024	PART OF E-126 PITAM PURA	4	160 kVA	Unplanned Outage	16-Feb-2024	11:34	16-Feb-2024	12:00	26	0.00001	EODB COMPLIANCE
53	16-Feb-2024	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	123	Other Outage	Unplanned Outage	16-Feb-2024	14:00	16-Feb-2024	14:20	20	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
54	16-Feb-2024	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR. PITAM PURA	199	630 kVA	Planned Outage	16-Feb-2024	14:35	16-Feb-2024	15:47	72	0.00006	PLANNED OUTAGE
55	17-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	2	160 kVA	Planned Outage	17-Feb-2024	07:17	17-Feb-2024	08:59	102	0.00006	PLANNED OUTAGE
56	17-Feb-2024	PARTS OF MULTANI MOHALLA, PART OF RANI BAGH, PART OF COMMERCIAL COMPLEX, PART OF MAHENDRA PARK PITAM PURA	621	Other Outage	Planned Outage	17-Feb-2024	10:28	17-Feb-2024	12:32	124	0.00045	PLANNED OUTAGE
57	17-Feb-2024	PARTS OF MULTANI MOHALLA, PART OF RANI BAGH, PART OF COMMERCIAL COMPLEX, PART OF MAHENDRA PARK PITAM PURA	554	990 kVA	Planned Outage	17-Feb-2024	14:46	17-Feb-2024	16:09	83	0.00060	PLANNED OUTAGE
58	17-Feb-2024	PART OF A-12 MIA PH-2 PITAM PURA	5	315 kVA	Unplanned Outage	17-Feb-2024	15:55	17-Feb-2024	16:41	46	0.00001	EODB COMPLIANCE
59	18-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	6	315 kVA	Planned Outage	18-Feb-2024	06:57	18-Feb-2024	08:24	87	0.00005	PLANNED OUTAGE
60	18-Feb-2024	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR. PITAM PURA	1792	Other Outage	Unplanned Outage	18-Feb-2024	09:52	18-Feb-2024	10:14	22	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
61	19-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	18	100 kVA	Planned Outage	19-Feb-2024	06:47	19-Feb-2024	07:47	60	0.00002	PLANNED OUTAGE
62	19-Feb-2024	PARTS OF KU, VP, MP, UP, BLOCK PITAM PURA	416	Other Outage	Planned Outage	19-Feb-2024	11:09	19-Feb-2024	12:40	91	0.00013	PLANNED OUTAGE
63	19-Feb-2024	PARTS OF B-1 MIA PHASE-2 PITAM PURA	60	Other Outage	Unplanned Outage	19-Feb-2024	13:26	19-Feb-2024	13:55	29	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
64	20-Feb-2024	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	178	Other Outage	Unplanned Outage	20-Feb-2024	10:30	20-Feb-2024	11:07	37	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
65	20-Feb-2024	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR PITAM PURA	263	990 kVA	Planned Outage	20-Feb-2024	10:42	20-Feb-2024	12:48	126	0.00042	PLANNED OUTAGE
66	20-Feb-2024	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR PITAM PURA	64	315 kVA	Planned Outage	20-Feb-2024	14:14	20-Feb-2024	16:10	116	0.00039	PLANNED OUTAGE
67	21-Feb-2024	PARTS OF BU SFS, PU, NU, MU BLOCK PITAM PURA	199	630 kVA	Planned Outage	21-Feb-2024	07:03	21-Feb-2024	09:00	117	0.00016	PLANNED OUTAGE
68	21-Feb-2024	PARTS OF KOHAT ENCLAVE AND VASUDHA KUNJ PITAM PURA	40	400 kVA	Planned Outage	21-Feb-2024	10:48	21-Feb-2024	12:31	103	0.00034	PLANNED OUTAGE
69	21-Feb-2024	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2 PITAM PURA	194	Other Outage	Planned Outage	21-Feb-2024	11:37	21-Feb-2024	17:27	349	0.00019	PSD ON INDUSTRIAL WEEKLY OFF

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
70	21-Feb-2024	PARTS OF P P JEWELLERS, MAX HOSPITAL, BIG JOS, NETAJI SUBHASH PALACE, H-1 SS PITAM PURA	285	630 kVA	Planned Outage	21-Feb-2024	14:33	21-Feb-2024	16:00	87	0.00012	PLANNED OUTAGE
71	21-Feb-2024	PART OF A-BLOCK MANGOLPURI INDUSTRIAL PITAM PURA	4	315 kVA	Unplanned Outage	21-Feb-2024	15:22	21-Feb-2024	15:43	21	0.00001	EODB COMPLIANCE
72	22-Feb-2024	PART OF NARENDRA AUTO WORK HOUSE PITAM PURA	14	160 kVA	Planned Outage	22-Feb-2024	06:55	22-Feb-2024	09:19	144	0.00008	PLANNED OUTAGE
73	22-Feb-2024	PARTS OF ZP BLOCK SCHOOL , YP & TP BLOCK PITAM PURA	220	400 kVA	Planned Outage	22-Feb-2024	07:07	22-Feb-2024	09:19	132	0.00037	PLANNED OUTAGE
74	22-Feb-2024	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	276	Other Outage	Planned Outage	22-Feb-2024	10:29	22-Feb-2024	13:54	205	0.00034	PLANNED OUTAGE
75	22-Feb-2024	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT, LOK VIHAR A BLOCK, PART OF CHANDER LOK PITAM PURA	89	400 kVA	Planned Outage	22-Feb-2024	10:34	22-Feb-2024	13:04	150	0.00008	PLANNED OUTAGE
76	22-Feb-2024	PARTS OF AP-1 BLOCK PITAM PURA	384	630 kVA	Planned Outage	22-Feb-2024	14:11	22-Feb-2024	15:30	79	0.00057	PLANNED OUTAGE
77	22-Feb-2024	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR PITAM PURA	425	630 kVA	Planned Outage	22-Feb-2024	15:00	22-Feb-2024	16:54	114	0.00082	PLANNED OUTAGE
78	23-Feb-2024	PARTS OF ANAND VIHAR, PART OF SHAKTI VIHAR, PART OF E & C BLOCK SARSWATI VIHAR, C BLOCK COMMUNITY CENTER MKT. PITAM PURA	663	Other Outage	Unplanned Outage	23-Feb-2024	02:07	23-Feb-2024	02:30	23	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
79	23-Feb-2024	PART OF NO-8 MIA PH-2 PITAM PURA	2	250 kVA	Planned Outage	23-Feb-2024	07:10	23-Feb-2024	08:45	95	0.00003	PLANNED OUTAGE
80	23-Feb-2024	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR. PITAM PURA	245	630 kVA	Planned Outage	23-Feb-2024	10:49	23-Feb-2024	13:02	133	0.00018	PLANNED OUTAGE
81	23-Feb-2024	PARTS OF MAHENDRA PARK AND RAMLILA GROUND PITAM PURA	763	990 kVA	Planned Outage	23-Feb-2024	11:41	23-Feb-2024	14:12	151	0.00063	PLANNED OUTAGE
82	23-Feb-2024	PARTS OF SADBHAWANA APPARTMENT. BANK VIHAR, MCD PUMP HOUSE NEAR AJAY APPARTMENT, B-BLOCK PUSHPANJLI, TARUN ENCLAVE PITAM PURA	549	Other Outage	Unplanned Outage	23-Feb-2024	19:51	23-Feb-2024	20:12	20	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
83	24-Feb-2024	PART OF NO-8 MIA PH-2 PITAM PURA	5	400 kVA	Planned Outage	24-Feb-2024	07:24	24-Feb-2024	09:07	103	0.00006	PLANNED OUTAGE
84	24-Feb-2024	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	110	Other Outage	Planned Outage	24-Feb-2024	11:36	24-Feb-2024	13:27	111	0.00009	PLANNED OUTAGE
85	25-Feb-2024	PART OF NO-8 MIA PH-2 PITAM PURA	5	160 kVA	Planned Outage	25-Feb-2024	07:08	25-Feb-2024	08:20	72	0.00002	PLANNED OUTAGE
86	25-Feb-2024	PART OF BHAGWAN MAHAVIR STAFF QTRS PITAM PURA	10	Other Outage	Unplanned Outage	25-Feb-2024	13:37	25-Feb-2024	16:08	151	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
87	25-Feb-2024	PARTS OF BHAGWAN MAHAVIR HOSPITAL, KEHSAV MAHAVIDYALAYA,BHAGWAN MAHAVIR STAFF QTRS PITAM PURA	106	Other Outage	Unplanned Outage	25-Feb-2024	13:41	25-Feb-2024	14:00	19	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
88	25-Feb-2024	PART OF BHAGWAN MAHAVIR STAFF QTRS PITAM PURA	10	Other Outage	Unplanned Outage	25-Feb-2024	13:41	25-Feb-2024	15:05	84	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
89	25-Feb-2024	PARTS OF RAJA ENCLAVE, ASHIYANA APPARTMENT, MANDAKNI APPARTMENT, EMINABAD MARKET, EMINABAD APPARTMENT, RAJASTHALI APPARTMENT, PART OF PITAMPURA VILLAGE PITAM PURA	1086	Other Outage	Unplanned Outage	25-Feb-2024	17:27	25-Feb-2024	17:57	30	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
90	25-Feb-2024	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2 PITAM PURA	131	Other Outage	Unplanned Outage	25-Feb-2024	21:22	26-Feb-2024	08:40	678	0.00094	FORCE MAJEURE/EXTERNAL FACTORS
91	25-Feb-2024	PARTS OF POLICE COMPLAX, PUSHPANJALI , TARUN ENCLAVE PITAM PURA	1105	Other Outage	Unplanned Outage	25-Feb-2024	22:19	25-Feb-2024	22:50	31	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
92	25-Feb-2024	PARTS OF POLICE COMPLAX, PUSHPANJALI , TARUN ENCLAVE PITAM PURA	81	Other Outage	Unplanned Outage	25-Feb-2024	22:19	25-Feb-2024	23:00	41	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
93	25-Feb-2024	PARTS OF POLICE COMPLAX, PUSHPANJALI , TARUN ENCLAVE PITAM PURA	225	Other Outage	Unplanned Outage	25-Feb-2024	22:19	25-Feb-2024	23:10	51	0.00006	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
94	25-Feb-2024	PART OF TARUN ENCLAVE PITAM PURA	1	Other Outage	Unplanned Outage	25-Feb-2024	22:19	26-Feb-2024	02:17	238	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
95	25-Feb-2024	PART OF TARUN ENCLAVE PITAM PURA	9	Other Outage	Unplanned Outage	25-Feb-2024	22:19	26-Feb-2024	02:18	239	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
96	26-Feb-2024	PART OF NO-8 MIA PH-2 PITAM PURA	7	400 kVA	Planned Outage	26-Feb-2024	06:54	26-Feb-2024	08:05	71	0.00004	PLANNED OUTAGE
97	26-Feb-2024	PARTS OF NO-8 MIA PH-2 PITAM PURA	189	Other Outage	Unplanned Outage	26-Feb-2024	08:32	26-Feb-2024	09:00	28	0.00005	INTERRUPTION DUE TO FAULT
98	26-Feb-2024	PARTS OF B-1 MIA PHASE-2 PITAM PURA	60	Other Outage	Unplanned Outage	26-Feb-2024	08:47	26-Feb-2024	08:54	7	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
99	26-Feb-2024	PARTS OF GD, JD, FD, HD BLOCK PITAM PURA	107	630 kVA	Planned Outage	26-Feb-2024	11:05	26-Feb-2024	13:33	148	0.00053	PLANNED OUTAGE
100	26-Feb-2024	PARTS OF GD, JD, FD, HD BLOCK PITAM PURA	1059	Other Outage	Unplanned Outage	26-Feb-2024	11:27	26-Feb-2024	12:05	37	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
101	26-Feb-2024	PARTS OF GD, JD, FD, HD BLOCK PITAM PURA	153	Other Outage	Unplanned Outage	26-Feb-2024	11:27	26-Feb-2024	12:11	44	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
102	26-Feb-2024	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	194	630 kVA	Planned Outage	26-Feb-2024	14:11	26-Feb-2024	16:26	135	0.00011	PLANNED OUTAGE
103	27-Feb-2024	PARTS OF BHAGWAN MAHAVIR HOSPITAL, KEHSAV MAHAVIDYALAYA,BHAGWAN MAHAVIR STAFF QTRS PITAM PURA	106	Other Outage	Unplanned Outage	27-Feb-2024	05:56	27-Feb-2024	06:28	32	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
104	27-Feb-2024	PART OF BHAGWAN MAHAVIR STAFF QTRS PITAM PURA	10	Other Outage	Unplanned Outage	27-Feb-2024	05:56	27-Feb-2024	07:56	120	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
105	27-Feb-2024	PARTS OF A, B, C, D BLOCK SARASWATI VIHAR PITAM PURA	2397	Other Outage	Unplanned Outage	27-Feb-2024	06:21	27-Feb-2024	06:53	31	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
106	27-Feb-2024	PARTS OF KP COMMERCIAL COMPLEX, TU, MP, LP, JP, KP, HP BLOCK PITAM PURA	123	630 kVA	Planned Outage	27-Feb-2024	10:28	27-Feb-2024	12:11	103	0.00066	PLANNED OUTAGE
107	27-Feb-2024	PART OF SADBRAWANA APPARTMENT PITAM PURA	1	Other Outage	Unplanned Outage	27-Feb-2024	10:51	27-Feb-2024	11:45	54	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
108	27-Feb-2024	PARTS OF SANDESH VIHAR PSS, NISHANT KUNI, POLICE COLONY, ROHIT KUNI, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS PITAM PURA	158	630 kVA	Planned Outage	27-Feb-2024	14:00	27-Feb-2024	16:34	154	0.00098	PLANNED OUTAGE
109	28-Feb-2024	PART OF NO-8 MIA PH-2 PITAM PURA	3	250 kVA	Planned Outage	28-Feb-2024	07:06	28-Feb-2024	08:38	92	0.00003	PSD ON INDUSTRIAL WEEKLY OFF
110	28-Feb-2024	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK PITAM PURA	178	Other Outage	Planned Outage	28-Feb-2024	10:30	28-Feb-2024	16:54	384	0.00053	PSD ON INDUSTRIAL WEEKLY OFF
111	28-Feb-2024	PARTS OF SIRI NAGAR KHATTE WALA, M BLOCK SHAKURPUR, SAMRAT ENCLAVE, A - BLOCK J.J. COLONY, RAJDHANI ENCLAVE, SIRI NAGAR GURUDWARA PITAM PURA	2163	Other Outage	Unplanned Outage	28-Feb-2024	15:04	28-Feb-2024	16:26	81	0.00048	FORCE MAJEURE/EXTERNAL FACTORS
112	29-Feb-2024	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR. PITAM PURA	189	630 kVA	Planned Outage	29-Feb-2024	11:14	29-Feb-2024	12:37	83	0.00005	PLANNED OUTAGE
113	29-Feb-2024	PARTS OF VAISHALI, KD, BP, AP, SACHDEVA PUBLIC SCHOOL,KP PLINTH, PART OF MD,DPCP BLOCK PITAM PURA	169	630 kVA	Planned Outage	29-Feb-2024	14:15	29-Feb-2024	15:45	90	0.00055	PLANNED OUTAGE
ROHINI												
1	01-Feb-2024	PARTS OF SECTOR 11 , A BLK ,B BLK AND C-BLK ROHINI	1983	Other Outage	Unplanned Outage	01-Feb-2024	00:58	01-Feb-2024	01:46	47	0.00050	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF SECTOR 11 , A BLK ,B BLK AND C-BLK ROHINI	2759	Other Outage	Unplanned Outage	01-Feb-2024	04:59	01-Feb-2024	05:15	15	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PART OF SECTOR 11 ROHINI	1	Other Outage	Unplanned Outage	01-Feb-2024	04:59	01-Feb-2024	09:01	242	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF UTSAV APPT. BLK- F LIG FLATS SEC 18, BLK- E PKT 3 SEC 18 ROHINI	454	Other Outage	Unplanned Outage	01-Feb-2024	05:14	01-Feb-2024	06:18	64	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF UTSAV APPT. BLK- F LIG FLATS SEC 18, BLK- E PKT 3 SEC 18 ROHINI	192	Other Outage	Unplanned Outage	01-Feb-2024	05:14	01-Feb-2024	06:52	98	0.00011	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
6	01-Feb-2024	PARTS OF UTSAV APPT. BLK- F LIG FLATS SEC 18, BLK- E PKT 3 SEC 18 ROHINI	454	Other Outage	Unplanned Outage	01-Feb-2024	12:35	01-Feb-2024	13:20	45	0.00031	FORCE MAJEURE/EXTERNAL FACTORS
7	01-Feb-2024	PART OF RITHALA SEWAGE PUMPING STN. ROHINI	2	160 kVA	Unplanned Outage	01-Feb-2024	16:04	01-Feb-2024	16:28	24	0.00001	EODB COMPLIANCE
8	02-Feb-2024	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	781	Other Outage	Unplanned Outage	02-Feb-2024	15:58	02-Feb-2024	16:50	51	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
9	03-Feb-2024	PARTS OF UTSAV APPT. BLK- F LIG FLATS SEC 18, BLK- E PKT 3 SEC 18 ROHINI	192	Other Outage	Planned Outage	03-Feb-2024	11:02	03-Feb-2024	15:43	281	0.00094	PLANNED OUTAGE
10	03-Feb-2024	PARTS OF LAL JYOTI APPT & GULAB VIHAR, SEC-9 ROHINI	142	Other Outage	Planned Outage	03-Feb-2024	11:30	03-Feb-2024	16:22	292	0.00024	PLANNED OUTAGE
11	03-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	846	Other Outage	Unplanned Outage	03-Feb-2024	17:00	03-Feb-2024	17:50	49	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
12	03-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	838	Other Outage	Unplanned Outage	03-Feb-2024	17:00	03-Feb-2024	18:11	70	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
13	03-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	48	Other Outage	Unplanned Outage	03-Feb-2024	17:00	03-Feb-2024	18:32	92	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
14	03-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	80	Other Outage	Unplanned Outage	03-Feb-2024	17:00	03-Feb-2024	18:40	99	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
15	03-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	33	Other Outage	Unplanned Outage	03-Feb-2024	17:00	03-Feb-2024	18:40	99	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
16	04-Feb-2024	PARTS OF C & B BLOCK SEC-16 ROHINI	2552	Other Outage	Unplanned Outage	04-Feb-2024	10:02	04-Feb-2024	10:08	6	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
17	05-Feb-2024	PARTS OF LAL JYOTI APPT & GULAB VIHAR, SEC-9 ROHINI	142	630 kVA	Planned Outage	05-Feb-2024	10:21	05-Feb-2024	16:02	341	0.00142	PLANNED OUTAGE
18	06-Feb-2024	PARTS OF BOOSTER PUMP ROHINI	57	Other Outage	Planned Outage	06-Feb-2024	11:24	06-Feb-2024	13:17	113	0.00031	PLANNED OUTAGE
19	06-Feb-2024	PARTS OF LAL JYOTI APPT & GULAB VIHAR, SEC-9 ROHINI	142	630 kVA	Planned Outage	06-Feb-2024	12:32	06-Feb-2024	16:38	246	0.00109	PLANNED OUTAGE
20	06-Feb-2024	PARTS OF SECTOR 24 RITHALA ROHINI	263	Other Outage	Unplanned Outage	06-Feb-2024	14:19	06-Feb-2024	14:59	39	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
21	06-Feb-2024	PARTS OF SECTOR 24 RITHALA ROHINI	928	Other Outage	Unplanned Outage	06-Feb-2024	14:19	06-Feb-2024	15:20	60	0.00015	FORCE MAJEURE/EXTERNAL FACTORS
22	06-Feb-2024	PARTS OF E,F POCKETS SEC-7, NAHARPUR VILLAGE, CSC-9,CSC-1 SEC=7 ROHINI	439	Other Outage	Unplanned Outage	06-Feb-2024	15:02	06-Feb-2024	16:05	63	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
23	06-Feb-2024	PART OF BOOSTER PUMP ROHINI	1	Other Outage	Planned Outage	06-Feb-2024	15:21	06-Feb-2024	17:04	103	0.00003	PLANNED OUTAGE
24	06-Feb-2024	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	919	Other Outage	Unplanned Outage	06-Feb-2024	17:03	06-Feb-2024	17:40	37	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
25	07-Feb-2024	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18 ROHINI	509	990 kVA	Planned Outage	07-Feb-2024	11:11	07-Feb-2024	12:50	99	0.00014	PLANNED OUTAGE
26	07-Feb-2024	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18 ROHINI	324	630 kVA	Planned Outage	07-Feb-2024	14:20	07-Feb-2024	16:04	104	0.00012	PLANNED OUTAGE
27	08-Feb-2024	PARTS OF PART AREA OF SEC-16 ROHINI	141	630 kVA	Planned Outage	08-Feb-2024	11:02	08-Feb-2024	12:47	105	0.00012	PLANNED OUTAGE
28	08-Feb-2024	PARTS OF PART AREA OF SEC-16 ROHINI	354	630 kVA	Planned Outage	08-Feb-2024	13:30	08-Feb-2024	15:40	130	0.00029	PLANNED OUTAGE
29	08-Feb-2024	PARTS OF N N MALL, MANGLAM PLACE, CHANDNI MKT ROHINI	49	630 kVA	Planned Outage	08-Feb-2024	14:33	08-Feb-2024	16:30	117	0.00016	PLANNED OUTAGE
30	09-Feb-2024	PARTS OF MCD QTRS. ROHINI	1200	Other Outage	Unplanned Outage	09-Feb-2024	05:45	09-Feb-2024	06:10	25	0.00026	FORCE MAJEURE/EXTERNAL FACTORS
31	09-Feb-2024	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION. ROHINI	174	Other Outage	Planned Outage	09-Feb-2024	11:10	09-Feb-2024	14:20	190	0.00121	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
32	09-Feb-2024	PARTS OF A-BLOCK PRASHANT VIHAR, B-BLOCK PRASHANT VIHAR, LANCER CONVENT SCHOOL ROHINI	544	990 kVA	Planned Outage	09-Feb-2024	11:24	09-Feb-2024	16:35	311	0.00052	PLANNED OUTAGE
33	10-Feb-2024	PARTS OF SECTOR - 11 ROHINI (PARTLY), H1 TO H5 BHAGWAN PARSHURAM ENGG COLLAGE, MCD OFFICE SEC-17 ROHINI	31	Other Outage	Planned Outage	10-Feb-2024	10:36	10-Feb-2024	12:11	95	0.00029	PLANNED OUTAGE
34	10-Feb-2024	PARTS OF D AND E BLK SEC-15 ROHINI	618	Other Outage	Planned Outage	10-Feb-2024	11:15	10-Feb-2024	14:24	189	0.00137	PLANNED OUTAGE
35	10-Feb-2024	PARTS OF B-BLOCK AVANTIKA & DDA FLATS ROHINI	1564	Other Outage	Planned Outage	10-Feb-2024	12:27	10-Feb-2024	16:35	248	0.00110	PLANNED OUTAGE
36	12-Feb-2024	PARTS OF SECTOR 24 RITHALA ROHINI	480	Other Outage	Unplanned Outage	12-Feb-2024	08:42	12-Feb-2024	09:24	42	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
37	12-Feb-2024	PARTS OF MANGOL PUR KHURD NO-6 ROHINI	78	Other Outage	Planned Outage	12-Feb-2024	11:50	12-Feb-2024	16:16	266	0.00118	PLANNED OUTAGE
38	12-Feb-2024	PARTS OF A-BLOCK PRASHANT VIHAR, B-BLOCK PRASHANT VIHAR, LANCER CONVENT SCHOOL ROHINI	421	1000 kVA	Planned Outage	12-Feb-2024	12:20	12-Feb-2024	14:17	117	0.00016	PLANNED OUTAGE
39	12-Feb-2024	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	209	Other Outage	Unplanned Outage	12-Feb-2024	14:12	12-Feb-2024	14:50	38	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
40	12-Feb-2024	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25, ROHINI	644	Other Outage	Unplanned Outage	12-Feb-2024	14:17	12-Feb-2024	14:40	23	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
41	12-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	80	Other Outage	Unplanned Outage	12-Feb-2024	15:30	12-Feb-2024	15:40	10	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
42	12-Feb-2024	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL ROHINI	33	Other Outage	Unplanned Outage	12-Feb-2024	15:30	12-Feb-2024	15:40	10	0.000003	FORCE MAJEURE/EXTERNAL FACTORS
43	13-Feb-2024	PARTS OF OLD VILLAGE BADLI,BADLI BUS STAND & PRIMARY SCHOOL ROHINI	589	Other Outage	Planned Outage	13-Feb-2024	11:33	13-Feb-2024	13:43	130	0.00022	PLANNED OUTAGE
44	13-Feb-2024	PART OF TELEPHONE EXCHANGE ROHINI	6	Other Outage	Unplanned Outage	13-Feb-2024	13:03	13-Feb-2024	14:02	59	0.00002	INTERRUPTION DUE TO FAULT
45	13-Feb-2024	PARTS OF OLD VILLAGE BADLI,BADLI BUS STAND & PRIMARY SCHOOL ROHINI	560	Other Outage	Planned Outage	13-Feb-2024	14:31	13-Feb-2024	16:21	110	0.00018	PLANNED OUTAGE
46	13-Feb-2024	PARTS OF BOOSTER PUMP,C-BLOCK SEC-19 & J.J. CLUSTER SEC-19, E BLOCK SEC-18 ROHINI	258	Other Outage	Unplanned Outage	13-Feb-2024	15:44	13-Feb-2024	16:50	66	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
47	14-Feb-2024	PARTS OF OLD VILLAGE BADLI,BADLI BUS STAND & PRIMARY SCHOOL ROHINI	85	Other Outage	Planned Outage	14-Feb-2024	11:29	14-Feb-2024	14:35	186	0.00052	PSD ON INDUSTRIAL WEEKLY OFF
48	14-Feb-2024	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK. ROHINI	1113	Other Outage	Unplanned Outage	14-Feb-2024	22:13	14-Feb-2024	22:30	17	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
49	15-Feb-2024	PART OF AMBEDKAR BHAWAN SECTOR 16 ROHINI	7	315 kVA	Planned Outage	15-Feb-2024	11:08	15-Feb-2024	12:53	105	0.00003	PLANNED OUTAGE
50	15-Feb-2024	PARTS OF BADLI JAI, JAIL COLONY, BADLI POLICE QTRS. SEWAGE PUMP SECTOR - 19 ROHINI	56	Other Outage	Planned Outage	15-Feb-2024	11:09	15-Feb-2024	16:23	314	0.00044	PLANNED OUTAGE
51	15-Feb-2024	PART OF JAPANI PARK ROHINI	2	315 kVA	Planned Outage	15-Feb-2024	14:24	15-Feb-2024	16:11	107	0.00003	PLANNED OUTAGE
52	15-Feb-2024	PARTS OF SECTOR-13 & BADLI RESIDENTIAL AREA ROHINI	513	Other Outage	Unplanned Outage	15-Feb-2024	15:44	15-Feb-2024	18:04	139	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
53	15-Feb-2024	PARTS OF A BLOCK SEC 16 ROHINI	2640	Other Outage	Unplanned Outage	15-Feb-2024	16:46	15-Feb-2024	16:50	3	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
54	16-Feb-2024	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18 ROHINI	213	Other Outage	Planned Outage	16-Feb-2024	11:06	16-Feb-2024	16:43	337	0.00056	PLANNED OUTAGE
55	16-Feb-2024	PART OF B BLOCK PRASHANT VIHAR ROHINI	5	Other Outage	Planned Outage	16-Feb-2024	11:50	16-Feb-2024	13:17	86	0.00002	PLANNED OUTAGE
56	16-Feb-2024	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18 ROHINI	48	Other Outage	Unplanned Outage	16-Feb-2024	12:38	16-Feb-2024	13:15	38	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
57	16-Feb-2024	PARTS OF B-BLOCK MASJID WALA, E-BLOCK AVANTIKA, M.R HOSPITAL, SEWAGE PUMP AVANTIKA ROHINI	309	630 kVA	Planned Outage	16-Feb-2024	14:45	16-Feb-2024	17:44	179	0.00114	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
58	17-Feb-2024	PART OF SPS DDA SEC-25 ROHINI	5	Other Outage	Planned Outage	17-Feb-2024	10:59	17-Feb-2024	15:05	246	0.00014	PLANNED OUTAGE
59	17-Feb-2024	PARTS OF POCKET-2, 10, 11, 12, 14 BLOCK-D SECTOR-8 ROHINI	430	630 kVA	Planned Outage	17-Feb-2024	12:04	17-Feb-2024	17:04	300	0.00125	PLANNED OUTAGE
60	17-Feb-2024	PARTS OF SECTOR - IV AVANTIKA ROHINI	2088	Other Outage	Unplanned Outage	17-Feb-2024	13:18	17-Feb-2024	13:40	21	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
61	18-Feb-2024	PART OF SPS DDA SEC-25 ROHINI	20	400 kVA	Planned Outage	18-Feb-2024	10:48	18-Feb-2024	13:44	176	0.00049	PLANNED OUTAGE
62	18-Feb-2024	PART OF SPS DDA SEC-25 ROHINI	4	990 kVA	Planned Outage	18-Feb-2024	10:53	18-Feb-2024	13:31	158	0.00022	PLANNED OUTAGE
63	19-Feb-2024	PARTS OF H-3 NO-2 SEC-18 ROHINI	538	Other Outage	Unplanned Outage	19-Feb-2024	06:29	19-Feb-2024	06:52	23	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
64	19-Feb-2024	PARTS OF AVANTIKA ROHINI	99	630 kVA	Planned Outage	19-Feb-2024	10:41	19-Feb-2024	12:36	115	0.00038	PLANNED OUTAGE
65	19-Feb-2024	PARTS OF E,F,H POCKETS SEC-7 ROHINI	415	Other Outage	Planned Outage	19-Feb-2024	11:31	19-Feb-2024	17:36	365	0.00051	PLANNED OUTAGE
66	19-Feb-2024	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION. ROHINI	220	400 kVA	Planned Outage	19-Feb-2024	14:22	19-Feb-2024	15:32	70	0.00045	PLANNED OUTAGE
67	19-Feb-2024	PARTS OF MCD QTRS. ROHINI	490	630 kVA	Planned Outage	19-Feb-2024	14:28	19-Feb-2024	16:31	123	0.00079	PLANNED OUTAGE
68	20-Feb-2024	PARTS OF MANGALAM PLACE 3, RING ROAD MALL, VIKAS SURYA ROHINI	34	630 kVA	Planned Outage	20-Feb-2024	10:38	20-Feb-2024	15:32	294	0.00098	PLANNED OUTAGE
69	20-Feb-2024	PARTS OF PART AREA OF SEC-16 ROHINI	579	Other Outage	Planned Outage	20-Feb-2024	11:26	20-Feb-2024	13:38	132	0.00044	PLANNED OUTAGE
70	20-Feb-2024	PART OF PARSHANT VIHAR ROHINI	11	Other Outage	Planned Outage	20-Feb-2024	11:54	20-Feb-2024	15:56	242	0.00013	PLANNED OUTAGE
71	20-Feb-2024	PARTS OF H-3 NO-2 SEC-18 ROHINI	29	315 kVA	Planned Outage	20-Feb-2024	14:08	20-Feb-2024	15:51	103	0.00029	PLANNED OUTAGE
72	20-Feb-2024	PARTS OF ONKARA, VARDHANMAN PLAZA, AGGERWAL CITY SQUARE, DTC DEPOT, DDA OFFICE, PETROL PUMP ROHINI	218	630 kVA	Planned Outage	20-Feb-2024	14:24	20-Feb-2024	16:27	123	0.00079	PLANNED OUTAGE
73	20-Feb-2024	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	83	Other Outage	Unplanned Outage	20-Feb-2024	23:23	20-Feb-2024	23:59	36	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
74	21-Feb-2024	PARTS OF AMBEDKAR BHAWAN SECTOR 16 ROHINI	212	Other Outage	Unplanned Outage	21-Feb-2024	00:30	21-Feb-2024	01:31	62	0.00017	FORCE MAJEURE/EXTERNAL FACTORS
75	21-Feb-2024	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18 ROHINI	62	Other Outage	Planned Outage	21-Feb-2024	11:28	21-Feb-2024	13:23	115	0.00006	PLANNED OUTAGE
76	21-Feb-2024	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK. ROHINI	664	Other Outage	Planned Outage	21-Feb-2024	11:59	21-Feb-2024	15:53	234	0.00150	PLANNED OUTAGE
77	21-Feb-2024	PARTS OF E,F POCKETS SEC-7, NAHARPUR VILLAGE, CSC-9,CSC-1 SEC=7 ROHINI	295	630 kVA	Planned Outage	21-Feb-2024	12:11	21-Feb-2024	14:38	147	0.00016	PLANNED OUTAGE
78	21-Feb-2024	PART OF SHIVAM APTT ROHINI	13	250 kVA	Planned Outage	21-Feb-2024	14:36	21-Feb-2024	15:57	81	0.00005	PLANNED OUTAGE
79	21-Feb-2024	PARTS OF CHANDNI MARKET AND AGGARWAL E-MALL ROHINI	619	Other Outage	Planned Outage	21-Feb-2024	15:03	21-Feb-2024	16:41	98	0.00022	PLANNED OUTAGE
80	22-Feb-2024	PARTS OF MCD QTRS. ROHINI	1038	Other Outage	Planned Outage	22-Feb-2024	11:08	22-Feb-2024	13:51	163	0.00054	PLANNED OUTAGE
81	22-Feb-2024	PART OF DC-1, SEC-10 ROHINI	2	Other Outage	Planned Outage	22-Feb-2024	11:24	22-Feb-2024	14:17	173	0.00005	PLANNED OUTAGE
82	22-Feb-2024	PARTS OF POKET 3& 4 ROHINI	458	Other Outage	Unplanned Outage	22-Feb-2024	14:36	22-Feb-2024	15:30	54	0.00006	FORCE MAJEURE/EXTERNAL FACTORS
83	22-Feb-2024	PARTS OF POKET 3& 4 ROHINI	756	Other Outage	Unplanned Outage	22-Feb-2024	14:36	22-Feb-2024	15:45	68	0.00008	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
84	22-Feb-2024	PARTS OF POKET 3& 4 ROHINI	843	Other Outage	Unplanned Outage	22-Feb-2024	14:36	22-Feb-2024	16:00	83	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
85	22-Feb-2024	PARTS OF H-3 NO-2 SEC-18 ROHINI	142	Other Outage	Unplanned Outage	22-Feb-2024	19:35	22-Feb-2024	20:22	47	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
86	22-Feb-2024	PARTS OF H-3 NO-2 SEC-18 ROHINI	41	Other Outage	Unplanned Outage	22-Feb-2024	19:36	22-Feb-2024	20:22	46	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
87	23-Feb-2024	PART OF JAIPUR GOLDEN HOSPITAL ROHINI	1	Other Outage	Planned Outage	23-Feb-2024	07:32	23-Feb-2024	09:11	99	0.00003	EODB COMPLIANCE
88	23-Feb-2024	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION. ROHINI	1068	Other Outage	Unplanned Outage	23-Feb-2024	09:59	23-Feb-2024	10:31	31	0.00022	INTERRUPTION DUE TO FAULT
89	23-Feb-2024	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION. ROHINI	1577	Other Outage	Unplanned Outage	23-Feb-2024	09:59	23-Feb-2024	12:18	139	0.00116	FORCE MAJEURE/EXTERNAL FACTORS
90	23-Feb-2024	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION. ROHINI	174	Other Outage	Unplanned Outage	23-Feb-2024	09:59	23-Feb-2024	14:16	256	0.00071	FORCE MAJEURE/EXTERNAL FACTORS
91	23-Feb-2024	PART OF 8/11 SEC-6 ROHINI	4	400 kVA	Planned Outage	23-Feb-2024	10:36	23-Feb-2024	13:18	162	0.00009	PLANNED OUTAGE
92	23-Feb-2024	PART OF PARSHANT VIHAR ROHINI	4	160 kVA	Unplanned Outage	23-Feb-2024	10:57	23-Feb-2024	12:47	110	0.00003	EODB COMPLIANCE
93	23-Feb-2024	PARTS OF TEMPO STAND WALA MANGOL PUR KALAN, KHATE WALA, MANGOLPURI POLICE STATION, PATHAR WALA, TALAB WALA ROHINI	64	Other Outage	Planned Outage	23-Feb-2024	11:28	23-Feb-2024	16:04	276	0.00077	PLANNED OUTAGE
94	23-Feb-2024	PARTS OF GANGA TRIVENI NO-1, NAVYUG, VIDYA VIHAR, BHAGYA LAKHSMI, G.D.GOENKA SCHOOL ROHINI	1298	Other Outage	Unplanned Outage	23-Feb-2024	13:54	23-Feb-2024	14:32	37	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
95	23-Feb-2024	PARTS OF GANGA TRIVENI NO-1, NAVYUG, VIDYA VIHAR, BHAGYA LAKHSMI, G.D.GOENKA SCHOOL ROHINI	691	Other Outage	Unplanned Outage	23-Feb-2024	14:32	23-Feb-2024	14:50	18	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
96	23-Feb-2024	PARTS OF GANGA TRIVENI NO-1, NAVYUG, VIDYA VIHAR, BHAGYA LAKHSMI, G.D.GOENKA SCHOOL ROHINI	191	Other Outage	Unplanned Outage	23-Feb-2024	14:32	23-Feb-2024	16:02	90	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
97	23-Feb-2024	PARTS OF SHIVAM APARTMENT AND DJB BLOCK-1 SECTRO-15 ROHINI	54	Other Outage	Unplanned Outage	23-Feb-2024	19:21	23-Feb-2024	19:48	27	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
98	25-Feb-2024	PARTS OF H-3 NO-2 SEC-18 ROHINI	355	Other Outage	Unplanned Outage	25-Feb-2024	10:37	25-Feb-2024	11:06	29	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
99	25-Feb-2024	PARTS OF H-3 NO-2 SEC-18 ROHINI	183	Other Outage	Unplanned Outage	25-Feb-2024	10:37	25-Feb-2024	11:24	47	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
100	25-Feb-2024	PARTS OF NALA WALA SECTOR-4 ROHINI	421	Other Outage	Unplanned Outage	25-Feb-2024	10:43	25-Feb-2024	11:32	49	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
101	25-Feb-2024	PARTS OF NALA WALA SECTOR-4 ROHINI	569	Other Outage	Unplanned Outage	25-Feb-2024	10:43	25-Feb-2024	11:38	56	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
102	26-Feb-2024	PARTS OF GANGA TRIVENI NO-1, NAVYUG, VIDYA VIHAR, BHAGYA LAKHSMI, G.D.GOENKA SCHOOL ROHINI	144	400 kVA	Planned Outage	26-Feb-2024	11:15	26-Feb-2024	13:04	109	0.00006	PLANNED OUTAGE
103	26-Feb-2024	PARTS OF TELEPHONE EXCHANGE SECTOR.- 3 ROHINI	1908	Other Outage	Unplanned Outage	26-Feb-2024	11:47	26-Feb-2024	12:39	52	0.00029	FORCE MAJEURE/EXTERNAL FACTORS
104	26-Feb-2024	PARTS OF GANGA TRIVENI NO-1, NAVYUG, VIDYA VIHAR, BHAGYA LAKHSMI, G.D.GOENKA SCHOOL ROHINI	103	315 kVA	Planned Outage	26-Feb-2024	14:08	26-Feb-2024	15:30	82	0.00005	PLANNED OUTAGE
105	26-Feb-2024	PART OF TELEPHONE EXCHANGE SECTOR- 3 ROHINI	1	Other Outage	Unplanned Outage	26-Feb-2024	15:29	26-Feb-2024	15:42	13	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
106	26-Feb-2024	PARTS OF SECTOR - 5 ROHINI	60	Other Outage	Unplanned Outage	26-Feb-2024	22:54	26-Feb-2024	23:30	36	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
107	26-Feb-2024	PARTS OF SECTOR - 5 ROHINI	45	Other Outage	Unplanned Outage	26-Feb-2024	22:54	26-Feb-2024	23:47	53	0.00007	FORCE MAJEURE/EXTERNAL FACTORS
108	26-Feb-2024	PART OF SECTOR - 5 ROHINI	5	Other Outage	Unplanned Outage	26-Feb-2024	22:54	27-Feb-2024	01:30	156	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
109	27-Feb-2024	PARTS OF POCKET-3 AND DDA MARKET SEC-13 ROHINI	463	Other Outage	Unplanned Outage	27-Feb-2024	03:30	27-Feb-2024	04:03	33	0.00005	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
110	27-Feb-2024	PARTS OF POCKET-3 AND DDA MARKET SEC-13 ROHINI	930	Other Outage	Unplanned Outage	27-Feb-2024	03:30	27-Feb-2024	04:06	36	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
111	27-Feb-2024	PARTS OF MCD QTRS. ROHINI	89	400 kVA	Planned Outage	27-Feb-2024	11:11	27-Feb-2024	13:54	163	0.00041	PLANNED OUTAGE
112	27-Feb-2024	PARTS OF POCKET - 7/23, DDA JAL BOARD WATER TANK. ROHINI	1101	Other Outage	Unplanned Outage	27-Feb-2024	12:40	27-Feb-2024	13:25	45	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
113	27-Feb-2024	PARTS OF LAL JYOTI APTT & GULAB VIHAR, SEC-9 ROHINI	169	Other Outage	Unplanned Outage	27-Feb-2024	15:04	27-Feb-2024	15:38	34	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
114	27-Feb-2024	PARTS OF LAL JYOTI APTT & GULAB VIHAR, SEC-9 ROHINI	1021	Other Outage	Unplanned Outage	27-Feb-2024	15:04	27-Feb-2024	16:00	56	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
115	27-Feb-2024	PART OF LAL JYOTI APTT ROHINI	1	Other Outage	Unplanned Outage	27-Feb-2024	15:04	27-Feb-2024	17:53	169	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
116	28-Feb-2024	PARTS OF SEC- 9 NORTH EX MALL, COMMUNITY CENTER & PART OF SECTOR - 14 ROHINI, PART OF PRASHANT VIHAR B ,C-BLK, RG COMPLEX SEC-14, PVR PRASHANT VIHAR, LSC -1 AND LSC 2 PRASHANT VIHAR ROHINI	92	Other Outage	Planned Outage	28-Feb-2024	11:21	28-Feb-2024	15:33	252	0.00077	PLANNED OUTAGE
117	29-Feb-2024	PARTS OF OLD VILLAGE BADLI,BADLI BUS STAND & PRIMARY SCHOOL ROHINI	2274	Other Outage	Unplanned Outage	29-Feb-2024	14:42	29-Feb-2024	14:58	16	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
118	29-Feb-2024	PARTS OF B-BLOCK AVANTIKA & DDA FLATS ROHINI	345	Other Outage	Unplanned Outage	29-Feb-2024	15:43	29-Feb-2024	17:17	94	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
119	29-Feb-2024	PARTS OF B-BLOCK AVANTIKA & DDA FLATS ROHINI	528	Other Outage	Unplanned Outage	29-Feb-2024	15:43	29-Feb-2024	18:00	137	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
SHALIMAR BAGH												
1	01-Feb-2024	PARTS OF WAZIRABAD VILLAGE , GALI NO. 1,2,3 4,5, 6, 8,, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	1975	Other Outage	Unplanned Outage	01-Feb-2024	01:12	01-Feb-2024	01:33	21	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
2	01-Feb-2024	PARTS OF WAZIRABAD VILLAGE , GALI NO. 1,2,3 4,5, 6, 8,, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	113	Other Outage	Unplanned Outage	01-Feb-2024	01:12	01-Feb-2024	02:25	73	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
3	01-Feb-2024	PARTS OF C&D BLOCK MUKUNDPUR DRAIN SHALIMAR BAGH	1344	Other Outage	Unplanned Outage	01-Feb-2024	02:39	01-Feb-2024	03:30	51	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
4	01-Feb-2024	PARTS OF BI BLOCK PSS SHALIMAR BAGH	917	Other Outage	Unplanned Outage	01-Feb-2024	06:28	01-Feb-2024	07:00	32	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
5	01-Feb-2024	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	885	Other Outage	Unplanned Outage	01-Feb-2024	08:00	01-Feb-2024	08:42	42	0.00023	FORCE MAJEURE/EXTERNAL FACTORS
6	01-Feb-2024	PART OF KAUSHIK ENCLAVE AND BURARI SHALIMAR BAGH	1	Other Outage	Planned Outage	01-Feb-2024	11:16	01-Feb-2024	15:44	268	0.00015	PLANNED OUTAGE
7	02-Feb-2024	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI SHALIMAR BAGH	1420	Other Outage	Unplanned Outage	02-Feb-2024	05:33	02-Feb-2024	06:15	42	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
8	02-Feb-2024	PARTS OF JAI HIND SOCIETY SHALIMAR BAGH	123	Other Outage	Unplanned Outage	02-Feb-2024	12:14	02-Feb-2024	12:32	18	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
9	02-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	1223	Other Outage	Unplanned Outage	02-Feb-2024	14:45	02-Feb-2024	15:23	39	0.00027	FORCE MAJEURE/EXTERNAL FACTORS
10	02-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	117	Other Outage	Unplanned Outage	02-Feb-2024	14:45	02-Feb-2024	16:10	85	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
11	02-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	116	Other Outage	Unplanned Outage	02-Feb-2024	14:45	02-Feb-2024	16:10	85	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
12	03-Feb-2024	PARTS OF BURARI TOMAR COLONY SHALIMAR BAGH	2266	Other Outage	Unplanned Outage	03-Feb-2024	10:24	03-Feb-2024	10:46	22	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
13	03-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	122	Other Outage	Planned Outage	03-Feb-2024	11:24	03-Feb-2024	16:10	286	0.00016	PLANNED OUTAGE
14	03-Feb-2024	PARTS OF BHAGAT COLONY SHALIMAR BAGH	866	Other Outage	Planned Outage	03-Feb-2024	11:29	03-Feb-2024	16:51	322	0.00206	PLANNED OUTAGE
15	03-Feb-2024	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	916	Other Outage	Planned Outage	03-Feb-2024	11:46	03-Feb-2024	14:31	165	0.00037	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
16	03-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	176	Other Outage	Planned Outage	03-Feb-2024	12:01	03-Feb-2024	16:25	264	0.00029	PLANNED OUTAGE
17	03-Feb-2024	PARTS OF RUN - 27, D - 22, CETP PLANT, RUN - 32, RUN - 33 SHALIMAR BAGH	37	Other Outage	Unplanned Outage	03-Feb-2024	13:10	03-Feb-2024	13:17	6	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
18	03-Feb-2024	PART OF JAGAT PUR EXT. NO.2 SHALIMAR BAGH	19	Other Outage	Unplanned Outage	03-Feb-2024	16:42	03-Feb-2024	17:25	43	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
19	03-Feb-2024	PART OF RAJASTHANI UDHYOG NAGAR SHALIMAR BAGH	2	Other Outage	Unplanned Outage	03-Feb-2024	17:33	03-Feb-2024	18:51	78	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
20	04-Feb-2024	PARTS OF DLF MALL SHALIMAR BAGH	281	Other Outage	Unplanned Outage	04-Feb-2024	10:18	04-Feb-2024	10:35	16	0.00005	INTERRUPTION DUE TO FAULT
21	04-Feb-2024	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK SHALIMAR BAGH	2208	Other Outage	Unplanned Outage	04-Feb-2024	12:44	04-Feb-2024	13:35	50	0.00028	INTERRUPTION DUE TO FAULT
22	04-Feb-2024	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK SHALIMAR BAGH	2208	Other Outage	Unplanned Outage	04-Feb-2024	17:48	04-Feb-2024	18:04	16	0.00010	INTERRUPTION DUE TO FAULT
23	05-Feb-2024	PARTS OF SANGAM VIHAR GALI NO. 1,2,3 4,, 5,6,7,8,9. SHALIMAR BAGH	3340	Other Outage	Unplanned Outage	05-Feb-2024	03:39	05-Feb-2024	04:00	21	0.00019	FORCE MAJEURE/EXTERNAL FACTORS
24	05-Feb-2024	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK SHALIMAR BAGH	2208	Other Outage	Unplanned Outage	05-Feb-2024	10:18	05-Feb-2024	10:47	28	0.00023	INTERRUPTION DUE TO FAULT
25	05-Feb-2024	PARTS OF HATHIWALA SANT NAGAR SHALIMAR BAGH	493	Other Outage	Planned Outage	05-Feb-2024	11:14	05-Feb-2024	14:11	177	0.00128	PLANNED OUTAGE
26	05-Feb-2024	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	673	Other Outage	Planned Outage	05-Feb-2024	11:17	05-Feb-2024	15:21	244	0.00081	PLANNED OUTAGE
27	05-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	117	Other Outage	Unplanned Outage	05-Feb-2024	19:33	05-Feb-2024	22:12	159	0.00035	FORCE MAJEURE/EXTERNAL FACTORS
28	06-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	463	Other Outage	Unplanned Outage	06-Feb-2024	02:27	06-Feb-2024	03:10	42	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
29	06-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	1115	Other Outage	Unplanned Outage	06-Feb-2024	02:27	06-Feb-2024	03:46	78	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
30	06-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	464	Other Outage	Unplanned Outage	06-Feb-2024	02:27	06-Feb-2024	04:00	93	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
31	06-Feb-2024	PARTS OF WAZIRABAD VILLAGE , GALI NO. 1,2,3 4,5, 6, 8,, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	1391	Other Outage	Planned Outage	06-Feb-2024	11:06	06-Feb-2024	16:06	300	0.00133	PLANNED OUTAGE
32	07-Feb-2024	PARTS OF NEEL KANTH APPARTMENT. SHALIMAR BAGH	85	Other Outage	Unplanned Outage	07-Feb-2024	05:37	07-Feb-2024	06:41	64	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
33	07-Feb-2024	PARTS OF NEEL KANTH APPARTMENT. SHALIMAR BAGH	1243	Other Outage	Unplanned Outage	07-Feb-2024	05:37	07-Feb-2024	09:28	231	0.00096	FORCE MAJEURE/EXTERNAL FACTORS
34	07-Feb-2024	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK SHALIMAR BAGH	1337	Other Outage	Planned Outage	07-Feb-2024	11:16	07-Feb-2024	16:25	309	0.00129	PLANNED OUTAGE
35	07-Feb-2024	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD SHALIMAR BAGH	853	Other Outage	Planned Outage	07-Feb-2024	11:24	07-Feb-2024	15:39	255	0.00106	PSD ON INDUSTRIAL WEEKLY OFF
36	07-Feb-2024	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94, SHALIMAR BAGH	879	Other Outage	Planned Outage	07-Feb-2024	11:43	07-Feb-2024	16:47	304	0.00211	PLANNED OUTAGE
37	07-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	122	Other Outage	Planned Outage	07-Feb-2024	11:57	07-Feb-2024	16:36	279	0.00016	PLANNED OUTAGE
38	07-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	176	Other Outage	Planned Outage	07-Feb-2024	12:12	07-Feb-2024	16:41	269	0.00112	PLANNED OUTAGE
39	07-Feb-2024	PARTS OF AK BLOCK, AO BLOCK II CLUSTER NO-2 SHALIMAR BAGH	2204	Other Outage	Unplanned Outage	07-Feb-2024	18:16	07-Feb-2024	18:39	23	0.00014	FORCE MAJEURE/EXTERNAL FACTORS
40	07-Feb-2024	PARTS OF AK BLOCK, AO BLOCK II CLUSTER NO-2 SHALIMAR BAGH	167	Other Outage	Unplanned Outage	07-Feb-2024	18:16	07-Feb-2024	18:52	36	0.00005	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
41	08-Feb-2024	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	1977	Other Outage	Unplanned Outage	08-Feb-2024	01:13	08-Feb-2024	01:25	12	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
42	08-Feb-2024	PART OF PWD OFFICE SHALIMAR BAGH	1	400 kVA	Planned Outage	08-Feb-2024	07:25	08-Feb-2024	08:49	84	0.00002	PLANNED OUTAGE
43	08-Feb-2024	PARTS OF HIMGIRI ENCLAVE B BLOCK NO. 2 SHALIMAR BAGH	212	Other Outage	Planned Outage	08-Feb-2024	11:00	08-Feb-2024	13:32	152	0.00068	PLANNED OUTAGE
44	08-Feb-2024	PARTS OF BANGALI COLONY SHALIMAR BAGH	2982	Other Outage	Planned Outage	08-Feb-2024	11:03	08-Feb-2024	16:21	318	0.00221	PLANNED OUTAGE
45	08-Feb-2024	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	1679	Other Outage	Planned Outage	08-Feb-2024	11:08	08-Feb-2024	16:26	318	0.00318	PLANNED OUTAGE
46	08-Feb-2024	PARTS OF NEEL KANTH APPARTMENT. SHALIMAR BAGH	85	Other Outage	Planned Outage	08-Feb-2024	11:21	08-Feb-2024	14:00	158	0.00053	PLANNED OUTAGE
47	08-Feb-2024	PARTS OF BHAGAT COLONY SHALIMAR BAGH	70	Other Outage	Unplanned Outage	08-Feb-2024	18:34	08-Feb-2024	19:02	28	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
48	08-Feb-2024	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	1741	Other Outage	Unplanned Outage	08-Feb-2024	20:16	08-Feb-2024	21:03	46	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
49	08-Feb-2024	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	236	Other Outage	Unplanned Outage	08-Feb-2024	20:16	08-Feb-2024	22:43	146	0.00041	FORCE MAJEURE/EXTERNAL FACTORS
50	08-Feb-2024	PART OF BHALSWA DAIRY SHALIMAR BAGH	1	Other Outage	Unplanned Outage	08-Feb-2024	20:16	08-Feb-2024	22:44	147	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
51	09-Feb-2024	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	2	63 kVA	Planned Outage	09-Feb-2024	07:22	09-Feb-2024	08:40	78	0.00002	PLANNED OUTAGE
52	09-Feb-2024	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	2	400 kVA	Unplanned Outage	09-Feb-2024	10:49	09-Feb-2024	11:26	37	0.00001	EODB COMPLIANCE
53	09-Feb-2024	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD SHALIMAR BAGH	654	Other Outage	Planned Outage	09-Feb-2024	12:03	09-Feb-2024	14:19	136	0.00026	PLANNED OUTAGE
54	09-Feb-2024	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY SHALIMAR BAGH	489	Other Outage	Planned Outage	09-Feb-2024	12:20	09-Feb-2024	14:19	119	0.00026	PLANNED OUTAGE
55	09-Feb-2024	PARTS OF NEEL KANTH APPARTMENT. SHALIMAR BAGH	85	Other Outage	Planned Outage	09-Feb-2024	14:48	09-Feb-2024	16:10	82	0.00005	PLANNED OUTAGE
56	10-Feb-2024	PARTS OF SANT NAGAR POCKET B BLOCK SHALIMAR BAGH	345	Other Outage	Planned Outage	10-Feb-2024	11:15	10-Feb-2024	16:05	290	0.00226	PLANNED OUTAGE
57	10-Feb-2024	PARTS OF HIMGIRI ENCLAVE B BLOCK NO. 2 SHALIMAR BAGH	1007	Other Outage	Planned Outage	10-Feb-2024	12:05	10-Feb-2024	13:35	90	0.00038	PLANNED OUTAGE
58	10-Feb-2024	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI SHALIMAR BAGH	413	Other Outage	Unplanned Outage	10-Feb-2024	13:54	10-Feb-2024	14:53	59	0.00013	FORCE MAJEURE/EXTERNAL FACTORS
59	10-Feb-2024	PART OF PWD OFFICE SHALIMAR BAGH	18	Other Outage	Unplanned Outage	10-Feb-2024	18:06	10-Feb-2024	19:18	72	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
60	11-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	2410	Other Outage	Unplanned Outage	11-Feb-2024	11:02	11-Feb-2024	11:35	33	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
61	11-Feb-2024	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	2380	Other Outage	Unplanned Outage	11-Feb-2024	16:00	11-Feb-2024	16:20	19	0.00025	FORCE MAJEURE/EXTERNAL FACTORS
62	12-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	58	Other Outage	Unplanned Outage	12-Feb-2024	00:44	12-Feb-2024	00:59	14	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
63	12-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	119	Other Outage	Unplanned Outage	12-Feb-2024	00:44	12-Feb-2024	01:12	27	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
64	12-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	69	Other Outage	Unplanned Outage	12-Feb-2024	00:44	12-Feb-2024	02:05	80	0.00005	FORCE MAJEURE/EXTERNAL FACTORS
65	12-Feb-2024	PART OF SHALIMAR BAGH INDUSTRIAL AREA SHALIMAR BAGH	4	400 kVA	Planned Outage	12-Feb-2024	07:27	12-Feb-2024	08:47	80	0.00002	PLANNED OUTAGE
66	12-Feb-2024	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B,C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE SHALIMAR BAGH	125	250 kVA	Planned Outage	12-Feb-2024	11:27	12-Feb-2024	13:32	125	0.00017	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
67	12-Feb-2024	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	949	Other Outage	Planned Outage	12-Feb-2024	11:45	12-Feb-2024	14:08	143	0.00040	PLANNED OUTAGE
68	12-Feb-2024	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	539	990 kVA	Planned Outage	12-Feb-2024	11:47	12-Feb-2024	14:09	142	0.00024	PLANNED OUTAGE
69	12-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	118	Other Outage	Unplanned Outage	12-Feb-2024	13:18	12-Feb-2024	13:45	27	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
70	13-Feb-2024	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	1	Other Outage	Planned Outage	13-Feb-2024	06:55	13-Feb-2024	07:59	64	0.00002	PLANNED OUTAGE
71	13-Feb-2024	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	1472	Other Outage	Planned Outage	13-Feb-2024	10:58	13-Feb-2024	15:44	286	0.00095	PLANNED OUTAGE
72	13-Feb-2024	PART OF SMA INDUSTRIAL AREA SHALIMAR BAGH	2	400 kVA	Unplanned Outage	13-Feb-2024	11:20	13-Feb-2024	11:51	31	0.00001	EODB COMPLIANCE
73	13-Feb-2024	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	3	315 kVA	Unplanned Outage	13-Feb-2024	12:28	13-Feb-2024	13:12	44	0.00001	EODB COMPLIANCE
74	13-Feb-2024	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N.PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART - 1& PART - 2, HIMGIRI, SAMTA VIHAR, J J PUNARWASH COLONY, RAJEEV NAGAR SHALIMAR BAGH	3491	Other Outage	Unplanned Outage	13-Feb-2024	18:19	13-Feb-2024	19:18	59	0.00082	FORCE MAJEURE/EXTERNAL FACTORS
75	13-Feb-2024	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N.PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART - 1& PART - 2, HIMGIRI, SAMTA VIHAR, J J PUNARWASH COLONY, RAJEEV NAGAR SHALIMAR BAGH	5112	Other Outage	Unplanned Outage	13-Feb-2024	18:19	13-Feb-2024	19:40	81	0.00121	FORCE MAJEURE/EXTERNAL FACTORS
76	13-Feb-2024	PART OF JJ PUNARWASH COLONY SHALIMAR BAGH	3	Other Outage	Unplanned Outage	13-Feb-2024	18:19	13-Feb-2024	22:56	277	0.00039	FORCE MAJEURE/EXTERNAL FACTORS
77	14-Feb-2024	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR SHALIMAR BAGH	473	Other Outage	Planned Outage	14-Feb-2024	11:09	14-Feb-2024	16:41	332	0.00240	PLANNED OUTAGE
78	14-Feb-2024	PARTS OF WAZIRABAD VILLAGE , GALI NO. 1,2,3 4,5, 6, 8,, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	1391	Other Outage	Planned Outage	14-Feb-2024	11:14	14-Feb-2024	14:14	180	0.00075	PLANNED OUTAGE
79	14-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	110	Other Outage	Planned Outage	14-Feb-2024	11:29	14-Feb-2024	17:04	335	0.00112	PSD ON INDUSTRIAL WEEKLY OFF
80	14-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	33	63 kVA	Planned Outage	14-Feb-2024	14:48	14-Feb-2024	16:27	99	0.00014	PLANNED OUTAGE
81	14-Feb-2024	PARTS OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	377	Other Outage	Unplanned Outage	14-Feb-2024	22:49	14-Feb-2024	23:25	36	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
82	14-Feb-2024	PARTS OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	1979	Other Outage	Unplanned Outage	14-Feb-2024	22:49	14-Feb-2024	23:42	53	0.00044	FORCE MAJEURE/EXTERNAL FACTORS
83	14-Feb-2024	PART OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	3	Other Outage	Unplanned Outage	14-Feb-2024	22:49	15-Feb-2024	00:53	124	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
84	15-Feb-2024	PART OF CETP PLANT SHALIMAR BAGH	1	Other Outage	Unplanned Outage	15-Feb-2024	10:27	15-Feb-2024	12:36	129	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
85	15-Feb-2024	PARTS OF BHALASWA AND PEPSI GODOWN SHALIMAR BAGH	2159	Other Outage	Planned Outage	15-Feb-2024	10:37	15-Feb-2024	15:44	307	0.00307	PLANNED OUTAGE
86	15-Feb-2024	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN, SHALIMAR BAGH	1139	Other Outage	Planned Outage	15-Feb-2024	11:14	15-Feb-2024	15:56	282	0.00094	PLANNED OUTAGE
87	15-Feb-2024	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE SHALIMAR BAGH	955	Other Outage	Unplanned Outage	15-Feb-2024	13:04	15-Feb-2024	13:30	26	0.00014	INTERRUPTION DUE TO FAULT
88	15-Feb-2024	PARTS OF DUSIB ESS NO-7 SHALIMAR BAGH	1368	Other Outage	Unplanned Outage	15-Feb-2024	13:05	15-Feb-2024	13:51	46	0.00036	FORCE MAJEURE/EXTERNAL FACTORS
89	15-Feb-2024	PART OF DUSIB ESS NO-6 SHALIMAR BAGH	1	Other Outage	Unplanned Outage	15-Feb-2024	13:05	15-Feb-2024	14:31	86	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
90	16-Feb-2024	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION. SHALIMAR BAGH	1499	Other Outage	Planned Outage	16-Feb-2024	11:20	16-Feb-2024	15:54	274	0.00091	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
91	16-Feb-2024	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	1	Other Outage	Planned Outage	16-Feb-2024	11:22	16-Feb-2024	17:10	348	0.00010	EODB COMPLIANCE
92	16-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	40	Other Outage	Unplanned Outage	16-Feb-2024	12:15	16-Feb-2024	13:29	74	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
93	16-Feb-2024	PART OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	3	Other Outage	Unplanned Outage	16-Feb-2024	22:34	16-Feb-2024	23:40	66	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
94	17-Feb-2024	PARTS OF HINDUSTAN PETROLEUM BURARI SHALIMAR BAGH	327	Other Outage	Unplanned Outage	17-Feb-2024	02:05	17-Feb-2024	02:45	40	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
95	17-Feb-2024	PART OF SHALIMAR BAGH INDUSTRIAL AREA SHALIMAR BAGH	2	400 kVA	Planned Outage	17-Feb-2024	07:32	17-Feb-2024	08:54	82	0.00002	PLANNED OUTAGE
96	17-Feb-2024	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	170	Other Outage	Planned Outage	17-Feb-2024	10:40	17-Feb-2024	15:16	276	0.00115	PLANNED OUTAGE
97	17-Feb-2024	PART OF TRANSPORT AUTHORITY SHALIMAR BAGH	19	Other Outage	Planned Outage	17-Feb-2024	10:53	17-Feb-2024	16:37	344	0.00010	PLANNED OUTAGE
98	17-Feb-2024	PART OF SMA INDUSTRIAL AREA SHALIMAR BAGH	7	160 kVA	Unplanned Outage	17-Feb-2024	12:50	17-Feb-2024	13:14	24	0.00001	EODB COMPLIANCE
99	17-Feb-2024	PART OF TRANSPORT AUTHORITY SHALIMAR BAGH	1	Other Outage	Unplanned Outage	17-Feb-2024	12:59	17-Feb-2024	13:37	37	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
100	17-Feb-2024	PARTS OF MN CONVENT SHALIMAR BAGH	1802	Other Outage	Unplanned Outage	17-Feb-2024	15:18	17-Feb-2024	17:09	111	0.00120	FORCE MAJEURE/EXTERNAL FACTORS
101	17-Feb-2024	PARTS OF WAZIRABAD VILLAGE , GALI NO. 1,2,3 4,5, 6, 8,, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	714	Other Outage	Unplanned Outage	17-Feb-2024	17:46	17-Feb-2024	18:22	36	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
102	18-Feb-2024	PART OF RAJASTHANI UDHYOG NAGAR SHALIMAR BAGH	4	315 kVA	Planned Outage	18-Feb-2024	07:29	18-Feb-2024	08:52	83	0.00005	PLANNED OUTAGE
103	18-Feb-2024	PART OF TRANSPORT AUTHORITY SHALIMAR BAGH	19	Other Outage	Planned Outage	18-Feb-2024	10:56	18-Feb-2024	16:53	357	0.00020	PLANNED OUTAGE
104	19-Feb-2024	PART OF SMA INDUSTRIAL AREA SHALIMAR BAGH	2	315 kVA	Planned Outage	19-Feb-2024	07:09	19-Feb-2024	08:00	51	0.00001	PLANNED OUTAGE
105	19-Feb-2024	PART OF HAIDER PUR VILLAGE SHALIMAR BAGH	8	Other Outage	Unplanned Outage	19-Feb-2024	10:18	19-Feb-2024	11:43	85	0.00024	FORCE MAJEURE/EXTERNAL FACTORS
106	19-Feb-2024	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	499	Other Outage	Planned Outage	19-Feb-2024	11:01	19-Feb-2024	16:15	314	0.00044	PLANNED OUTAGE
107	19-Feb-2024	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY SHALIMAR BAGH	1746	Other Outage	Planned Outage	19-Feb-2024	11:14	19-Feb-2024	16:08	294	0.00294	PLANNED OUTAGE
108	19-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	1708	Other Outage	Unplanned Outage	19-Feb-2024	11:16	19-Feb-2024	11:49	32	0.00018	FORCE MAJEURE/EXTERNAL FACTORS
109	19-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	1060	Other Outage	Planned Outage	19-Feb-2024	12:07	19-Feb-2024	15:19	192	0.00064	PLANNED OUTAGE
110	19-Feb-2024	PART OF SHALIMAR BAGH INDUSTRIAL AREA SHALIMAR BAGH	1	Other Outage	Unplanned Outage	19-Feb-2024	18:49	19-Feb-2024	19:21	32	0.00001	FORCE MAJEURE/EXTERNAL FACTORS
111	20-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	1270	Other Outage	Unplanned Outage	20-Feb-2024	00:29	20-Feb-2024	01:18	49	0.00020	FORCE MAJEURE/EXTERNAL FACTORS
112	20-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	308	Other Outage	Unplanned Outage	20-Feb-2024	00:29	20-Feb-2024	01:18	49	0.00004	FORCE MAJEURE/EXTERNAL FACTORS
113	20-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	463	Other Outage	Unplanned Outage	20-Feb-2024	00:29	20-Feb-2024	01:30	61	0.00008	FORCE MAJEURE/EXTERNAL FACTORS
114	20-Feb-2024	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	615	Other Outage	Unplanned Outage	20-Feb-2024	00:45	20-Feb-2024	02:20	95	0.00016	FORCE MAJEURE/EXTERNAL FACTORS
115	20-Feb-2024	PART OF SHALIMAR BAGH INDUSTRIAL AREA SHALIMAR BAGH	4	315 kVA	Planned Outage	20-Feb-2024	07:07	20-Feb-2024	09:07	120	0.00003	PLANNED OUTAGE
116	20-Feb-2024	PART OF KALANDER COLONY SHALIMAR BAGH	1	Other Outage	Unplanned Outage	20-Feb-2024	12:21	20-Feb-2024	13:12	50	0.00001	FORCE MAJEURE/EXTERNAL FACTORS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
117	20-Feb-2024	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	736	Other Outage	Unplanned Outage	20-Feb-2024	19:00	20-Feb-2024	19:35	35	0.00054	FORCE MAJEURE/EXTERNAL FACTORS
118	20-Feb-2024	PARTS OF HARYANA FLAT, PLOT NO 144, SINGAL PUR VILLAGE. SHALIMAR BAGH	2461	Other Outage	Unplanned Outage	20-Feb-2024	19:00	20-Feb-2024	19:40	40	0.00028	FORCE MAJEURE/EXTERNAL FACTORS
119	21-Feb-2024	PART OF PWD OFFICE SHALIMAR BAGH	2	250 kVA	Planned Outage	21-Feb-2024	07:17	21-Feb-2024	09:15	118	0.00003	PSD ON INDUSTRIAL WEEKLY OFF
120	21-Feb-2024	PARTS OF SSI INDUSTRIAL AREA SHALIMAR BAGH	40	Other Outage	Planned Outage	21-Feb-2024	10:33	21-Feb-2024	15:41	308	0.00017	PSD ON INDUSTRIAL WEEKLY OFF
121	21-Feb-2024	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE VIJAY COLONY & JOGI MOHALLA SHALIMAR BAGH	493	Other Outage	Planned Outage	21-Feb-2024	11:21	21-Feb-2024	12:40	79	0.00057	PLANNED OUTAGE
122	22-Feb-2024	PART OF PWD OFFICE SHALIMAR BAGH	2	160 kVA	Planned Outage	22-Feb-2024	07:41	22-Feb-2024	08:51	70	0.00004	PLANNED OUTAGE
123	22-Feb-2024	PARTS OF JAI HIND SOCIETY SHALIMAR BAGH	727	Other Outage	Planned Outage	22-Feb-2024	11:05	22-Feb-2024	13:24	139	0.00100	PLANNED OUTAGE
124	22-Feb-2024	PARTS OF C&D BLOCK MUKUNDPUR DRAIN SHALIMAR BAGH	1344	Other Outage	Planned Outage	22-Feb-2024	11:17	22-Feb-2024	13:37	140	0.00058	PLANNED OUTAGE
125	22-Feb-2024	PARTS OF RADHA VIHAR NO-1, C & D BLOCK MUKUNDPUR PART-1 SHALIMAR BAGH	204	400 kVA	Planned Outage	22-Feb-2024	14:21	22-Feb-2024	15:44	83	0.00007	PLANNED OUTAGE
126	22-Feb-2024	PARTS OF BG & BJ BLOCKS , BM, BN EAST, POLIC COLONY, BF BLOCK AND BF MARKET SHALIMAR BAGH	1241	Other Outage	Unplanned Outage	22-Feb-2024	14:33	22-Feb-2024	14:44	10	0.00009	FORCE MAJEURE/EXTERNAL FACTORS
127	23-Feb-2024	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD SHALIMAR BAGH	667	Other Outage	Planned Outage	23-Feb-2024	11:08	23-Feb-2024	15:14	246	0.00205	PLANNED OUTAGE
128	23-Feb-2024	PARTS OF HINDUSTAN PETROLEUM BURARI SHALIMAR BAGH	1070	Other Outage	Planned Outage	23-Feb-2024	11:09	23-Feb-2024	15:56	287	0.00199	PLANNED OUTAGE
129	23-Feb-2024	PARTS OF DISTRIC CENTRE BLK C&D FDR-4 SHALIMAR BAGH	591	Other Outage	Planned Outage	23-Feb-2024	11:49	23-Feb-2024	14:27	158	0.00035	PLANNED OUTAGE
130	24-Feb-2024	PARTS OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	1982	Other Outage	Unplanned Outage	24-Feb-2024	10:31	24-Feb-2024	10:56	25	0.00010	FORCE MAJEURE/EXTERNAL FACTORS
131	24-Feb-2024	PARTS OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	134	Other Outage	Unplanned Outage	24-Feb-2024	10:31	24-Feb-2024	11:20	49	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
132	24-Feb-2024	PARTS OF GALI NO 12 - 17 SWAROOP NAGAR, SHRADHA NAND COLONY, JJ CLUSTER 1 & 2 SHALIMAR BAGH	3087	Other Outage	Planned Outage	24-Feb-2024	11:19	24-Feb-2024	16:16	297	0.00198	PLANNED OUTAGE
133	24-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	1351	Other Outage	Planned Outage	24-Feb-2024	11:30	24-Feb-2024	16:35	305	0.00169	PLANNED OUTAGE
134	24-Feb-2024	PARTS OF AMBEDKAR NAGAR EXTENSION SHALIMAR BAGH	198	Other Outage	Planned Outage	24-Feb-2024	11:41	24-Feb-2024	14:19	158	0.00114	PLANNED OUTAGE
135	24-Feb-2024	PARTS OF BHALSWA SMA INDUSTRIAL AREA SHALIMAR BAGH	29	Other Outage	Unplanned Outage	24-Feb-2024	12:16	24-Feb-2024	12:57	42	0.00012	FORCE MAJEURE/EXTERNAL FACTORS
136	24-Feb-2024	PARTS OF BHALSWA SMA INDUSTRIAL AREA SHALIMAR BAGH	29	Other Outage	Unplanned Outage	24-Feb-2024	13:53	24-Feb-2024	15:17	84	0.00002	FORCE MAJEURE/EXTERNAL FACTORS
137	24-Feb-2024	PARTS OF JAGAT PUR EXT NO.1, WAZBAD GALI NO. 16,15, 13, 12, 9, SHALIMAR BAGH	1350	Other Outage	Unplanned Outage	24-Feb-2024	16:42	24-Feb-2024	17:23	41	0.00011	FORCE MAJEURE/EXTERNAL FACTORS
138	25-Feb-2024	PARTS OF SANT NAGAR POCKET B BLOCK SHALIMAR BAGH	5733	Other Outage	Unplanned Outage	25-Feb-2024	05:46	25-Feb-2024	06:00	14	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
139	26-Feb-2024	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D,E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	637	Other Outage	Unplanned Outage	26-Feb-2024	07:56	26-Feb-2024	08:50	54	0.00030	FORCE MAJEURE/EXTERNAL FACTORS
140	26-Feb-2024	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D,E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	1415	Other Outage	Unplanned Outage	26-Feb-2024	07:56	26-Feb-2024	10:11	135	0.00038	FORCE MAJEURE/EXTERNAL FACTORS
141	26-Feb-2024	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D,E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	170	Other Outage	Unplanned Outage	26-Feb-2024	07:56	26-Feb-2024	10:23	147	0.00021	FORCE MAJEURE/EXTERNAL FACTORS
142	26-Feb-2024	PARTS OF BADLI AND LABOUR CHOWK AREA SHALIMAR BAGH	1409	Other Outage	Planned Outage	26-Feb-2024	10:31	26-Feb-2024	11:59	88	0.00064	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11kV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unservd (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
143	26-Feb-2024	PART OF BURARI PRADHAN ENCLAVE SHALIMAR BAGH	6	Other Outage	Planned Outage	26-Feb-2024	11:41	26-Feb-2024	15:41	240	0.00007	PLANNED OUTAGE
144	26-Feb-2024	PARTS OF WAZIRABAD VILLAGE , GALI NO. 1,2,3 4,5, 6, 8,, PART OF GALI NO. 12, 14, 16 WZB VILLAGE, SHALIMAR BAGH	714	Other Outage	Planned Outage	26-Feb-2024	12:14	26-Feb-2024	16:41	267	0.00037	PLANNED OUTAGE
145	27-Feb-2024	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	1474	Other Outage	Unplanned Outage	27-Feb-2024	10:47	27-Feb-2024	11:49	62	0.00052	FORCE MAJEURE/EXTERNAL FACTORS
146	27-Feb-2024	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR SHALIMAR BAGH	155	Other Outage	Planned Outage	27-Feb-2024	11:16	27-Feb-2024	16:00	284	0.00032	PLANNED OUTAGE
147	27-Feb-2024	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY SHALIMAR BAGH	1746	Other Outage	Planned Outage	27-Feb-2024	11:29	27-Feb-2024	15:55	266	0.00192	PLANNED OUTAGE
148	27-Feb-2024	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	499	Other Outage	Planned Outage	27-Feb-2024	11:52	27-Feb-2024	16:13	261	0.00087	PLANNED OUTAGE
149	27-Feb-2024	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR SHALIMAR BAGH	1474	Other Outage	Unplanned Outage	27-Feb-2024	14:33	27-Feb-2024	15:00	26	0.00022	FORCE MAJEURE/EXTERNAL FACTORS
150	28-Feb-2024	PART OF LAXMI VIHAR SHALIMAR BAGH	1	Other Outage	Unplanned Outage	28-Feb-2024	02:00	28-Feb-2024	04:00	120	0.00003	FORCE MAJEURE/EXTERNAL FACTORS
151	28-Feb-2024	PARTS OF BHALSWA SMA INDUSTRIAL AREA SHALIMAR BAGH	29	Other Outage	Planned Outage	28-Feb-2024	10:49	28-Feb-2024	16:54	365	0.00020	PSD ON INDUSTRIAL WEEKLY OFF
152	28-Feb-2024	PARTS OF KAUSHIK ENCLAVE AND BURARI SHALIMAR BAGH	1004	Other Outage	Planned Outage	28-Feb-2024	11:04	28-Feb-2024	15:52	288	0.00184	PLANNED OUTAGE
153	28-Feb-2024	PARTS OF GOV. STAFF QUARTER HAIDERPUR SHALIMAR BAGH	154	Other Outage	Planned Outage	28-Feb-2024	11:33	28-Feb-2024	14:00	147	0.00008	PSD ON INDUSTRIAL WEEKLY OFF
154	28-Feb-2024	PARTS OF SMA INDUSTRIAL AREA SHALIMAR BAGH	47	Other Outage	Planned Outage	28-Feb-2024	12:08	28-Feb-2024	15:41	213	0.00012	PSD ON INDUSTRIAL WEEKLY OFF
155	28-Feb-2024	PART OF BHALSWA DAIRY, JJ CLUSTER SHALIMAR BAGH	2	Other Outage	Unplanned Outage	28-Feb-2024	19:14	02-Mar-2024	00:35	3201	0.00089	FORCE MAJEURE/EXTERNAL FACTORS
156	29-Feb-2024	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D,E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	1415	Other Outage	Planned Outage	29-Feb-2024	11:00	29-Feb-2024	16:01	301	0.00217	PLANNED OUTAGE
157	29-Feb-2024	PARTS OF GOPI WALA , JHARODA SCHOOL , BHAGWAN PARK, SURNDER COLONY PART 1 &2,,KAYAKALP HOSPITAL, SHALIMAR BAGH	1803	Other Outage	Planned Outage	29-Feb-2024	11:25	29-Feb-2024	14:05	160	0.00116	PLANNED OUTAGE
158	29-Feb-2024	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D,E BLK, NUMBERDAR COLONY & TEACHER COLONY SHALIMAR BAGH	170	Other Outage	Planned Outage	29-Feb-2024	13:39	29-Feb-2024	15:59	140	0.00090	PLANNED OUTAGE
TOTAL											1.00903146	