

**Delhi Electricity Regulatory Commission**  
**Viniyamak Bhawan, 'C' Block, Shivalik, Malviya Nagar, New Delhi – 17.**

No. F.11(515)/DERC/2009-10/

**Petition No. 13/2009**

**In the matter of:** Approval of Incentive based on availability of Transmission System of Delhi Transco Limited for FY 2008-09.

Delhi Transco Limited  
Through its: **CMD**  
Shakti Sadan, Kotla Road,  
New Delhi-110002.

.....**Petitioner**

***VERSUS***

1. BSES Rajdhani Power Limited  
Through its : **CEO**  
BSES Bhawan, Nehru Place,  
New Delhi-110019.
2. BSES Yamuna Power Ltd.  
Through its: **CEO**  
Shakti Kiran Building,  
Karkardooma  
New Delhi – 110 092.
3. North Delhi Power Ltd.  
Through its: **Sr. General Manager**  
33Kv Sub Station Building,  
Hudson Lane,  
Delhi 110 009,
4. The Secretary  
New Delhi Municipal Council  
Palika Kendra, Sansad Marg  
New Delhi 100 001
5. Chief Engineer (Utilities)  
CWE, MES, Kotwali Road,  
Delhi Cantt,  
New Delhi 110 010
6. General Manager  
State Load Dispatch Centre  
33KV Grid S/Station  
SLDC Building Minto Road,  
Behind Zakir Hussain Collage  
New Delhi 110 002

...**Respondents.**

**Coram:**

**Sh. P.D. Sudhakar, Chairman, Sh. Shyam Wadhera, Member &  
Sh. J.P. Singh, Member.**

Appearance:

1. Sh. Bhupender Nath, GM (Comml), DTL
2. Sh. S. Mohari, DGM (Comml) DTL
3. Sh. N.K. Sharma, Manager (Comml), DTL
4. Sh. S.C. Sharma, BYPL
5. Sh. Akash Supakar, GM. (Tech.) BYPL
6. Sh. Mukesh Dadhich, DGM (SO) BYPL
7. Sh. Rajeev Rajjan, Manager, BYPL
8. Sh. P. Asokan, Asstt. Manager , BRPL
9. Sh. S.S. Sondhi ASVP, BRPL
10. Sh. S.K. Bhardwaj, S.E. NDMC
11. Sh. R.R. Singh, CE (ET) NDMC
12. Sh. Chaman Lal, NDMC
13. Sh K.P. Garg, MES
14. Sh. Roop Kumar, GM (SLDC
15. Sh. V. Venugopal, DGM (SO) SLDC
16. Sh. Sanjeev Kumar, AM (SO), SLDC

**ORDER**

(Date of Hearing: 29.09.2011)

(Date of Order: 12.10.2011)

1. The Petitioner, Delhi Transco Ltd. filed a petition for approval of incentive based on availability of transmission system of DTL for the year 2008-09. The Petitioner through this petition prayed that the Commission may be pleased to approve the incentive based on the availability of transmission system of DTL for the year 2008-09.
2. The Commission heard the petitioner and the respondents and perused the record regarding final computation of availability of transmission system and calculations for incentive based on availability of transmission system. On the query of the Commission, it is confirmed by the petitioner and the respondents that they agreed in the 4<sup>th</sup> Grid Coordination Committee meeting held on 06.11.2009 and accept the 98.78% availability of transmission system as claimed by the DTL.
3. In the light of above discussion the Commission directed as under:
  - i) The availability of DTL Transmission System is accepted as 98.78% for the FY 2008-09.
  - ii) Based on the above availability, DTL may raise incentive bills in accordance with the provisions of the MYT Regulations.
4. Ordered accordingly.

Sd/-  
(J.P. Singh)  
MEMBER

Sd/-  
(Shyam Wadhera)  
MEMBER

Sd/-  
(P.D. Sudhakar)  
CHAIRMAN