

## DELHI ELECTRICITY REGULATORY COMMISSION

Viniyamak Bhawan, 'C' Block, Shivalik, Malviya Nagar, New Delhi- 110017.

No. F.11(463)/DERC/2008-09/

### Petition No. 69/2008

**In the matter of :**      Endangering the Regional Grid Security by continuous violation of  
Section 24.1-24.3 of Delhi Electricity Grid Code:

The General Manager,  
State Load Despatch Center (SLDC),  
SLDC Building,  
33KV Grid Sub-Station,  
Minto Road, New Delhi-02

.....**Petitioner**

### VERSUS

1.      BSES Rajdhani Power Limited  
Through its : **CEO**  
BSES Bhawan, Nehru Place,  
New Delhi-110019.
2.      BSES Yamuna Power Ltd.  
Through its: **CEO**  
Shakti Kiran Building,  
Karkardooma  
New Delhi – 110 092.
3.      North Delhi Power Ltd.  
Through its: **Managing Director**  
Sub Station Building,  
Hudson Lane,  
Delhi 110 009,
4.      The Secretary  
New Delhi Municipal Council  
Palika Kendra, Sansad Marg  
New Delhi 100 001
5.      Chief Engineer (Utilities)  
CWE, MES, Kotwali Road,  
Delhi Cantt,  
New Delhi 110 010

...**Respondents.**

**Coram :**

**Sh. P.D. Sudhakar, Chairman, Sh. Shyam Wadhera, Member,  
& Sh. J.P. Singh, Member**

Appearance :

1. Sh. Roop Kumar, GM, SLDC
2. Sh. V.Venugopal, DGM(SO) SLDC
3. Sh. Deepak Sharma, AM(T)SLDC
4. Sh. S.S. Sondhi, Asstt. Vice President, BRPL
5. Sh. Ajay Kumar, Addl. Mgr. BRPL
6. Sh. Megea Bajpeyi, AM, BRPL
7. Sh. Mukesh Dadhich, DGM (SO) BYPL
8. Sh. Abhishek Srivastava, A.M. BYPL
9. Sh. Ashis Kumar Dutta, AGM, NDPL
10. Sh. Madan Pal, NDMC
11. Sh. S.K. Bhardwaj, SEE NDMC,
12. Sh. K.P. Garg, AEE/M MES,
13. Sh. Sanjeev Kumar A.M. (SO)

**ORDER**

(Date of Hearing 15.09.2011)  
(Date of Order 29.09.2011)

1. Mr. V. Venugopal, DGM(SO) appearing for SLDC submitted that NDPL has installed under Frequency Relays in its area of supply. However, the other Discoms have yet to comply with the directions of the Commission regarding installation of under Frequency Relays in their area of supply.
2. Sh. Madan Pal appearing for NDMC submitted that recently the schemes regarding installation of under Frequency Relays in the NDMC area have been approved and installation of under Frequency Relays will take at least a year.
3. Sh. S.S. Sondhi, Asstt. Vice President, appearing for BRPL submitted that under Frequency Relays have been installed in their area.
4. The Commission directs all Discoms to submit update status regarding installation of under Frequency Relays in their respective areas of distribution within a month.
5. The Commission further directs Director (Power) NDMC to attend the Operation Coordination Committee meeting scheduled to be held in the month of October, 2011.

6. The matter is listed for further hearing on **24<sup>th</sup> October, 2011**.
7. Ordered Accordingly.

Sd/-  
(J.P. Singh)  
Member

Sd/-  
(Shyam Wadhera)  
Member

Sd/-  
(P.D. Sudhakar)  
Chairman