

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, 'C' Block, Shivalik, Malviya Nagar, New Delhi – 17.

No. F.11(457)DERC/2010-11/

Petition No. 07/2009

In the matter of : **Petition for resolving issues with DTL which includes**
 a) Determination of suitable compensation to account for
 excess system losses in the transmission network of DTL.
 b) Resolving interface metering issues.

BSES Rajdhani Power Limited
Through its : **CEO**
BSES Bhawan,
Nehru Place,
Delhi 110 019

..... Petitioner

Vs.

Delhi Transco Ltd.
Through its : CMD
Shakti Sadan, Kotla Road,
New Delhi 110 002

.....Respondent

Coram :
 Sh. P.D. Sudhakar, Chairman, Sh. Shyam Wadhera, Member &
 Sh. J.P. Singh, Member.

Appearance:

1. Mr. S.K. Sharma, DGM (P), DTL,
2. Mr. G. Saabasivarao, Manager (T) DTL
3. Mr. S. Mohari, DGM (Comml.) DTL
4. MR. N.K. Sharma, Manager (Comml.), DTL
5. Mr. Sanjeev Kumar, AM (SO), SLDC
6. Mr. Deepak Sharma, AM (SO), SLDC
7. Mr. Rajeev Choudhary, HOD, BRPL
8. Mr. Ajay Kumar, BRPL

ORDER

(Date of Hearing: 17.11.2011)
(Date of Order: 05.12.2011)

1. Mr. Rajeev Chowdhury, HOD, BRPL submitted that transmission losses of DTL in MYT order for FY 2007-08 to 2010-11 have been specified as 0.95% according to which energy input at periphery of BRPL was determined.
2. Mr. Chowdhury further submitted that DTL losses are varying in the range of 1.2% to 1.5% which needs to be verified by independent agency and thereafter necessary adjustment in energy may be done.

3. Mr. S.K. Sharma, Dy. Gen. Manager (Comml.) DTL, submitted that earlier operational consumption losses were determined on monthly basis till 31st March, 2007 Intra-State ABT was implemented w.e.f. 01.04.2007 and Special Energy Meters were installed which have accuracy of 0.2 clause whereas the meters installed earlier had accuracy clause of 0.5. Since, accuracy level of new Special Energy Meters are higher therefore, losses have increased.
4. The Commission heard both the parties at length. The Commission directs Engg. Division to hold a meeting with BRPL & DTL to enable them to mutually agree on a procedure to resolve this issue.
5. The Commission further directs BRPL and DTL to submit the status report to the Commission within 3 weeks.
6. The Matter is listed for further hearing **19.01.2012**
7. Ordered accordingly.

Sd/-
(J.P. Singh)
Member

Sd/-
(Shyam Wadhera)
Member

Sd/-
(P.D. Sudhakar)
Chairman