

## Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI  
Period of Report: Dec' 2020  
Year: 2020

[illegible]

4	On dated 05.09.2020 some persons were cutting tree at Ganga Sahay colony Harsh Vihar and due to tree branches falling on HTAB cable, one no. 11 M PCC pole, one no. 25 KVA single phase transformer and 30 meters HTAB 1X95 sq mm cable were damaged. Estimate for damages and copy of complaint lodged in Police Station are sent,	05.09.2020	Unknown (Public – 1 fatal & 1 non-fatal)						
5	Flash occurred to Sh.Ramdas S/o Sh.Moolchandra in 3 phase busbar at Mulla colony scrap store on dated 24.10.2020 around 12.30 HRS.	24.10.2020	Non- Fatal Employee (Vendor)						
6	Lineman slipped from the ladder and fell from height.	17.11.2020	Fatal Employee (Vendor)						

(Signature of the Licensee)