

Name of Company

BSES Yamuna Power Ltd, Delhi

Period of Report

February

Year

2022

Service Area	Standard wrt AT&C losses			Pending complaint of the previous	Complaint received during the month	Total Complaint	Complaints attended during the			Balance complaint to be attended
3	Upto 10%	More than 10% and upto 20%	More than 20%				Within Specified Time	Beyond specified time	Total	
1	2			3	4	5=3+4	6	7	8=6+7	9=5-8
Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement	Within three hours	Within four hours	Within six hours	19	21301	21320	21175	131	21306	14
Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	Within two hours	Within three hours	Within four hours	0	168	168	162	5	167	1
Continuous power supply failure requiring replacement of distribution transformer	Within six hours			0	0	0	0	0	0	0
Continuous scheduled power outages	Within 12 hours or restoration of power supply by 6PM			0	568	568	568	0	568	0
Replacement of burnt meter or stolen meter	Restoration of supply within three hours either by bypassing the			0	951	951	951	0	951	0
Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS)					33	33	32	1	33	0