

Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: JULY 2019
Year: 2019

Sl. No.	Location of accident and details of victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI /AEI	Remedies suggested by CEI/EI /AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	66 KV Gazipur Gantry at Gazipur Dairy Farm Road. Victim: Unknown	28 April 19	Fatal	Electrocution while stealing the earthing strips meant for cable & structure earthing inside the gantry.	-	-	-	-	-
2	Shop no. 2778, Cheera Khana market, S/D: Town Hall, Chandni Chowk Victim: Sh. Faheem , Lineman, M/s Parihar Electricals	25 May 19	Non-Fatal	Electrocution of lineman while changing consumer's MCB during meter replacement work.					
3	Kh no 433, Property no 44, Office no 3 S/F, Veer Savarkar Block, Shakarpur, Near Govt School Delhi, Laxmi Nagar Victim: Unknown	5 July 19	Fatal	Electrocution from illegal taping of service cable.					
4	Char Khamba, Main Wazirabad Road, Mandoli Ext., Nand Nagri Victim: Animal	27 July 19	Fatal	Electrocution of a cow and a bull due to current leakage from high mast pole.	.				

(Signature of the Licensee)