

Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
 Period of Report: Jun’ 2021
 Year: 2021

Sl. No.	Location of Accident and Details Of Victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	Div : Dilshad Garden Shri Rajesh, L/M & Pankaj, ALM went to R-38 R-Block (Old) Dilshad Garden where eight single phase meters were got burnt. Shri Pankaj, ALM was injured due to short circuit flash. His right hand and some part of face got burnt injuries.	09.05.2021	Non- Fatal (Employee)						
2	Div : Karkardoomaa A call received from Police to switch off the supply of the areas on dated 21.05.2021 at 9.20 PM , as per police statement there was leakage of current in nala at that time of PCR call . AMC staff reached at site & immediately 'switch off' the supply of the area from s/stn Halkara Kuan No1 as required by police . A person name Salman, rag picker was found in nala near red light Kasturba Ngr by Police. The Police has called the JCB to break the RCC covered NALA . Police picked up the person from the nala and took him to the hospital. Thereafter, the area was energised & no current leakage was observed in BYPL network in the related area as confirmed by the AMC staff,Engineer/supervisor (Mr Taran Khanna).	21.05.2021	Fatal (Public)						
3	Div:Karawal Nagar PCR call was received regarding electrocution at Sherpur chowk wine shop, Karawal Nagar,No public complaint received regarding any leakage of current or any electrocution at location mentioned in the FIR so far at the office of BYPL.	20.06.2021	Fatal (Public)						
4	On 22.07.2021 at 10:41Hrs. 220 Kv Patparganj to 33Kv Scope Tower Ckt tripped on E/F Protection from Patparganj end due to Flash over occurred in 33Kv Scope Tower Incomer Panel- Cable box compartment at Scope Tower Grid	22.07.2021	Non- Fatal (Employee)						
5	On 24.07.2021 , at around 02:26 AM PCR complaint received at Shankar Road and later auto assigned to Preet Vihar Zone and then to PD Vihar Zone. Lineman reached at site and supply was turned off following the disconnection of service cable from feeding point. He noticed that an	24.07.2021	Fatal (Public)						

	unknown person is lying on the road near the service cable and is dead.								
6	A PCR complaint was received through IOMS vide complaint No-21073101177 at Guddu Garage Kotla Village Mayur Vihar Phase 1, Line man Shri Jagdish reached at site immediately at 18:11 hrs and found that PCR team was already there and an unknown person had got electric shock by spreading wires at Guddu Garage, Kotla Village for E-Rickshaw Charging and PCR team taken injured person to the hospital.	31.07.2021	Fatal (Public)						

(Signature of the Licensee)