

Name of Company

BSES Yamuna Power Ltd, Delhi

Period of Report

July

Year

2021

Service Area	Standard wrt AT&C losses			Pending complaint of the previous	Complaint received during the month	Total Complaint	Complaints attended during the			Balance complaint to be attended
	Upto 10%	More than 10% and upto 20%	More than 20%				Within Specified Time	Beyond specified time	Total	
3										
1	2			3	4	5=3+4	6	7	8=6+7	9=5-8
Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement	Within three hours	Within four hours	Within six hours	126	50911	51037	50782	206	50988	49
Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	Within two hours	Within three hours	Within four hours	2	632	634	614	20	634	0
Continuous power supply failure requiring replacement of distribution transformer	Within six hours			0	7	7	7	0	7	0
Continuous scheduled power outages	Within 12 hours or restoration of power supply by 6PM			0	202	202	199	3	202	0
Replacement of burnt meter or stolen meter	Restoration of supply within three hours either by bypassing the			0	2330	2330	2328	0	2328	2
Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS)				0	68	68	68	0	68	0