

**Format II**

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI  
Period of Report: JUNE 2019  
Year: 2019

| Sl. No. | Location of accident and details of victim   | Date of occurrence | Type of accident | Cause of accident  | Findings of CEI/EI /AEI | Remedies suggested by CEI/EI /AEI in various cases | Whether the remedy suggested is complied | Action taken to avoid recurrence of such accidents | Amount paid as compensation |
|---------|--|--------------------|------------------|--|-------------------------|--|--|--|-----------------------------|
| 1       | 66 KV Gazipur Gantry at Gazipur Dairy Farm Road.<br>Victim: Unknown  | 28 April 19        | Fatal            | Electrocution while stealing the earthing strips meant for cable & structure earthing inside the gantry. | -                       | -  | -  | -  | -                           |
| 2       | Shop no. 2778, Cheera Khana market, S/D: Town Hall, Chandni Chowk<br>Victim: Sh. Faheem , Lineman, M/s Parihar Electricals | 25 May 19          | Non-Fatal        | Electrocution of lineman while changing consumer's MCB during meter replacement work.                    |                         |  |  |  |                             |

(Signature of the Licensee)

