

Summary of Overall Standards of Performance:- October--2019

Sr No	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (C)%
				Within Specified Time	Beyond specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits	25013	24889	116	99.50%
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.		431	426	5	98.84%
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		1	1	0	100.00%
(iv)	Continuous scheduled power outages	At least 95% of cases resolved within time limit	40	40	0	100.00%
(v)	Replacement of burnt meter or stolen Meter		1552	1552	0	100.00%
(vi)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above	At least 95% calls received should be rectified within prescribed time limits	30	29	1	96.67%
Period of Scheduled Outage						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	23	23	0	100.00%
	Restoration of supply by 6:00 PM		23	23	0	100.00%
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	3384	3380	4	99.88%
	Reliability Indices					
4	SAIFI	To be laid down by the Commission based on SAIDI the targets proposed by the Licensees.				
	SAIDI					
	CAIDI					
			No. of bills served during the month		No of bills with mistakes the month	Standard of Performance achieved (C)%
7	Percentage billing mistakes	Shall not exceed 0.2%	1723534		42	0.002%