

FORMAT II: Action taken report for safety measures compiled for the accidents occurred

Name of Company: BSES RAJDHANI POWER LIMITED.
 Period of Report: Jul-19
 Year: 2019

Sl. No.	Location of accident and details of victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI /AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	Raju Enclave Near Vishwakarma Mandir.	04.07.2019 at around 02:24 / 02:46 PM	Fatal	A complaint has been received on dated 04.07.2019 at around 02:34 / 02:46 PM (PCR Complaint) has been received through IOMS vide entry No. 6026 / 6153 dated 04.07.2019 address Raju Enclave Near Vishwakarma Mandir. Sh. Rahul Telephone Operator on dated Deputed Sh. Krishan LM (Telephonically Message at 02:45 PM to attend this PCR complaint. Telephone operator also informed to Sh. Intezar Ali supervisor about this matter. Lineman attended the same and checked the complete network on PCC pole DWK E 551 (near house number RZ 27 / 11 plot number 8 Raju enclave old palam road). Our staff checked the all network on this pole where incident occurred. It has been found that there is no discrepancy found observed at site. Again a PCR message received in IOMS 6153 at 02:46 pm showing that a wire lying on ground on subjected Pole. Both complaints have been attended by Shri Krishan lineman but there was no wire found from site during visit by our staff. Our Staff asked nearby subjected site what happened ? nearby consumers stated that a child has been electrocuted. Safety Officer West 1 is requested to visit the subjected site jointly.	N.A.	N.A.	N.A.	N.A.	N.A.
2	Near H.No E-175, Vishkarma Colony, Lal Kuan, New Delhi	05.07.2019 at about 12:30 PM	Non-Fatal	A telephonic complaint was received from Lal Kuan near Bharat Gas Godown on 05.07.2019 at about 12:30 PM that a boy named Sanjay aged 8 yrs approximately got electric shock from some nearby cable. Sh. Sahil Lineman and Sh. Surjit Supervisor visited the site and found two incoming cables from pole are cut down and make a temporary arrangement on a wall intentionally for theft purposes by some local public. Also some building works are going on that sitewhere another meter cable also cut down and put U/G from the wall where theft arrangement found. There are no other U/G service line in that area. The boy was playing with his friend near the wall and somehow he touched the open part of the cable and got electric shock. Nearby public / family members taken him to hospital and he is now out of danger.	N.A.	N.A.	N.A.	N.A.	N.A.
3	j-11 / 135, third floor, Rajouri Garden, New delhi 110027.	05.07.2019	Fatal	on dated 05.07.2019 at about 9:50 AM, a PCR Complaint received through online in IOMS vide complaint No 19070502179 regd. Current leakage in house. Immediately Lineman deputed at site who found / informed that an incident of electrocution has been occurred at J-11 / 135 third floor, Rajouri Garden due to current leakage in House electrical wiring. BSES disconnected the power supply of the premise for safety reasons (C.A.No 102889684 & Meter No 40481077)	N.A.	N.A.	N.A.	N.A.	N.A.
4	Sub Station Bhim Colony, Delhi	10.07.2019 at about 07:30 PM	Non-Fatal	The information gather from site reveals that a boy of 5 years old named Lucky was playing with his friends near Sub station Bhim Colony, when a ball with which they were playing fell inside the Sub station Bhim Colony. Master Lucky while trying to take out the ball reportedly came in contact with HT 11 kv Line inside Sub station at around 07:30 PM on dated 10.07.2019. In this process, he got an electric shock. The HT line got tripped from the RMU at Priyanka Camp. He was taken to Saldarjung for treatment and is presently under observation in the hospital.	N.A.	N.A.	N.A.	N.A.	N.A.
5	Jonapur Village, Delhi.	21.07.2019	Fatal	The accident took place at connecting road from 7th Avenue RMB to Jonapur Village. There was heavy thunder strom and rain in the Aya Nagar region as per IMD. The BSES HT conductor was broken at 03:35 PM (approximately) and our 11KV O/G feeder NBCC from C DOT grid was tripped / disconnected from NBCC Bhatta Substation, so the reason of accident is not cleared. After accident victims namely Md. Salim and Sh. Hoshiyar Singh Rawat were taken by Delhi Police as per sources. The police has seized the broken conductor. The status quo is as it is from BSES point of view. No BSES employee was present at the time of accident.	N.A.	N.A.	N.A.	N.A.	N.A.
6	Near Police Station Jaitpur.	27.07.2019 at about 02:00 AM	Fatal	On 27.07.2019 at about 10:30 AM calls received from public representatives that an electrical accident had occurred on 27.07.2019 at about 02:00 AM when a group of kavadiya boys were moving under 11 kv road crossing conductors of said feeder. The height of the truck along with DJ installations and structures mounted therein was more than specified RTO limits. The probable cause of accident is unknown in which one person is reported to be electrocuted and fell down from the truck - he died. During the night we received individual category NCC at about 02:10 AM and area was checked and when lineman found no fault - the area was energized. Accident situation remained unknown at night. There is regular daily movement of buses and high trucks on this road, but they do not touch the conductors.	N.A.	N.A.	N.A.	N.A.	N.A.
7	Pole No. BSES SVR V-124 & premise house no. F-33 / 3, GF, Block-F, Gali No. 3, Molarband Extn, Badarpur, New Delhi	28.07.2019 at about 12:25 PM	Non-Fatal	On dated 28.07.2019 at about 12:25 PM complaint registered for electricity off in the area. Sh. Laki, Lineman visited the site found tripping from sub station no. 8 MB Extn. Also DD fuse blown off at F Block HVDS DP supply restored and at that place found electrical accident occurred at Gali No. 3 F Block MB Extn. due to which tripping occurred from these places. As per information gathered at site Smt. Punita Kumari victim fell down sariya from roof which was got unbalanced and got touched upon the HVDS DD fuse and tripping occurred.	N.A.	N.A.	N.A.	N.A.	N.A.