

Summary of Overall Standards of Performance:- December--2018

Sr No	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (C)%
				Within Specified Time	Beyond specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits	23944	23743	194	99.16%
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.		308	300	8	97.40%
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		4	4	0	100.00%
(iv)	Continuous scheduled power outages	At least 95% of cases resolved within time limit	635	635	0	100.00%
(v)	Replacement of burnt meter or stolen Meter		1088	1088	0	100.00%
(vi)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above	At least 95% calls received should be rectified within prescribed time limits	37	37	0	100.00%
Period of Scheduled Outage						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	598	598	0	100.00%
	Restoration of supply by 6:00 PM		598	598	0	100.00%
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	4443	4426	17	99.62%
Reliability Indices						
4	SAIFI	To be laid down by the Commission based on SAIDI the targets proposed by the Licensees.	0.35			
	SAIDI		0.28			
	CAIDI		0.81			
5	Frequency variation	To maintain supply frequency within range as per IEGC.				
			Total Bills served during the month	No. of bills with mistakes during the month		Standard of Performance achieved (C)%
6	Voltage imbalance	Maximum of 3% at point of commencement of supply				
7	Percentage billing mistakes	Shall not exceed 0.2%	1694894	100		0.006%