

Name of Company  
Period of Report  
Year

BSES Yamuna Power Ltd, Delhi  
February  
2019

Service Area	Standard wrt AT&C losses			Pending complaint of the previous month	Complaint received during the month	Total Complaint	Complaints attended during the month			Balance complaint to be attended
	Upto 10%	More than 10% and upto 20%	More than 20%				Within Specified Time	Beyond specified time	Total	
1	2			3	4	5=3+4	6	7	8=6+7	9=5-8
Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement	Within three hours	Within four hours	Within six hours	24	21717	21741	21553	174	21727	14
Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	Within two hours	Within three hours	Within four hours	0	316	316	309	7	316	0
Continuous power supply failure requiring replacement of distribution transformer	Within six hours			0	3	3	3	0	3	0
Continuous scheduled power outages	Within 12 hours or restoration of power supply by 6PM			0	859	859	858	1	859	0
Replacement of burnt meter or stolen meter	Restoration of supply within three hours either by bypassing the			0	1064	1064	1063	0	1063	1
Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS)				0	31	31	31	0	31	0