

Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: APRIL 2018-NOV 18
Year: 2018

Sl. No.	Location of accident and details of victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	Gali no 2, C Blk, Ambika Vihar, Division- KWN Victim: Mrs. Sangeeta	24 May 18	Non-Fatal	HVDS conductor broken	-	-	-	-	-
2	Kotla road, near Bal Bhawan, Division- Darya Ganj Victim: Unknown	10 June 18	Fatal	Illegally shifting of electricity meter	-	-	-	-	-
3	Gate of H.No. 406, Gali Ramjas School, Sitaram Bazaar, Chawri Bazaar, Division- Darya Ganj Victim: Sh. Ram Asrey	2 July 18	Fatal	Current leakage at consumer's premises					
4	H.No. 122, Khasra No 579/2, Gali no 4/7, Biharipur Ext., Div- Karawal Nagar Victim: Public	9 July 18	Non-Fatal	Encroachment near HVDS transformer					
5	Filmistan Main Road, Division Phahar ganj; Victim: Sh. Suresh	13 July 18	Fatal	Current leakage from faulty underground cable of the dismantled traffic signal.					
6	Near DND xing, Yamuna Khadar side, Division- Mayur Vihar I Victim: Unknown	13 July 18	Fatal	Current leakage from consumer installation					
7	LIG Flats Pocket A2, Div-MVR-III Victim: Sh. Rahul Kumar Thakkar	13 July 18	Fatal	Current leakage from High Mast maintained by MCD.					
8	In front of Pearl Banquet Hall, Ghazipur Road, Div-Laxmi Nagar Victim: Sh. Ravinder Singh s/o Sh. Sher Singh	21 July 18	Fatal	Current leakage from consumer installation					

9	Near CNG Pump, Paper Market, Div-MVR-III Victim: 1 Horse+ 1 dog	21 July 18	Fatal	Electrocution from illegal wire					
10	9690/9 Multani Dhanda , Paharganj Victim: Unknown	26 July 18	Fatal	Electrocution from consumer wiring					
11	E2-Block, Sonia Vihar, near Green day Public School, Karawal Nagar Victim: Unknown	25 Aug 18	Fatal	Electrocution while changing the direction of BYPL street light pole while he was unauthorised to interfere with BYPL network.					
12	New C- Block Kabir Nagar s/stn, Division- Nand Nagri Victim: Unknown	12 Sept 18	Non- Fatal	Electrocution to a child who entered sub-station with intention of theft.					
13	Near Barshabulla s/stn, Chawri Bazaar, Division- Chandni Chowk Victim: Unknown	16 Sept 18	Non- Fatal (4 nos)	Electrocution from u/g cable which was lying at low depth.					
14	Location: H 11, Surya Vihar Gali no 4 Shadatpur extn , Karawal Nagar.	4 Nov 18	Fatal	Illegal interference with the HVDS pole by the construction worker led to his electrocution.					

(Signature of the Licensee)

