

### Summary of Overall Standards of Performance:- November--2018

Sr No	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (C )%
				Within Specified Time	Beyond specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits	23711	23565	128	99.38%
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement		280	274	6	97.86%
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		1	1	0	100.00%
(iv)	Continuous scheduled power outages	At least 95% of cases resolved within time limit	314	314	0	100.00%
(v)	Replacement of burnt meter or stolen Meter		1051	1051	0	100.00%
(vi)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above	At least 95% calls received should be rectified within prescribed time limits	25	25	0	100.00%
Period of scheduled outage						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	339	339	0	100.00%
	Restoration of supply by 6:00 PM		339	339	0	100.00%
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	4017	3957	60	98.51%
Reliability Indices						
4	SAIFI	To be laid down by the Commission based on SAIDI the targets proposed by the Licensees.	0.42			
	SAIDI		0.35			
	CAIDI		0.83			
			Total Bills served during the month		Bills with mistakes	Standard of Performance achieved (C )%
7	Percentage billing mistakes	Shall not exceed 0.2%	1690410		60	0.004%