

**Format II**

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI  
Period of Report: Aug’ 2021  
Year: 2021

Sl. No.	Location of Accident and Details Of Victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	Div : Dilshad Garden Shri Rajesh, L/M & Pankaj, ALM went to R-38 R-Block (Old) Dilshad Garden where eight single phase meters were got burnt. Shri Pankaj, ALM was injured due to short circuit flash. His right hand and some part of face got burnt injuries.	09.05.2021	Non- Fatal (Employee)	-	-	-	-	-	-
2	Div : Karkardoomaa A call received from Police to switch off the supply of the areas on dated 21.05.2021 at 9.20 PM , as per police statement there was leakage of current in nala at that time of PCR call . AMC staff reached at site & immediately 'switch off' the supply of the area from s/stn Halkara Kuan No1 as required by police . A person name Salman, rag picker was found in nala near red light Kasturba Ngr by Police. The Police has called the JCB to break the RCC covered NALA . Police picked up the person from the nala and took him to the hospital. Thereafter, the area was energised & no current leakage was observed in BYPL network in the related area as confirmed by the AMC staff,Engineer/supervisor (Mr Taran Khanna).	21.05.2021	Fatal (Public)	-	-	-	-	-	-
3	Div:Karawal Nagar PCR call was received regarding electrocution at Sherpur chowk wine shop, Karawal Nagar,No public complaint received regarding any leakage of current or any electrocution at location mentioned in the FIR so far at the office of BYPL.	20.06.2021	Fatal (Public)	-	-	-	-	-	-
4	On 22.07.2021 at 10:41Hrs. 220 Kv Patparganj to 33Kv Scope Tower Ckt tripped on E/F Protection from Patparganj end due to Flash over occurred in 33Kv Scope Tower Incomer Panel- Cable box compartment at Scope Tower Grid	22.07.2021	Non- Fatal (Employee)	-	-	-	-	-	-
5	On 24.07.2021 , at around 02:26 AM PCR complaint received at Shankar Road and later auto assigned to Preet Vihar Zone and then to PD Vihar Zone. Lineman reached at site and supply was turned off following the disconnection of service cable from feeding point. He noticed that an	24.07.2021	Fatal (Public)	-	-	-	-	-	-

	unknown person is lying on the road near the service cable and is dead.								
6	A PCR complaint was received through IOMS vide complaint No-21073101177 at Guddu Garage Kotla Village Mayur Vihar Phase 1, Line man Shri Jagdish reached at site immediately at 18:11 hrs and found that PCR team was already there and an unknown person had got electric shock by spreading wires at Guddu Garage, Kotla Village for E-Rickshaw Charging and PCR team taken injured person to the hospital.	31.07.2021	Fatal (Public)						
7	A PCR complaint was received on dated 18.08.2021 at 18:35 hrs, electrocution of plumber While working on the water pumping system.	18.08.2021	Fatal (Public)						
8	On dated 21.08.2021 at 09:19 hrs, a PCR complaint was received for current leakage near Gate No-2, C Block, Anand vihar .A private security person of RWA Anand Vihar was laying on the ground near Gate No-2, C Block, Anand Vihar	21.08.2021	Fatal (Public)						
9	Cow has been electrocuted at M155, Gali No. SBS Colony, S/Div, KWN due to touching the consumer's submersible pump & current leakage from the joint submersible pump.	21.08.2021	Fatal (Animal)						
10	An accident occurred at C3 harsh vihar Gali no 28, where Meter Shifting work was being carried out . During this activity victim's hand touched the HVDS Network and got minor flash.	04.08.2021	Non- Fatal (Employee ) (1nos.)						
11	Maintenance staff gone for pole strengthening/repairing work at pahadi imli jama masjid near old dujana chowk due to pole tilted. As in this pole straight through joints and service cables were present, so for repairing work supply put off and work started for removing of these cables at the same time sparking occurred from one of these cable and lineman came close to sparking and got flash.	09.08.2021	Non- Fatal Employee (1nos.)						
12	Kite thread touched HVDS Trf. DD unit & earth strip in ph. 7 Shiv Vihar S/Div.KWR. A Girl was standing with HVDS pole and earthing strips. RMU panel tripped simultaneously but She got electrocuted and hospitalized.	20.08.2021	Non- Fatal Public (1 nos.)						

(Signature of the Licensee)

