

**Format II**

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI

Period of Report: Jul' 2020

Year: 2020

Sl. No.	Location of Accident and Details Of Victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	One labour got injured while cleaning the site for shifting of all cables when a Cable flashed on its own. This cable was already partly damaged. Four nos. of ckt. From 220KV PPG to GAN ckt No. 1 &2, Scope Minar ckt and CBD I Ckt to be shifted due to expansion of Railway line and platform. The victim was hospitalised and expired on 29.05.2020.	21.05.2020	Fatal Employee (Vendor)		-	-	-	-	-
2	<ul style="list-style-type: none"><li>• Mr. Raj Singh sub div. Kantinagar incharge reported that a PCR complaint of fire in house received.</li><li>• The LM reached at site to attend the complaint.</li><li>• Then he came to knew that a child had got electrocuted at</li></ul>	28.06.2020	Non Fatal (Public)						

	<p>kaushik puri park sub station .The vendor's superior reached at site and confirmed.</p> <ul style="list-style-type: none"><li>• Some children were playing in the park. One of them climbed the fencing of substation to catch the kite with the help of the broom (kite which fell on the transformer). Some another child pushed him and he came in contact with HT fuse and was electrocuted. After which he fell down on ground.</li><li>• This information was gathered from neighbours and the parents of child electrocuted(11-12year old) took him to RML HOSPITAL</li></ul>								
3	<p>During cleaning work of 11 kv bus bar under shutdown at bus coupler side , the person working tried to discharge but a flash occured may be due to live part touch with discharging rod , 4 persons working nearby there got affected by flash , three Sri seth , Sri Akshit and Raja ram have minor flash affect and they have been discharged after treatment from Puspanjali hospital on yesterday noon , one person named Tribhuwan has more burning admitted in hospital and as per hospital 15 days they will kept him under treatment</p>	19.07.2020	Non- Fatal Employee (Vendor)						

(Signature of the Licensee)